

US EPA ARCHIVE DOCUMENT



# CALPINE CORPORATION

717 TEXAS AVENUE, SUITE 1000  
HOUSTON, TX 77002

NYSE CPN September 1, 2011

Mr. Jeff Robinson  
Chief, Air Permits Section  
U.S. EPA Region 6, 6PD  
1445 Ross Avenue, Suite 1200  
Dallas, TX 75202-2733

RE: Application for a Prevention of Significant Deterioration Air Quality Permit for Greenhouse Gas Emissions  
Deer Park Energy Center LLC  
Deer Park, Harris County, Texas

Mr. Robinson:

On behalf of Deer Park Energy Center LLC, Calpine Corporation is hereby submitting this application for a Prevention of Significant Deterioration (PSD) air quality permit for greenhouse gas emissions for the construction of an additional natural gas fired combustion turbine generator with a duct fired heat recovery steam generator at the Deer Park Energy Center located in Deer Park, Harris County, Texas.

The attached application includes a copy of the Texas Commission on Environmental Quality (TCEQ) Form PI-1 - General Application for Air Preconstruction Permit and Amendments, which is being submitted simultaneously to the TCEQ to authorize the state/PSD/Nonattainment air permit for non-greenhouse gas emissions for the project. The U.S. Environmental Protection Agency's (EPA) document *PSD and Title V Permitting Guidance For Greenhouse Gases, November 2010 and March 2011*, was utilized as a guide for preparation of the attached application.

Since preparing and reviewing PSD applications for greenhouse gas emissions is new for both permit writers and permit applicants, Calpine is committed to working closely with EPA Region 6 to get the application review completed as expeditiously as possible. Calpine will be contacting your staff soon after submittal of this application to arrange a meeting to review the application and answer any EPA questions.

Should you have any questions regarding this application, please contact Calpine's technical contact for this application, Ms. Jan Stavinoha, at [jstavinoha@calpine.com](mailto:jstavinoha@calpine.com) or by telephone at (713) 570-4814.

Sincerely,

Patrick Blanchard  
Director, EHS  
Calpine Corporation

Mr. Jeff Robinson  
September 1, 2011  
Page 2

---

Enclosure

cc: Mr. Mike Wilson, P.E., Director, Air Permits Division, TCEQ  
Mr. Larry Moon, P.E., Zephyr Environmental Corporation


**PREVENTION OF SIGNIFICANT DETERIORATION  
GREENHOUSE GAS PERMIT APPLICATION  
FOR AN ADDITIONAL COMBINED CYCLE COGENERATION UNIT AT THE  
DEER PARK ENERGY CENTER  
HARRIS COUNTY, TEXAS**

*SUBMITTED TO:*  
**ENVIRONMENTAL PROTECTION AGENCY  
REGION VI  
MULTIMEDIA PLANNING AND PERMITTING DIVISION  
FOUNTAIN PLACE 12<sup>TH</sup> FLOOR, SUITE 1200  
1445 ROSS AVENUE  
DALLAS, TEXAS 75202-2733**

*SUBMITTED BY:*  
**DEER PARK ENERGY CENTER LLC  
DEER PARK, TEXAS 77536**

*PREPARED BY:*  
**ZEPHYR ENVIRONMENTAL CORPORATION  
2600 VIA FORTUNA, SUITE 450  
AUSTIN, TEXAS 78746**

**SEPTEMBER, 2011**



**TABLE OF CONTENTS**

---

1.0	INTRODUCTION.....	1
	FORM PI-1 GENERAL APPLICATION.....	2
2.0	PROJECT SCOPE.....	12
2.1	Introduction.....	12
2.2	Combustion Turbine Generator.....	12
2.3	Heat Recovery Steam Generator.....	12
2.4	Natural Gas Piping.....	13
2.5	Electrical Equipment Insulated with Sulfur Hexafluoride (SF <sub>6</sub> ).....	13
	PROCESS FLOW DIAGRAM.....	14
	PLOT PLAN.....	15
	AREA MAP.....	16
3.0	GHG EMISSION CALCULATIONS.....	17
3.1	GHG Emissions From Combined Cycle Combustion Turbine.....	17
3.2	GHG Emissions From Natural Gas Piping Fugitives and Natural Gas Maintenance and Startup/Shutdown Related Releases.....	17
3.3	GHG Emissions From Electrical Equipment Insulated with SF <sub>6</sub> .....	18
4.0	PREVENTION OF SIGNIFICANT DETERIORATION APPLICABILITY.....	25
	TCEQ PSD NETTING TABLES.....	26
5.0	BEST AVAILABLE CONTROL TECHNOLOGY (BACT).....	30
5.1	BACT for the Combined Cycle Combustion Turbine.....	31
5.1.1	Step 1: Identify All Available Control Technologies.....	31
5.1.2	Step 2: Eliminate Technically Infeasible Options.....	36
5.1.3	Step 3: Rank Remaining Control Technologies.....	39
5.1.4	Step 4: Evaluate Most Effective Controls and Document Results.....	39
5.1.5	Step 5: Select BACT.....	39
5.2	BACT for SF <sub>6</sub> Insulated Electrical Equipment.....	41
5.2.1	Step 1: Identify All Available Control Technologies.....	41
5.2.2	Step 2: Eliminate Technically Infeasible Options.....	41
5.2.3	Step 3: Rank Remaining Control Technologies.....	41
5.2.4	Step 4: Evaluate Most Effective Controls and Document Results.....	42
5.2.5	Step 5: Select BACT.....	42
	MAP OF EXISTING CO <sub>2</sub> PIPELINES AND POTENTIAL GEOLOGIC STORAGE SITES IN TEXAS.....	43
	TABLE 5-1.....	44
	RANGE OF APPROXIMATE ANNUAL COSTS FOR INSTALLATION AND OPERATION OF CAPTURE, TRANSPORT, AND STORAGE SYSTEMS FOR CONTROL OF CO <sub>2</sub> EMISSIONS FROM PROPOSED ELECTRIC GENERATING UNIT 3 AT CHANNEL ENERGY CENTER, HARRIS COUNTY, TEXAS.....	44

**PREVENTION OF SIGNIFICANT DETERIORATION GREENHOUSE GAS PERMIT APPLICATION  
FOR A NEW COMBINED CYCLE COGENERATION UNIT AT THE DEER PARK ENERGY CENTER  
DEER PARK ENERGY CENTER LLC**

---

TABLE 5-2 ..... 45

6.0 OTHER PSD REQUIREMENTS ..... 46

    6.1 Impacts Analysis ..... 46

    6.2 GHG Preconstruction Monitoring ..... 46

    6.3 Additional Impacts Analysis..... 46

---

**APPENDICES**

---

**APPENDIX A: GHG PSD APPLICABILITY FLOWCHART – EXISTING SOURCES**

**US EPA ARCHIVE DOCUMENT**

## **1.0 INTRODUCTION**

The Deer Park Energy Center (DPEC) is a combined-cycle cogeneration facility, located in Deer Park, Harris County, Texas. The facility is authorized under Permit Nos. 45642, PSD-TX-979, and N-036. The DPEC plant currently consists of four combustion turbine generators (CTGs) with duct fired heat recovery steam generators (HRSGs).

The purpose of this amendment is to authorize a fifth natural gas fired CTG/HRSG unit. The proposed unit is a combined cycle gas turbine in which the gas turbine generates electricity and the heat from the gas turbine exhaust will be used to produce steam in the heat recovery steam generator. Steam from the new CTG/HRSG unit will drive an existing on-site steam turbine generator (STG) to produce electricity or may be sold for use in an adjacent industrial facility. The recovery of energy from the gas turbine exhaust, which otherwise would be wasted, increases the energy efficiency of unit.

On June 3, 2010, the EPA published final rules for permitting sources of Greenhouse Gases (GHGs) under the prevention of significant deterioration (PSD) and Title V air permitting programs, known as the GHG Tailoring Rule.<sup>1</sup> After July 1, 2011, new sources having the potential to emit more than 100,000 tons/yr of GHGs and modifications increasing GHG emissions more than 75,000 tons/yr on a carbon dioxide equivalent (CO<sub>2</sub>e) basis at existing major sources are subject to GHG PSD review, regardless of whether PSD was triggered for other pollutants.

On December 23, 2010, EPA issued a Federal Implementation Plan (FIP) authorizing EPA to issue PSD permits in Texas for GHG sources until Texas submits the required SIP revision for GHG permitting and it is approved by EPA.<sup>2</sup>

The DPEC project for the addition of the fifth CTG/HRSG unit triggers PSD review for GHG regulated pollutants because the project will increase GHG emissions by more than 75,000 tons/yr and the site is considered an existing major source. Included in this application are a project scope description, GHG emissions calculations, GHG netting analysis, and a GHG Best Available Control Technology (BACT) analysis.

---

<sup>1</sup> 75 FR 31514 (June 3, 2010).

<sup>2</sup> 75 FR 81874 (Dec. 29, 2010).

**US EPA ARCHIVE DOCUMENT**



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**Update:** The TCEQ **requires** that a Core Data Form be submitted on all incoming applications unless a Regulated Entity and Customer Reference Number have been issued by the TCEQ **and** no core data information has changed. For more information regarding the Core Data Form, call (512) 239-5175 or go to the TCEQ Web site at [www.tceq.state.tx.us/permitting/central\\_registry/guidance.html](http://www.tceq.state.tx.us/permitting/central_registry/guidance.html).

**US EPA ARCHIVE DOCUMENT**

<b>I. APPLICANT INFORMATION</b>		
A. Company or Other Legal Name: <b>Deer Park Energy Center LLC</b>		
Texas Secretary of State Charter/Registration Number ( <i>if applicable</i> ):		
B. Company Official Contact Name ( <input checked="" type="checkbox"/> Mr. <input type="checkbox"/> Mrs. <input type="checkbox"/> Ms. <input type="checkbox"/> Dr.): <b>Patrick Blanchard</b>		
Title: <b>Director, EHS</b>		
Mailing Address: <b>717 Texas, Suite 1000</b>		
City: <b>Houston</b>	State: <b>TX</b>	ZIP Code: <b>77002</b>
Telephone No: <b>713-830-8717</b>	Fax No.: <b>713-830-8871</b>	E-mail Address: <b>patrickb@calpine.com</b>
C. Technical Contact Name ( <input type="checkbox"/> Mr. <input type="checkbox"/> Mrs. <input checked="" type="checkbox"/> Ms. <input type="checkbox"/> Dr.): <b>Jan Stavinoha</b>		
Title: <b>Manager, EHS</b>		
Company Name: <b>Calpine Corporation</b>		
Mailing Address: <b>717 Texas, Suite 1000</b>		
City: <b>Houston</b>	State: <b>TX</b>	ZIP Code: <b>77002</b>
Telephone No.: <b>713-570-4814</b>	Fax No.: <b>713-830-8871</b>	E-mail Address: <b>jstavinoha@calpine.com</b>
D. Facility Location Information:		
Street Address: <b>5665 La Porte Highway</b>		
If no street address, provide clear driving directions to the site in writing:		
City: <b>Deer Park</b>	County: <b>Harris</b>	ZIP Code: <b>77536</b>
E. TCEQ Account Identification Number (leave blank if new site or facility): <b>HX-2762-V</b>		
F. Is a TCEQ Core Data Form (TCEQ Form No. 10400) attached?		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
G. TCEQ Customer Reference Number ( <i>leave blank if unknown</i> ): <b>CN603598624</b>		
H. TCEQ Regulated Entity Number ( <i>leave blank if unknown</i> ): <b>RN100222033</b>		
<b>II. IMPORTANT GENERAL INFORMATION</b>		
A. Is confidential information submitted with this application?		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
If "YES," is each "confidential" page marked "CONFIDENTIAL" in large red letters?		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO





**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**US EPA ARCHIVE DOCUMENT**

<b>II. IMPORTANT GENERAL INFORMATION (continued)</b>		
B. Is this application in response to a TCEQ investigation or enforcement action?		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
If "YES", attach a copy of any correspondence from the TCEQ		
C. Number of New Jobs: <b>150 Temporary Construction Jobs; 0 Permanent Jobs</b>		
D. Names of the State Senator and district number for this facility site: <b>Hon. Mario Gallegos, Jr. , District 6</b>		
Names of State Representative and district number for this facility site: <b>Hon. Ken Legler, District 144</b>		
E. For Concrete Batch Plants, and PSD, or Nonattainment Permits that require public notice, name of the County Judge for this facility site: <b>Hon. Ed Emmett</b>		
Mailing Address: <b>1001 Preston, Suite 911</b>		
City: <b>Houston</b>	State: <b>TX</b>	ZIP Code: <b>77002</b>
F. For Concrete Batch Plants, is the facility located in a municipality or an extraterritorial jurisdiction of a municipality?		<input type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," list the name(s) of the Presiding Officer(s) for this facility site:		
Mailing Address:		
City:	State:	ZIP Code:
<b>III. FACILITY AND SOURCE INFORMATION</b>		
A. Site Name: <b>Deer Park Energy Center</b>		
B. Area Name/Type of Facility: <b>CTG/HRSG Cogeneration Unit</b>		<input checked="" type="checkbox"/> Permanent <input type="checkbox"/> Portable
C. Principal Company Product or Business: <b>Electricity Generation</b>		
Principal Standard Industrial Classification Code: <b>4911</b>		
D. Projected Start of Construction Date: <u>12/01/2012</u>		Projected Start of Operation Date: <u>06/01/2014</u>
<b>IV. TYPE OF PERMIT ACTION REQUESTED</b>		
A. Permit Number (if existing): <b>45642, PSD-TX-979, N-036</b>		
B. Is this an initial permit application?		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
If "YES," check the type of permit requested (check <u>all</u> that apply):		
<input type="checkbox"/> State Permit	<input type="checkbox"/> Nonattainment Federal Permit	
<input type="checkbox"/> Flexible Permit	<input type="checkbox"/> Prevention of Significant Deterioration Federal Permit	
<input type="checkbox"/> Multiple Plant Permit	<input type="checkbox"/> Hazardous Air Pollutants Permit Federal Clean Air Act § 112(g)	
Other: _____		



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**US EPA ARCHIVE DOCUMENT**

<b>IV. TYPE OF PERMIT ACTION REQUESTED (continued)</b>		
C. Is this a permit amendment?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
Is this a permit revision?? (SB 1126 change)	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
If "YES," check the type of permit requested ( <i>check all that apply</i> ): <input checked="" type="checkbox"/> State Permit Amendment <input type="checkbox"/> Flexible Permit Amendment <input type="checkbox"/> Multiple Plant Permit Amendment <input checked="" type="checkbox"/> Nonattainment Major Modification <input checked="" type="checkbox"/> Prevention of Significant Deterioration Major Modification <input type="checkbox"/> Hazardous Air Pollutants Permit Federal Clean Air Act § 112(g) Modification Other: _____		
D. Is a permit renewal application being submitted in conjunction with this amendment in accordance with Senate Bill 1673? [THSC 382.055(a)(2)](80 <sup>th</sup> Legislative)	<input type="checkbox"/> YES <input type="checkbox"/> NO <b>Not applicable</b>	
E. Is this application for a change of location of previously permitted facilities?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
If "YES," answer IVE. 1. - IVE. 4.		
1. Current location of facility:		
Street Address ( <i>If no street address, provide clear driving directions to the site in writing.</i> ):		
City:	County:	ZIP Code:
2. Proposed location of facility:		
Street Address ( <i>If no street address, provide clear driving directions to the site in writing.</i> ):		
City:	County:	ZIP Code:
3. Will the proposed facility, site, and plot plan meet all current technical requirements of the permit special conditions?	<input type="checkbox"/> YES <input type="checkbox"/> NO	
If "NO," attach detailed information.		
4. Is the site where the facility is moving considered major?	<input type="checkbox"/> YES <input type="checkbox"/> NO	
F. Is this a relocation?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
G. Are there any standard permits, exemptions or permits by rule to be consolidated into this permit?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**US EPA ARCHIVE DOCUMENT**

<b>IV. TYPE OF PERMIT ACTION REQUESTED (continued)</b>	
H. Are you permitting a facility or group of facilities that have planned maintenance, startup and shutdown emissions that cannot be authorized by a permit by rule or standard permit or that are authorized by a permit by rule or standard permit and are being rolled into this permit?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," attach information on any changes to emissions under this application as specified in Sections IX, and X.	
If "YES," answer IVH. 1 -IVH. 3.	
1. Are the activities to be included in this permit covered by any previously existing MSS authorizations?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
If "YES," provide a listing of all other authorizations (permit by rule or standard permit and the associated registration number if any).	
2. Have the emissions been previously submitted as part of an emissions inventory?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
3. List which years the MSS activities were included in emissions inventory submittals:	
<b>I. Federal Operating Permit Requirements (30 TAC Chapter 122 Applicability)</b>	
Is this facility located at a site required to obtain a federal operating permit under 30 TAC Chapter 122?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> To be Determined
1. Identify the requirements of 30 TAC Chapter 122 that will be triggered if this PI-1 application is approved. <input checked="" type="checkbox"/> FOP Significant Revision <input type="checkbox"/> FOP Minor <input type="checkbox"/> Application for an FOP Revision <input type="checkbox"/> Operational Flexibility/Off-Permit Notification <input type="checkbox"/> Streamlined Revision for GOP <input type="checkbox"/> To be determined <input type="checkbox"/> None	
2. Identify the type(s) of FOP(s) issued and/or FOP application(s) submitted/pending for the site (check all that apply) <input type="checkbox"/> GOP Issued <input type="checkbox"/> GOP application/revision application: submitted or under APD review <input checked="" type="checkbox"/> SOP Issued <input type="checkbox"/> SOP application/revision application: submitted or under APD review	
<b>V. PERMIT FEE INFORMATION</b>	
A. Fee paid for this application:	\$ 75,000
1. Is a copy of the check or money order attached to the original submittal of this application?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
2. Is a Table 30 entitled, "Certification of estimated Capital Cost and Fee Verification," attached?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**US EPA ARCHIVE DOCUMENT**

<b>VI. PUBLIC NOTICE APPLICABILITY</b>	
A. Is this a new permit application or a change of location application?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
B. Is this an application for a major modification of a PSD, NA or 30 TAC § 112(g) permit?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
C. Is this a state permit amendment application?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," answer VIC. 1. - VIC. 3.	
1. Is there any change in character of emissions in this application?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
Is there a new air contaminant in this application?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
2. Do the facilities handle, load, unload, dry, manufacture, or process grain, seed, legumes, or vegetables fibers (agricultural facilities)?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
3. List the total annual emission increases associated with the application ( <i>list all that apply</i> ):	
Volatile Organic Compounds (VOC):	16.7 tpy
Sulfur Dioxide (SO <sub>2</sub> ):	5.3 tpy
Carbon Monoxide (CO):	291.6 tpy
Hazardous Air Pollutants (HAPs):	< 10 tpy individual HAP and < 25 tpy total HAPs
Nitrogen Oxides (NO <sub>x</sub> ):	65.9 tpy
Particulate Matter (PM):	67.5 tpy
PM <sub>10</sub> :	63.5 tpy
PM <sub>2.5</sub> :	63.5 tpy
Lead (Pb):	0 tpy
Other air contaminants not listed above:	NH3 83.6 tpy
<b>VII. PUBLIC NOTICE INFORMATION (<i>complete if applicable</i>)</b>	
A. Responsible Person:	
Name ( <input type="checkbox"/> Mr. <input type="checkbox"/> Mrs. <input checked="" type="checkbox"/> Ms. <input type="checkbox"/> Dr.): <b>Jan Stavinoha</b>	
Title: <b>Manager, EHS</b>	
Mailing Address: <b>717 Texas, Suite 1000</b>	
City: <b>Houston</b>	State: <b>TX</b> ZIP Code: <b>77002</b>
Telephone No.: <b>713-570-4814</b>	Fax No.: <b>713-830-8871</b> E-mail Address: <b>jstavinoha@calpine.com</b>



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**US EPA ARCHIVE DOCUMENT**

<b>VII. PUBLIC NOTICE INFORMATION</b> <i>(complete if applicable)</i>		
<b>B. Technical Contact:</b>		
Company Name : <b>Calpine Corporation</b>		
Name ( <input type="checkbox"/> Mr. <input type="checkbox"/> Mrs. <input checked="" type="checkbox"/> Ms. <input type="checkbox"/> Dr.): <b>Jan Stavinoha</b>		
Title: <b>Manager, EHS</b>		
Mailing Address: <b>717 Texas, Suite 1000</b>		
City: <b>Houston</b>	State: <b>TX</b>	ZIP Code: <b>77002</b>
Telephone No.: <b>713-570-4814</b>	Fax No.: <b>713-830-8871</b>	E-mail Address: <b>jstavinoha@calpine.com</b>
<b>C. Application in Public Place:</b>		
Name of Public Place: <b>TCEQ Houston Regional Office</b>		
Physical Address: <b>5425 Polk Ave., Ste. H</b>		
City: <b>Houston</b>	County: <b>Harris</b>	
The public place has granted authorization to place the application for public viewing and copying?		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
The public place has internet access available for the public?		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Complete VII.D. 1. - VII.D. 3., as applicable.		
<b>D.1. Name of the Mayor for this facility site:</b>		
<b>Wayne Riddle</b>		
Mailing Address: <b>710 East San Augustine</b>		
City: <b>Deer Park</b>	State: <b>TX</b>	ZIP Code: <b>77536</b>
<b>D.2. Name of the Federal Land Manager for this facility site: NA</b>		
Mailing Address:		
City:	State:	ZIP Code:
<b>D.3. Name of the Indian Governing Body for this facility site: NA</b>		
Mailing Address:		
City:	State:	ZIP Code:



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**US EPA ARCHIVE DOCUMENT**

<b>VII. PUBLIC NOTICE INFORMATION</b> <i>(complete if applicable)</i>				
E. Is a bilingual program <b>required</b> by the Texas Education Code in the School District?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Are the children who attend either the elementary school or the middle school closest to your facility eligible to be enrolled in a bilingual program provided by the district?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," which language is <b>required</b> by the bilingual program?			<b>Spanish</b>	
<b>VIII. SMALL BUSINESS CLASSIFICATION</b> <i>(required)</i>				
A. Does this company (including parent companies and subsidiary companies) have fewer than 100 employees or less than \$6 million in annual gross receipts?				<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
B. Is the site a major source under 30 TAC Chapter 122, Federal Operating Permit Program?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
C. Are the site emissions of any individual air contaminant greater than 50 tpy?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
D. Are the site emissions of all air contaminants combined greater than 75 tpy?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
<b>IX. TECHNICAL INFORMATION</b>				
A. Is a current area map attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Are any schools located within 3,000 feet of this facility?				<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
B. Is a plot plan of the plant property attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
C. Is a process flow diagram and a process description attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
D. Maximum Operating Schedule:		Hours: <b>8,760</b>	Day(s):	Week(s):
Seasonal Operation?				<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
If "YES," please describe.				
E. Are worst-case emissions data and calculations attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
1. Is a Table 1(a) entitled, "Emission Point Summary Table," attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
2. Is a Table 2 entitled, "Material Balance Table," attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
3. Are equipment, process, or control device tables attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
F. Are actual emissions for the last two years (determination federal applicability) attached?				<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

**US EPA ARCHIVE DOCUMENT**

<b>X. STATE REGULATORY REQUIREMENTS</b>	
<i>Applicants must be in compliance with all applicable state regulations to obtain a permit or amendment.</i>	
A. The emissions from the proposed facility will comply with all rules and regulations of the TCEQ and details are attached?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
B. The proposed facility will be able to measure emissions of significant air contaminants and details are attached?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
C. A demonstration of Best Available Control Technology (BACT) is attached?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
D. The proposed facilities will achieve the performance in the permit application and compliance demonstration or record keeping information is attached?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
E. Is atmospheric dispersion modeling attached?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
F. Does this application involve any air contaminants for which a "disaster review" is required?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," details must be attached.	
<i>Note: For a list of air contaminants for which a "disaster review" will be required, refer to the NSRPD Disaster Review Guidance Document at <a href="http://www.tceq.state.tx.us/permitting/air/rules/federal/63/63hmpg.html">www.tceq.state.tx.us/permitting/air/rules/federal/63/63hmpg.html</a>.</i>	
G. Is this facility or group of facilities located at a site within an Air Pollutant Watch List (APWL) area?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," answer X.G. 1. - X.G. 3.	
1. List the APWL Site Number: <b>APWL1204</b>	
2. Does the site emit a pollutant of concern for the APWL area in which the site is located?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
3. If "YES," list the pollutant(s) of concern emitted by this site:	
H. Is this facility or group of facilities located at a site within the Houston/Galveston nonattainment area? (Brazoria, Chambers, Fort Bend, Galveston, Harris, Liberty, Montgomery, or Waller Counties)	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," answer X.H. 1. - X.H. 4.	
1. Does the facility or group of facilities located at this site have an uncontrolled design capacity to emit 10 tpy or more of NO <sub>x</sub> ?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
2. Is this site subject to 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emissions Cap and Trade)?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
3. Does this action make the site subject to 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emissions Cap and Trade)?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
4. Does this action require the site to obtain additional emission allowances?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO



**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**


**US EPA ARCHIVE DOCUMENT**

<b>XI. FEDERAL REGULATORY REQUIREMENTS</b>	
<i>Applicants must be in compliance with all applicable federal regulations to obtain a permit or amendment. If any of the following questions are answered "YES, the application must contain detailed attachments addressing applicability, identify federal regulation Subparts, show how requirements are met, and include compliance information.</i>	
A. Does a Title 40 Code of Federal Regulations Part 60, (40 CFR Part 60) New Source Performance Standard (NSPS) apply to a facility in this application?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
B. Does 40 CFR Part 61, National Emissions Standard for Hazardous Air Pollutants (NESHAP) apply to a facility in this application?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
C. Does a 40 CFR Part 63, Maximum Achievable Control Technology (MACT) standard apply to a facility in this application?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
D. Does nonattainment permitting requirements apply to this application?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
E. Does prevention of significant deterioration permitting requirements apply to this application?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
F. Does Hazardous Air Pollutant Major Source [FAA § 112(g)] requirements apply to this application?	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
<b>XII. COPIES OF THIS APPLICATION</b>	
A. Has the required fee been sent separately with a copy of this Form PI-1 to the TCEQ Revenue Section? (MC 214, P.O. Box 13088, Austin, Texas 78711).	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NA
B. Are the Core Data Form, Form PI-1, and all attachments being sent to the TCEQ in Austin?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
<b>OPTIONAL:</b> Has an extra copy of the Core Data Form, Form PI-1 and all attachments been sent to the TCEQ in Austin?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," please mark this application as "COPY."	
C. Is a copy of the Core Data Form, the Form PI-1, and all attachments being sent to the appropriate TCEQ regional office?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
D. Is a copy of the Core Data Form, the Form PI-1, and all attachments being sent to each appropriate local air pollution control program(s)?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
List all local air pollution control program(s): <b>Harris County Public Health &amp; Environmental Services</b>	
E. Is a copy of the Core Data Form, Form PI-1, and all attachments (without confidential information) being sent to the EPA Region 6 office in Dallas, Texas? (federal applications only)	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
F. This facility is located within 100 kilometers of the Rio Grande River and a copy of the application was sent to the International Boundary and Water Commission (IBWC):	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
G. This facility is located within 100 kilometers of a federally-designated Class I area and a copy of the application was sent to the appropriate Federal Land Manager:	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO





**Texas Commission on Environmental Quality  
Form PI-1 General Application for  
Air Preconstruction Permit and Amendments**

<b>XIII. PROFESSIONAL ENGINEER (P.E.) SEAL</b>	
Is the estimated capital cost of the project greater than \$2 million dollars?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
If "YES," the application must be submitted under the seal of a Texas licensed Professional Engineer (P.E.).	
<b>XIV. DELINQUENT FEES AND PENALTIES</b>	
Notice: This form will not be processed until all delinquent fees and/or penalties owed to the TCEQ or the Office of the Attorney General on behalf of the TCEQ is paid in accordance with the "Delinquent Fee and Penalty Protocol." For more information regarding Delinquent Fees and Penalties, go to the TCEQ Web site at: <a href="http://www.tceq.state.tx.us/agency/delin/index.html">www.tceq.state.tx.us/agency/delin/index.html</a> .	
<b>XV. SIGNATURE</b>	
The signature below confirms that I have knowledge of the facts included in this application and that these facts are true and correct to the best of my knowledge and belief. I further state that to the best of my knowledge and belief, the project for which application is made will not in any way violate any provision of the Texas Water Code (TWC), Chapter 7, Texas Clean Air Act (TCAA), as amended, or any of the air quality rules and regulations of the Texas Commission on Environmental Quality or any local governmental ordinance or resolution enacted pursuant to the TCAA. I further state that I understand my signature indicates that this application meets all applicable nonattainment, prevention of significant deterioration, or major source of hazardous air pollutant permitting requirements. I further state that I have read and understand TWC §§ 7.177-7.183, which defines <u>CRIMINAL OFFENSES</u> for certain violations, including intentionally or knowingly making or causing to be made false material statements or representations in this application, and TWC § 7.187, pertaining to <u>CRIMINAL PENALTIES</u> .	
NAME: Patrick Blanchard	
SIGNATURE: 	
<i>Original Signature Required</i>	
DATE: 8-31-11	

## 2.0 PROJECT SCOPE

### 2.1 INTRODUCTION

The DPEC plant currently consists of four Siemens 501F CTG/HRSG trains, one STG, and ancillary equipment. This amendment will authorize a fifth Siemens 501F CTG/HRSG train and ancillary equipment. The fifth unit, Emission Point Number (EPN) ST-5, will consist of a CTG rated at 180 MW nominal, and a duct burner-fired heat recovery steam generator (HRSG). The maximum design rated capacity of the duct burners will be 725 million British thermal units per hour (MMBtu/hr). The CTG and duct burner will be fired exclusively with pipeline-quality natural gas.

The combined-cycle natural gas turbine technology proposed for the DPEC is the “FD3” turbine technology which is the current state-of-the-art electrical generating equipment for a facility of this type. Existing turbine ST-1 is scheduled to be upgraded with the FD3 technology in the future. The Siemens 501F turbine was chosen for the proposed fifth turbine at DPEC because it has the appropriate size (MW rating) needed for this site; it allows the use of common spare parts with the existing turbines at the site; and site personnel have operational and maintenance experience with that specific type of turbine.

The new CTG/HRSG will utilize an existing steam turbine generator and an existing cooling tower. A process flow diagram is included as Figure IX-C-1.

### 2.2 COMBUSTION TURBINE GENERATOR

The combustion turbine generator burns natural gas to rotate an electrical generator to generate electricity. The main components of a CTG consist of a compressor, combustor, turbine, and generator. The compressor pressurizes combustion air to the combustor where the fuel is mixed with the combustion air and burned. Hot exhaust gases then enter the turbine where the gases expand across the turbine blades, driving one or more shafts to power an electric generator. The exhaust gas exits the CTG and is routed to the HRSG for steam production.

The typical operating range will be from 60% to 100% of base load. Inlet fogging will be used to increase the mass air flow through the turbine on hot days where the ambient air is less dense. Steam injection for power augmentation may also be used to enhance power output.

### 2.3 HEAT RECOVERY STEAM GENERATOR

The exhaust gas from the CTG will pass through an HRSG. Heat recovered in the HRSG will be utilized to produce steam. Steam generated within the HRSG will be utilized to drive a steam turbine and associated electrical generator, or as process steam at an adjacent industrial process, or injected into the CTG for power augmentation. The HRSG will be equipped with duct burners for supplemental steam production. The duct burners will be fired with pipeline-

quality natural gas. The duct burners have a maximum heat input capacity of 725 MMBtu/hr. The exhaust gases from the unit, including emissions from the CTG and the duct burners, will exit through a stack to the atmosphere.

The normal duct burner operation will vary from 0 to 100 percent of the maximum capacity. Duct burners will be located in the HRSG prior to the selective catalytic reduction system.

## **2.4 NATURAL GAS PIPING**


Natural gas is delivered to the site via pipeline. Gas will be metered and piped to the new combustion turbine and duct burners. Project fugitive emissions from the natural gas piping components associated with the new CTG/HRSG unit will include emissions of methane (CH<sub>4</sub>) and carbon dioxide (CO<sub>2</sub>). Emissions from the natural gas piping are designated as EPN NG-FUG.


## **2.5 ELECTRICAL EQUIPMENT INSULATED WITH SULFUR HEXAFLUORIDE (SF<sub>6</sub>)**

The generator circuit breaker associated with the proposed unit will be insulated with SF<sub>6</sub>. SF<sub>6</sub> is a colorless, odorless, non-flammable, and non-toxic synthetic gas. It is a fluorinated compound that has an extremely stable molecular structure. The unique chemical properties of SF<sub>6</sub> make it an efficient electrical insulator. The gas is used for electrical insulation, arc quenching, and current interruption in high-voltage electrical equipment. SF<sub>6</sub> is only used in sealed and safe systems which under normal circumstances do not leak gas. The capacity of the generator circuit breaker associated with the proposed unit will be approximately 72 lb.


The proposed circuit breaker at the generator output will have a low pressure alarm and a low pressure lockout. The alarm will alert operating personnel of any leakage in the system and the lockout prevents any operation of the breaker due to lack of "quenching and cooling" SF<sub>6</sub> gas.

## PROCESS FLOW DIAGRAM



<b>DEER PARK ENERGY CENTER</b>		<b>FIGURE IX-C-1 PROCESS FLOW DIAGRAM</b>			
Permit Amendment Application		Filename: Fig C-1 PFD			
	Drawn by:	Checked by:	Project No.:	Date:	Sheet:
	E Rapier	L Moon	011311	8/30/2011	1 of 1

## PLOT PLAN



MAP SOURCE: Terrain Navigator Pro  
DATUM: NAD83



PLOT PLAN

DEER PARK ENERGY CENTER  
HARRIS COUNTY, TEXAS


DEER PARK ENERGY CENTER LLC

File Name:	H:\Calpine\01931 Deer Park\Plot Plan		
Designed By:	Reviewed By:	Project No.:	Date:
R. von Czoernig	D. Castro	01931.001	8/10/2011

## AREA MAP

US EPA ARCHIVE DOCUMENT





Datum: NAD83

Copyright (C) 2008, MyTopo



Digital USGS 7.5 Minute Topographic Series  
 -PASADENA, TX QUADRANGLE (1982)  
 MAP SOURCE: Terrain Navigator Pro



SITE  
 LOCATION



AREA MAP

DEER PARK ENERGY CENTER  
 HARRIS COUNTY, TEXAS

DEER PARK ENERGY CENTER LLC

File Name: H:\Calpine\11311.001 Deer Park Unit 5\areamap\Deer Park.11311.001.dwg

Designed By: R. von Czoernig	Reviewed By: L. Moon	Project No.:\n11311.001	Date: 08/15/2011
---------------------------------	-------------------------	-------------------------	---------------------

### 3.0 GHG EMISSION CALCULATIONS

#### 3.1 GHG EMISSIONS FROM COMBINED CYCLE COMBUSTION TURBINE

GHG emission calculations for the combined cycle combustion turbine are calculated in accordance with the procedures in the Mandatory Greenhouse Reporting Rules, Subpart D – Electric Generation.<sup>3</sup> CO<sub>2</sub> emissions are calculated using equation G-4 of the Acid Rain Rules.<sup>4</sup>

$$W_{CO_2} = \left( \frac{F_c \times H \times U_f \times MW_{CO_2}}{2000} \right) \quad (Eq. G-4)$$

Where:

$W_{CO_2}$  = CO<sub>2</sub> emitted from combustion, tons/yr.

$MW_{CO_2}$  = Molecular weight of carbon dioxide, 44.0 lb/lb-mole.

$F_c$  = Carbon based F-factor, 1040 scf/MMBtu for natural gas.

$H$  = Annual heat input in MMBtu.

$U_f$  = 1/385 scf CO<sub>2</sub>/lb-mole at 14.7 psia and 68 °F.

Emissions of CH<sub>4</sub> and nitrous oxide (N<sub>2</sub>O) are calculated using the emission factors (kg/MMBtu) for natural gas combustion from Table C-2 of the Mandatory Greenhouse Gas Reporting Rules.<sup>5</sup> The global warming potential factors used to calculate carbon dioxide equivalent (CO<sub>2</sub>e) emissions are based on Table A-1 of Mandatory Greenhouse Gas Reporting Rules.

#### 3.2 GHG EMISSIONS FROM NATURAL GAS PIPING FUGITIVES AND NATURAL GAS MAINTENANCE AND STARTUP/SHUTDOWN RELATED RELEASES

GHG emission calculations for natural gas piping component fugitive emissions are based on emission factors from Table W-1A of the Mandatory Greenhouse Gas Reporting Rules.<sup>6</sup> The concentrations of CH<sub>4</sub> and CO<sub>2</sub> in the natural gas are based on a typical natural gas analysis.

---

<sup>3</sup> 40 C.F.R. 98, Subpart D – *Electricity Generation*

<sup>4</sup> 40 C.F.R. 75, Appendix G – *Determination of CO<sub>2</sub> Emissions*

<sup>5</sup> *Default CH<sub>4</sub> and N<sub>2</sub>O Emission Factors for Various Types of Fuel*, 40 C.F.R. 98, Subpt. C, Tbl. C-2

<sup>6</sup> *Default Whole Gas Emission Factors for Onshore Petroleum and Natural Gas Production*, 40 C.F.R. Pt. 98, Subpt. W, Tbl. W-1A.

The global warming potential factors used to calculate CO<sub>2</sub>e emissions are based on Table A-1 of Mandatory Greenhouse Gas Reporting Rules.<sup>7</sup>

GHG emission calculations for releases of natural gas related to piping maintenance and turbine startup/shutdowns are calculated on the same basis as natural gas piping fugitives.

### 3.3 GHG EMISSIONS FROM ELECTRICAL EQUIPMENT INSULATED WITH SF<sub>6</sub>

SF<sub>6</sub> emissions from the new generator circuit breaker associated with the proposed unit are calculated using a predicted SF<sub>6</sub> annual leak rate of 0.5% by weight. The global warming potential factors used to calculate CO<sub>2</sub>e emissions are based on Table A-1 of Mandatory Greenhouse Gas Reporting Rules.<sup>8</sup>

---

<sup>7</sup> *Global Warming Potentials*, 40 C.F.R. Pt. 98, Subpt. A, Tbl. A-1.

<sup>8</sup> *Id.*

**Table 3-1  
Annual GHG Emission Calculations - New Combined Cycle Combustion Turbine  
Deer Park Energy Center LLC**

**Annual GHG Emissions Contribution From Natural Gas Fired CTG5/HRSG5**

EPN	Annual Heat Input <sup>1</sup> (MMBtu/hr)	Pollutant	Emission Factor (kg/MMBtu) <sup>2</sup>	GHG Mass Emissions <sup>3</sup> (tpy)	Global Warming Potential <sup>4</sup>	CO <sub>2</sub> e (tpy)
CTG5/HRSG5	17,880,459.5	CO <sub>2</sub>		1,062,610	1	1,062,610
		CH <sub>4</sub>	1.0E-03	20	21	414
		N <sub>2</sub> O	1.0E-04	2	310	611
		<b>Totals</b>		<b>1,062,632</b>		<b>1,063,635</b>

Note

1. The following annual firing rate information is from the PSD application submitted to TCEQ on 09/01/2011.

Operating Mode	CTG Data Case Number	Annual Operating Hours hr/yr	Turbine Heat Input MMBtu/hr	Duct Burner Heat Input MMBtu/hr	Total Hourly Heat Input MMBtu/hr	Total Annual Heat Input MMBtu/yr
Base Load, 70 °F Ambient, Avg Duct Burner Firing	9b	6760	1,827.5	110	1,937.5	13,097,214.5
Base Load, 90 °F Ambient, Peak Duct Burner Firing	4b	1500	1,751.7	595	2,346.7	3,520,042.8
Base Load, 90 °F Ambient, Peak Duct Burner Firing, Power Augmentation	2b	500	1,871.4	655	2,526.4	1,263,202.3
		8760				<b>17,880,459.5</b>

2. CH<sub>4</sub> and N<sub>2</sub>O GHG factors based on Table C-2 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.

3. CO<sub>2</sub> emissions based on 40 CFR Part 75, Appendix G, Equation G-4

$$W_{CO_2} = (F_c \times H \times U_i \times MW_{CO_2}) / 2000$$

W<sub>CO<sub>2</sub></sub> = CO<sub>2</sub> emitted from combustion, tons/yr

F<sub>c</sub> = Carbon based F-factor, 1040 scf/MMBtu

H = Heat Input (MMBtu/yr)

U<sub>i</sub> = 1/385 scf CO<sub>2</sub>/lbmole at 14.7 psia and 68 °F

MW<sub>CO<sub>2</sub></sub> = Molecule weight of CO<sub>2</sub>, 44.0 lb/lbmole

4. Global Warming Potential factors based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.

**Table 3-2  
Startup GHG Emission Calculations - New Combined Cycle Combustion Turbine  
Deer Park Energy Center LLC**

**Startup/Shutdown Hourly GHG Emissions From Natural Gas Fired CTG5/HRSG5**

EPN	Heat Input During Startup <sup>1,2</sup> (MMBtu/hr)	Pollutant	Emission Factor (kg/MMBtu) <sup>3</sup>	GHG Mass Emissions <sup>4</sup> (ton/hr)	Global Warming Potential <sup>5</sup>	CO <sub>2</sub> e (ton/hr)
CTG5/HRSG5	1,163.9	CO <sub>2</sub>		69	1	69
		CH <sub>4</sub>	1.0E-03	0.0013	21	0.0269
		N <sub>2</sub> O	1.0E-04	0.0001	310	0.0398
		<b>Totals</b>		<b>69</b>		<b>69</b>

Note

1. The following hourly firing rates information is from the PSD application submitted to TCEQ on 09/01/2011.

	Operating Mode	CTG Data Case Number	Turbine Heat Input MMBtu/hr	Duct Burner Heat Input MMBtu/hr	Total Hourly Heat Input MMBtu/hr
Maximum Hourly Heat Input	Base Load, 20 °F Ambient, Max Duct Burner Firing	13b	2,016.5	690	2,706.5
Maximum Hourly Heat Input During Startup	60% Load, 90 °F Ambient, no Duct Burner Firing	7	1,163.9	0	1,163.9

2. Startup Emission Basis: A startup period begins when an initial flame detection signal is recorded in the plant's Data Acquisition and Handling System (DAHS) and ends when the combustion turbine output reaches 60% load. Since GHG emissions are proportional to fuel consumption, high GHG emissions during a startup occurs at the point of highest fuel consumption (approximately 60% load).

3. CH<sub>4</sub> and N<sub>2</sub>O GHG factors based on Table C-2 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.

4. CO<sub>2</sub> emissions based on 40 CFR Part 75, Appendix G, Equation G-4

$$W_{CO_2} = (F_c \times H \times U_f \times MW_{CO_2}) / 2000$$

$W_{CO_2}$  = CO<sub>2</sub> emitted from combustion, tons/yr

$F_c$  = Carbon based F-factor, 1040 scf/MMBtu

$H$  = Heat Input (MMBtu/yr)

$U_f$  = 1/385 scf CO<sub>2</sub>/lbmole at 14.7 psia and 68 °F

$MW_{CO_2}$  = Molecule weight of CO<sub>2</sub>, 44.0 lb/lbmole

5. Global Warming Potential factors based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.

**Table 3-3  
GHG Emission Calculations - Natural Gas Piping  
Deer Park Energy Center LLC**

**GHG Emissions From New Natural Gas Piping Components Associated with New Turbine 5**

EPN	Source Type	Fluid State	Count	Emission Factor <sup>1</sup> scf/hr/comp	CO <sub>2</sub> <sup>2</sup> (tpy)	Methane <sup>3</sup> (tpy)	Total (tpy)
NG-FUG	Valves	Gas/Vapor	60	0.123	0.05	1.27	
	Flanges	Gas/Vapor	240	0.017	0.03	0.70	
	Relief Valves	Gas/Vapor	8	0.196	0.01043	0.26986	
	Sampling Connections <sup>5</sup>	Gas/Vapor	18	0.123	0.01472	0.38104	
GHG Mass-Based Emissions					0.09	2.24	<b>2.3</b>
Global Warming Potential <sup>4</sup>					1	21	
CO <sub>2</sub> e Emissions					0.09	47.09	<b>47.2</b>

Note

1. Emission factors from Table W-1A of 40 CFR 98 Mandatory Greenhouse Gas Reporting
2. CO<sub>2</sub> emissions based on vol% of CO<sub>2</sub> in natural gas 1.33% from natural gas analysis
3. CH<sub>4</sub> emissions based on vol% of CH<sub>4</sub> in natural gas 94.44% from natural gas analysis
4. Global Warming Potential factors based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.
5. No emission factor in Table W-1a so conservatively used valve emission factor.

Example calculation:

50 valve	0.123 scf gas	0.0133 scf CO <sub>2</sub>	lbmole	44.01 lb CO <sub>2</sub>	8760 hr	ton =	0.05 ton/yr
	hr * valve	scf gas	385.5 scf	lbmole	yr	2000 lb	

**TABLE 3-4  
Gaseous Fuel Venting During Turbine Shutdown/Maintenance and  
Small Equipment and Fugitive Component Repair/Replacement  
Deer Park Energy Center LLC**

Location	Initial Conditions			Final Conditions			CO <sub>2</sub> <sup>3</sup>	CH <sub>4</sub> <sup>4</sup>	Total
	Volume <sup>1</sup> (ft <sup>3</sup> )	Press. (psig)	Temp. (°F)	Press. (psig)	Temp. (°F)	Volume <sup>2</sup> (scf)	Annual (tpy)	Annual (tpy)	Annual (tpy)
Turbine Fuel Line Shutdown/Maintenance	955	50	50	0	68	4,397	0.0033	0.09	
Small Equipment/Fugitive Component Repair/Replacement	6.7	50	50	0	68	31	0.00002	0.00060	
GHG Mass-Based Emissions							0.0034	0.0870	0.0904
Global Warming Potential <sup>5</sup>							1	21	
CO <sub>2</sub> e Emissions							0.0034	1.8269	1.8303

1. Initial volume is calculated by multiplying the cross-sectional area by the length of pipe using the following formula:  $V = \pi \cdot [(diameter\ in\ inches/12)/2]^2 \cdot length\ in\ feet = ft^3$
2. Final volume calculated using ideal gas law  $[(P_1V_1)/Z_1T_1] = [(P_2V_2)/Z_2T_2]$ .  $V_2 = V_1 \cdot (P_1/P_2) \cdot (T_2/T_1) \cdot (Z_1/Z_2)$ , where Z is estimated using the following equation:  $Z = 0.9994 - 0.0002P + 3E-08P^2$ .
3. CO<sub>2</sub> emissions based on vol% of CO<sub>2</sub> in natural gas 1.33% from natural gas analysis
4. CH<sub>4</sub> emissions based on vol% of CH<sub>4</sub> in natural gas 94.4% from natural gas analysis
5. Global Warming Potential factors based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.

Example calculation:

4,397 scf Nat Gas	0.0133 scf CO <sub>2</sub>	lbmole	44.01 lb CO <sub>2</sub>	ton =	= 0.0033 ton/yr CO <sub>2</sub>
yr	scf Nat Gas	385.5 scf	lbmole	2000 lb	

**Table 3-5**  
**GHG Emission Calculations - Electrical Equipment Insulated With SF<sub>6</sub>**  
**Deer Park Energy Center LLC**

**Assumptions**

New insulated circuit breaker SF <sub>6</sub> capacity	72	lb
Estimated annual SF <sub>6</sub> leak rate	0.5%	by weight
Estimated annual SF <sub>6</sub> mass emission rate	0.00018	ton/yr
Global Warming Potential <sup>1</sup>	23,900	
Estimated annual CO <sub>2</sub> e emission rate	4.3	ton/yr

Note

1. Global Warming Potential factors based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.



#### 4.0 PREVENTION OF SIGNIFICANT DETERIORATION APPLICABILITY

In the EPA guidance document *PSD and Title V Permitting Guidance for Greenhouse Gases*, the following PSD Applicability Test was provided for Step 1 of the PSD Tailoring rule for existing sources:

##### ***EPA Tailoring Rule Step 1 - PSD Applicability Test for GHGs***

PSD applies to the GHG emissions from a proposed modification to an existing major source if the following is true:

- The emissions increase **and** the **net** emissions increase of GHGs from the modification would be equal to or greater than 75,000 TPY on a CO<sub>2</sub>e basis **and** greater than zero TPY on a mass basis.

Since the project emissions increase of GHG is greater than 75,000 ton/yr of CO<sub>2</sub>e and greater than zero ton/yr on a mass basis, and there are no contemporaneous emission reductions of GHG and CO<sub>2</sub>e, PSD is triggered for GHG emissions. The emissions netting analysis is documented on the attached TCEQ PSD netting tables: Table 1F and Table 2F. Also included in Appendix A is the “The GHG PSD APPLICABILITY FLOWCHART – EXISTING SOURCES from the *PSD and Title V Permitting Guidance for Greenhouse Gases*

## TCEQ PSD NETTING TABLES



**TABLE 1F  
AIR QUALITY APPLICATION SUPPLEMENT**

Permit No.:	45642, PSD-TX-979, N-036	Application Submittal Date:	
Company	Deer Park Energy Center LLC		
RN:	RN100222033	Facility Location:	Deer Park
City		County:	Harris
Permit Unit I.D.:	ST-5	Permit Name:	CTG5 and HRSG5
Permit Activity:	<input type="checkbox"/> New Major Source <input checked="" type="checkbox"/> Modification		
Project or Process Description:	Authorize a new turbine unit with heat recovery steam generator		

Complete for all pollutants with a project emission increase.	POLLUTANTS						
	Ozone		CO	SO <sub>2</sub>	PM	GHG	CO <sub>2</sub> e
	NOx	VOC					
Nonattainment? (yes or no)						No	No
Existing site PTE (tpy)	This form for GHG only					> 100,000	> 100,000
Proposed project increases (tpy from 2F) <sup>3</sup>							
Is the existing site a major source? If not, is the project a major source by itself? (yes or no)	Yes						
If site is major, is project increase significant? (yes or no)						Yes	Yes
If netting required, estimated start of construction:	6/1/12						
5 years prior to start of construction:	6/2/07		Contemporaneous				
estimated start of operation:	6/1/14		Period				
Net contemporaneous change, including proposed project, from Table 3F (tpy)						Note 4	Note 4
FNSR applicable? (yes or no)						Yes	Yes

- Other PSD pollutants
  - Nonattainment major source is defined in Table 1 in 30 TAC 116.12(11) by pollutant and county. PSD thresholds are found in 40 CFR §51.166(b)(1).
  - Sum of proposed emissions minus baseline emissions, increases only. Nonattainment thresholds are found in Table 1 in 30 TAC 116.12(11) and PSD thresholds in 40 CFR §51.166(b)(23).
  - Since there are no contemporaneous decreases which would potentially affect PSD applicability and an impacts analysis is not required for GHG emissions, contemporaneous emission changes are not included on this table.
- The presentations made above and on the accompanying tables are true and correct to the best of my knowledge.

*Robert C. Sanchez*  
Signature

*Director S.H.S.*  
Title

*8-31-11*  
Date





## 5.0 BEST AVAILABLE CONTROL TECHNOLOGY (BACT)

The PSD rules define BACT as:

*Best available control technology* means an emissions limitation (including a visible emission standard) based on the maximum degree of reduction for each pollutant subject to regulation under [the] Act which would be emitted from any proposed major stationary source or major modification which the Administrator, on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs, determines is achievable for such source or modification through application of production processes or available methods, systems, and techniques, including fuel cleaning or treatment or innovative fuel combustion techniques for control of such pollutant. In no event shall application of best available control technology result in emissions of any pollutant which would exceed the emissions allowed by any applicable standard under 40 CFR parts 60 and 61. If the Administrator determines that technological or economic limitations on the application of measurement methodology to a particular emissions unit would make the imposition of an emissions standard infeasible, a design, equipment, work practice, operational standard, or combination thereof, may be prescribed instead to satisfy the requirement for the application of best available control technology. Such standard shall, to the degree possible, set forth the emissions reduction achievable by implementation of such design, equipment, work practice or operation, and shall provide for compliance by means which achieve equivalent results.<sup>9</sup>

In the EPA guidance document titled *PSD and Title V Permitting Guidance for Greenhouse Gases*, EPA recommended the use of the Agency's five-step "top-down" BACT process to determine BACT for GHGs.<sup>10</sup> In brief, the top-down process calls for all available control technologies for a given pollutant to be identified and ranked in descending order of control effectiveness. The permit applicant should first examine the highest-ranked ("top") option. The top-ranked options should be established as BACT unless the permit applicant demonstrates to the satisfaction of the permitting authority that technical considerations, or energy, environmental, or economic impacts justify a conclusion that the top ranked technology is not "achievable" in that case. If the most effective control strategy is eliminated in this fashion, then the next most effective alternative should be evaluated, and so on, until an option is selected as BACT.

EPA has broken down this analytical process into the following five steps:

**Step 1: Identify all available control technologies.**

**Step 2: Eliminate technically infeasible options.**

**Step 3: Rank remaining control technologies.**

---

<sup>9</sup> 40 C.F.R. § 52.21(b)(12.)

<sup>10</sup> EPA, *PSD and Title V Permitting Guidance for Greenhouse Gases*, p. 18 (Nov. 2010).

**Step 4: Evaluate most effective controls and document results.**

**Step 5: Select the BACT.**

## **5.1 BACT FOR THE COMBINED CYCLE COMBUSTION TURBINE**

### **5.1.1 Step 1: Identify All Available Control Technologies**

#### *5.1.1.1 Inherently Lower-Emitting Processes/Practices/Designs*

DEPC performed a search of the EPA's RACT/BACT/LAER Clearinghouse for natural gas fired combustion turbine generators and found no entries which address BACT for GHG emissions. Although not listed in the RACT/BACT/LAER Clearinghouse, a GHG BACT analysis was performed by the Russell City Energy Center for a 612 MW natural gas fired combined cycle power plant to be located in Hayward, California. The Russell City Energy Center project included two Siemens-Westinghouse 501FD3 combustion turbines. That analysis determined that BACT for GHG emissions was maintenance of the high energy efficiency that is inherent with natural gas fired combined cycle power plants. A GHG BACT permit condition was established which set an efficiency limit (also referred to as heat rate) of 7,730 Btu/kWh measured during baseload conditions – a heat rate appropriate for that particular combination of gas turbine, heat recovery steam generator, and steam turbine models. The 7,730 Btu/kWh net heat rate was based on a design base rate with factors added to account for a design margin and degradation between major overhauls.

A summary of available, lower greenhouse gas emitting processes, practices, and designs for combustion turbine power generators is presented below.

#### 5.1.1.1.1 Combustion Turbine Energy Efficiency Processes, Practices, and Designs

##### **Combustion Turbine Design**

CO<sub>2</sub> is a product of combustion of fuel containing carbon, which is inherent in any power generation technology using fossil fuel. It is not possible to reduce the amount of CO<sub>2</sub> generated from combustion, as CO<sub>2</sub> is the essential product of the chemical reaction between the fuel and the oxygen in which it burns, not a byproduct caused by imperfect combustion. As such, there is no technology available that can effectively reduce CO<sub>2</sub> generation by adjusting the conditions in which combustion takes place.

The only effective means to reduce the amount of CO<sub>2</sub> generated by a fuel-burning power plant is to generate as much electric power as possible from the combustion, thereby reducing the amount of fuel needed to meet the plant's required power output. This result is obtained by using the most efficient generating technologies available, so that as much of the energy content of the fuel as possible goes into generating power.

The most efficient way to generate electricity from a natural gas fuel source is the use of a combined cycle design. For fossil fuel technologies, efficiency ranges from approximately 30-50% (higher heating value [HHV]). A typical coal-fired Rankine cycle power plant has a base load efficiency of approximately 30% (HHV), while a modern F-Class natural gas fired combined cycle unit operating under optimal conditions has a baseload efficiency of approximately 50% (HHV).

Combined cycle units operate based on a combination of two thermodynamic cycles: the Brayton and the Rankine cycles. A combustion turbine operates on the Brayton cycle and the HRSG and steam turbine operate on the Rankine cycle. The combination of the two thermodynamic cycles allows for the high efficiency associated with combined cycle plants.

The combined-cycle natural gas turbine technology proposed for the Deer Park Energy Center is the "FD3" turbine technology which is the current state-of-the-art electrical generating equipment for a facility of this type.

In addition to the high-efficiency primary components of the turbine, there are a number of other design features employed within the combustion turbine that can improve the overall efficiency of the machine. These additional features include those summarized below.

#### **Periodic Burner Tuning**

Modern F-Class combustion turbines have regularly scheduled maintenance programs. These maintenance programs are important for the reliable operation of the unit, as well as to maintain optimal efficiency. As the combustion turbine is operated, the unit experiences degradation and loss in performance. The combustion turbine maintenance program helps restore the recoverable lost performance. The maintenance program schedule is determined by the number of hours of operation and/or turbine starts. There are three basic maintenance levels, commonly referred to as combustion inspections, hot gas path inspections, and major overhauls. Combustion inspections are the most frequent of the maintenance cycles. As part of this maintenance activity, the combustors are tuned to restore highly efficient low-emission operation.

#### **Reduction in Heat Loss**

Modern F-Class combustion turbines have high operating temperatures. The high operating temperatures are a result of the heat of compression in the compressor along with the fuel combustion in the burners. To minimize heat loss from the combustion turbine and protect the personnel and equipment around the machine, insulation blankets are applied to the combustion turbine casing. These blankets minimize the heat loss through the combustion turbine shell and help improve the overall efficiency of the machine.

#### **Instrumentation and Controls**

Modern F-Class combustion turbines have sophisticated instrumentation and controls to automatically control the operation of the combustion turbine. The control system is a digital-type and is supplied with the combustion turbine. The distributed control system (DCS) controls



all aspects of the turbine's operation, including the fuel feed and burner operations, to achieve efficient low-NO<sub>x</sub> combustion. The control system monitors the operation of the unit and modulates the fuel flow and turbine operation to achieve optimal high-efficiency low-emission performance for full-load and part-load conditions.

#### 5.1.1.1.2 Heat Recovery Steam Generator Energy Efficiency Processes, Practices, and Designs

The HRSG takes waste heat from the combustion turbine exhaust and uses the waste heat to convert boiler feed water to steam. Duct burning involves burning additional natural gas in the ducts to the heat recovery boiler, which increases the temperature of the exhaust coming from the combustion turbines and thereby creates additional steam for the steam turbine. For cogeneration units such as the proposed unit, duct burner firing serves two purposes: (1) additional power generation capacity during periods of high electrical demand, and (2) additional steam generation capacity during periods of high steam demand from the host facility.

The modern F-Class combustion turbine-based combined cycle HRSG is generally a horizontal natural circulation drum-type heat exchanger designed with three pressure levels of steam generation, reheat, split superheater sections with interstage attemperation, post-combustion emissions control equipment, and condensate recirculation. The HRSG is designed to maximize the conversion of the combustion turbine exhaust gas waste heat to steam for all plant ambient and load conditions. Maximizing steam generation will increase the steam turbine's power generation, which maximizes plant efficiency.

#### **Heat Exchanger Design Considerations**

HRSGs are heat exchangers designed to capture as much thermal energy as possible from the combustion turbine exhaust gases. This is performed at multiple pressure levels. For a drum-type configuration, each pressure level incorporates an economizer section(s), evaporator section, and superheater section(s). These heat transfer sections are made up of many thin-walled tubes to provide surface area to maximize the transfer of heat to the working fluid. Most of the tubes also include extended surfaces (e.g., fins). The extended surface optimizes the heat transfer, while minimizing the overall size of the HRSG. Additionally, flow guides are used to distribute the flow evenly through the HRSG to allow for efficient use of the heat transfer surfaces and post-combustion emissions control components. Low-temperature economizer sections employ recirculation systems to minimize cold-end corrosion, and stack dampers are used for cycling operation to conserve the thermal energy within the HRSG when the unit is off line.

#### **Insulation**

HRSGs take waste heat from the combustion turbine exhaust gas and uses that waste heat to convert boiler feed water to steam. As such, the temperatures inside the HRSG are nearly equivalent to the exhaust gas temperatures of the turbine. For F-Class combustion turbines, these temperatures can approach 1,200°F. HRSGs are designed to maximize the conversion of the waste heat to steam. One aspect of the HRSG design in maximizing this waste heat

conversion is the use of insulation. Insulation minimizes heat loss to the surroundings, thereby improving the overall efficiency of the HRSG. Insulation is applied to the HRSG panels that make up the shell of the unit, to the high-temperature steam and water lines, and typically to the bottom portion of the stack.

### **Minimizing Fouling of Heat Exchange Surfaces**

HRSGs are made up of a number of tubes within the shell of the unit that are used to generate steam from the combustion turbine exhaust gas waste heat. To maximize this heat transfer, the tubes and their extended surfaces need to be as clean as possible. Fouling of the tube surfaces impedes the transfer of heat. Fouling occurs from the constituents within the exhaust gas stream. To minimize fouling, filtration of the inlet air to the combustion turbine is performed. Additionally, cleaning of the tubes during is performed during periodic outages. By reducing the fouling, the efficiency of the unit is maintained.

### **Minimizing Vented Steam and Repair of Steam Leaks**

As with all steam-generated power facilities, minimization of steam vents and repair of steam leaks is important in maintaining the plant's efficiency. A combined cycle facility has just a few locations where steam is vented from the system, including at the deaerator vents, blowdown tank vents, and vacuum pumps/steam jet air ejectors. These vents are necessary to improve the overall heat transfer within the HRSG and condenser by removing solids and air that potentially blankets the heat transfer surfaces lowering the equipment's performance. Additionally, power plant operators are concerned with overall efficiency of their facilities. Therefore, steam leaks are repaired as soon as possible to maintain facility performance. Minimization of vented steam and repair of steam leaks will be performed for this project.

#### **5.1.1.1.3 Plant-wide Energy Efficiency Processes, Practices, and Designs**

There are a number of other components within the combined cycle plant that help improve overall efficiency, including:

- **Fuel gas preheating** – The overall efficiency of the combustion turbine is increased with increased fuel inlet temperatures. For the F-Class combustion turbine based combined cycle, the fuel gas is generally heated with high temperature water from the HRSG. This improves the efficiency of the combustion turbine.
- **Drain operation** – Drains are required to allow for draining the equipment for maintenance (i.e., maintenance drains), and also to allow condensate to be removed from the steam piping and drains for operation (i.e., operation drains). Operation drains are generally controlled to minimize the loss of energy from the cycle. This is accomplished by closing the drains as soon as the appropriate steam conditions are achieved.
- **Multiple combustion turbine/HRSG trains** – Multiple combustion turbine/HRSG trains help with part-load operation. The multiple trains allow the

unit to achieve higher overall plant part-load efficiency by shutting down trains operating at less efficient part-load conditions and ramping up the remaining train(s) to high-efficiency full-load operation.

- **Boiler feed pump fluid drives** – The boiler feed pumps are used as the means to impart high pressure on the working fluid. The pumps require considerable power. To minimize the power consumption at part-loads, the use of fluid drives or variable-frequency drives can be employed. For this project, fluid drives are being used to minimize power consumption at part-load, improving the facility's overall efficiency.

#### 5.1.1.2 Add-On Controls

In addition to power generation process technology options discussed above, it is appropriate to consider add-on technologies as possible ways to capture GHG emissions that are emitted from natural gas combustion in the proposed project's CTG/HRSG unit and to prevent them from entering the atmosphere. These emerging carbon capture and storage (CCS) technologies generally consist of processes that separate CO<sub>2</sub> from combustion process flue gas, and then inject it into geologic formations such as oil and gas reservoirs, unmineable coal seams, and underground saline formations. Of the emerging CO<sub>2</sub> capture technologies that have been identified, only amine absorption is currently commercially used for state-of-the-art CO<sub>2</sub> separation processes. Amine absorption has been applied to processes in the petroleum refining and natural gas processing industries and for exhausts from gas-fired industrial boilers. Other potential absorption and membrane technologies are currently considered developmental.

The U.S. Department of Energy's National Energy Technology Laboratory (DOE-NETL) provides the following brief description of state-of-the-art post-combustion CO<sub>2</sub> capture technology and related implementation challenges:

...In the future, emerging R&D will provide numerous cost-effective technologies for capturing CO<sub>2</sub> from power plants. At present, however, state-of-the-art technologies for existing power plants are essentially limited to amine absorbents. Such amines are used extensively in the petroleum refining and natural gas processing industries... Amine solvents are effective at absorbing CO<sub>2</sub> from power plant exhaust streams—about 90 percent removal—but the highly energy-intensive process of regenerating the solvents decreases plant electricity output...<sup>11</sup>

---

<sup>11</sup> DOE-NETL, *Carbon Sequestration: FAQ Information Portal*, [http://extsearch1.netl.doe.gov/search?q=cache:e0yvzjAh22cJ:www.netl.doe.gov/technologies/carbon\\_seq/FAQs/tech-status.html+emerging+R%26D&access=p&output=xml\\_no\\_dtd&ie=UTF-8&client=default\\_frontend&site=default\\_collection&proxystylesheet=default\\_frontend&oe=ISO-8859-1](http://extsearch1.netl.doe.gov/search?q=cache:e0yvzjAh22cJ:www.netl.doe.gov/technologies/carbon_seq/FAQs/tech-status.html+emerging+R%26D&access=p&output=xml_no_dtd&ie=UTF-8&client=default_frontend&site=default_collection&proxystylesheet=default_frontend&oe=ISO-8859-1) (last visited Aug. 8, 2011).

The DOE-NETL adds:

...Separating CO<sub>2</sub> from flue gas streams is challenging for several reasons:

- CO<sub>2</sub> is present at dilute concentrations (13-15 volume percent in coal-fired systems and 3-4 volume percent in gas-fired turbines) and at low pressure (15-25 pounds per square inch absolute [psia]), which dictates that a high volume of gas be treated.
- Trace impurities (particulate matter, sulfur dioxide, nitrogen oxides) in the flue gas can degrade sorbents and reduce the effectiveness of certain CO<sub>2</sub> capture processes.
- Compressing captured or separated CO<sub>2</sub> from atmospheric pressure to pipeline pressure (about 2,000 psia) represents a large auxiliary power load on the overall power plant system...<sup>12</sup>

If CO<sub>2</sub> capture can be achieved at a power plant, it would need to be routed to a geologic formation capable of long-term storage. The long-term storage potential for a formation is a function of the volumetric capacity of a geologic formation and CO<sub>2</sub> trapping mechanisms within the formation, including dissolution in brine, reactions with minerals to form solid carbonates, and/or adsorption in porous rock. The DOE-NETL describes the geologic formations that could potentially serve as CO<sub>2</sub> storage sites as follows:

“Geologic carbon dioxide (CO<sub>2</sub>) storage involves the injection of supercritical CO<sub>2</sub> into deep geologic formations (injection zones) overlain by competent sealing formations and geologic traps that will prevent the CO<sub>2</sub> from escaping. Current research and field studies are focused on developing better understanding of 11 major types of geologic storage reservoir classes, each having their own unique opportunities and challenges. Understanding these different storage classes provides insight into how the systems influence fluids flow within these systems today, and how CO<sub>2</sub> in geologic storage would be anticipated to flow in the future. The different storage formation classes include: deltaic, coal/shale, fluvial, alluvial, strandplain, turbidite, eolian, lacustrine, clastic shelf, carbonate shallow shelf, and reef. Basaltic interflow zones are also being considered as potential reservoirs. These storage reservoirs contain fluids that may include natural gas, oil, or saline water; any of which may impact CO<sub>2</sub> storage differently...”<sup>13</sup>

### 5.1.2 Step 2: Eliminate Technically Infeasible Options

In this section, DPEC addresses the potential feasibility of implementing CCS technology as BACT for GHG emissions from the proposed project’s gas turbine/HRSG train. Each

---

<sup>12</sup> *Id.*

<sup>13</sup> DOE-NETL, *Carbon Sequestration: Geologic Storage Focus Area*, [http://www.netl.doe.gov/technologies/carbon\\_seq/corerd/storage.html](http://www.netl.doe.gov/technologies/carbon_seq/corerd/storage.html) (last visited Aug.8, 2011)

component of CCS technology (i.e., capture and compression, transport, and storage) is discussed separately.

#### 5.1.2.1 *CO<sub>2</sub> Capture and Compression*

Though amine absorption technology for CO<sub>2</sub> capture has been applied to processes in the petroleum refining and natural gas processing industries and to exhausts from gas-fired industrial boilers, it is not yet commercially available for power plant gas turbine exhausts, which have considerably larger flow volumes and considerably lower CO<sub>2</sub> concentrations. The Obama Administration's Interagency Task Force on Carbon Capture and Storage confirms this in its recently completed report on the current status of development of CCS systems:

"Current technologies could be used to capture CO<sub>2</sub> from new and existing fossil energy power plants; however, they are not ready for widespread implementation primarily because they have not been demonstrated at the scale necessary to establish confidence for power plant application. Since the CO<sub>2</sub> capture capacities used in current industrial processes are generally much smaller than the capacity required for the purposes of GHG emissions mitigation at a typical power plant, there is considerable uncertainty associated with capacities at volumes necessary for commercial deployment."<sup>14</sup>

#### 5.1.2.2 *CO<sub>2</sub> Transport*

Even if it is assumed that CO<sub>2</sub> capture and compression could feasibly be achieved for the proposed project, the high-volume CO<sub>2</sub> stream generated would need to be transported to a facility capable of storing it. Potential geologic storage sites in Texas, Louisiana, and Mississippi to which CO<sub>2</sub> could be transported if a pipeline was constructed are delineated on the map found at the end of Section 5.<sup>15</sup> The potential length of such a CO<sub>2</sub> transport pipeline is uncertain due to the uncertainty of identifying a site(s) that is suitable for large-scale, long-term CO<sub>2</sub> storage. The hypothetical minimum length required for any such pipeline(s) will be the lesser of the following:

- The distance to the closest site with recognized potential for some geological storage of CO<sub>2</sub>, which is an enhanced oil recovery (EOR) reservoir site located within 15 miles of the proposed project; or
- The distance to a CO<sub>2</sub> pipeline that Denbury Green Pipeline-Texas is currently constructing within 10 miles of the project site for the purpose of providing CO<sub>2</sub> to support various EOR operations in Southeast Texas beginning in late 2013.

---

<sup>14</sup> *Report of the Interagency Task Force on Carbon Capture and Storage* at 50 (Aug. 2010).

<sup>15</sup> Susan Hovorka, University of Texas at Austin, Bureau of Economic Geology, Gulf Coast Carbon Center, *New Developments: Solved and Unsolved Questions Regarding Geologic Sequestration of CO<sub>2</sub> as a Greenhouse Gas Reduction Method* (GCCC Digital Publication #08-13) at slide 4 (Apr. 2008), available at: <http://www.beg.utexas.edu/gcccc/forum/codexdownloadpdf.php?ID=100> (last visited Aug. 8, 2011).

However, none of the Southeast Texas EOR reservoir or other geologic formation sites have yet been technically demonstrated for large-scale, long-term CO<sub>2</sub> storage.

In comparison, the closest site that is currently being field-tested to demonstrate its capacity for large-scale geological storage of CO<sub>2</sub> is the Southeast Regional Carbon Sequestration Partnership's (SECARB) Cranfield test site, which is located in Adams and Franklin Counties, Mississippi over 260 miles away (see the map at the end of Section 5 for the test site location). Therefore, to access this potentially large-scale storage capacity site, assuming that it is eventually demonstrated to indefinitely store a substantial portion of the large volume of CO<sub>2</sub> generated by the proposed project, a very long and sizable pipeline would need to be constructed to transport the large volume of high-pressure CO<sub>2</sub> from the plant to the storage facility, thereby rendering implementation of a CO<sub>2</sub> transport system infeasible.

### 5.1.2.3 CO<sub>2</sub> Storage

Even if it is assumed that CO<sub>2</sub> capture and compression could feasibly be achieved for the proposed project and that the CO<sub>2</sub> could be transported economically, the feasibility of CCS technology would still depend on the availability of a suitable sequestration site. The suitability of potential storage sites is a function of volumetric capacity of their geologic formations, CO<sub>2</sub> trapping mechanisms within formations (including dissolution in brine, reactions with minerals to form solid carbonates, and/or adsorption in porous rock), and potential environmental impacts resulting from injection of CO<sub>2</sub> into the formations. Potential environmental impacts resulting from CO<sub>2</sub> injection that still require assessment before CCS technology can be considered feasible include:

- Uncertainty concerning the significance of dissolution of CO<sub>2</sub> into brine,
- Risks of brine displacement resulting from large-scale CO<sub>2</sub> injection, including a pressure leakage risk for brine into underground drinking water sources and/or surface water,
- Risks to fresh water as a result of leakage of CO<sub>2</sub>, including the possibility for damage to the biosphere, underground drinking water sources, and/or surface water,<sup>16</sup> and
- Potential effects on wildlife.

Potentially suitable storage sites, including EOR sites and saline formations, exist in Texas, Louisiana, and Mississippi. In fact, sites with such recognized potential for some geological storage of CO<sub>2</sub> are located within 15 miles of the proposed project, but such nearby sites have not yet been technically demonstrated with respect to all of the suitability factors described above. In comparison, the closest site that is currently being field-tested to demonstrate its capacity for geological storage of the volume of CO<sub>2</sub> that would be generated by the proposed power unit, i.e., SECARB's Cranfield test site, is located in Mississippi over 260 miles away. It should be noted that, based on the suitability factors described above, currently the suitability of

---

<sup>16</sup> *Id.*

the Cranfield site or any other test site to store a substantial portion of the large volume of CO<sub>2</sub> generated by the proposed project has yet to be fully demonstrated.

Based on the reasons provided above, DPEC believes that CCS technology should be eliminated from further consideration as a potential feasible control technology for purposes of this BACT analysis. However, to answer possible questions that the public or the EPA may have concerning the relative costs of implementing hypothetical CCS systems, DPEC has estimated such costs. Those cost estimates are presented on Table 5-1 at the end of Section 5.

### **5.1.3 Step 3: Rank Remaining Control Technologies**

As documented above, implementation of CCS technology is currently infeasible, leaving energy efficiency measures as the only technically feasible emission control options. As all of the energy efficiency related processes, practices, and designs discussed in Section 5.1.1 of this application are being proposed for this project, a ranking of the control technologies is not necessary for this application.

### **5.1.4 Step 4: Evaluate Most Effective Controls and Document Results**

As all of the energy efficiency related processes, practices, and designs discussed in Section 5.1.1 of this application are being proposed for this project, an examination of the energy, environmental, and economic impacts of the efficiency designs is not necessary for this application. Because the CCS add-on control option discussed in Section 5.1.2 was determined to be technically infeasible, an examination of the energy, environmental, and economic impacts of that option is not necessary for this application. However, at the request of EPA Region 6, DPEC is including estimated costs for implementation of CCS.

### **5.1.5 Step 5: Select BACT**

DPEC proposes as BACT for this project, the following energy efficiency processes, practices, and designs for the proposed combined cycle combustion turbine:

- Use of Combined Cycle Power Generation Technology
- Combustion Turbine Energy Efficiency Processes, Practices, and Designs
  - Efficient turbine design
  - Turbine inlet air cooling
  - Periodic turbine burner tuning
  - Reduction in heat loss
  - Instrumentation and controls
- HRSG Energy Efficiency Processes, Practices, and Designs
  - Efficient heat exchanger design
  - Insulation of HRSG
  - Minimizing Fouling of heat exchange surfaces
  - Minimizing vented steam and repair of steam leaks

- Plant-wide Energy Efficiency Processes, Practices, and Designs
  - Fuel gas preheating
  - Drain operation
  - Multiple combustion turbine/HRSG trains
  - Boiler feed pump fluid drive design

To determine the appropriate heat-input efficiency limit, DPEC started with the turbine's design base load net heat rate for combined cycle operation and then calculated a compliance margin based upon reasonable degradation factors that may foreseeably reduce efficiency under real-world conditions. The design base load net heat rate for the Siemens 501F-FD3 turbine is 6,852 Btu/kWhr (HHV) without duct firing and 6,970 Btu/kWhr (HHV) with duct firing. Note that this rate reflects the facility's "net" power production, meaning the denominator is the amount of power provided to the grid; it does not reflect the total amount of energy produced by the plant, which also includes auxiliary load consumed by operation of the plant. To be consistent with the Russell City Energy Center GHG BACT analysis, the net heat rate without duct firing is used to calculate the heat-input efficiency limit.

During periods when some or all of the generated steam is sold to the neighboring facility rather than sent to the on-site steam turbine, the energy efficiency of the equipment utilizing the steam at the neighboring facility may be different than the efficiency of DPEC's existing steam turbine. Therefore, for purposes of the heat input limit for this application, the heat rate is calculated assuming that all steam generated in the heat recovery steam generator is used to generate electricity in the existing on-site steam turbine.

To determine an appropriate heat rate limit for the permit, the following compliance margins are added to the base heat rate limit:

- A 3.3% design margin reflecting the possibility that the constructed facility will not be able to achieve the design heat rate.
- A 6% performance margin reflecting efficiency losses due to equipment degradation prior to maintenance overhauls.
- A 3% degradation margin reflecting the variability in operation of auxiliary plant equipment due to use over time.

These factors are consistent with the compliance margin factors used in with the Russell City Energy Center GHG BACT analysis. As a result of these adjustments, DPEC is proposing a BACT net heat rate for the Project of 7,730 Btu/kWh (HHV), corrected to ISO conditions of:

- Ambient Dry Bulb Temperature: 59°F
- Ambient Relative Humidity: 60%
- Barometric Pressure: 14.69 psia
- Fuel Lower Heating Value: 20,647 Btu/lb
- Fuel HHV/LHV Ratio: 1.1086

This heat rate limit is equivalent to an output based GHG BACT limit of 0.460 ton CO<sub>2</sub>e/MWhr (net) BACT. The calculation of the net heat rate and the equivalent ton CO<sub>2</sub>e/MWhr is provided on Table 5-2 of this application.



## 5.2 BACT FOR SF<sub>6</sub> INSULATED ELECTRICAL EQUIPMENT

### 5.2.1 Step 1: Identify All Available Control Technologies

Step 1 of the Top-Down BACT analysis is to identify all feasible control technologies. One technology is the use of state-of-the-art SF<sub>6</sub> technology with leak detection to limit fugitive emissions. In comparison to older SF<sub>6</sub> circuit breakers, modern breakers are designed as a totally enclosed-pressure system with far lower potential for SF<sub>6</sub> emissions. In addition, the effectiveness of leak-tight closed systems can be enhanced by equipping them with a density alarm that provides a warning when 10% of the SF<sub>6</sub> (by weight) has escaped. The use of an alarm identifies potential leak problems before the bulk of the SF<sub>6</sub> has escaped, so that it can be addressed proactively in order to prevent further release of the gas.

One alternative considered in this analysis is to substitute another, non-greenhouse-gas substance for SF<sub>6</sub> as the dielectric material in the breakers. Potential alternatives to SF<sub>6</sub> were addressed in the National Institute of Standards and Technology (NIST) Technical Note 1425, *Gases for Electrical Insulation and Arc Interruption: Possible Present and Future Alternatives to Pure SF<sub>6</sub>*.<sup>17</sup>

### 5.2.2 Step 2: Eliminate Technically Infeasible Options

According to the report NIST Technical Note 1425, SF<sub>6</sub> is a superior dielectric gas for nearly all high voltage applications.<sup>18</sup> It is easy to use, exhibits exceptional insulation and arc-interruption properties, and has proven its performance by many years of use and investigation. It is clearly superior in performance to the air and oil insulated equipment used prior to the development of SF<sub>6</sub>-insulated equipment. The report concluded that although "...various gas mixtures show considerable promise for use in new equipment, particularly if the equipment is designed specifically for use with a gas mixture... it is clear that a significant amount of research must be performed for any new gas or gas mixture to be used in electrical equipment." Therefore there are currently no technically feasible options besides use of SF<sub>6</sub>.

### 5.2.3 Step 3: Rank Remaining Control Technologies

The use of state-of-the-art SF<sub>6</sub> technology with leak detection to limit fugitive emissions is the highest ranked control technology that is technically feasible for this application.

---

<sup>17</sup> Christophorous, L.G., J.K. Olthoff, and D.S. Green, *Gases for Electrical Insulation and Arc Interruption: Possible Present and Future Alternatives to Pure SF<sub>6</sub>*, NIST Technical Note 1425, Nov.1997.

<sup>18</sup> *Id.* at 28 – 29.

#### 5.2.4 Step 4: Evaluate Most Effective Controls and Document Results

Energy, environmental, or economic impacts were not addressed in this analysis because the use of alternative, non-greenhouse-gas substance for SF<sub>6</sub> as the dielectric material in the breakers is not technically feasible.

#### 5.2.5 Step 5: Select BACT

Based on this top-down analysis, DPEC concludes that using state-of-the-art enclosed-pressure SF<sub>6</sub> circuit breakers with leak detection would be the BACT control technology option. The circuit breakers will be designed to meet the latest of the American National Standards Institute (ANSI) C37.013 standard for high voltage circuit breakers.<sup>19</sup> The proposed circuit breaker at the generator output will have a low pressure alarm and a low pressure lockout. This alarm will function as an early leak detector that will bring potential fugitive SF<sub>6</sub> emissions problems to light before a substantial portion of the SF<sub>6</sub> escapes. The lockout prevents any operation of the breaker due to lack of “quenched and cooled” SF<sub>6</sub> gas.

DPEC will monitor emissions annually in accordance with the requirements of the Mandatory Greenhouse Gas Reporting rules for Electrical Transmission and Distribution Equipment Use.<sup>20</sup> Annual SF<sub>6</sub> emissions will be calculated according to the mass balance approach in Equation DD-1 of Subpart DD.

---

<sup>19</sup> ANSI Standard C37.013, *Standard for AC High-Voltage Generator Circuit Breakers on a Symmetrical Current*.

<sup>20</sup> See 40 C.F.R. Pt. 98, Subpt. DD.

**MAP OF EXISTING CO<sub>2</sub> PIPELINES AND POTENTIAL GEOLOGIC STORAGE SITES IN  
TEXAS**

**US EPA ARCHIVE DOCUMENT**





# Frio Test Site

# SECARB Phase II&III Cranfield

SECARB

SSCB

SACROC  
Southwest  
Partnership  
NM Tech



- CO<sub>2</sub>-EOR candidate reservoirs
- Existing CO<sub>2</sub> pipelines
- Additional oil-production area with CO<sub>2</sub>-EOR production and potential
- Major oil plays

Source: Base drawing from University of Texas at Austin, Bureau of Economic Geology, Gulf Coast Carbon Center.

**Table 5-1  
Range of Approximate Annual Costs for Installation and Operation of Capture, Transport, and Storage Systems  
for Control of CO<sub>2</sub> Emissions from Proposed Electric Generating Unit 5  
at Deer Park Energy Center, Harris County, Texas**

Carbon Capture and Storage (CCS) Component System	Factors for Approximate Costs for CCS Systems	Annual System CO <sub>2</sub> Throughput (tons of CO <sub>2</sub> captured, transported, and stored) <sup>1</sup>	Pipeline Length for CO <sub>2</sub> Transport System (km CO <sub>2</sub> transported) <sup>5</sup>	Range of Approximate Annual Costs for CCS Systems (\$)
<b>Post-Combustion CO<sub>2</sub> Capture and Compression System</b>				
Minimum Cost	\$44.11 / ton of CO <sub>2</sub> avoided <sup>2</sup>	956,349		\$42,184,554
Maximum Cost	\$103.42 / ton of CO <sub>2</sub> avoided <sup>3</sup>	956,349		\$98,904,711
Average Cost	\$73.76 / ton of CO <sub>2</sub> avoided <sup>4</sup>	956,349		\$70,544,632
<b>CO<sub>2</sub> Transport System</b>				
Minimum Cost	\$0.91 / ton of CO <sub>2</sub> transported per 100 km <sup>3</sup>	956,349	24	\$209,562
Maximum Cost	\$2.72 / ton of CO <sub>2</sub> transported per 100 km <sup>3</sup>	956,349	24	\$628,685
Average Cost	\$1.81 / ton of CO <sub>2</sub> transported per 100 km <sup>4</sup>	956,349	24	\$419,123
<b>CO<sub>2</sub> Storage System</b>				
Minimum Cost	\$0.51 / ton of CO <sub>2</sub> stored <sup>3,6</sup>	956,349		\$485,848
Maximum Cost	\$18.14 / ton of CO <sub>2</sub> stored <sup>3,6</sup>	956,349		\$17,351,704
Average Cost	\$9.33 / ton of CO <sub>2</sub> stored <sup>4</sup>	956,349		\$8,918,776
<b>Total Cost for CO<sub>2</sub> Capture, Transport, and Storage Systems</b>				
Minimum Cost	\$44.84 / ton of CO <sub>2</sub> removed	956,349		\$42,879,964
Maximum Cost	\$122.22 / ton of CO <sub>2</sub> removed	956,349		\$116,885,099
Average Cost	\$83.53 / ton of CO <sub>2</sub> removed <sup>4</sup>	956,349		\$79,882,531

<sup>1</sup> Assumes that a capture system would be able to capture 90% of the total CO<sub>2</sub> emissions generated by the power plant's gas turbines.

<sup>2</sup> This cost factor is the minimum found for implementation/operation of CO<sub>2</sub> capture systems within the cost-related information reviewed for CCS technology. The factor is from the on the "Properties" spreadsheet of the *Greenhouse Gas Mitigation Strategies Database* (Apr. 2010) (<http://ghg.ie.unc.edu:8080/GHGMDb/#data>), which was obtained through the EPA GHG web site (<http://www.epa.gov/nsr/ghgpermitting.html>). The factor is based on the increased cost of electricity (COE; in \$/MW-h) resulting from implementation and operation at a CO<sub>2</sub> capture system on a natural gas-fired combined cycle power plant. The factor accounts for annualized capital costs, fixed operating costs, variable operating costs, and fuel costs.

<sup>3</sup> These cost factors are from *Report of the Interagency Task Force on Carbon Capture and Storage*, pp.33, 34, 37, and 44 (Aug. 2010) ([http://www.epa.gov/climatechange/policy/ccs\\_task\\_force.html](http://www.epa.gov/climatechange/policy/ccs_task_force.html)). The factors from the report in the form of \$/tonne of CO<sub>2</sub> avoided, transported, or stored and have been converted to \$/ton. Per the report, the factors are based on the increased cost of electricity (COE; in \$/kW-h) of an "energy-generating system, including all the costs over its lifetime: initial investment, operations and maintenance, cost of fuel, and cost of capital".

<sup>4</sup> The average cost factors were calculated as the arithmetic mean of the minimum and maximum factors for each CCS component system and for all systems combined.

<sup>5</sup> The length of the pipeline was assumed to be the distance to the closest potential geologic storage site, as identified by the University of Texas at Austin, Bureau of Economic Geology, Gulf Coast Carbon Center, available at: [http://www.beg.utexas.edu/gccc/graphics/Basemap\\_state\\_lands\\_fp\\_lg.jpg](http://www.beg.utexas.edu/gccc/graphics/Basemap_state_lands_fp_lg.jpg) (last visited Aug. 11, 2011).

<sup>6</sup> "Cost estimates [for geologic storage of CO<sub>2</sub>] are limited to capital and operational costs, and do not include potential costs associated with long-term liability." (from the *Report of the Interagency Task Force on Carbon Capture and Storage*, p. 44)

**Table 5-2  
GHG Emission Calculations - Calculation of Design Heat Rate Limit  
Deer Park Energy Center LLC**

<b>Base Net Heat Rate</b>	<b>6,852</b>	<b>Btu/kWH (HHV) (Without Duct Firing)</b>
	<b>3.3%</b>	<b>Design Margin</b>
	<b>6.0%</b>	<b>Performance Margin</b>
	<b>3.0%</b>	<b>Degradation Margin</b>
<b>Calculated Base Net Heat Rate with Compliance Margins</b>	<b>7,727.9</b>	<b>Btu/kWH (HHV) (Without Duct Firing)</b>

**Calculate of ton CO<sub>2</sub>e/MWhr Heat Rate Limit for CTG5/HRSG5**

EPN	Base Heat Rate (Btu/kWhr)	Heat Input Required to Produce 1 MW (MMBtu/hr)	Pollutant	Emission Factor (kg/MMBtu) <sup>1</sup>	ton GHG/MWhr <sup>2</sup>	Global Warming Potential <sup>3</sup>	ton CO <sub>2</sub> e/MWhr
CTG5/HRSG5	7727.9	7.73	CO <sub>2</sub>		0.459	1	0.459
			CH <sub>4</sub>	1.0E-03	8.52E-06	21	1.79E-04
			N <sub>2</sub> O	1.0E-04	8.52E-07	310	2.64E-04
			<b>Totals</b>		<b>0.459</b>		<b>0.460</b>

Note

1. CH<sub>4</sub> and N<sub>2</sub>O GHG factors based on Table C-2 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.

2. CO<sub>2</sub> emissions based on 40 CFR Part 75, Appendix G, Equation G-4

$$W_{CO_2} = (F_c \times H \times U_f \times MW_{CO_2}) / 2000$$

*W<sub>CO<sub>2</sub></sub>* = CO<sub>2</sub> emitted from combustion, tons/yr

*F<sub>c</sub>* = Carbon based F-factor, 1040 scf/MMBtu

*H* = Heat Input (MMBtu/yr)

*U<sub>f</sub>* = 1/385 scf CO<sub>2</sub>/lbmole at 14.7 psia and 68 ° F

*MW<sub>CO<sub>2</sub></sub>* = Molecule weight of CO<sub>2</sub>, 44.0 lb/lbmole

3. Global Warming Potential factors based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting.

## 6.0 OTHER PSD REQUIREMENTS

### 6.1 IMPACTS ANALYSIS

An impacts analysis is not being provided with this application in accordance with EPA's recommendations:

*Since there are no NAAQS or PSD increments for GHGs, the requirements in sections 52.21(k) and 51.166(k) of EPA's regulations to demonstrate that a source does not cause contribute to a violation of the NAAQS are not applicable to GHGs. Therefore, there is no requirement to conduct dispersion modeling or ambient monitoring for CO<sub>2</sub> or GHGs.<sup>21</sup>*

### 6.2 GHG PRECONSTRUCTION MONITORING

A pre-construction monitoring analysis for GHG is not being provided with this application in accordance with EPA's recommendations:

*EPA does not consider it necessary for applicants to gather monitoring data to assess ambient air quality for GHGs under section 52.21(m)(1)(ii), section 51.166(m)(1)(ii), or similar provisions that may be contained in state rules based on EPA's rules. GHGs do not affect "ambient air quality" in the sense that EPA intended when these parts of EPA's rules were initially drafted. Considering the nature of GHG emissions and their global impacts, EPA does not believe it is practical or appropriate to expect permitting authorities to collect monitoring data for purpose of assessing ambient air impacts of GHGs.<sup>22</sup>*

### 6.3 ADDITIONAL IMPACTS ANALYSIS

A PSD additional impacts analysis is not being provided with this application in accordance with EPA's recommendations:

*Furthermore, consistent with EPA's statement in the Tailoring Rule, EPA believes it is not necessary for applicants or permitting authorities to assess impacts from GHGs in the context of the additional impacts analysis or Class I area provisions of the PSD regulations for the following policy reasons. Although it is clear that GHG emissions contribute to global warming and other climate changes that result in impacts on the environment, including impacts on Class I areas and soils and vegetation due to the global scope of the problem, climate change modeling and evaluations of risks and impacts of GHG emissions is typically conducted for changes in emissions orders of magnitude larger than the emissions from individual projects that might be analyzed in PSD permit reviews. Quantifying the exact impacts attributable to a specific GHG source obtaining a permit in specific places and points would not be possible with current climate change modeling. Given these considerations, GHG emissions would*

---

<sup>21</sup> EPA, *PSD and Title V Permitting Guidance For Greenhouse Gases* at 48-49.

<sup>22</sup> *Id.* at 49.

PREVENTION OF SIGNIFICANT DETERIORATION GREENHOUSE GAS PERMIT APPLICATION  
FOR A NEW COMBINED CYCLE COGENERATION UNIT AT THE DEER PARK ENERGY CENTER  
DEER PARK ENERGY CENTER LLC

---

*serve as the more appropriate and credible proxy for assessing the impact of a given facility. Thus, EPA believes that the most practical way to address the considerations reflected in the Class I area and additional impacts analysis is to focus on reducing GHG emissions to the maximum extent. In light of these analytical challenges, compliance with the BACT analysis is the best technique that can be employed at present to satisfy the additional impacts analysis and Class I area requirements of the rules related to GHGs.<sup>23</sup>*

---


<sup>23</sup> *Id.*



**APPENDIX A**

**GHG PSD APPLICABILITY FLOWCHART – EXISTING SOURCES**

**GHG Applicability Flowchart – Modified Sources  
(On or after July 1, 2011)**



From prior page

7  
For units that are part of the modification, determine the future projected actual emissions (or PTE) in TPY for each of the 6 GHG pollutants.

8  
For each unit, determine the increase or decrease in mass emissions of each of the 6 GHG pollutants by subtracting past actual emissions from future actual emissions. (For new units that are not "replacement units," future actual emissions are equal to the PTE.)

9  
For each unit, sum any increase or decrease in GHG emissions on a mass basis.

10  
For all units that have mass emissions increase, sum the GHG emissions on a mass basis.

11  
Is the sum of GHG mass emissions increase over zero TPY?

NO

GHG emissions are not subject to PSD as part of this permit review.

YES

12  
For each unit, convert any increase or decrease in emissions of each of the 6 GHG pollutants to their CO<sub>2</sub>e emissions using the global warming potential factors applied to the mass of each of the 6 GHG pollutants and sum them for each unit to arrive at one GHG CO<sub>2</sub>e number for each unit.

13  
Sum the GHG emissions on a CO<sub>2</sub>e basis for all units that have an emissions increase. (Emission decreases are not considered in this step.)

Go to next page

