

US EPA ARCHIVE DOCUMENT

Statement of Basis

Draft Greenhouse Gas Prevention of Significant Deterioration Preconstruction Permit for the La Paloma Energy Center, LLC

Permit Number: PSD-TX-1288-GHG

March 2013

This document serves as the Statement of Basis (SOB) for the above-referenced draft permit, as required by 40 CFR 124.7. This document sets forth the legal and factual basis for the draft permit conditions and provides references to the statutory or regulatory provisions, including provisions under 40 CFR 52.21, that would apply if the permit is finalized. This document is intended for use by all parties interested in the permit.

I. Executive Summary

On April 30, 2012, La Paloma Energy Center, LLC (La Paloma), submitted to EPA Region 6 a Prevention of Significant Deterioration (PSD) permit application for Greenhouse Gas (GHG) emissions for a proposed construction project. On July 17, 2012 and August 6, 2012, La Paloma submitted additional information for inclusion into the application. In connection with the same proposed construction project, La Paloma submitted an application for a PSD Permit for non-GHG pollutants to the Texas Commission on Environmental Quality (TCEQ) on March 15, 2012. The project proposes to construct a new natural gas fired combined cycle electric generating plant, La Paloma Energy Center (LPEC), to be located near Harlingen, Cameron County, Texas. The LPEC will consist of two natural gas fired combustion turbines, each exhausting to a heat recovery steam generator (HRSG) to produce steam to drive a shared steam turbine. After reviewing the application, EPA Region 6 has prepared the following SOB and draft air permit to authorize construction of air emission sources at the La Paloma Energy Center.

This SOB documents the information and analysis EPA used to support the decisions EPA made in drafting the air permit. It includes a description of the proposed facility, the applicable air permit requirements, and an analysis showing how the applicant complied with the requirements.

EPA Region 6 concludes that La Paloma's application is complete and provides the necessary information to demonstrate that the proposed project meets the applicable air permit regulations. EPA's conclusions rely upon information provided in the permit application, supplemental information requested by EPA and provided by La Paloma, and EPA's own technical analysis. EPA is making all this information available as part of the public record.

II. Applicant

La Paloma Energy Center, LLC
4011 West Plano Parkway
Suite 128
Plano, TX 75093

Facility Physical Address:
24684 FM 1595
Harlingen, TX 78550

Contact:
Kathleen Smith
President
La Paloma Energy Center, LLC
(281) 253-4385

III. Permitting Authority

On May 3, 2011, EPA published a federal implementation plan (FIP) that makes EPA Region 6 the PSD permitting authority for the pollutant GHGs. See 75 FR 25178 (promulgating 40 CFR § 52.2305).

The GHG PSD Permitting Authority for the State of Texas is:

EPA, Region 6
1445 Ross Avenue
Dallas, TX 75202

The EPA, Region 6 Permit Writer is:
Aimee Wilson
Air Permitting Section (6PD-R)
(214) 665-7596

The Non-GHG PSD Permitting Authority for the State of Texas is:

Air Permits Division (MC-163)
TCEQ
P.O. Box 13087
Austin, TX 78711-3087

IV. Facility Location


The La Paloma Energy Center (LPEC) will be located in Cameron County, Texas, and this area is currently designated “attainment” for all criteria pollutants. The nearest Class 1 area is the Big Bend National Park, which is located well over 100 miles from the site. The geographic coordinates for this proposed facility site are as follows:

Latitude: 26° 12' 58.9" North

Longitude: -97° 37' 41.02" West

Below, Figure 1 illustrates the proposed facility location for this draft permit.

Figure 1. La Paloma Energy Center Location



V. Applicability of Prevention of Significant Deterioration (PSD) Regulations

EPA Region 6 implements a GHG PSD FIP for the State of Texas under the provisions of 40 CFR 52.21 (except paragraph (a)(1)). See 40 CFR § 52.2305. For the proposed construction project, La Paloma estimates potential GHG emissions of 3,292,862 tons per year (tpy) of CO₂e. Since the proposed project's GHG emissions would make LPEC a major stationary source for pursuant to 40 CFR 52.21(b)(1)(i) and (b)(49)(iv), EPA concludes that La Paloma's application is subject to PSD review for GHG.

La Paloma represents that TCEQ, the permitting authority for regulated NSR pollutants other than GHGs, will determine that LPEC is also subject to PSD review for VOC, NO_x, CO, PM, PM₁₀, PM_{2.5}, and H₂SO₄. Accordingly, under the circumstances of this project, the TCEQ will issue the non-GHG portion of the permit and EPA will issue the GHG portion.¹

EPA Region 6 applies the policies and practices reflected in EPA's *PSD and Title V Permitting Guidance for Greenhouse Gases* (March 2011). Consistent with that guidance, we have not required the applicant to model or conduct ambient monitoring for GHGs, nor have we required any assessment of impacts of GHGs in the context of the additional impacts analysis or Class I area provisions. Instead, EPA has determined that compliance with the BACT analysis is the best technique that can be employed at present to satisfy the additional impacts analysis and Class I area requirements of the rules related to GHGs. We note again, however, that the project has regulated NSR pollutants that are non-GHG pollutants, which are addressed by the PSD permit to be issued by TCEQ.

VI. Project Description

The proposed GHG PSD permit, if finalized, would authorize La Paloma Energy Center to construct a new combined cycle electric generating plant (LPEC) in Cameron County, Texas. LPEC will generate 637 - 735 megawatts (MW) of gross electrical power near the City of Harlingen. The gross electrical power output is based on two turbines rated between 183 and 232 MW each and the steam from the HRSGs driving a third electric generator with an electricity output capacity of 271 MW. The LPEC will consist of the following sources of GHG emissions:

- Two natural gas-fired combustion turbines equipped with lean pre-mix low-NO_x combustors;
- Two natural gas-fired duct burner system equipped Heat Recovery Steam Generators (HRSG);
- Natural gas piping and metering;

¹ See EPA, Question and Answer Document: Issuing Permits for Sources with Dual PSD Permitting Authorities, April 19, 2011, <http://www.epa.gov/nsr/ghgdocs/ghgissuedualpermitting.pdf>

- One diesel fuel-fired emergency electrical generator engine;
- One diesel fuel-fired fire water pump engine;
- One natural gas-fired auxiliary boiler; and
- Electrical equipment insulated with sulfur hexafluoride (SF₆).

Combustion Turbine Generator

The plant will consist of two identical natural gas-fired combustion turbines (CTGs). There are three models being considered by LPEC: the General Electric 7FA, the Siemens SGT6-5000F(4), and the Siemens SGT6-5000F(5). The final selection of the combustion turbine model to be used at the plant will likely be made after the permit is issued. Each combustion turbine will exhaust to a heat recovery steam generator (HRSG). As explained below, the final permit will include BACT limits and related conditions specific to each of the possible turbine models. If a final selection of combustion turbine is made after the public notice begins, and before the issuance of the final permit, EPA will issue a final permit including only the limits for the selected turbine.

The combustion turbine will burn pipeline natural gas to rotate an electrical generator to generate electricity. The main components of a combustion turbine generator consist of a compressor, combustor, turbine, and generator. The compressor pressurizes combustion air to the combustor where the fuel is mixed with the combustion air and burned. Hot exhaust gases then enter the turbine where the gases expand across the turbine blades, driving a shaft to power an electric generator. The exhaust gas will exit the combustion turbine and be routed to the HRSG for steam production.

Heat Recovery Steam Generator with Duct Burners

Heat recovered in the HRSG will be utilized to produce steam. Steam generated within the HRSG will be utilized to drive a steam turbine and associated electrical generator. The HRSG will be equipped with duct burners for supplemental steam production. The duct burners will be fired with pipeline quality natural gas. The duct burners have a maximum heat input capacity of 750 MMBtu/hr per unit. The exhaust gases from the unit, including emissions from the CT and the duct burners, will exit through a stack to the atmosphere.

The normal duct burner operation will vary from 0 to 100 percent of the maximum capacity. Duct burners will be located in the HRSG prior to the selective catalytic reduction (SCR) system.

Generators Overall

Steam produced by each of the two HRSGs will be routed to the steam turbine. The two combustion turbines and one steam turbine will be coupled to electric generators to produce

electricity for sale to the Electric Reliability Council of Texas (ERCOT) power grid. Each combustion turbine model has an approximate maximum base-load electric power output as follows: GE 7FA output of 183 MW, the Siemens SGT6-5000F(4) output of 205 MW, and the Siemens SGT6-5000F(5) output of 232 MW. The maximum electric power output from the steam turbine is approximately 271 MW for both the GE and Siemens configurations. The units may operate at reduced load to respond to changes in system power requirements and/or stability.

Auxiliary Boiler

One auxiliary boiler will be available to facilitate startup of the combined cycle turbine units. The auxiliary boiler will have a maximum heat input of 150 MMBtu/hr and will burn pipeline natural gas. The auxiliary boiler is proposed to be permitted to operate up to 876 hours per year.

Emergency Equipment

The site will be equipped with one nominally rated 1,072-hp diesel-fired emergency generator to provide electricity to the facility in case of power failure. A nominally rated 500-hp diesel-fired pump will be installed at the site to provide water in the event of a fire. Each emergency engine will be limited to 100 hours of operation per year for purposes of maintenance checks and readiness testing.

Electrical Equipment Insulated with Sulfur Hexafluoride (SF₆)

The generator circuit breakers associated with the proposed units will be insulated with SF₆. SF₆ is a colorless, odorless, non-flammable, and non-toxic synthetic gas. It is a fluorinated compound that has an extremely stable molecular structure. The unique chemical properties of SF₆ make it an efficient electrical insulator. The gas is used for electrical insulation, arc quenching, and current interruption in high-voltage electrical equipment. SF₆ is only used in sealed and safe systems which under normal circumstances do not leak gas. The capacity of the circuit breakers associated with the proposed plant is currently estimated to be 400 lbs of SF₆. The proposed circuit breaker at the generator output will have a low pressure alarm and a low pressure lockout. The alarm will alert personnel of any leakage in the system and the lockout prevents any operation of the breaker due to lack of “quenching and cooling” of SF₆ gas.

VII. General Format of the BACT Analysis

The BACT analyses for this draft permit were conducted in accordance with EPA’s *PSD and Title V Permitting Guidance for Greenhouse Gases* (March 2011), which outlines the steps for conducting a “top-down” BACT analysis. Those steps are listed below.

- (1) Identify all available control options;
- (2) Eliminate technically infeasible control options;
- (3) Rank remaining control options;
- (4) Evaluate the most effective controls (taking into account the energy, environmental, and economic impacts) and document the results; and
- (5) Select BACT.

VIII. Applicable Emission Units for BACT Analysis

The majority of the GHGs associated with the project are from emissions at combustion sources (i.e., combined cycle combustion turbines, auxiliary boiler, emergency engine, and fire water pump). The project will have fugitive emissions from piping components which will account for 423 TPY of CO₂e, or less than 0.01% of the project's total CO₂e emissions. Stationary combustion sources primarily emit CO₂, and small amounts of N₂O and CH₄. The following equipment is included in this proposed GHG PSD permit:

- Combined Cycle Combustion Turbines (U1-STK and U2-STK)
- Auxiliary Boiler (AUXBLR)
- Emergency Generator (EMGEN1-STK)
- Fire Water Pump (FWP1-STK)
- Natural Gas Fugitives (NG-FUG)
- SF₆ Insulated Equipment (SF6-FUG)
- Gaseous Fuel Venting (TRB-MSS)

IX. Combined Cycle Combustion Turbines (U1-STK and U2-STK)

There will be two new natural gas fired combined cycle combustion turbines (U1-STK and U2-STK) used for power generation. La Paloma is evaluating three combustion turbines for this project: General Electric 7FA, Siemens SGT6-5000F(4), and Siemens SGT6-5000F(5). The BACT analysis for the turbines considered two types of GHG emission reduction alternatives: (1) energy efficiency processes, practices, and designs for the turbines and other facility components; and (2) carbon capture and storage/sequestration (CCS). The proposed energy efficiency processes, practices, and designs discussed in Step 1 will be the same for the three models being considered. The proposed BACT limits listed in Step 5 section are specific to each turbine model.

As part of the PSD review, La Paloma provided in the GHG permit application a 5-step top-down BACT analysis for the combustion turbines. EPA has reviewed La Paloma's BACT analysis for the combustion turbines, which is part of the record for this permit (including this

Statement of Basis), and we also provide our own analysis in setting forth BACT for this proposed permit, as summarized below.

Step 1 – Identify All Available Control Options

(1) Energy Efficiency Processes, Practices, and Design

Combustion Turbine:

- *Combustion Turbine Design* – The most efficient way to generate electricity from a natural gas fuel source is the use of a combined cycle combustion turbine. Furthermore, the three turbine models under consideration for the LPEC facility are highly efficient turbines, in terms of their heat rate (expressed as number of BTUs of heat energy required to produce a kilowatt-hour of electricity), which is a measure that reflects how efficiently a generator uses heat energy.
- *Periodic Burner Tuning* – Periodic combustion inspections involving tuning of the combustors to restore highly efficient low-emission operation.
- *Reduction in Heat Loss* – Insulation blankets are applied to the combustion turbine casing. These blankets minimize the heat loss through the combustion turbine shell and help improve the overall efficiency of the machine.
- *Instrumentation and Controls*– The control system is a digital type supplied with the combustion turbine. The control system monitors the operation of the unit and modulates the fuel flow and turbine operation to achieve optimal high-efficiency low-emission performance for full load and part-load conditions.

Heat Recovery Steam Generator:

- *Heat Exchanger Design Considerations* – The HRSG's are designed with multiple pressure levels. Each pressure level incorporates an economizer section(s), evaporator section, and superheater section(s). These heat transfer sections are made up of many thin-walled tubes to provide surface area to maximize the transfer of heat to the working fluid.
- *Insulation* – Insulation minimizes heat loss to the surrounding air thereby improving the overall efficiency of the HRSG. Insulation is applied to the HRSG panels that make up the shell of the unit, to the high-temperature steam and water lines, and typically to the bottom portion of the stack.
- *Minimizing Fouling of Heat Exchange Surfaces* – Filtration of the inlet air to the combustion turbine is performed to minimize fouling. Additionally, cleaning of the tubes is performed during periodic outages. By reducing the fouling, the efficiency of the unit is maintained.
- *Minimizing Vented Steam and Repair of Steam Leaks* – Steam is vented from the system from deaerator vents, blowdown tank vents, and vacuum pumps/steam jet air ejectors. These

vents are necessary to improve the overall heat transfer within the HRSG and condenser by removing solids and air that potentially blankets the heat transfer surfaces lowering the equipment's performance. Steam leaks are repaired as soon as possible to maintain facility performance.

Steam Turbine:

- *Use of Reheat Cycles* – Reheat cycles are employed to minimize the moisture content of the exhaust steam. This cycle reheats partially expanded steam from the steam turbine.
- *Use of Exhaust Steam Condenser* – The exhaust steam is saturated under vacuum condition by the use of a condenser. The condensing steam creates a vacuum in the condenser, which increases steam turbine efficiency.
- *Efficient Blading Design and Turbine Seals* – Blade design has evolved for high-efficiency transfer of the energy in the steam to power generation. Blade materials are also important components in blade design, which allow for high-temperature and large exhaust areas to improve performance. The steam turbines have a multiple steam seal design to obtain the highest efficiency from the steam turbine.
- *Efficient Steam Turbine Generator Design* – The generator for modern steam turbines are cooled allowing for the highest efficiency of the generator, resulting in an overall high-efficiency steam turbine. The cooling method for the LPEC steam turbine will be either totally enclosed water to air cooling or hydrogen cooling.

Other Plant-wide Energy Efficiency Features

La Paloma has proposed a number of other measures that help improve overall energy efficiency of the facility (and thereby reducing GHG emissions from the emission units), including:

- *Fuel Gas Preheating* – The overall efficiency of the combustion turbine is increased with increased fuel inlet temperatures.
- *Drain Operation* – Drains are required to allow for draining the equipment for maintenance, and also allow condensate to be removed from steam piping and drains for operation. Closing the drains as soon as the appropriate steam conditions are achieved will minimize the loss of energy from the cycle.
- *Multiple Combustion Turbine/HRSG Trains* – Multiple trains allow the unit to achieve higher overall plant part-load efficiency by shutting down a train operating at less efficient part-load conditions and ramping up the remaining train to high-efficiency full-load operation.
- *Boiler Feed Pump Variable Speed Drives* – To minimize the power consumption at part-loads, the use of variable speed drives will be used improving the facility's overall efficiency.

(2) Carbon Capture and Sequestration (CCS)

Carbon capture and storage is a GHG control process that can be used by “facilities emitting CO₂ in large concentrations, including fossil fuel-fired power plants, and for industrial facilities with high-purity CO₂ streams (e.g., hydrogen production, ammonia production, natural gas processing, ethanol production, ethylene oxide production, cement production, and iron and steel manufacturing).”² CCS systems involve the use of adsorption or absorption processes to remove CO₂ from flue gas, with subsequent desorption to produce a concentrated CO₂ stream. The three main capture technologies for CCS are pre-combustion capture, post-combustion capture, and oxyfuel combustion (IPCC, 2005). Of these approaches, pre-combustion capture is applicable primarily to gasification plants, where solid fuel such as coal is converted into gaseous components by applying heat under pressure in the presence of steam and oxygen (U.S. Department of Energy, 2011). At this time, oxyfuel combustion has not yet reached a commercial stage of deployment for gas turbine applications and still requires the development of oxy-fuel combustors and other components with higher temperature tolerances (IPCC, 2005). Accordingly, pre-combustion capture and oxyfuel combustion are not considered available control options for this proposed gas turbine facility; the third approach, post-combustion capture, is applicable to gas turbines.

With respect to post-combustion capture, a number of methods may potentially be used for separating the CO₂ from the exhaust gas stream, including adsorption, physical absorption, chemical absorption, cryogenic separation, and membrane separation (Wang et al., 2011). Many of these methods are either still in development or are not suitable for treating power plant flue gas due to the characteristics of the exhaust stream (Wang, 2011; IPCC, 2005). Of the potentially applicable technologies, post-combustion capture with an amine solvent such as monoethanolamine (MEA) is currently the preferred option because it is the most mature and well-documented technology (Kvamsdal et al., 2011), and because it offers high capture efficiency, high selectivity, and the lowest energy use compared to the other existing processes (IPCC, 2005). Post-combustion capture using MEA is also the only process known to have been previously demonstrated in practice on gas turbines (Reddy, Scherffius, Freguia, & Roberts, 2003). As such, post-combustion capture is the sole carbon capture technology considered in this BACT analysis.

In a typical MEA absorption process, the flue gas is cooled before it is contacted counter-currently with the lean solvent in a reactor vessel. The scrubbed flue gas is cleaned of solvent and vented to the atmosphere while the rich solvent is sent to a separate stripper where it is regenerated at elevated temperatures and then returned to the absorber for re-use. Fluor’s

²U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards, *PSD and Title V Permitting Guidance for Greenhouse Gases*, March 2011, <<http://www.epa.gov/nsr/ghgdocs/ghgpermittingguidance.pdf>> (March 2011)

Econamine FG Plus process operates in this manner, and it uses an MEA-based solvent that has been specially designed to recover CO₂ from oxygen-containing streams with low CO₂ concentrations typical of gas turbine exhaust (Fluor, 2009). This process has been used successfully to capture 365 tons per day of CO₂ from the exhaust of a natural gas combined-cycle plant owned by Florida Power and Light in Bellingham, Massachusetts. The CO₂ capture plant was maintained in continuous operation from 1991 to 2005 (Reddy, Scherffius, Freguia, & Roberts, 2003). As this technology is commercially available and has been demonstrated in practice on a combined-cycle plant, EPA generally considers it to be technically feasible for natural gas combined cycle turbines.

Once CO₂ is captured from the flue gas, the captured CO₂ is compressed to 100 atmospheres (atm) or higher for ease of transport (usually by pipeline). The CO₂ would then be transported to an appropriate location for underground injection into a suitable geological storage reservoir, such as a deep saline aquifer or depleted coal seam, or used in crude oil production for enhanced oil recovery (EOR). There is a large body of ongoing research and field studies focused on developing better understanding of the science and technologies for CO₂ storage.³

Step 2 – Elimination of Technically Infeasible Alternatives

All options identified in Step 1 are considered technically feasible for this project.⁴

Step 3 – Ranking of Remaining Technologies Based on Effectiveness

Since all of the energy efficiency processes, practices, and designs discussed in Step 1, are proposed for this project, we will rank CCS and the suite of energy efficiency measures in BACT Step 4.

Step 4 – Evaluation of Control Options in Order of Most Effective to Least Effective, with Consideration of Economic, Energy, and Environmental Impacts

Carbon Capture and Storage

La Paloma developed a cost analysis for CCS. The estimated total annual cost of CCS would be \$271,000,000 per year. The estimated plant construction cost with CCS is approximately \$974,000,000. EPA Region 6 reviewed La Paloma's CCS cost estimate and believes it

³ U.S. Department of Energy, Office of Fossil Energy, National Energy Technology Laboratory *Carbon Sequestration Program: Technology Program Plan*, <http://www.netl.doe.gov/technologies/carbon_seq/refshelf/2011_Sequestration_Program_Plan.pdf>, February 2011

⁴ Based on the information provided by La Paloma and reviewed by EPA for this BACT analysis, while there are some portions of CCS that may be technically infeasible for this project, EPA has determined that overall Carbon Capture and Storage (CCS) technology is technologically feasible at this source.

adequately approximates the cost of a CCS control for this project and demonstrates those costs are high in relation to the overall cost of the proposed project without CCS, which is estimated at \$443,800,000.

Furthermore, the recovery and purification of CO₂ from the stack gases would necessitate significant additional processing, including energy, and environmental/air quality penalties, to achieve the necessary CO₂ concentration for effective sequestration. The additional process equipment required to separate, cool, and compress the CO₂, would require a significant additional water and power expenditure. This equipment would include amine scrubber vessels, CO₂ strippers, amine transfer pumps, flue gas fans, an amine storage tank, and CO₂ gas compressors. The LPEC will utilize the effluent discharge from the local waste water treatment facility to provide both the cooling water and the boiler make-up water requirements. The local waste treatment facility currently processes and discharges a daily average of seven million gallons of effluent. This volume of effluent cannot support the daily water requirements of an F-class natural gas fired combined cycle facility if equipped with CCS. The water use for a combined cycle plant with CCS would be 7.6 - 9.5 million gallons per day. The additional GHG emissions resulting from additional fuel combustion would either further increase the cost of the CCS system, if the emissions were also captured for sequestration, or reduce the net amount GHG emission reduction, making CCS even less cost effective than expected.

Therefore, since the cost of CCS would more than double the cost of the current project, and considering the adverse energy and environmental impacts of CCS, CCS has been eliminated as BACT for this project.

Energy Efficiency Measures

None of the Energy Efficiency Measures have been eliminated from the BACT review based on adverse economic, environmental, or energy impacts. As noted above, the three turbine models under consideration are some of the most efficient combined cycle turbines, based on their lower heat rate in comparison to other combustion turbine models. From a GHG perspective, these factors may make IC engines the preferred generation alternative in some situations. Furthermore, the other energy efficiency measures proposed by La Paloma make the suite of Energy Efficiency options the preferred option for BACT.

Step 5 – Selection of BACT

To date, other similar facilities with a GHG BACT limit are summarized in the table below:

Company / Location	Process Description	Control Device	BACT Emission Limit / Requirements	Year Issued	Reference
Lower Colorado River Authority (LCRA), Thomas C. Ferguson Plant Horseshoe Bay, TX	590 MW combined cycle combustion turbine and heat recovery steam generator	Energy Efficiency/ Good Design & Combustion Practices	Combustion turbine annual net heat rate limited to 7,720 Btu/kWh (HHV) GHG BACT limit of 0.459 tons CO ₂ /MWh (net) without duct burning. 365-day average, rolling daily for the combustion turbine unit	2011	PSD-TX-1244-GHG
Palmdale Hybrid Power Plant Project Palmdale, CA	570 MW combined cycle combustion turbine and heat recovery steam generator and 50 MW Solar-Thermal Plant	Energy Efficiency/ Good Design & Combustion Practices	Combustion turbine annual net heat rate limited to 7,319 Btu/kWh (HHV) GHG BACT limit of 0.387 tons CO ₂ /MWh (net)* 365-day average, rolling daily for the combustion turbine unit	2011	SE 09-01
Calpine Russell City Energy Hayward, CA	600 MW combined cycle power plant	Energy Efficiency/ Good Design & Combustion Practices	Combustion Turbine Operational limit of 2,038.6 MMBtu/kWh	2011	15487
PacifiCorp Energy - Lake Side Power Plant Vineyard, UT	629 MW (without duct burning) combined cycle turbine	Energy Efficiency/ Good Design & Combustion Practices	Combustion turbine BACT limit of 950 lb CO ₂ e/MWh (gross) on a 12-month rolling average basis	2011	DAQE-AN0130310010-11
Kennecott Utah Copper-Repowering South Jordan, UT	275 MW combined combustion	Energy Efficiency/ Good Design & Combustion Practices	Combustion turbine BACT limit of 1,162,552 tpy CO ₂ e rolling 12-month period	2011	DAQE-IN105720026-11

Company / Location	Process Description	Control Device	BACT Emission Limit / Requirements	Year Issued	Reference
Pioneer Valley Energy Center Westfield, MA	431 MW combined cycle turbine generator	Energy Efficiency/ Good Design & Combustion Practices	825 lbs CO ₂ e/MWh _{grid} (initial performance test) 895 lb CO ₂ e/MWh _{grid} on a 365-day rolling average	2012	052-042-MA15
Calpine Deer Park Energy Center Deer Park, TX	168 MW/180 MW combustion turbine generator with heat recovery steam generator	Energy Efficiency/ Good Design & Combustion Practices	0.460 tons CO ₂ /MWh on a 30 day rolling average without duct burning.	2012	PSD-TX-979-GHG
Calpine Channel Energy Center Pasadena, TX	168 MW/180 MW combustion turbine generator with heat recovery steam generator	Energy Efficiency/ Good Design & Combustion Practices	0.460 tons CO ₂ /MWh on a 30 day rolling average without duct burning.	2012	PSD-TX-955-GHG

*The Palmdale facility BACT limit is reduced due to the offset of emissions from the use of a 50 MW Solar-Thermal Plant that was part of the permitted project.

The following specific BACT practices are proposed for the turbines:

- Use of Combined Cycle Power Generation Technology
- Combustion Turbine Energy Efficiency Processes, Practices, and Design
 - Highly Efficient Turbine Design
 - Turbine Inlet Air Cooling
 - Periodic Turbine Burner Tuning
 - Reduction in Heat Loss
 - Instrumentation and Controls
- HRSG Energy Efficiency Processes, Practices, and Design
 - Efficient Heat Exchanger Design
 - Insulation of HRSG
 - Minimizing Fouling of Heat Exchange Surfaces
 - Minimizing Vented Steam and Repair of Steam Leaks
- Steam Turbine Energy Efficiency Processes, Practices, and Design
 - Use of Reheat Cycles
 - Use of Exhaust Steam Condenser
 - Efficient Blading Design
 - Efficient Generator Design

- Plant-wide Energy Efficiency Processes, Practices, and Design
 - o Fuel Gas Preheating
 - o Drain Operation
 - o Multiple Combustion Turbine/HRSG Trains
 - o Boiler Feed Pump Fluid Drive Design

BACT Limits and Compliance:

To determine the appropriate heat-input efficiency limit, LPEC started with the turbine's design base load net heat rate for combined cycle operation and then calculated a compliance margin based upon reasonable degradation factors that may foreseeably reduce efficiency under real-world conditions. The design base load net heat rates for the combustion turbines being considered for this project are as follows:

- General Electric 7FA
 - o 6674 Btu/kWhr (HHV) without duct burner firing
 - o 7051 Btu/kWhr (HHV) with duct burner firing
- Siemens SGT6-5000F(4)
 - o 6782 Btu/kWhr (HHV) without duct burner firing
 - o 7045 Btu/kWhr (HHV) with duct burner firing
- Siemens SGT6-5000F(5)
 - o 6891 Btu/kWhr (HHV) without duct burner firing
 - o 7204 Btu/kWhr (HHV) with duct burner firing

These rates reflect the facility's "net" power production, meaning the amount of power provided to the grid; it does not reflect the total amount of energy produced by the plant, which also includes auxiliary load consumed by operation of the plant. To be consistent with other recent GHG BACT determinations, the net heat rate without duct burner firing is used to calculate the heat-input efficiency limit.

To determine an appropriate heat rate limit for the permit, the following compliance margins are added to the base heat rate limit:

- A 3.3% design margin reflecting the possibility that the constructed facility will not be able to achieve the design heat rate.
- A 6% performance margin reflecting efficiency losses due to equipment degradation prior to maintenance overhauls.
- A 3% degradation margin reflecting the variability in operation of auxiliary plant equipment due to use over time.

Design and construction of a combined-cycle power plant involves many assumptions about anticipated performance of the many elements of the plant, which are often imprecise or not

reflective of conditions once installed at the site. As a consequence, the facility also calculates an “Installed Base Heat Rate,” which represents a design margin of 3.3% to address such items as equipment underperformance and short-term degradation.

To establish an enforceable BACT condition that can be achieved over the life of the facility, the permit limit must also account for anticipated degradation of the equipment over time between regular maintenance cycles. The manufacturer’s degradation curves project anticipated degradation rates of 5% within the first 48,000 hours of the gas turbine’s useful life; they do not reflect any potential increase in this rate which might be expected after the first major overhaul and/or as the equipment approaches the end of its useful life. Further, the projected 5% degradation rate represents the average, and not the maximum or guaranteed, rate of degradation for the gas turbines. Therefore, LPEC proposes that, for purposes of deriving an enforceable BACT limitation on the proposed facility’s heat rate, gas turbine degradation may reasonably be estimated at 6% of the facility’s heat rate. This degradation rate is comparable to the rates estimated by other natural gas fired power plants that have received a GHG PSD permit.

Finally, in addition to the heat rate degradation from normal wear and tear on the combustion turbines, LPEC is also providing a reasonable compliance margin based on potential degradation in other elements of the combined cycle plant that would cause the overall plant heat rate to rise (i.e., cause efficiency to fall). Degradation in the performance of the heat recovery steam generator, steam turbine, heat transfer, cooling tower, and ancillary equipment such as pumps and motors is also expected to occur over the course of a major maintenance cycle.

The following BACT limits are proposed:

Turbine Model	Gross Heat Rate, with duct burner firing (Btu/kWh) (HHV)	Output Based Emission Limit (lb CO ₂ /MWh) gross with duct burning
General Electric 7FA	7,861.8	934.5
Siemens SGT6-5000F(4)	7,649.0	909.2
Siemens SGT6-5000F(5)	7,679.0	912.7

The calculation of the gross heat rate and the equivalent lb CO₂/MWh is provided in Tables 5-1, 5-2, and 5-3 of the application. There is a 2.6% variation from the lowest proposed BACT limit to the highest proposed BACT limit. The BACT limit will not apply during startup conditions, shutdown, or during periods of maintenance (MSS will account for no more than 500 hours of operation a year). The turbines will comply with the BACT limit during all operational conditions, with and without duct burner firing. While energy efficiency will be a consideration for final selection of a turbine, other considerations will include the capacity of the turbine, cost, reliability, and predicted longevity of the turbines. Since the plant heat rate varies according to turbine operating load and amount of duct burner firing, LPEC proposes to demonstrate

compliance with the proposed heat rate with an annual compliance test, at 100% load, corrected to ISO conditions.

LPEC requested the BACT limit to be expressed in lbs CO₂/MWh. When converting the BACT limits to tons CO₂/MWh gives a range of 0.455 tons CO₂/MWh to 0.467 tons CO₂/MWh with duct burning. When compared to other BACT limits established for other combined cycle/heat recovery steam generating units, the proposed limits for LPEC are comparable to the limits established for LCRA, Calpine Deer Park, Calpine Channel Energy Center, Pioneer Valley Energy Center, and PacifiCorp Energy Lake Side Power Plant. The differences in BACT between La Paloma and LCRA and Cricket Valley Energy Center (CVEC) are related to the net heat rate for the turbines. The net heat rate of the turbines proposed by LPEC are higher than those at LCRA and CVEC. The BACT limit proposed for LPEC is higher than the limit proposed for Pioneer Valley Energy Center (PVEC). PVEC is more likely to operate at base load conditions, whereas LPEC will operate as a load cycling unit. The BACT for LPEC (without duct burner firing is 0.437 to 0.443 tons CO₂e/MWh) is less than that established for both Calpine facilities (0.46 tons CO₂e/MWh).

On March 27, 2012, the EPA proposed New Source Performance Standard (NSPS), 40 CFR Part 60 Subpart TTTT, that would control CO₂ emissions from new electric generating units (EGUs).⁵ The proposed rule would apply to fossil-fuel fired EGUs that generate electricity for sale and are larger than 25 MW. The EPA proposed that new EGUs meet an annual average output based standard of 1,000 lb CO₂/MWh, on a gross basis. The proposed emission rate for the LPEC turbines on a gross electrical output basis ranges from 909.2 to 934.5 lb/MWh with maximum duct burner firing. The proposed CO₂ emission rates from the LPEC combined cycle turbines are well within the emission limit proposed in the NSPS at 40 CFR §60 Subpart TTTT.

LPEC shall meet the BACT limit, for the chosen combustion turbine, on a 12-month rolling average.

For all combustion turbines considered, the combined cycle combustion turbine unit will be designed with a number of features to improve the overall efficiency. The additional combustion turbine design features include:

- Inlet evaporative cooling to utilize water to cool the inlet air and thereby increasing the turbine's efficiency;
- Periodic burner tuning as part of a regularly scheduled maintenance program to help ensure a more reliable operation of the unit and maintain optimal efficiency;

⁵ Standards of Performance for Greenhouse Gas Emissions for New Stationary Sources: Electric Utility Generating Units, 77 Fed Reg 22392, April 13, 2012. Available at <http://www.epa.gov/ttn/atw/nsps/electric/fr13ap12.pdf>

- A Distributed Control System (DCS) will control all aspects of the turbine's operation, including fuel feed and burner operations, to achieve optimal high-efficiency low-emission performance for full-load and partial-load conditions;
- Insulation blankets are utilized to minimize the heat loss through the combustion turbine shell and help improve the overall efficiency of the machine; and
- Totally enclosed water to air cooling or hydrogen cooling will be used to cool the generators resulting in a lower electrical loss and higher unit efficiency.

The Heat Recovery Steam Generator (HRSG) energy efficiency processes, practices and designs considered include:

- Energy efficient heat exchanger design. In this design, each pressure level incorporates an economizer section(s), evaporator section, and superheater section(s);
- Addition of insulation to the HRSG panels, high-temperature steam and water lines and to the bottom portion of the stack;
- Filtration of the inlet air to the combustion turbine and periodic cleaning of the tubes (performed at least every 18 months) is performed to minimize fouling; and
- Minimization of steam vents and repairs of steam leaks.

Within the combined-cycle power plant, several plant-wide, overall energy efficiency processes, practices and designs are included as BACT requirements because the additional operating conditions/practices help maintain the efficiency of the turbine. The requirements include:

- Fuel gas preheating. For the F-class combustion turbine based combined-cycle, the fuel gas is pre-heated to temperature of approximately 300°F with high temperature water from the HRSG;
- Drain operation. Operation drains are controlled to minimize the loss of energy from the cycle but closing the drains as soon as the appropriate steam conditions are achieved;
- Multiple combustion turbine/HRSG trains. Multiple combustion turbine/HRSG trains help with part-load operation. A higher overall plant part-load efficiency is achieved by shutting down trains operating at less efficient part-load conditions and ramping up the remaining train(s) to high-efficiency full-load operation; and
- Boiler feed pump fluid drives. To minimize the power consumption at part-loads, the use of fluid drives or variable-frequency drives are used to minimize the power consumption at part-load conditions

La Paloma will demonstrate compliance with the CO₂ limit established as BACT by using fuel flow meters to monitor the quantity of fuel combusted in the electric generating unit and performing periodic scheduled fuel sampling pursuant to 40 CFR 75.10(3)(ii) and the procedures listed in 40 CFR 75, Appendix G. Results of the fuel sampling will be used to calculate a site-specific Fc factor, and that factor will be used in the equation below to calculate CO₂ mass

emissions. The proposed permit also includes an alternative compliance demonstration method in which LPEC may install, calibrate, and operate a CO₂ CEMS and volumetric stack gas flow monitoring system with an automated data acquisition and handling system for measuring and recording CO₂ emissions. To demonstrate compliance with the CO₂ BACT limit using CO₂ CEMS, the measured hourly CO₂ emissions are divided by the net hourly energy output and averaged daily.

La Paloma proposes to determine a site-specific Fc factor using the ultimate analysis and GCV in equation F-7b of 40 CFR 75, Appendix F. The site-specific Fc factor will be re-determined annually in accordance with 40 CFR 75, Appendix F, §3.3.6.

The equation for estimating CO₂ emissions as specified in 40 CFR 75.10(3)(ii) is as follows:

$$W_{CO_2} = (Fc \times H \times Uf \times MW_{CO_2})/2000$$

Where:

W_{CO_2} = CO₂ emitted from combustion, tons/hour

MW_{CO_2} = molecular weight of CO₂, 44.0 lbs/mole

Fc = Carbon-based Fc-Factor, 1040 scf/MMBtu for natural gas or site-specific Fc factor

H = hourly heat input in MMBtu, as calculated using the procedure in 40 CFR 75, Appendix F, §5

Uf = 1/385 scf CO₂/lb-mole at 14.7 psia and 68°F

La Paloma is subject to all applicable requirements for fuel flow monitoring and quality assurance pursuant to 40 CFR 75, Appendix D, which include:

- Fuel flow meter- meets an accuracy of 2.0%, required to be tested once each calendar quarter pursuant to 40 CFR 75, Appendix D, §2.1.5 and §2.1.6(a))
- Gross Calorific Value (GCV)- determine the GCV of pipeline natural gas at least once per calendar month pursuant to 40 CFR 75, Appendix D, §2.3.4.1

Additionally, this approach is consistent with the CO₂ reporting requirements of 40 CFR 98, Subpart D- GHG Mandatory Reporting Rule for Electricity Generation. Furthermore, La Paloma proposed CO₂ monitoring method is consistent with the recently proposed New Source Performance Standards, Subpart TTTT- Standards of Performance for Greenhouse Gas Emissions for Electric Utility Generating Units (40 CFR 60.5535(c)) which allows for electric generating units firing gaseous fuel to determine CO₂ mass emissions by monitoring fuel combusted in the affected electric generating unit and using a site specific Fc factor determined in accordance to 40 CFR 75, Appendix F.

If La Paloma chooses to install and operate the CO₂ CEMS equipped with a volumetric stack gas monitoring system, the applicant shall rely on the data from the CO₂ CEMS for compliance purposes.

The emission limits associated with CH₄ and N₂O are calculated based on emission factors provided in 40 CFR Part 98, Table C-2 and the actual heat input (HHV). Comparatively, the emissions from CO₂ contribute the most (greater than 99%) to the overall emissions from the combined cycle combustion turbines and; therefore, additional analysis is not required for CH₄ and N₂O. To calculate the CO₂e emissions, the draft permit requires calculation of the emissions based on the procedures and Global Warming Potentials (GWP) contained in the Greenhouse Gas Regulations, 40 CFR Part 98, Subpart A, Table A-1. Records of the calculations would be required to be kept to demonstrate compliance with the emission limits on a 12-month, rolling average.

An initial stack test demonstration will be required for CO₂ emissions from U1-STK and U2-STK. La Paloma also proposes to demonstrate compliance with the proposed heat rate with an annual compliance test, at 100% load, corrected to ISO conditions. An initial stack test demonstration for CH₄ and N₂O emissions are not required because the CH₄ and N₂O emission are approximately 0.01% of the total CO₂e emissions from the combustion turbines.

X. Auxiliary Boiler (AUXBLR)

One nominally rated 150 MMBtu/hr auxiliary boiler (EPN AUXBLR) will be utilized to facilitate startup of the combined cycle units. The auxiliary boiler will be limited to 876 hours of operation per year.

Step 1 – Identification of Potential Control Technologies for GHGs

- *Use of Low Carbon Fuels* – Fuels vary in the amount of carbon per Btu, which in turn affects the quantity of CO₂ emissions generated per unit of heat input. Selecting low carbon fuels is a viable method of reducing GHG emissions. Natural gas is the lowest carbon fuel available at LPEC.
- *Use of Good Operating and Maintenance Practices* – Following the manufacturer's recommended operating and maintenance procedures; maintaining good fuel mixing in the combustion zone; and maintain the proper air/fuel ratio so that sufficient oxygen is provided to provide complete combustion of fuel while at the same time preventing introduction of more air than is necessary into the boiler.
- *Energy Efficient Design* – The auxiliary boiler is designed for a thermal efficiency of approximately 80%. The energy efficient design includes insulation to retain heat within the

boiler and a computerized process control system that will optimize the fuel/air mixture and limit excess air in the boiler.

- *Low Annual Capacity* – The auxiliary boiler will be used to facilitate the startup of the two combustion turbines and the annual hours of operation will be limited to 876 hours per year.

Step 2 – Elimination of Technically Infeasible Alternatives

All options identified in Step 1 are technically feasible.

Step 3 – Ranking of Remaining Technologies Based on Effectiveness

All of the energy efficiency related processes, practices, and designs discussed in Step 1 are being proposed. Therefore, a ranking of the control technologies is not necessary.

Step 4 – Evaluation of Control Technologies in Order of Most Effective to Least Effective, with Consideration of Economic, Energy, and Environmental Impacts

As all of the energy efficiency related processes, practices, and designs discussed in Step 1 are being proposed for this project, an examination of the energy, environmental, and economic impacts of the efficiency designs is not necessary.

Step 5 – Selection of BACT

La Paloma proposes to use natural gas as a low carbon fuel; good operation and maintenance practices; energy efficient design, and low annual capacity as BACT for the auxiliary boiler. The following specific BACT practices are proposed for the heaters:

- Use of low carbon fuel (natural gas). Natural gas will be the only fuel fired in the proposed auxiliary boiler. It is the lowest carbon fuel available for use at LPEC.
- Good operation and maintenance practices will include following the manufacturer's recommended operating and maintenance procedures; maintaining good fuel mixing, and limiting the amount of excess air in the combustion chamber to maximize thermal efficiency.
- Energy efficient design will incorporate insulation to retain heat within the boiler.
- The auxiliary boiler will be limited to 876 hours of operation a year.

Use of these practices corresponds with a permit limit of 7,687 tpy CO₂e for the auxiliary boiler. Compliance will be determined by the number of hours of operation and the calculated emissions using Equation C-1 from 40 CFR Part 98 Subpart C which is based on metered fuel usage and the emission factor for natural gas.

XI. Emergency Engines (EMGEN1-STK and FWP1-STK)

The LPEC site will be equipped with one nominally rated 1,072-hp diesel-fired emergency generator to provide electricity to the facility in the case of power failure and one nominally rated 500-hp diesel-fired pump to provide water in the event of a fire.

Step 1 – Identification of Potential Control Technologies

- *Low Carbon Fuels* – Engine options includes engines powered by electricity, natural gas, or liquid fuel, such as gasoline or fuel oil.
- *Good Combustion Practices and Maintenance* – Good combustion practices include appropriate maintenance of equipment, such as periodic readiness testing, and operating within the recommended air to fuel ratio recommended by the manufacturer.
- *Low Annual Capacity Factor* – Limiting the hours of operation reduces the emissions produced. Each emergency engine will be limited to 100 hours of operation per year for purposes of maintenance checks and readiness testing.

Step 2 – Elimination of Technically Infeasible Alternatives

- *Low Carbon Fuels* – The purpose of the engines is to provide a power source during emergencies, which includes outages of the combustion turbines, natural gas supply outages, and natural disasters. Electricity and natural gas may not be available during an emergency and therefore cannot be used as an energy source for the emergency engines and are eliminated as technically infeasible for this facility. The engines must be powered by a liquid fuel that can be stored on-site in a tank and supplied to the engines on demand, such as gasoline or diesel. Gasoline fuel has a much higher volatility than diesel, and is thus less safe for use in an emergency situation, and it cannot be stored for long periods of time, which may be necessary for emergency use. Therefore, gasoline is eliminated as infeasible for these emergency engines.
- *Good Combustion Practices and Maintenance* – Is considered technically feasible
- *Low Annual Capacity Factor* – Is considered technically feasible since the engines will only be operated either for readiness testing or for actual emergencies.

Step 3 – Ranking of Remaining Technologies Based on Effectiveness

Since the remaining technically feasible processes, practices, and designs in Step 1 are being proposed for the engines, a ranking of the control technologies is not necessary.

Step 4 – Evaluation of Control Technologies in Order of Most Effective to Least Effective, with Consideration of Economic, Energy, and Environmental Impacts

Since the remaining technically feasible processes, practices, and designs in Step 1 are being proposed for the engines, an evaluation of the most effective controls is not necessary.

Step 5 – Selection of BACT

The following specific BACT practices are proposed for the diesel-fired emergency generators:

- *Good Combustion Practices and Maintenance* – Good combustion practices for compression ignition engines include appropriate maintenance of equipment, periodic testing conducted weekly, and operating within the recommended air to fuel ratio, as specified by its design.
- *Low Annual Capacity Factor* – The emergency engines will not be operated more than 100 hours per year each. They will only be operated for maintenance and readiness testing, and in actual emergency operation.

Using the BACT practices identified above results in a BACT limit of 65 tpy CO₂e for the Emergency Generator (EMGEN1-STK) and 28 tpy CO₂e for the Fire Water Pump (FWP1-STK). La Paloma will demonstrate compliance with the CO₂ emission limit using the default emission factor and default high heating value for diesel fuel from 40 CFR Part 98 Subpart C, Table C-1. The equation for estimating CO₂ emissions as specified in 40 CFR 98.33(a)(3)(iii) is as follows:

$$CO_2 = 1 \times 10^{-3} * Fuel * HHV * EF * 1.102311$$

Where:

CO₂ = Annual CO₂ mass emissions from combustion of diesel fuel (short tons)

Fuel = Mass or volume of fuel combusted per year, from company records.

HHV = Default high heat value of the fuel, from Table C-1 of 40 CFR Part 98 Subpart C.

EF = Fuel specific default CO₂ emission factor, from Table C-1 of 40 CFR Part 98 Subpart C.

1×10^{-3} = Conversion of kg to metric tons.

1.102311 = Conversion of metric tons to short tons.

The emission limits associated with CH₄ and N₂O are calculated based on emission factors provided in 40 CFR Part 98, Table C-2, site specific analysis of process fuel gas, and the actual heat input (HHV).

XII. Natural Gas Fugitive Emissions (NG-FUG)

The proposed project will include natural gas piping components. These components are potential sources of methane and CO₂ emissions due to emissions from rotary shaft seals, connection interfaces, valve stems, and similar points. The additional methane and CO₂ emissions from process fugitives have been conservatively estimated to be 423 tpy as CO₂e. Fugitive emissions are negligible, and account for less than 0.01% of the project's total CO₂e emissions.

Step 1 – Identification of Potential Control Technologies for GHGs

- *Implementing a leak detection and repair (LDAR) program using a handheld analyzer;*
- *Implement alternative monitoring using a remote sensing technology such as infrared camera monitoring; and*
- *Implementing an auditory/visual/olfactory (AVO) monitoring program.*

Step 2 – Elimination of Technically Infeasible Alternatives

LDAR programs are a technically feasible option for controlling process fugitive GHG emissions.

Step 3 – Ranking of Remaining Technologies Based on Effectiveness

Instrument LDAR programs and remote sensing using an infrared camera have been determined by EPA to be equivalent methods of piping fugitive controls.⁶ The most stringent LDAR program potentially applicable to this facility is TCEQ's 28LAER, which provides for 97% control credit for valves, flanges, and connectors.

As-observed audio, visual, and olfactory (AVO) observation methods are generally somewhat less effective than instrument LDAR and remote sensing, since they are not conducted at specific intervals. However, since pipeline natural gas is odorized with very small quantities of mercaptan, as-observed olfactory observation is a very effective method for identifying and correcting leaks in natural gas systems. Due to the pressure and other physical properties of plant fuel gas, as-observed audio and visual observations of potential fugitive leaks are likewise moderately effective.

⁶ 73 FR 78199-78219, December 22, 2008.

Step 4 – Evaluation of Control Technologies in Order of Most Effective to Least Effective, with Consideration of Economic, Energy, and Environmental Impacts

Although instrument LDAR and/or remote sensing of piping fugitive emissions in natural gas service may be somewhat more effective than as-observed AVO methods, the incremental GHG emissions controlled by implementation of the TCEQ 28LAER LDAR program or a comparable remote sensing program is less than 0.05% of the total project's proposed CO₂e emissions. Accordingly, given the costs of implementing 28LAER or a comparable remote sensing program when not otherwise required, these methods are not economically practicable for GHG control from components in natural gas service.

Step 5 – Selection of BACT

Based on the economic impracticability of instrument monitoring and remote sensing for natural gas piping components, La Paloma proposes to incorporate as-observed AVO as BACT for the piping components in the new combined cycle power plant in natural gas service. The proposed permit contains a condition to implement AVO inspections on a daily basis.

XIII. SF₆ Insulated Electrical Equipment (SF₆-FUG)

The generator circuit breakers associated with the proposed units will be insulated with SF₆. The capacity of the circuit breakers associated with the proposed plant is currently estimated to be 400 lb of SF₆.

Step 1 – Identification of Potential Control Technologies for GHGs

In comparison to older SF₆ circuit breakers, modern circuit breakers are designed as a totally enclosed-pressure system with far lower potential for SF₆ emissions. In addition, the effectiveness of leak-tight closed systems can be enhanced by equipping them with a density alarm that provides a warning when 10% of the SF₆ (by weight) has escaped. The use of an alarm identifies potential leak problems before the bulk of the SF₆ has escaped, so that it can be addressed proactively in order to prevent further release of the gas.

One alternative considered in this analysis is to substitute another non-GHG substance for SF₆ as the dielectric material in the breakers. Potential alternatives to SF₆ were addressed in the National Institute of Standards and Technology (NIST) Technical note 1425, *Gases for*

*Electrical Insulation and Arc Interruption: Possible Present and Future Alternatives to Pure SF₆.*⁷

Step 2 – Elimination of Technically Infeasible Alternatives

According to the report NIST Technical Note 1425, SF₆ is a superior dielectric gas for nearly all high voltage applications. It is easy to use, exhibits exceptional insulation and arc-interruption properties, and has proven its performance by many years of use and investigation. It is clearly superior in performance to the air and oil insulated equipment used prior to the development of SF₆ insulated equipment. The report concluded that although “...various gas mixtures show considerable promise for use in new equipment, particularly if the equipment is designed specifically for use with a gas mixture...it is clear that a significant amount of research must be performed for any new gas or gas mixture to be used in electrical equipment”. Therefore, there are currently no technically feasible options besides the use of SF₆.

Step 3 – Ranking of Remaining Technologies Based on Effectiveness

The use of state-of-the-art SF₆ technology with leak detection to limit fugitive emissions is the highest ranked control technology that is feasible for this application.

Step 4 – Evaluation of Control Technologies in Order of Most Effective to Least Effective, with Consideration of Economic, Energy, and Environmental Impacts

Energy, environmental, or economic impacts are not addressed because the use of alternative, non-greenhouse gas substance for SF₆ as the dielectric material in the breakers is not technically feasible.

Step 5 – Selection of BACT

La Paloma concludes that using state-of-the-art enclosed-pressure SF₆ circuit breakers with leak detection as the BACT control technology option. The circuit breakers will be designed to meet the latest of the American National Standards Institute (ANSI) C37.013 standard for high voltage circuit breakers.⁸ The proposed circuit breaker at the generator output will have a low pressure alarm and a low pressure lockout. This alarm will function as an early leak detector that will bring potential fugitive SF₆ emissions problems to light before a substantial portion of the SF₆ escapes. The lockout prevents any operation of the breaker due to the lack of “quenching and cooling” SF₆ gas.

⁷ Christophorous, L.G., J.K. Olthoff, and D.S. Green, *Gases for Electrical Insulation and Arc Interruption: Possible Present and Future Alternatives to Pure SF₆*. NIST Technical Note 1425, Nov. 1997. Available at http://www.epa.gov/electricpower-sf6/documents/new_report_final.pdf

⁸ ANSI Standard C37.013, *Standard for AC High-Voltage Generator Circuit Breakers on a Symmetrical Current*.

LPEC will monitor emissions annually in accordance with the requirements of the Mandatory Greenhouse Gas Reporting rules for Electrical Transmissions and Distribution Equipment Use.⁹ Annual SF₆ emissions will be calculated according to the mass balance approach in Equation DD-1 of Subpart DD.

XIV. Gaseous Venting (TRB-MSS)

LPEC will have small amounts of GHGs emitted from gaseous fuel venting during turbine shutdown and maintenance from the fuel lines being cleared of fuel. They will also have small amounts of GHGs emitted from the repair and replacement of small equipment and fugitive components. The GHG emissions from these activities account for less than 0.0001% of the total project GHG emissions. Due to the infrequent nature of these activities and small quantity of GHG emissions, a BACT analysis is not warranted.

XV. Endangered Species Act

Pursuant to Section 7(a)(2) of the Endangered Species Act (ESA) (16 U.S.C. 1536) and its implementing regulations at 50 CFR Part 402, EPA is required to insure that any action authorized, funded, or carried out by EPA is not likely to jeopardize the continued existence of any federally-listed endangered or threatened species or result in the destruction or adverse modification of such species' designated critical habitat.

To meet the requirements of Section 7, EPA is relying on a Biological Assessment (BA) prepared by the applicant and adopted by EPA. Further, EPA designated La Paloma Energy Center, LLC ("La Paloma") and its consultant, Zephyr Environmental Corporation ("Zephyr"), as non-federal representatives for purposes of preparation of the BA.

A draft BA has identified eighteen (18) species listed as federally endangered or threatened in Cameron County, Texas:

Federally Listed Species for Cameron County by the U.S. Fish and Wildlife Service (USFWS), National Marine Fisheries Service (NMFS) and the Texas Parks and Wildlife Department (TPWD)	Scientific Name
Birds	
Piping Plover	<i>Charadrius melodus</i>
Eskimo Curlew	<i>Numenius borealis</i>
Northern Aplomado Falcon	<i>Falco femoralis septentrionalis</i>
Interior Least Tern	<i>Sterna antillarum athalassos</i>

⁹ See 40 CFR Part 98 Subpart DD.

Federally Listed Species for Cameron County by the U.S. Fish and Wildlife Service (USFWS), National Marine Fisheries Service (NMFS) and the Texas Parks and Wildlife Department (TPWD)	Scientific Name
Fish	
Smalltooth Sawfish	<i>Pristis pectinata</i>
Rio Grande Silvery Minnow	<i>Hybognathus amarus</i>
Mammals	
Gulf Coast Jaguarundi	<i>Herpailurus yaguarondi</i>
Ocelot	<i>Leopardus pardalis</i>
Jaguar	<i>Panthera onca</i>
West Indian Manatee	<i>Trichechus manatus</i>
Plant	
South Texas ambrosia	<i>Ambrosia cheiranthifolia</i>
Star cactus	<i>Astrophytum asterias</i>
Texas ayenia	<i>Ayenia limitaris</i>
Reptiles	
Green Sea Turtle	<i>Chelonia mydas</i>
Kemp's Ridley Sea Turtle	<i>Lepidochelys kempii</i>
Leatherback Sea Turtle	<i>Dermochelys coriacea</i>
Loggerhead Sea Turtle	<i>Caretta caretta</i>
Atlantic Hawksbill Sea Turtle	<i>Eretmochelys imbricata</i>

Based on the information provided in the BA, EPA determines that issuance of the proposed PSD permit allowing La Paloma to construct two natural gas-fired combustion turbines will have no effect on 15 species because there are no records of occurrence, no designated critical habitat, nor potential suitable habitat for any of these species within the action area. Those fifteen species include: piping plover, Eskimo curlew, interior least tern, smalltooth sawfish, Rio Grande silvery minnow, jaguar, West Indian manatee, South Texas ambrosia, star cactus, Texas ayenia, green sea turtle, Kemp's ridley sea turtle, leatherback sea turtle, loggerhead sea turtle, and Atlantic hawksbill sea turtle.

However, based on the information provided in the BA and by the USFWS, EPA determines that the issuance of the permit may affect, but is not likely to adversely affect, the Northern Aplomado falcon, Gulf Coast jaguarundi and the ocelot. EPA and La Paloma (as EPA's designated non-federal representative) engaged in informal consultation with the USFWS's Southwest Region, Corpus Christi, Texas Ecological Services Field Office and the sub-office in Alamo, Texas. During consultation, USFWS indicated that they have recently released Northern Aplomado falcons in Cameron County, outside of the action area, and that there is potential that the falcon could forage within the action area or perch on transmission lines being constructed

for this project. The USFWS also indicated that an irrigation canal located adjacent to the facility as well as other vegetated areas within the action area may provide travel or migration corridors for the ocelot or jaguarundi. USFWS provided recommendations for additional protections of all of these species, which La Paloma has committed to implement. By letter dated March 7, 2013, EPA requested USFWS's written concurrence with EPA's "may effect" determination.

Any interested party is welcome to bring particular concerns or information to our attention regarding this project's potential effect on listed species. The final draft biological assessment can be found at EPA's Region 6 Air Permits website at <http://yosemite.epa.gov/r6/Apermit.nsf/AirP>.

XVI. National Historic Preservation Act (NHPA)

Section 106 of the NHPA requires EPA to consider the effects of this permit action on properties on or eligible for inclusion in the National Register of Historic Places. To make this determination, EPA relied on and adopted a cultural resource report prepared by Horizon Environmental Services, Inc. ("Horizon") on behalf of Zephyr submitted on December 19, 2012.

For purposes of the NHPA review, the Area of Potential Effect (APE) was determined to be approximately 78 acres of land within and adjacent to the construction footprint of the existing facility. Horizon conducted a field survey of the property and a desktop review on the archaeological background and historical records within a 1-mile radius area of potential effect (APE) which included a review of the Texas Historical Commission's online Texas Archaeological Site Atlas (TASA) and the National Park Service's National Register of Historic Places (NRHP). Based on the results of the field survey, no archaeological resources or historic structures were found within the APE. Based on the desktop review, one archaeological site was located 0.7 miles from the APE but was not recommended to be eligible to be listed on the National Register.

EPA Region 6 determines that because no historic properties are located within the APE and that a potential for the location of archaeological resources within the construction footprint itself is low, issuance of the permit to La Paloma will not affect properties potentially eligible for listing on the National Register.

On January 10, 2013, EPA sent letters to Indian tribes identified by the Texas Historical Commission as having historical interests in Texas to inquire if any of the tribes have historical interest in the particular location of the project and to inquire whether any of the tribes wished to consult with EPA in the Section 106 process. EPA received no requests from any tribe to consult on this proposed permit. EPA will provide a copy of the report to the State Historic Preservation Officer for consultation and concurrence with its determination. Any interested party is welcome

to bring particular concerns or information to our attention regarding this project's potential effect on historic properties. A copy of the report may be found at <http://yosemite.epa.gov/r6/Apermit.nsf/AirP>.

XVII. Environmental Justice (EJ)

Executive Order (EO) 12898 (59 FR 7629 (Feb. 16, 1994)) establishes federal executive branch policy on environmental justice. Based on this Executive Order, the EPA's Environmental Appeals Board (EAB) has held that environmental justice issues must be considered in connection with the issuance of federal Prevention of Significant Deterioration (PSD) permits issued by EPA Regional Offices [See, e.g., *In re Prairie State Generating Company*, 13 E.A.D. 1, 123 (EAB 2006); *In re Knauf Fiber Glass, GmbH*, 8 E.A.D. 121, 174-75 (EAB 1999)]. This permitting action, if finalized, authorizes emissions of GHG, controlled by what we have determined is the Best Available Control Technology for those emissions. It does not select environmental controls for any other pollutants. Unlike the criteria pollutants for which EPA has historically issued PSD permits, there is no National Ambient Air Quality Standard (NAAQS) for GHGs. The global climate-change inducing effects of GHG emissions, according to the "Endangerment and Cause or Contribute Finding", are far-reaching and multi-dimensional (75 FR 66497). Climate change modeling and evaluations of risks and impacts are typically conducted for changes in emissions that are orders of magnitude larger than the emissions from individual projects that might be analyzed in PSD permit reviews. Quantifying the exact impacts attributable to a specific GHG source obtaining a permit in specific places and points would not be possible [PSD and Title V Permitting Guidance for GHGs at 48]. Thus, we conclude it would not be meaningful to evaluate impacts of GHG emissions on a local community in the context of a single permit. Accordingly, we have determined an environmental justice analysis is not necessary for the permitting record.

XVIII. Conclusion and Proposed Action

Based on the information supplied by La Paloma, our review of the analyses contained the TCEQ PSD Permit Application and the GHG PSD Permit Application, and our independent evaluation of the information contained in our Administrative Record, it is our determination that the proposed facility would employ BACT for GHGs under the terms contained in the draft permit. Therefore, EPA is proposing to issue La Paloma a PSD permit for GHGs for the facility, subject to the PSD permit conditions specified therein. This permit is subject to review and comments. A final decision on issuance of the permit will be made by EPA after considering comments received during the public comment period.

APPENDIX

Annual Facility Emission Limits

Three models being considered by LPEC: the General Electric 7FA, the Siemens SGT6-5000F(4), and the Siemens SGT6-5000F(5). The final selection of the combustion turbine model to be used at the plant will likely be made after the permit is issued. Accordingly, this action proposes to issue a final permit that will include BACT limits and related conditions specific to each of the possible turbine models, and EPA will require the applicant to amend the permit after it has made a final turbine selection to remove the turbine options not selected.

Annual emissions, in tons per year (TPY) on a 12-month, rolling average, shall not exceed the following if the General Electric 7FA is selected as the combustion turbine model:

Table 1A. Annual Emission Limits¹ - General Electric 7FA

FIN	EPN	Description	GHG Mass Basis		TPY CO ₂ e ^{2,3}	BACT Requirements
				TPY ²		
U1-STK	U1-STK	Combined Cycle Combustion Turbine/Heat Recovery Steam Generator ⁴	CO ₂	1,261,820	1,263,055	934.5 lb CO ₂ /MWh (gross) with duct burning ⁵ . See Special Conditions III.A.1.
			CH ₄	23.4		
			N ₂ O	2.4		
U2-STK	U2-STK	Combined Cycle Combustion Turbine/Heat Recovery Steam Generator ⁴	CO ₂	1,261,820	1,263,055	934.5 lb CO ₂ /MWh (gross) with duct burning ⁵ . See Special Conditions III.A.1.
			CH ₄	23.4		
			N ₂ O	2.4		
AUXBLR	AUXBLR	Auxiliary Boiler	CO ₂	7,680	7,687	Good Combustion and Operating Practices. Limit to 876 hours of operation per year. See Special Conditions III.B.
			CH ₄	0.14		
			N ₂ O	0.01		
EMGEN1-STK	EMGEN1-STK	Emergency Generator	CO ₂	64	64	Good Combustion and Operating Practices. Limit to 100 hours of operation per year. See Special Conditions III.C.
			CH ₄	No Numerical Limit Established ⁶		
			N ₂ O	No Numerical Limit Established ⁶		

FIN	EPN	Description	GHG Mass Basis		TPY CO ₂ e ^{2,3}	BACT Requirements
				TPY ²		
FWP1-STK	FWP1-STK	Fire Water Pump	CO ₂	28	28	Good Combustion and Operating Practices. Limit to 100 hours of operation per year. See Special Conditions III.C.
			CH ₄	No Numerical Limit Established ⁶		
			N ₂ O	No Numerical Limit Established ⁶		
TRB-MSS	TRB-MSS	Maintenance , Startup, and Shutdown	CO ₂	No Numerical Limit Established ⁶	2.2	Negligible emissions, EPA verified the provided analysis.
			CH ₄	0.106		
NG-FUG	NG-FUG	Natural Gas Fugitives	CO ₂	Not Applicable	Not Applicable	Implementation of AVO Monitoring. See Special Condition III.D.
			CH ₄	Not Applicable		
SF6-FUG	SF6-FUG	SF ₆ Insulated Equipment	SF ₆	No Numerical Limit Established ⁶	23.9	Instrumented monitoring and alarm. See Special condition III.D.
Totals⁷			CO ₂	2,531,413	CO₂e 2,534,338	
			CH ₄	67		
			N ₂ O	4.8		

1. Compliance with the annual emission limits (tons per year) is based on a 12 month rolling average.
2. The TPY emission limits specified in this table are not to be exceeded for this facility and include emissions from the facility during all operations and include MSS activities.
3. Global Warming Potentials (GWP): CH₄ = 21, N₂O = 310
4. The annual emissions limit for the combustion turbines is based on operating at maximum duct burner firing for 8,260 hours per year, and operating during startup, shutdown, and maintenance (MSS) for 500 hours per year.
5. The BACT limit for the combustion turbine does not apply during MSS.
6. All values indicated as "No Numerical Limit Established" are less than 0.01 TPY with appropriate rounding. The emission limit will be a design/work practice standard as specified in the permit.
7. The total emissions for CH₄ and CO₂e include the PTE for process fugitive emissions of CH₄. Total emissions are for information only and do not constitute an emission limit.

Annual emissions, in tons per year (TPY) on a 12-month, rolling average, shall not exceed the following if the Siemens SGT6-5000F(4) is selected as the combustion turbine model:

Table 1B. Annual Emission Limits¹ - Siemens SGT6-5000F(4)

FIN	EPN	Description	GHG Mass Basis		TPY CO ₂ e ^{2,3}	BACT Requirements
				TPY ²		
U1-STK	U1-STK	Combined Cycle Combustion Turbine/Heat Recovery Steam Generator ⁴	CO ₂	1,415,907	1,417,263	909.2 lb CO ₂ /MWh (gross) with duct burning ⁵ . See Special Conditions III.A.1.
			CH ₄	26.2		
			N ₂ O	2.6		
U2-STK	U2-STK	Combined Cycle Combustion Turbine/Heat Recovery Steam Generator ⁴	CO ₂	1,415,907	1,417,263	909.2 lb CO ₂ /MWh (gross) with duct burning ⁵ . See Special Conditions III.A.1.
			CH ₄	26.2		
			N ₂ O	2.6		
AUXBLR	AUXBLR	Auxiliary Boiler	CO ₂	7,680	7,687	Good Combustion and Operating Practices. Limit to 876 hours of operation per year. See Special Conditions III.B.
			CH ₄	0.14		
			N ₂ O	0.01		
EMGEN1-STK	EMGEN1-STK	Emergency Generator	CO ₂	64	64	Good Combustion and Operating Practices. Limit to 100 hours of operation per year. See Special Conditions III.C.
			CH ₄	No Numerical Limit Established ⁶		
			N ₂ O	No Numerical Limit Established ⁶		
FWP1-STK	FWP1-STK	Fire Water Pump	CO ₂	28	28	Good Combustion and Operating Practices. Limit to 100 hours of operation per year. See Special Conditions III.C.
			CH ₄	No Numerical Limit Established ⁶		
			N ₂ O	No Numerical Limit Established ⁶		
TRB-MSS	TRB-MSS	Maintenance, Startup, and Shutdown	CO ₂	No Numerical Limit Established ⁶	2.2	Negligible emissions, EPA verified the provided analysis.
			CH ₄	0.106		

FIN	EPN	Description	GHG Mass Basis		TPY CO ₂ e ^{2,3}	BACT Requirements
				TPY ²		
NG-FUG	NG-FUG	Natural Gas Fugitives	CO ₂	Not Applicable	Not Applicable	Implementation of AVO Monitoring. See Special Condition III.D.
			CH ₄	Not Applicable		
SF6-FUG	SF6-FUG	SF ₆ Insulated Equipment	SF ₆	No Numerical Limit Established ⁶	23.9	Instrumented monitoring and alarm. See Special condition III.D.
Totals⁷			CO₂	2,839,587	CO₂e 2,842,754	
			CH₄	73		
			N₂O	5.2		

1. Compliance with the annual emission limits (tons per year) is based on a 12 month rolling average.
2. The TPY emission limits specified in this table are not to be exceeded for this facility and include emissions from the facility during all operations and include MSS activities.
3. Global Warming Potentials (GWP): CH₄ = 21, N₂O = 310
4. The annual emissions limit for the combustion turbines is based on operating at maximum duct burner firing for 8,260 hours per year, and operating during startup, shutdown, and maintenance (MSS) for 500 hours per year.
5. The BACT limit for the combustion turbine does not apply during MSS.
6. All values indicated as "No Numerical Limit Established" are less than 0.01 TPY with appropriate rounding. The emission limit will be a design/work practice standard as specified in the permit.
7. The total emissions for CH₄ and CO₂e include the PTE for process fugitive emissions of CH₄. Total emissions are for information only and do not constitute an emission limit.

Annual emissions, in tons per year (TPY) on a 12-month, rolling average, shall not exceed the following if the Siemens SGT6-5000F(5) is selected as the combustion turbine model:

Table 1C. Annual Emission Limits¹ - Siemens SGT6-5000F(5)

FIN	EPN	Description	GHG Mass Basis		TPY CO ₂ e ^{2,3}	BACT Requirements
				TPY ²		
U1-STK	U1-STK	Combined Cycle Combustion Turbine/Heat Recovery Steam Generator ⁴	CO ₂	1,594,162	1,595,712	912.7 lb CO ₂ /MWh (gross) with duct burning ⁵ . See Special Conditions III.A.1.
			CH ₄	29.5		
			N ₂ O	3		
U2-STK	U2-STK	Combined Cycle Combustion Turbine/Heat Recovery Steam Generator ⁴	CO ₂	1,594,162	1,595,712	912.7 lb CO ₂ /MWh (gross) with duct burning ⁵ . See Special Conditions III.A.1.
			CH ₄	29.5		
			N ₂ O	3		
AUXBLR	AUXBLR	Auxiliary Boiler	CO ₂	7,680	7,687	Good Combustion and Operating Practices. Limit to 876 hours of operation per year. See Special Conditions III.B.
			CH ₄	0.14		
			N ₂ O	0.01		
EMGEN1-STK	EMGEN1-STK	Emergency Generator	CO ₂	64	64	Good Combustion and Operating Practices. Limit to 100 hours of operation per year. See Special Conditions III.C.
			CH ₄	No Numerical Limit Established ⁶		
			N ₂ O	No Numerical Limit Established ⁶		
FWP1-STK	FWP1-STK	Fire Water Pump	CO ₂	28	28	Good Combustion and Operating Practices. Limit to 100 hours of operation per year. See Special Conditions III.C.
			CH ₄	No Numerical Limit Established ⁶		
			N ₂ O	No Numerical Limit Established ⁶		

FIN	EPN	Description	GHG Mass Basis		TPY CO ₂ e ^{2,3}	BACT Requirements
				TPY ²		
TRB-MSS	TRB-MSS	Maintenance , Startup, and Shutdown	CO ₂	No Numerical Limit Established ⁶	2.2	Negligible emissions, EPA verified the provided analysis.
			CH ₄	0.106		
NG-FUG	NG-FUG	Natural Gas Fugitives	CO ₂	Not Applicable	Not Applicable	Implementation of AVO Monitoring. See Special Condition III.D.
			CH ₄	Not Applicable		
SF6-FUG	SF6-FUG	SF ₆ Insulated Equipment	SF ₆	No Numerical Limit Established ⁶	23.9	Instrumented monitoring and alarm. See Special condition III.D.
Totals⁷			CO ₂	3,196,097	CO₂e 3,199,650	
			CH ₄	80		
			N ₂ O	6		

1. Compliance with the annual emission limits (tons per year) is based on a 12 month rolling average.
2. The TPY emission limits specified in this table are not to be exceeded for this facility and include emissions from the facility during all operations and include MSS activities.
3. Global Warming Potentials (GWP): CH₄ = 21, N₂O = 310
4. The annual emissions limit for the combustion turbines is based on operating at maximum duct burner firing for 8,260 hours per year, and operating during startup, shutdown, and maintenance (MSS) for 500 hours per year.
5. The BACT limit for the combustion turbine does not apply during MSS.
6. All values indicated as "No Numerical Limit Established" are less than 0.01 TPY with appropriate rounding. The emission limit will be a design/work practice standard as specified in the permit.
7. The total emissions for CH₄ and CO₂e include the PTE for process fugitive emissions of CH₄. Total emissions are for information only and do not constitute an emission limit.