

US EPA ARCHIVE DOCUMENT

Magee, Melanie

From: Carlson, Larry <LCarlson@TENASKA.com>
Sent: Thursday, April 10, 2014 12:18 PM
To: Randy Hamilton
Cc: Latha Kambham
Subject: RE: Brownsville CO2 emissions

Randy-

It appears the discrepancy in the lb/MMBtu CO₂ values at 20 deg F vs the other ambient cases is in error. The CO₂ lbs/hr data included in the table (see below) were supplied by MHI and calculated based upon exhaust mass flow multiplied by CO₂ concentration. The values (at all ambients other than 20 deg) included a nominal 6% margin applied by MHI to account for uncertainty and variation in exhaust flow rate, CO concentration (i.e., degree of combustion completeness), fuel carbon content, and other factors that could affect a combustion-based calculation. The hourly data contained in the table for the 20 deg F cases do not include the 6% margin. An example calculation for the 20 deg F/100% load case is below:

CT exhaust flow: 5,339,000 lbs/hr x 6.39%_{weight} CO₂ = 341,162 lbs CO₂/hr [same value shown in the table]

341,162 lbs CO₂/hr x 1.06 = 361,632 lbs CO₂/hr ÷ 2,903 MMBtu/hr = 124.57 lbs CO₂/MMBtu [similar to the values for the other ambient cases]

Ambient		Inlet Air		Output Load			Heat Input – MMBtu/hr			Heat Rate		CO ₂		
Dry Bulb	RH	Air	CTG	CTG	STG	DB	Total (CT+DB)		CT	CT+ST	lb/MMBtu	lbs/MWh	lb/hr	
°F	%	Cooling	%	MW _{gross}	MW _{gross}	HHV	HHV	LHV	Btu/kWh - LHV		HHV			
20	72.5	OFF	100	305	174	250	3,153	2,842	8,566	5,923	117.5	772	370,435	
20	72.5	OFF	100	305	148	0	2,903	2,616	8,566	5,768	117.5	752	341,162	
20	72.5	OFF	75	229	113	0	2,228	2,008	8,769	5,880	117.3	765	261,323	
20	72.5	OFF	50	153	98	0	1,699	1,531	10,039	6,107	117.1	793	198,912	
62	79.1	ON	100	274	168	250	2,890	2,604	8,629	5,894	124.4	814	359,612	
62	79.1	OFF	100	274	142	0	2,620	2,361	8,629	5,677	125.4	790	328,503	
62	79.1	OFF	75	203	106	0	2,046	1,844	9,070	5,956	124.7	824	255,148	
62	79.1	OFF	50	135	93	0	1,579	1,423	10,510	6,241	124.8	864	197,009	
84	69.7	ON	100	258	165	250	2,774	2,500	8,811	5,913	124.4	816	345,118	
84	69.7	ON	100	258	135	0	2,524	2,274	8,811	5,782	124.4	798	314,009	
84	69.7	OFF	75	189	104	0	1,952	1,760	9,307	6,013	124.4	830	242,828	
84	69.7	OFF	50	126	91	0	1,518	1,368	10,866	6,310	125.2	876	189,986	
106	28.9	ON	100	254	164	250	2,743	2,472	8,843	5,920	124.6	818	341,740	
106	28.9	ON	100	254	133	0	2,493	2,247	8,843	5,799	124.5	801	310,279	
106	28.9	OFF	75	173	99	0	1,839	1,657	9,578	6,087	124.8	843	229,578	
106	28.9	OFF	50	115	89	0	1,464	1,319	11,450	6,475	125.4	901	183,552	

As discussed, we did not base the hourly CO₂ emission rates on the lb/MMBtu values, as those were merely calculated by us using the MHI-supplied hourly mass rates divided by the MHI-supplied heat input rates. If we are to demonstrate compliance with the BACT limit by using equation G-4 from Part 75 (see below) to calculate hourly CO₂ emission rates and then divide by hourly gross output, equation G-4 results in a factor of 118.9 lbs/MMBtu if the default F_c factor of

US EPA ARCHIVE DOCUMENT

1,040 is used or approximately 117.3 lb/MMBtu if a site-specific F_c factor (1,026) is calculated (which is required by other permits I have seen). The un-margined values have a calculated factor of approximately 117.5 lb/MMBtu at base load.

Two example calculations using the 20 deg F ambient un-fired base load case from the table above (2nd row from top), one using the default F_c factor and one using a calculated site-specific F_c factor (calculated using the project design fuel, not a worst-case high-Btu fuel), are below. Therefore, we propose to use the margined values (the 20 deg F values will need to be revised) to account for variations in the site-specific F_c factor (i.e., fuel carbon content/GCV) that could exceed the associated 117.5 lb/MMBtu factor.

$W_{lbs/hr} = 1,040 \times 2,903 \div 385 \times 44.0 = 345,042 \text{ lbs/hr}$ [exceeds 341,162 value in table above]... $345,042 \text{ lbs/hr} \div 2,903 \text{ MMBtu/hr} = 118.9 \text{ lb/MMBtu}$

$W_{lbs/hr} = 1,026 \times 2,903 \div 385 \times 44.0 = 340,397 \text{ lbs/hr}$ [99.8% of 341,162 value in table above]... $340,397 \text{ lbs/hr} \div 2,903 \text{ MMBtu/hr} = 117.3 \text{ lb/MMBtu}$

$$W_{CO_2} = \left(\frac{F_c \times H \times U_f \times MW_{CO_2}}{2000} \right) \quad (Eq. G-4)$$

(Eq. G-4)

Where:

W_{CO_2} = CO₂ emitted from combustion, tons/hr.

MW_{CO_2} = Molecular weight of carbon dioxide, 44.0 lb/lb-mole.

F_c = Carbon based F-factor, 1040 scf/mmBtu for natural gas; 1,420 scf/mmBtu for crude, residual, or distil other gaseous fuels.

H = Hourly heat input in mmBtu, as calculated using the procedures in section 5 of appendix F of this part.

U_f = 1/385 scf CO₂/lb-mole at 14.7 psia and 68 °F.

From: Carlson, Larry
Sent: Monday, April 07, 2014 3:42 PM
To: randy.hamilton@tceq.texas.gov
Cc: Latha Kambham
Subject: Brownsville CO2 emissions

Randy-
 Following up on our conversation Friday, I discussed the discrepancy with our engineers. They spoke with MHI this afternoon and MHI would like to add it to the agenda for the already-scheduled meeting here on Wednesday with our engineering staff. Therefore, we should have an answer late in the day or Thursday a.m.

Larry G. Carlson, QEP
 Director, Air Programs

TENASKA INC.

14302 FNB Parkway | Omaha | NE | 68154-5212

o: 402.938.1661 | c: 402.203.5263 | f: 402.691.9530

LCarlson@TENASKA.com

ADDRESS CHANGE NOTICE

Effective March 31, 2014, Tenaska and its affiliates are moving Omaha offices. Among the affected companies are Tenaska, Inc. (corporate), Tenaska Capital Management, LLC, Tenaska Commodities, LLC, Tenaska Gas Storage, LLC, Tenaska Marketing Ventures, and Tenaska NG Fuels, LLC.

Our new address will be:

14302 FNB Parkway

Omaha, NE 68154

Please update your records accordingly. Our phone, fax and email will remain the same.



www.tenaska.com

US EPA ARCHIVE DOCUMENT