

US EPA ARCHIVE DOCUMENT

THE TEXT YOU ARE VIEWING IS A COMPUTER-GENERATED OR RETYPED VERSION OF A PAPER PHOTOCOPY OF THE ORIGINAL. ALTHOUGH CONSIDERABLE EFFORT HAS BEEN EXPENDED TO QUALITY ASSURE THE CONVERSION, IT MAY CONTAIN TYPOGRAPHICAL ERRORS. TO OBTAIN A LEGAL COPY OF THE ORIGINAL DOCUMENT, AS IT CURRENTLY EXISTS, THE READER SHOULD CONTACT THE OFFICE THAT ORIGINATED THE CORRESPONDENCE OR PROVIDED THE RESPONSE.

RECORD OF COMMUNICATION

MEMORANDUM:

-----

DATE: September 19, 1979

SUBJECT: PSD Guidance, 40 CFR 52.21 (b) (2) (d) - Definition of "capable of accommodating"

FROM: Roger Pfaff

TO: Wagner, Brandon

In response to a request from Bill Mitchell of the Georgia agency, regarding Savannah Electric's Effingham Plant, I called Rich Biondi of DSSE to determine at what point in time a new source becomes capable of accommodating a fuel. The reg allows a future fuel switch if the source was "capable" before 1/6/75. Rich said that if it had been designed, and had "commenced" construction under PSD before 1/6/75, it would be treated as being "capable of accommodating" the fuel, if the design of the source allowed firing of the fuel.