

US EPA ARCHIVE DOCUMENT

	B	C
1	Source Description	
2		
3	Phase I ID No.	3018
4	EPA ID No.	PRD090021056
5	Facility Name	Squibb Manufacturing, Inc.
6	Facility Location	
7	City	Humacao
8	State	Puerto Rico
9	Unit ID Name/No.	Caloric 1 unit
10	Other Sister Facilities	Caloric 2 unit, Trane incinerator
11	Number of Sister Facilities	2
12	Combustor Class	Onsite incinerator
13	Combustor Type	Liquid injection
14	Combustor Characteristics	Vertically-fired liquid injection incinerator. Model No. AVS-1600 installed in 1988
15	Capacity (MMBtu/hr)	
16	Soot Blowing	
17	APCS Detailed Acronym	Q/VS/PT/CHEAF
18	APCS General Class	WQ, HEWS, LEWS
19	APCS Characteristics	Quench, venturi scrubber. CHEAF to enhance PM removal. Packed bed tower reduces the HCl emissions by treating the effluent gas with caustic soda solution.
20	Hazardous Wastes	Liq
21	Haz Waste Description	Water spent solvent generated during the manufacturing process which are not amenable to recovery or re-use.
22	Supplemental Fuel	Misc fuel
23		Kerosene
24		
25	Stack Characteristics	
26	Diameter (ft)	1.67
27	Height (ft)	47.8
28	Gas Velocity (ft/sec)	
29	Gas Temperature (°F)	
30		
31	Permitting Status	Tier I for all metal except Hg, As, Cr (tier III)
32	HWC Burn Status (Date if Terminated)	

	B	C
1	Condition Description	
2		
3	3018C1	
4		
5	Report Name/Date	Final Trial Burn Report for Caloric 1 Incinerator. November 1998
6	Report Prepare	ENSR Corporation
7	Testing Firm	ENSR Corporation
8	Testing Dates	August 30-31, 1998
9	Cond Dates	Aug-98
10	Condition Descr	Trial burn, min oper temp cond
11	Content	PM, DRE, HCl/Cl ₂ , CO, PCDD/F
12		
13	3018C2	
14		
15	Report Name/Date	Final Trial Burn Report for Caloric 1 Incinerator. November 1998
16	Report Prepare	ENSR Corporation
17	Testing Firm	ENSR Corporation
18	Testing Dates	August 31 and September 1, 1998
19	Cond Dates	Aug-98
20	Condition Descr	Trial burn, elevated oper temp cond
21	Content	PM, metals, HCl/Cl ₂ , CO, PCDD/F

	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Stack Gas Emissions 1													
2														
3		Comments	Units	7% O2										
4														
5	3018C1	Trial Burn				R1		R2		R3		Cond Avg		
6														
7	PM	E1	gr/dscf	y		0.0739		0.0715		0.0694		0.0716		
8	CO (RA)	E1	ppmv	y		11		9		6.8		8.93		
9														
10	NOx		ppmv	n		84.5		86.7		80.80				
11	HCl		lb/hr			0.0183		0.0232		0.079				
12	Cl2		lb/hr			0.0126		0.0154		0.0141				
13														
14	POHC DRE	Monochlorobenzene												
15	POHC Feedrate		lb/hr			10.6		10.6		10.6				
16	Emission Rate	E2	lb/hr			2.70E-05		3.20E-05		6.50E-05				
17	DRE	E2	%			99.9998		99.9997		99.9994				
18														
19	POHC DRE	1,2-Dichlorobenzene												
20	POHC Feedrate		lb/hr			5.3		5.3		5.3				
21	Emission Rate	E2	lb/hr			1.40E-05		2.10E-05		3.50E-05				
22	DRE	E2	%			99.9997		99.9996		99.9993				
23														
24	POHC DRE	Methylene Chloride												
25	POHC Feedrate		lb/hr			559.5		559.02		557.71				
26	Emission Rate	E2	lb/hr		nd	6.80E-03	nd	6.80E-03	nd	6.80E-03				
27	DRE	E2	%			99.9988		99.9988		99.9988				
28														
29	Sampling Train	PM, HCl/Cl2	E1											
30	Stack Gas Flowrate		dscfm			6561		6369		6426		6452.0		
31	O2		%			6.8		6.8		7		6.9		
32	Moisture		%			13.3		13.2		12.2		12.9		
33	Temperature		°F			178		176		175		176.3		
34														
35	Sampling Train	DRE	E2											
36	Stack Gas Flowrate		dscfm			6427		6405		6470		6434		
37	O2		%											
38	Moisture		%											
39	Temperature		°F											
40														
41	Sampling Train	PCDD/F	E3											
42	Stack Gas Flowrate		dscfm			6454		6481		6569		6501.3		
43	O2		%			6.8		6.8		7		6.9		
44	Moisture		%			13.5		12.9		12.1		12.8		
45	Temperature		°F											
46														
47	NOx	E1	ppmv	y		83.3		85.5		80.8		83		
48	HCl	E1	ppmv	y		0.5		0.6		2.2		1.1		
49	Cl2	E1	ppmv	y		0.2		0.3		0.3		0.3		
50	Total Chlorine	E1	ppmv	y		0.93		1.20		2.70		1.6		
51														
52	3018C2	Trial Burn				R1		R2		R3		R4		Cond Avg
53														
54	PM	E1	gr/dscf	y		0.0727		0.0375		0.0708		0.0671		0.0620
55	CO (RA)	E1	ppmv	y		5.1		5.2				12.10		7.5
56														
57	NOx		ppmv	n		97.4		100.1				95.50		
58	HCl		lb/hr			0.0129		0.3069				0.0156		
59	Cl2		lb/hr			0.0119		0.0972				0.0104		
60														
61	Chromium (Hex)		ug/dscm	n	nd	0.41	nd	0.41			nd	0		
62	Arsenic		ug/dscm	n	nd	1.13	nd	1.11			nd	1.10		
63	Beryllium		ug/dscm	n	nd	0.11	nd	0.11			nd	0.11		
64	Cadmium		ug/dscm	n	nd	0.23	nd	0.22				0.36		
65	Chromium		ug/dscm	n	nd	0.79		5.57			nd	3.32		
66	Mercury		ug/dscm	n		7.57		7.14				7.06		
67	Antimony		ug/dscm	n		1.93		2.62				3.96		
68	Barium		ug/dscm	n	nd	1.1	nd	1.62			nd	1.61		
69	Lead		ug/dscm	n	nd	2.27		3.10				3.07		
70	Silver		ug/dscm	n	nd	1.13	nd	1.11			nd	1.07		
71	Thallium		ug/dscm	n	nd	6.8	nd	6.64			nd	6.43		

	B	C	D	E	F	G	H	I	J	K	L	M	N	O
72	Nickel		ug/dscm	n	nd	1.13		1.88				1.11		
73	Selenium		ug/dscm	n	nd	6.8	nd	6.64			nd	6.43		
74														
75	Sampling Train	PM, HCl/Cl2	E1											
76	Stack Gas Flowrate		dscfm			6120		5798		6166		6026.0		6027.5
77	O2		%			6		6		6		6.0		6.0
78	Moisture		%			11.2		13.6		15.3		15.5		13.9
79	Temperature		°F			178		176		182		182.0		179.5
80														
81	Sampling Train	metals	E2											
82	Stack Gas Flowrate		dscfm			6250		6182				6204.0		6212.0
83	O2		%			6		6				6.0		6.0
84	Moisture		%			52.1		50.9				55.6		52.9
85	Temperature		°F			182		180				184.0		182.0
86														
87	Sampling Train	Cr+6	E3											
88	Stack Gas Flowrate		dscfm			6001		6097				6164.0		6087.3
89	O2		%			6		6				6.0		6.0
90	Moisture		%			14.1		14.2				10.8		13.0
91	Temperature		°F			176		176				179.0		177.0
92														
93	Sampling Train	PCDD/F	E4											
94	Stack Gas Flowrate		dscfm			6339		6260				6311.0		6303.3
95	O2		%			6		6				6.0		6.0
96	Moisture		%			13.2		14.1				15.1		14.1
97	Temperature		°F											
98														
99	NOx	E1	ppmv	y		90.9		93.4				89.1		91.2
100	HCl	E1	ppmv	y		0.4		8.8				0.4		3.2
101	Cl2	E1	ppmv	y		0.2		1.7				0.2		0.7
102	Total Chlorine	E1	ppmv	y		0.77		12.32				0.80		4.6
103														
104	Chromium (Hex)	E3	ug/dscm	y	nd	0.38	nd	0.38			nd	0.38	100	0.4
105	Arsenic	E2	ug/dscm	y	nd	1.05	nd	1.04			nd	1.03	100	1.0
106	Beryllium	E2	ug/dscm	y	nd	0.10	nd	0.10			nd	0.10	100	0.1
107	Cadmium	E2	ug/dscm	y	nd	0.21	nd	0.21				0.34	100	0.3
108	Chromium	E2	ug/dscm	y	nd	0.74		5.20			nd	3.10	100	3.0
109	Mercury	E2	ug/dscm	y		7.07		6.66				6.59		6.8
110	Antimony	E2	ug/dscm	y		1.80		2.45				3.70		2.6
111	Barium	E2	ug/dscm	y	nd	1.03	nd	1.51			nd	1.50		1.3
112	Lead	E2	ug/dscm	y	nd	2.12		2.89				2.87	100	2.6
113	Silver	E2	ug/dscm	y	nd	1.05	nd	1.04			nd	1.00	100	1.0
114	Thallium	E2	ug/dscm	y	nd	6.35	nd	6.20			nd	6.00	100	6.2
115	Nickel	E2	ug/dscm	y	nd	1.05		1.75				1.04		1.3
116	Selenium	E2	ug/dscm	y	nd	6.35	nd	6.20			nd	6.00		6.2
117	SVM	E2	ug/dscm	y	100	2.33	100	3.10			100	3.20	100	2.9
118	LVM	E2	ug/dscm	y	100	1.89	17.97	6.34			100	4.23	58	4.2

B	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ	AR
1	Feedrate Calculations														
2															
3															
4	3018C1	R1	R2	R3	R3		Cond Avg								
5															
6	Feedstream Number	F4	F4	F4	F4										
7	Feed Class	Total	Total	Total	Total		Total								
8	Feed Class 2	Total	Total	Total	Total		Total								
9	Feedstream Description	Total	Total	Total	Total		Total								
10	Feed Rate	5129.0	5111.0	5078.0	5106.0										
11	Feed Rate														
12	Thermal Feedrate														
13	Heating Value														
14	Density														
15	Viscosity														
16	Ash														
17	Chlorine														
18															
19	Stack Gas Flowrate														
20	Oxygen														
21															
22	Thermal Feedrate	3.9	3.5	3.4	3.6										
23	Estimated Firing Rate	29.6	29.6	29.6	29.6										
24															
25	<i>Feedrate MTEC Calculat</i>														
26	Ash														
27	Chlorine														
28															
29	3018C2	R3	R4	Cond Avg	R1										
30															
31	Feedstream Number	F3	F3	F3	F4										
32	Feed Class	Misc. Fuel	Misc. Fuel	Misc. Fuel	Total		Total								
33	Feed Class 2	MF	MF	MF	Total		Total								
34	Feedstream Description	Kerosene	Kerosene	Kerosene	Total		Total								
35	Feed Rate				4875		5050		5082		5007		5007		
36	Feed Rate	2	2.1	2.1	2.2		2.0		2.1		2.1		2.1		
37	Thermal Feedrate														
38	Heating Value														
39	Density	0.965	0.965												
40	Viscosity														
41	Ash	0.019	0.019		4		3		3		3		3		
42	Chlorine				567		567		566		568		568		
43	Mercury				2.2E-04		2.1E-04		2.1E-04		2.0E-04		2.0E-04		
44	Silver														
45	Arsenic														
46	Barium														
47	Beryllium														
48	Cadmium														
49	Chromium														
50	Nickel														
51	Lead														
52	Antimony														
53	Selenium														
54	Thallium														
55	Chromium (Hex)														
56															
57	Stack Gas Flowrate	6166	6026	6027.5	6120		5798		6166		6026		6026		
58	Oxygen	6	6	6	6		6		6		6		6		
59															
60	Thermal Feedrate				2.6		6.0		4.6		4.2		4.2		

	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z	AA	AB	AC	
61	Estimated Firing Rate		MMBtu/hr			29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1															
62																													
63	Feedrate MTEC Calculations																												
64	Ash		mg/dscm		6580.4	6497.2	6286.0	6286.0	6286.0	6286.0	6177.0	6385.2	6385.2	6385.2															
65	Chlorine		ug/dscm		4469038	4502030	4265717	4265717	4265717	4265717	4277856	4378660.3	4378660.3	4378660.3	18826232	19880381	18693877	18693877	18693877	18693877	19169598	19169598	19142521.7	19142521.7					
66	Mercury		ug/dscm		0.91	0.84	0.47	0.47	0.47	0.47	0.59	0.7	0.7	0.7	8.08	8.53	8.02	8.02	8.02	8.21	8.21	8.2	8.2						
67	Silver		ug/dscm		2.66	2.75	1.62	1.62	1.62	1.62	2.03	2.3	2.3	2.3	13.47	14.22	13.37	13.37	13.37	13.68	13.68	13.7	13.7						
68	Arsenic		ug/dscm	100	35.50	36.61	36.05	36.05	36.05	36.05	36.88	36.3	36.3	36.3	13.47	14.22	13.37	13.37	13.37	13.68	13.68	13.7	13.7						
69	Barium		ug/dscm		5.33	4.03	3.97	3.97	3.97	3.97	3.69	4.3	4.3	4.3															
70	Beryllium		ug/dscm	100	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.2	0.2	0.2															
71	Cadmium		ug/dscm	100	0.36	0.37	0.36	0.36	0.36	0.36	0.37	0.4	0.4	0.4															
72	Chromium		ug/dscm		65.68	67.74	48.66	48.66	48.66	48.66	53.48	58.9	58.9	58.9															
73	Nickel		ug/dscm		39.05	42.11	34.24	34.24	34.24	34.24	36.88	38.1	38.1	38.1															
74	Lead		ug/dscm		7.46	4.39	9.37	9.37	9.37	9.37	7.56	7.2	7.2	7.2															
75	Antimony		ug/dscm	100	5.33	5.49	5.41	5.41	5.41	5.41	5.53	5.4	5.4	5.4															
76	Selenium		ug/dscm	100	10.65	10.98	10.81	10.81	10.81	10.81	11.06	10.9	10.9	10.9															
77	Thallium		ug/dscm	100	10.65	10.98	10.81	10.81	10.81	10.81	11.06	10.9	10.9	10.9															
78	Chromium (Hex)		ug/dscm												367.34	387.74	364.60	364.60	364.60	373.07	373.07	373.2	373.2						
79	SVM		ug/dscm	4.55	7.81	7.7	4.76	4.76	4.76	4.76	7.93	5	5	5															
80	LVM		ug/dscm	35.2	101.36	35	104.53	43	84.89	40.9	90.55	38	95.3	380.81	401.96	377.97	377.97	377.97	377.97	386.75	386.75	386.9	386.9						

	B	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ	AR
61	Estimated Firing Rate							29.1		29.1		29.1		29.1		
62																
63	Feedrate MTEC Calculat															
64	Ash	7.4		8.0		8.1E+00		6588.6		6505.9		6293.5		6185.0		6393
65	Chlorine							23295269.8		24382411.0		22959594.1		23447453.4		23521182
66	Mercury							9.0		9.4		8.5		8.8		8.9
67	Silver							2.7		2.7		1.6		2.0		2.3
68	Arsenic						72	49.0	72	50.8	73	49.4	73	50.6	73	49.9
69	Barium							5.3		4.0		4.0		3.7		4.3
70	Beryllium						100	0.2	100	0.2	100	0.2	100	0.2	100	0.2
71	Cadmium						100	0.4	100	0.4	100	0.4	100	0.4	100	0.4
72	Chromium							65.7		67.7		48.7		53.5		58.9
73	Nickel							39.1		42.1		34.2		36.9		38.1
74	Lead							7.5		4.4		9.4		7.6		7.2
75	Antimony						100	5.3	100	5.5	100	5.4	100	5.5	100	5.4
76	Selenium						100	10.7	100	11.0	100	10.8	100	11.1	100	10.9
77	Thallium						100	10.7	100	11.0	100	10.8	100	11.1	100	10.9
78	Chromium (Hex)							367.3		387.7		364.6		373.1		373
79	SVM						4.5	7.81	7.7	4.76	3.7	9.73	4.7	7.93	5	7.6
80	LVM						7.4	482.18	7.3	506.50	7.8	462.86	7.8	477.30	8	482

	B	C	D	E	F	G	H
1	Process Information						
2							
3	3018C1 Trial burn			R1	R2	R3	
4							
5	Combustion Chamber Temp (min)	°C		1072	1076	1074	
6	Quench Tank pH	pH		7.6	7.4	7.3	
7	Quench Blowdown Rate	gpm		29.8	29.8	30.8	
8	Venturi Press. Drop	in W.C		81.90	81.8	81.6	
9	Incinerator Press.	psig		0	0	0.06	
10							
11	3018C2 Trial burn			R1	R2	R2B	R3
12							
13	Combustion Chamber Temp (min)	°C		1144.0	1144	1146	1147
14	Quench Tank pH	pH		7.60	7.6	7.6	7.6
15	Quench Blowdown Rate	gpm		30.1	29.9	29.8	32.3
16	Venturi Press. Drop	in W.C		81.5	81.5	82	82
17	Incinerator Press.	psig		0.1	0.2	0.3	0.2

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	PCDD/PCDF																
2	N																
3	Facility Name and ID:	Squibb Manufacturing, Inc.															
4	Condition ID:	3018C1															
5	Condition/Test Date:	Trial burn, min oper temp cond															
6																	
7		I-TEF															
8		Wght Fact															
9																	
10	Detected in sample volume (pg)																
11	2,3,7,8-TCDD	1	nd	4	0.00	5.70	2	2	4	0.00	2.10	2	2	4	0.00	4	2
12	Total TCDD	0		5.7	0.00	5.70			4.2	0.00	2.10			3.9	0.00	1.95	0.00
13	1,2,3,7,8-PCDD	0.5	nd	3.1	1.55	1.55			3.2	1.60	1.60			2.3	1.15	1.15	0.58
14	Total PCDD	0		4.6	0.00	4.60			3.2	0.00	1.60			2.5	0.00	1.25	0.00
15	1,2,3,4,7,8-HxCDD	0.1	nd	3.7	0.37	1.85			6.6	0.66	3.30			3.6	0.36	1.80	0.18
16	1,2,3,6,7,8-HxCDD	0.1	nd	3.0	0.30	1.50			5.4	0.54	2.70			3.0	0.30	1.50	0.15
17	1,2,3,7,8,9-HxCDD	0.1	nd	3.0	0.30	1.50			5.3	0.53	2.65			2.9	0.29	1.45	0.15
18	Total HxCDD	0		13.0	0.00	13.00			6.6	0.00	3.30			6.2	0.00	6.20	0.00
19	1,2,3,4,6,7,8-HpCDD	0.01		8.8	0.09	8.80			18.0	0.18	18.00			5.1	0.05	5.10	0.05
20	Total HpCDD	0		13.0	0.00	13.00			28.0	0.00	28.00			11.0	0.00	11.00	0.00
21	OCDD	0.001		22.0	0.02	22.00			35.0	0.04	35.00			21.0	0.02	21.00	0.02
22	2,3,7,8-TCDF	0.1	nd	2.4	0.24	1.20			2.5	0.25	2.50			1.7	0.17	0.85	0.09
23	Total TCDF	0		98.0	0.00	98.00			90.0	0.00	90.00			110.0	0.00	110.00	0.00
24	1,2,3,7,8-PCDF	0.05	nd	4.6	0.23	2.30			4.2	0.21	4.20			3.6	0.18	1.80	0.09
25	2,3,4,7,8-PCDF	0.5	nd	4.3	2.15	2.15			6.3	3.15	6.30			3.4	1.70	1.70	0.85
26	Total PCDF	0		18.0	0.00	18.00			47.0	0.00	47.00			20.0	0.00	20.00	0.00
27	1,2,3,4,7,8-HxCDF	0.1		7.4	0.74	7.40			8.2	0.82	8.20			4.0	0.40	4.00	0.40
28	1,2,3,6,7,8-HxCDF	0.1		5.1	0.51	5.10			6.2	0.62	6.20			2.3	0.23	1.15	0.12
29	2,3,4,6,7,8-HxCDF	0.1		7.1	0.71	7.10			6.2	0.62	6.20			3.0	0.30	1.50	0.15
30	1,2,3,7,8,9-HxCDF	0.1	nd	2.3	0.23	1.15			5.2	0.52	2.60			1.8	0.18	0.90	0.09
31	Total HxCDF	0		44.0	0.00	44.00			37.0	0.00	37.00			14.0	0.00	14.00	0.00
32	1,2,3,4,6,7,8-HpCDF	0.01		23.0	0.23	23.00			28.0	0.28	28.00			11.0	0.11	11.00	0.11
33	1,2,3,4,7,8,9-HpCDF	0.01	nd	2.1	0.02	1.05			3.9	0.04	1.95			1.5	0.02	0.75	0.01
34	Total HpCDF	0		23.0	0.00	23.00			28.0	0.00	28.00			11.0	0.00	11.00	0.00
35	OCDF	0.001		17.0	0.02	17.00			49.0	0.05	49.00			21.0	0.02	21.00	0.02
36																	
37	Gas sample volume (dsct)				126.23	126.23				128.34	128.34			129.82	129.82	129.82	129.82
38	O2 (%)				6.80	6.80				6.80	6.80			7.00	7.00	7.00	7.00
39																	
40	PCDD/PCDF (ng in sample)				0.0115	0.2583				0.0143	0.3210			0.0094	0.2174	0.0050	0.0050
41	PCDD/PCDF (ng/dscm @ 7% O2)		79.9		0.0032	0.0713				0.0039	0.0871			0.0026	0.0592	0.0014	0.0014
42																	
43	TEQ Cond Avg																
44	Total Cond Avg																

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	PCDD/PCDF																
2																	
3	Facility Name and ID:	Squibb Manufacturing, Inc.															
4	Condition ID:	3018C2															
5	Condition/Test Date:	Trial burn, elevated oper temp cond															
6																	
7																	
8																	
9																	
10																	
11	Detected in sample volume (pg)																
12	2,3,7,8-TCDD	1	nd														
13	Total TCDD	0	nd	4.4	0.00	2.20	0.00	2 nd	4.0	0.00	4.00	0.00 nd	2 nd	3.7	0.00	1.85	0.00
14	1,2,3,7,8-PCDD	0.5	nd	3.8	1.90	1.90	0.95 nd		3.4	1.70	1.70	0.85 nd		2.5	1.25	1.25	0.63
15	Total PCDD	0	nd	3.8	0.00	1.90	0.00 nd		6.9	0.00	3.45	0.00 nd		5.5	0.00	1.25	0.00
16	1,2,3,4,7,8-HxCDD	0.1	nd	4.9	0.49	2.45	0.25 nd		5.7	0.57	2.85	0.29 nd		5.5	0.55	2.75	0.28
17	1,2,3,6,7,8-HxCDD	0.1	nd	4.0	0.40	2.00	0.20 nd		4.6	0.46	2.30	0.23 nd		4.5	0.45	2.25	0.23
18	1,2,3,7,8,9-HxCDD	0.1	nd	4.0	0.40	2.00	0.20 nd		4.6	0.46	2.30	0.23 nd		4.4	0.44	2.20	0.22
19	Total HxCDD	0		8.3	0.00	8.30	0.00		11.0	0.00	11.00	0.00 nd		5.5	0.00	2.75	0.00
20	1,2,3,4,6,7,8-HpCDD	0.01		3.2	0.03	3.20	0.03		3.8	0.04	3.80	0.04		3.8	0.04	3.80	0.04
21	Total HpCDD	0		9.2	0.00	9.20	0.00		9.1	0.00	9.10	0.00		7.3	0.00	7.30	0.00
22	OCDD	0.001		20.0	0.02	20.00	0.02		23.0	0.02	23.00	0.02		16.0	0.02	16.00	0.02
23	2,3,7,8-TCDF	0.1	nd	2.2	0.22	1.10	0.11 nd		4.1	0.41	2.05	0.21 nd		3.6	0.36	1.80	0.18
24	Total TCDF	0		50.0	0.00	50.00	0.00		100.0	0.00	100.00	0.00		61.0	0.00	61.00	0.00
25	1,2,3,7,8-PCDF	0.05	nd	4.6	0.23	2.30	0.12 nd		4.9	0.25	2.45	0.12 nd		3.8	0.19	1.90	0.10
26	2,3,4,7,8-PCDF	0.5	nd	4.3	2.15	2.15	1.08		5.3	2.65	5.30	2.65		6.0	3.00	6.00	3.00
27	Total PCDF	0	nd	4.6	0.00	2.30	0.00		22.0	0.00	22.00	0.00		37.0	0.00	37.00	0.00
28	1,2,3,4,7,8-HxCDF	0.1		6.6	0.66	6.60	0.66		8.1	0.81	8.10	0.81		9.2	0.92	9.20	0.92
29	1,2,3,6,7,8-HxCDF	0.1		4.1	0.41	4.10	0.41		4.9	0.49	4.90	0.49		6.3	0.63	6.30	0.63
30	2,3,4,6,7,8-HxCDF	0.1		5.9	0.59	5.90	0.59		7.2	0.72	7.20	0.72		13.0	1.30	13.00	1.30
31	1,2,3,7,8,9-HxCDF	0.1	nd	2.4	0.24	1.20	0.12 nd		3.3	0.33	1.65	0.17 nd		2.9	0.29	1.45	0.15
32	Total HxCDF	0		30.0	0.00	30.00	0.00		40.0	0.00	40.00	0.00		56.0	0.00	56.00	0.00
33	1,2,3,4,6,7,8-HpCDF	0.01		21.0	0.21	21.00	0.21		29.0	0.29	29.00	0.29		27.0	0.27	27.00	0.27
34	1,2,3,4,7,8,9-HpCDF	0.01	nd	1.4	0.01	0.70	0.01 nd		3.1	0.03	1.55	0.02 nd		1.9	0.02	0.95	0.01
35	Total HpCDF	0		21.0	0.00	21.00	0.00		29.0	0.00	29.00	0.00		27.0	0.00	27.00	0.00
36	OCDF	0.001		18.0	0.02	18.00	0.02		31.0	0.03	31.00	0.03		17.0	0.02	17.00	0.02
37	Gas sample volume (dscl)			125.41	6.00	125.41	125.41		123.59	6.00	123.59	123.59		125.13	6.00	125.13	125.13
38	O2 (%)			6.00	6.00	6.00	6.00		6.00	6.00	6.00	6.00		6.00	6.00	6.00	6.00
39																	
40	PCDD/PCDF (ng in sample)			0.0124	0.0033	0.1629	0.0072		0.0126	0.0034	0.2726	0.0088		0.0134	0.0035	0.2272	0.0098
41	PCDD/PCDF (ng/dscm @ 7% O2)		84.3	0.0033	0.0033	0.0428	0.0019	59.8	0.0034	0.0034	0.0727	0.0023	53.9	0.0035	0.0035	0.0599	0.0026
42																	
43	TEQ Cond Avg			0.0023													
44	Total Cond Avg			0.0585													