

US EPA ARCHIVE DOCUMENT

	B	C
1	Source Description	
2		
3	Phase I ID No.	609
4	EPA ID No.	TXD055141378
5	Facility Name	Safety-Kleen Inc.
6	Facility Location	
7	City	Deer Park
8	State	TX
9	Unit ID Name/No.	Safety-Kleen incineration system
10	Other Sister Facilities	None
11	Number of Sister Facilities	0
12	Combustor Class	Commercial incinerator
13	Combustor Type	Rotary kiln
14	Combustor Characteristics	Composed of two trains that exhaust to a common stack. Train I is a 3.6 meter diameter rotary kiln and an afterburner which has a gas residence time of 2 seconds or more. Train II has a 4.4-meter diameter rotary kiln and a rotary reactor that feed gases in to an after burner.
15	Capacity (MMBtu/hr)	
16	Soot Blowing	None
17	APCS Detailed Acronym	S/PT/VS
18	APCS General Class	WQ,LEWS,HEWS
19	APCS Characteristics	Saturator which provides a rapid quench to less than 200F gas temperature, dual packed tower condensers,and a high energy-impact Calvert venturi scrubber.
20	Hazardous Wastes	Liq,solid Liq wastes (RCRA BLD T27/28, RCRA BLD V110, direct burn, TOx stream and PCB BLD T131). Solid wastes (RCRA repack, rotary reactor
21	Haz Waste Description	bulk solids and reburn ash)
22	Supplemental Fuel	Natural gas
23		
24	Stack Characteristics	
25	Diameter (ft)	6.00
26	Height (ft)	216.0
27	Gas Velocity (ft/sec)	46.3
28	Gas Temperature (°F)	130
29		
30	Permitting Status	Tier III for Sb, As, Be, Cd, Cr, Pb
31	HWC Burn Status (Date if Terminated)	

	B	C
1	Condition Description	
2		
3	609C10	
4		
5	Report Name/Date	Trial Burn/ Risk Burn Report Conditions 1,2 and 4, August 1998
6	Report Prepare	TRC Environmental Corporation
7	Testing Firm	TRC Environmental Corporation
8	Testing Dates	April 2-3, 1998
9	Cond Dates	Apr-98
10	Condition Descr	Risk burn organics, max RR feed, low temp-Condition 1
11	Content	CO, PCDD/F, particle sizes, SO2, NOx
12		
13	609C11	
14		
15	Report Name/Date	Trial Burn/ Risk Burn Report Conditions 1,2 and 4, August 1998
16	Report Prepare	TRC Environmental Corporation
17	Testing Firm	TRC Environmental Corporation
18	Testing Dates	April 1, 1998
19	Cond Dates	Apr-98
20	Condition Descr	Risk burn metals, high temp, max RR feed, moderate metals spike - Condition 2
21	Content	PM, HCl/ Cl2, metals
22		
23	609C13	
24		
25	Report Name/Date	Trial Burn/ Risk Burn Report Conditions 1,2 and 4, August 1998
26	Report Prepare	TRC Environmental Corporation
27	Testing Firm	TRC Environmental Corporation
28	Testing Dates	March 31, 1998
29	Cond Dates	Apr-98
30	Condition Descr	Trial burn, max temp, max metals spike - Condition 4
31	Content	PM, HCl/ Cl2, metals
32		
33	609C12A	
34		
35	Report Name/Date	Trial Burn/ Risk Burn Report Conditions 3I and 3II, October 1998
36	Report Prepare	TRC Environmental Corporation
37	Testing Firm	TRC Environmental Corporation
38	Testing Dates	June 16-17, 1998
39	Cond Dates	Oct-98
40	Condition Descr	Trial burn, min temp, max feedrate, DRE train I - Condition
41	Content	PM, HCl/Cl2, DRE
42		
43	609C12B	
44		
45	Report Name/Date	Trial Burn/ Risk Burn Report Conditions 3I and 3II, October 1998
46	Report Prepare	TRC Environmental Corporation
47	Testing Firm	TRC Environmental Corporation
48	Testing Dates	August 11-12, 1998
49	Cond Dates	Oct-98
50	Condition Descr	Trial burn, min temp, max feedrate, DRE train II - Condition
51	Content	PM, HCl/Cl2, DRE
52		
53	609C1	
54		
	Report Name/Date	REX(TX) Stack Test Results, Incinerator Trains I/II Tri-Annual RCRA Requirements and TSCA (PCB) Testing, prepared for Rollins Environmental Services, Deer Park TX, prepared by TRC Environmental, April 1995
55		
56	Report Prepare	TRC Environmental
57	Testing Firm	TRC Environmental
58	Cond Descr	TRAIN I: IS A RCRA AND TSCA PERMITTED INCINERATOR
59	Testing Dates	March 7-17, 1995
60	Cond Dates	Apr-95

	B	C	D	E	F	G	H	I	J	K	L	M
1	Stack Gas Emissions 1											
2												
3		Comments	Units	7% O2								
4												
5	609C10	Risk Burn				R1		R2		R3		Cond Avg
6												
7	CO (RA)	E1	ppmv	y	nd	0.11	nd	0.11	nd	0.11		0.11
8	HC (RA)		ppmv	n		0.4		0.29		0.78		
9	SO2		ppmv	n		1.7	nd	0.1	nd	0.1		
10	NOx		ppmv	n		97.6		99.3		39		
11												
12	Sampling Train	PM, HCl/Cl2	E1									
13	Stack Gas Flowrate		dscfm			70527		70003		70613		70381.0
14	O2		%			8.5		8.2		8.4		8.4
15	Moisture		%			3.5		3.6		3.2		3.4
16	Temperature		°F			112.9		114.9		114		113.9
17												
18	Sampling Train	PCDD/F	E2									
19	Stack Gas Flowrate		dscfm			68082		67166		70191		68479.7
20	O2		%			8.5		8.2		8.4		8.4
21	Moisture		%			4.6		5.3		3.8		4.6
22	Temperature		°F			110.6		138.7		111.1		120.1
23												
24	HC (RA)	E1	ppmv	y		0.4		0.3		0.9		0.5
25	SO2	E1	ppmv	y		1.9	nd	0.1	nd	0.1		0.7
26	NOx	E1	ppmv	y		109.3		108.6		43.3		87.1
27												
28	609C11	Risk Burn				R1		R2		R3		Cond Avg
29												
30	PM	E1	gr/dscf	y		0.0118		0.0116		0.011		0.0115
31												
32	HCl		lb/hr			0.12		0.22		0.17		
33	Cl2		lb/hr		nd	0.14	nd	0.13	nd	0.18		
34												
35	Antimony		g/hr			9		6		6		
36	Arsenic		g/hr			7		5.9		6.2		
37	Beryllium		g/hr			0.058	nd	0.04	nd	0.04		
38	Cadmium		g/hr			7.1		6.1		6.1		
39	Chromium		g/hr			0.92		1.09		0.8		
40	Chromium (Hex)		g/hr			0.18		0.21		0.17		
41	Lead		g/hr			136		136		122		
42	Barium		g/hr			7.7		4.1		4.2		
43	Mercury		g/hr			5.3		3.4		3.2		
44	Nickel		g/hr			6.3		3.8		3.6		
45	Selenium		g/hr		nd	4.1	nd	3.9	nd	4		
46	Silver		g/hr			0.35		0.23		0.21		
47	Thallium		g/hr		nd	41	nd	39	nd	40		
48	Zinc		g/hr			66		50		53		
49												
50	Sampling Train	PM, metals	E1									
51	Stack Gas Flowrate		dscfm			70963		71422		72252		71545.7
52	O2		%			7.4		6.6		6.6		6.9
53	Moisture		%			3.1		3.3		3.2		3.2
54	Temperature		°F			114.6		116.1		115.5		115.4
55												
56	Sampling Train	HCl/Cl2	E2									
57	Stack Gas Flowrate		dscfm			74320		73004		70808		72710.7
58	O2		%			7.4		6.6		6.6		6.9
59	Moisture		%			3.1		3.2		3.3		3.2
60	Temperature		°F			112.8		114.7		113.6		113.7
61												
62	Sampling Train	Cr+6	E3									
63	Stack Gas Flowrate		dscfm			70164		70128		71109		70467
64	O2		%			7.4		6.6		6.6		7
65	Moisture		%			3		3.3		4		3
66	Temperature		°F			114		115.5		114.6		115
67												
68	HCl	E2	ppmv	y		0.3		0.5		0.4		0.41
69	Cl2	E2	ppmv	y	nd	0.2	nd	0.2	nd	0.2		0.19
70	Total Chlorine	E2	ppmv	y	55	0.65	##	0.84	##	0.87	##	0.79
71												

	B	C	D	E	F	G	H	I	J	K	L	M
72	Antimony	E1	ug/dscm	y		76.9		48.1		47.5		57.5
73	Arsenic	E1	ug/dscm	y		59.8		47.3		49.1		52.1
74	Beryllium	E1	ug/dscm	y		0.5		0.3		0.3		0.4
75	Cadmium	E1	ug/dscm	y		60.7		48.9		48.3		52.6
76	Chromium	E1	ug/dscm	y		7.9		8.7		6.3		7.6
77	Chromium (Hex)	E1	ug/dscm	y		1.6		1.7		1.4		1.5
78	Lead	E1	ug/dscm	y		1161.9		1090.3		966.8		1073.0
79	Barium	E1	ug/dscm	y		65.8		32.9		33.3		44.0
80	Mercury	E1	ug/dscm	y		45.3		27.3		25.4		32.6
81	Nickel	E1	ug/dscm	y		53.8		30.5		28.5		37.6
82	Selenium	E1	ug/dscm	y	nd	35.0	nd	31.3	nd	31.7		32.7
83	Silver	E1	ug/dscm	y		3.0		1.8		1.7		2.2
84	Thallium	E1	ug/dscm	y	nd	350.3	nd	312.7	nd	317.0		326.6
85	Zinc	E1	ug/dscm	y		563.8		400.8		420.0		461.6
86	SVM	E1	ug/dscm	y		1222.5		1139.2		1015.1		1125.6
87	LVM	E1	ug/dscm	y		68.2		56.4		55.8		60.1
88												
89	609C13	Trial Burn				R1		R2		R3		Cond Avg
90												
91	PM	E1	gr/dscf	y		0.0152		0.0138		0.0158		0.0149
92												
93	HCl		lb/hr			0.32		0.33		0.42		
94	Cl2		lb/hr		nd	0.14	nd	0.16	nd	0.16		
95												
96	Antimony		g/hr			101		95		122		
97	Arsenic		g/hr			15		14		15		
98	Beryllium		g/hr			1.2	nd	1.1	nd	1.5		
99	Cadmium		g/hr			21		16		20		
100	Chromium		g/hr			2.14		2.05		2.57		
101	Chromium (Hex)		g/hr			0.16		0.35		0.23		
102	Lead		g/hr			418		326		497		
103	Barium		g/hr			7.5		5		5.3		
104	Mercury		g/hr			5.5		6.3		5.2		
105	Nickel		g/hr			3		3.9		3.3		
106	Selenium		g/hr		nd	4.3	nd	4	nd	4.1		
107	Silver		g/hr			0.59		0.46		0.35		
108	Thallium		g/hr		nd	43	nd	40	nd	41		
109	Zinc		g/hr			66		50		53		
110												
111	Sampling Train	PM, metals	E1									
112	Stack Gas Flowrate		dscfm			74080		71358		72439		72625.7
113	O2		%			7.7		7.1		7.4		7.4
114	Moisture		%			3.6		3.2		3.3		3.4
115	Temperature		°F			113.7		115		113.5		114.1
116												
117	Sampling Train	HCl/Cl2	E2									
118	Stack Gas Flowrate		dscfm			74911		72505		74842		74086.0
119	O2		%			7.6		7.1		7.4		7.4
120	Moisture		%			3.5		3.4		3.2		3.4
121	Temperature		°F			112.2		113.7		112.1		112.7
122												
123	Sampling Train	Cr+6	E3									
124	Stack Gas Flowrate		dscfm			72066		71904		72391		72120.3
125	O2		%			7.6		7.1		7.4		7.4
126	Moisture		%			3.3		2.9		2.8		3.0
127	Temperature		°F			114		115.2		113.5		114.2
128												
129	HCl	E2	ppmv	y		0.8		0.8		1.0		0.88
130	Cl2	E2	ppmv	y	nd	0.2	nd	0.2	nd	0.2		0.20
131	Total Chlorine	E2	ppmv	y	31	1.16	##	1.23	##	1.44	##	1.27
132												
133	Antimony	E1	ug/dscm	y		845.2		789.7		1021.0		885.3
134	Arsenic	E1	ug/dscm	y		125.5		116.4		125.5		122.5
135	Beryllium	E1	ug/dscm	y		10.0		9.1		12.6		10.6
136	Cadmium	E1	ug/dscm	y		175.7		133.0		167.4		158.7
137	Chromium	E1	ug/dscm	y		17.9		17.0		21.5		18.8
138	Chromium (Hex)	E1	ug/dscm	y		1.3		2.9		1.9		2.1
139	Lead	E1	ug/dscm	y		3498.0		2709.9		4159.4		3455.8
140	Barium	E1	ug/dscm	y		62.8		41.6		44.4		49.6
141	Mercury	E1	ug/dscm	y		46.0		52.4		43.5		47.3
142	Nickel	E1	ug/dscm	y		25.1		32.4		27.6		28.4

	B	C	D	E	F	G	H	I	J	K	L	M
143	Selenium	E1	ug/dscm	y	nd	36.0	nd	33.3	nd	34.3		34.5
144	Silver	E1	ug/dscm	y		4.9		3.8		2.9		3.9
145	Thallium	E1	ug/dscm	y	nd	359.8	nd	332.5	nd	343.1		345.2
146	Zinc	E1	ug/dscm	y		552.3		415.6		443.6		470.5
147	SVM	E1	ug/dscm	y		3673.7		2842.9		4326.8		3614.5
148	LVM	E1	ug/dscm	y		153.5		142.6		159.6		151.9
149												
150	609C12A	Trial Burn				R1		R2		R3		Cond Avg
151												
152	PM	E1	gr/dscf	y		0.0186		0.0133		0.0192		0.0170
153												
154	HCl		lb/hr				1	0.9		1.4		
155	Cl2		lb/hr		nd	0.06	nd	0.3	nd	0.32		
156												
157	POHC DRE		1,2-Dichlorobenzene									
158	POHC Feedrate		lb/hr			990		889		687		
159	Emission Rate	E1	lb/hr		nd	3.20E-04	nd	3.00E-04	nd	3.00E-04		
160	DRE	E1	%			99.99997		99.99997		99.99996		
161												
162	POHC DRE		1,2,4,5-Tetrachlorobenzene									
163	POHC Feedrate		lb/hr			921		900		996		
164	Emission Rate	E1	lb/hr		nd	3.20E-04	nd	3.00E-04	nd	3.00E-04		
165	DRE	E1	%			99.99997		99.99997		99.99997		
166												
167												
168	Sampling Train	PM	E1									
169	Stack Gas Flowrate		dscfm			52281		58770		59746		56932.3
170	O2		%			10.6		10.1		10.1		10.3
171	Moisture		%			5.1		5		4.7		4.9
172	Temperature		°F			145.8		134.9		135.3		138.7
173												
174	Sampling Train	HCl/Cl2	E2									
175	Stack Gas Flowrate		dscfm			58251		60501		59382		59378.0
176	O2		%			10.6		10.1		10.1		10.3
177	Moisture		%			5.1		5		4.7		4.9
178	Temperature		°F			135.5		133.6		135.4		134.8
179												
180	Sampling Train	DRE	E3									
181	Stack Gas Flowrate		dscfm			54066		56024		51892		53994.0
182	O2		%			10.6		10.1		10.1		10.3
183	Moisture		%			5.1		5		4.7		4.9
184	Temperature		°F			134.1		133.3		134.7		134.0
185												
186	HCl	E2	ppmv	y		2.5		2.1		3.4		2.68
187	Cl2	E2	ppmv	y	nd	0.1	nd	0.4	nd	0.4		0.28
188	Total Chlorine	E2	ppmv	y	6	2.63	##	2.87	##	4.24	##	3.25
189												
190												
191	609C12B	Trial Burn				R1		R2		R3		Cond Avg
192												
193	PM	E1	gr/dscf	y		0.0153		0.0131		0.0145		0.0143
194												
195	HCl		lb/hr			0.77		0.87		0.79		
196	Cl2		lb/hr		nd	0.13		0.14	nd	0.1		
197												
198	POHC DRE		1,2-Dichlorobenzene									
199	POHC Feedrate		lb/hr			1069		1087		1034		
200	Emission Rate	E1	lb/hr		nd	2.30E-04	nd	2.30E-04	nd	2.30E-04		
201	DRE	E1	%			99.99998		99.99998		99.99998		
202												
203	POHC DRE		1,2,4,5-Tetrachlorobenzene									
204	POHC Feedrate		lb/hr			1016		1071		1044		
205	Emission Rate	E1	lb/hr		nd	2.30E-04	nd	2.30E-04	nd	2.30E-04		
206	DRE	E1	%			99.99998		99.99998		99.99998		
207												
208	Sampling Train	PM	E1									
209	Stack Gas Flowrate		dscfm			47570		49140		47930		48213.3
210	O2		%			9.6		9		9.7		9.4
211	Moisture		%			6		6		5.5		5.8
212	Temperature		°F					128.5		125.3		126.9
213												

	B	C	D	E	F	G	H	I	J	K	L	M
214	Sampling Train	HCl/Cl2	E2									
215	Stack Gas Flowrate		dscfm			46090		48513		47653		47418.7
216	O2		%			9.6		9		9.7		9.4
217	Moisture		%			6		6		5.5		5.8
218	Temperature		°F			126.5		128.9		125.9		127.1
219												
220	Sampling Train	DRE	E3									
221	Stack Gas Flowrate		dscfm			46996		48753		47812		47853.7
222	O2		%			9.6		9		9.7		9.4
223	Moisture		%			5.7		6		5.7		5.8
224	Temperature		°F			128.9		130.5		128.1		129.2
225												
226	HCl	E2	ppmv	y		1.9		2.1		1.9		1.97
227	Cl2	E2	ppmv	y	nd	0.2		0.2	nd	0.1		0.15
228	Total Chlorine	E2	ppmv	y	15	2.23		2.41	##	2.19	##	2.28

	B	C	D	E	F	G	H	I	J	K	L	M
1	Stack Gas Emissions 2											
2												
3												
4	609C1					R1		R2		R3		Cond Avg
5												
6	PM	E2	gr/dscf	y		0.0172		0.0098		0.0113		0.0127
7	CO (RA)	E2	ppmv	y	nd	0.5		1.0		2.5		1.3
8	HC (RA)	E2	ppmv	y		1.5		1.5		0.5		1.2
9	HCl	E2	ppmv	y		1.8		1.0		0.7		1.1
10	Cl2	E2	ppmv	y		0.0		0.0		0.0		0.0
11	Total Chlorine	E2	ppmv	y		1.8		1.0		0.7		1.2
12	Antimony	E3	ug/dscm	y		42.6		40.0		87.7		56.8
13	Arsenic	E3	ug/dscm	y		39.9		58.5		77.4		58.6
14	Barium	E3	ug/dscm	y		46.8		24.2		65.3		45.4
15	Beryllium	E3	ug/dscm	y	nd	0.1 nd		0.1 nd		0.1		0.1
16	Cadmium	E3	ug/dscm	y		34.2		33.8		61.1		43.0
17	Chromium	E3	ug/dscm	y		22.3		16.9		30.0		23.1
18	Copper	E3	ug/dscm	y		898.5		688.5		656.7		747.9
19	Iron	E3	ug/dscm	y		495.4		203.2		219.4		306.0
20	Lead	E3	ug/dscm	y		887.0		647.8		1761.2		1098.7
21	Mercury	E3	ug/dscm	y		20.3		13.4		68.3		34.0
22	Nickel	E3	ug/dscm	y		102.5		57.4		47.1		69.0
23	Silver	E3	ug/dscm	y		4.1		4.0		5.2		4.4
24	Thallium	E3	ug/dscm	y		26.3		31.9		58.8		39.0
25	Vanadium	E3	ug/dscm	y		6.3		1.9		0.1		2.8
26	SVM	E3	ug/dscm	y		921.2		681.6		1822.3		1141.7
27	LVM	E3	ug/dscm	y	0	62.4 0.2		75.5 ##		107.5 0		81.8
28												
29	PCBs	E1	%			99.999997		99.999998		99.999997		
30												
31	Sampling Train	Dioxin & Fu	E1									
32	Stack Gas Flowrate		dscfm			83902.0		84467.0		79913.0		
33	O2		%			8.1		7.7		8.0		
34	Moisture		%			2.4		2.2		2.4		
35	Temperature		°F			104.9		106.3		113.1		
36												
37	Sampling Train	PM/Haloge	E2									
38	Stack Gas Flowrate		dscfm			89407.0		82658.0		75251.0		
39	O2		%			8.1		7.7		8.0		
40	Moisture		%			2.8		2.4		3.0		
41	Temperature		°F			104.4		105.6		112.9		
42												
43	Sampling Train	Metals	E3									
44	Stack Gas Flowrate		dscfm			83874.0		81840.0		74037.0		
45	O2		%			8.1		7.7		8.0		
46	Moisture		%			2.4		2.6		2.8		
47	Temperature		°F			104.0		105.3		112.8		

	B	C	D	AT	AV	AX	AZ	BB	BD	BF	BH	BJ	BL	BL	
1	Feedstream 1														
2															
3															
4	609C10	Risk burn													
5															
6	Feedstream Description														
7	Feed Rate	lb/hr													
8	Thermal Feedrate	MMBtu/hr													
9															
10	609C11	Risk burn													
11															
12	Feedstream Number	F1	F1	F1	F1	F2	F2	F2	F2	F3	F3				
13	Feed Class														
14	Feedstream Description	Haz wastes													
15	Feed Class 2	HW	HW	HW	HW	Spike	Spike	Spike	Spike	Total	Total	Total	Total	Total	
16	Feed Rate	lb/hr													
17	Heating Value	Btu/lb													
18	Density	kg/L													
19	Chlorine	878134	885112	833414	865553.3						878134	885112			
20	Antimony	122.3	122.1	129.0	124.5						122.3	122.1			
21	Arsenic	53.44	53.93	50.27	52.5	899	899	941	913	952.44	952.93				
22	Barium	2274.72	2177.7	2083.3	2178.6						2274.7	2177.7			
23	Beryllium	0	0	0	0.0	227	227	237	230.3	227	227				
24	Cadmium	0	1.6	5	2.1	225	225	235	228.3	225	226.6				
25	Chromium	1385.7	1376	1289	1350.2	1800	1800	1883	1828	3185.7	3176				
26	Lead	737	610.3	589.1	645.5	8865	8865	9273	9001	9602	9475.3				
27	Mercury	3.0228	3.4964	3.0537	3.2						3.0228	3.4964			
28	Nickel	2308.7	2239.6	2112.2	2220.2						2308.7	2239.6			
29	Selenium	12.37	11.9	11.46	11.9						12.37	11.9			
30	Silver	14.073	13.99	13.89	14.0						14.073	13.99			
31	Thallium	3.4	3.3	3.1	3.3						3.4	3.3			
32	Zinc	9519	9498	9887	9634.7						9519	9498			
33															
34	Stack Gas Flowrate	dscfm													
35	Oxygen	%													
36															
37	Thermal Feedrate	MMBtu/hr													
38	Estimated Firing Rate	MMBtu/hr													
39															
40	<i>Feedrate MTEC Calculations</i>														
41	Chlorine	ug/dscm	7160168	7217065	6795528	7057587						7160168	7217065		
42	Antimony	ug/dscm	997	995	1052	1015						997	995		
43	Arsenic	ug/dscm	436	440	410	428	7330	7330	7673	7444	7766	7770			
44	Barium	ug/dscm	18548	17757	16987	17764						18548	17757		
45	Beryllium	ug/dscm	0	0	0	0	1851	1851	1932	1878	1851	1851			
46	Cadmium	ug/dscm	0	13	41	18	1835	1835	1916	1862	1835	1848			
47	Chromium	ug/dscm	11299	11220	10510	11010	14677	14677	15354	14903	25976	25897			
48	Lead	ug/dscm	6009	4976	4803	5263	72284	72284	75611	73393	78293	77260			
49	Mercury	ug/dscm	25	29	25	26						25	29		
50	Nickel	ug/dscm	18825	18261	17223	18103						18825	18261		
51	Selenium	ug/dscm	101	97	93	97						101	97		
52	Silver	ug/dscm	115	114	113	114						115	114		
53	Thallium	ug/dscm	28	27	25	27						28	27		
54	Zinc	ug/dscm	77616	77445	80617	78560						77616	77445		
55	SVM	ug/dscm	6009	4989	4844	5281	74118	74118	77527	75255	80128	79108			
56	LVM	ug/dscm	11735	11659	10920	11438	23858	23858	24959	24225	35593	35518			
57															
58	609C13	Trial burn													
59															
60	Feedstream Number	F1	F1	F1	F1	F2	F2	F2	F2	F3	F3				

	B	BN	BP	BR	BT	BV	BX
1	Feedstream 1						
2							
3							
4	609C10						
5							
6	Feedstream Description						
7	Feed Rate						
8	Thermal Feedrate						
9							
10	609C11	R3		Cond Avg			
11							
12	Feedstream Number	F3		F3			
13	Feed Class	Total		Total			
14	Feedstream Description	Total		Total			
15	Feed Class 2	Total		Total			
16	Feed Rate	39394		40082			
17	Heating Value						
18	Density						
19	Chlorine	833414		865553.3			
20	Antimony	129.0		124.5			
21	Arsenic	991.27		965.5			
22	Barium	2083.3		2178.6			
23	Beryllium	237		230.3			
24	Cadmium	240		230.4			
25	Chromium	3172		3177.9			
26	Lead	9862.1		9646.5			
27	Mercury	3.0537		3.2			
28	Nickel	2112.2		2220.2			
29	Selenium	11.46		11.9			
30	Silver	13.89		14.0			
31	Thallium	3.1		3.3			
32	Zinc	9887		9634.7			
33							
34	Stack Gas Flowrate	72252		71545.7			
35	Oxygen	6.6		6.9			
36							
37	Thermal Feedrate						
38	Estimated Firing Rate	330.29		321.01			
39							
40	<i>Feedrate MTEC Calculations</i>						
41	Chlorine	6795528		7057587			
42	Antimony	1052		1015			
43	Arsenic	8083		7873			
44	Barium	16987		17764			
45	Beryllium	1932		1878			
46	Cadmium	1957		1880			
47	Chromium	25864		25912			
48	Lead	80414		78656			
49	Mercury	25		26			
50	Nickel	17223		18103			
51	Selenium	93		97			
52	Silver	113		114			
53	Thallium	25		27			
54	Zinc	80617		78560			
55	SVM	82371		80536			
56	LVM	35879		35663			
57							
58	609C13	R3		Cond Avg			
59							
60	Feedstream Number	F3		F3			

	B	C	D	AT	AV	AX	AZ	BB	BD	BF	BH	BJ	BL
61	Feed Class							Spike	Spike	Spike	Spike	Total	Total
62	Feed Class 2			HW	HW	HW	HW	Spike	Spike	Spike	Spike	Total	Total
63	Feedstream Description			Haz wastes	Haz wastes	Haz wastes	Haz wastes	Spike	Spike	Spike	Spike	Total	Total
64	Feed Rate	lb/hr		35515	36773	36024	36104.0					35515	36773
65	Thermal Feedrate	MM Btu/hr											
66	Heating Value	Btu/lb											
67	Density	kg/L											
68	Chlorine	g/hr		922074	964296	939326	941898.7					922074	964296
69	Antimony	g/hr		6929	6925	6858	6904.0	23078	23275	23374	23242.3	30007	30200
70	Arsenic	g/hr		741	736	740	739.0	1549	1563	1569	1560.3	2290	2299
71	Barium	g/hr		4006	3971	4081	4019.3					4006	3971
72	Beryllium	g/hr		272	272	272	272.0	621	626	629	625.3	893	898
73	Cadmium	g/hr		418	421	420	419.7	775	781	785	780.3	1193	1202
74	Chromium	g/hr		5303	5287	5370	5320.0	5349	5394	5417	5386.7	10652	10681
75	Lead	g/hr		11541	11658	11570	11589.7	33541	33828	33972	33780.3	45082	45486
76	Mercury	g/hr		29	28	30	29.0					29	28
77	Nickel	g/hr		1890	1863	2007	1920.0					1890	1863
78	Selenium	g/hr		22	22	23	22.3					22	22
79	Silver	g/hr		22	23	24	23.0					22	23
80	Thallium	g/hr		6.5	6.4	6.9	6.6					6.5	6.4
81	Zinc	g/hr		4221	4138	4485	4281.3					4221	4138
82													
83	Stack Gas Flowrate	dscfm		72625.7								74080	71358
84	Oxygen	%		7.4								7.7	7.1
85													
86	Thermal Feedrate	MMBtu/hr											
87	Estimated Firing Rate	MMBtu/hr										312.8	314.9
88													
89	<i>Feedrate MTEC Calculations</i>												
90	Chlorine	ug/dscm		7697099	8049551	7841112	7862587					7697099	8049551
91	Antimony	ug/dscm		57840	57807	57248	57632					57840	57807
92	Arsenic	ug/dscm		6186	6144	6177	6169	12930	13047	13097	13025	19116	19191
93	Barium	ug/dscm		33440	33148	34067	33552					33440	33148
94	Beryllium	ug/dscm		2271	2271	2271	2271	5184	5226	5251	5220	7454	7496
95	Cadmium	ug/dscm		3489	3514	3506	3503	6469	6519	6553	6514	9959	10034
96	Chromium	ug/dscm		44267	44134	44827	44409	44651	45027	45219	44966	88919	89161
97	Lead	ug/dscm		96340	97316	96582	96746	279987	282382	283584	281985	376326	379699
98	Mercury	ug/dscm		242	234	250	242					242	234
99	Nickel	ug/dscm		15777	15552	16754	16027					15777	15552
100	Selenium	ug/dscm		184	184	192	186					184	184
101	Silver	ug/dscm		184	192	200	192					184	192
102	Thallium	ug/dscm		54	53	58	55					54	53
103	Zinc	ug/dscm		35235	34542	37439	35739					35235	34542
104	SVM	ug/dscm		99829	100831	100088	100249	286456	288902	290137	288498	386285	389732
105	LVM	ug/dscm		52723	52548	53274	52849	62766	63300	63567	63211	115489	115848
106													
107	609C12A	Trial burn		R1	R2	R3	Cond Avg	R1	R2	R3	Cond Avg	R1	R2
108													
109	Feedstream Number			F1	F1	F1	F1	F2	F2	F2	F2	F3	F3
110	Feed Class											Total	Total
111	Feed Class 2			HW	HW	HW	HW					Total	Total
112	Feedstream Description			Haz wastes	Haz wastes	Haz wastes	Haz wastes	ABC	ABC	ABC	ABC	Total	Total
113	Feed Rate	lb/hr		13445	12689	13162	13098.7	13142	13555	14000	13565.7	26587	26244
114	Thermal Feedrate	MM Btu/hr											
115	Heating Value	Btu/lb											
116	Density	kg/L											
117	Ash	lb/hr		9514	8722	9047	9094.3	509	764	778	683.7	10023	9486
118	Chlorine	lb/hr		3931	4009	4321	4087.0					3931	4009
119													
120	Stack Gas Flowrate	dscfm		56932.3								52281	58770

	B	BN	BP	BR	BT	BV	BX
61	Feed Class	Total	Total				
62	Feed Class 2	Total	Total				
63	Feedstream Description	Total	Total				
64	Feed Rate	36024	36104				
65	Thermal Feedrate						
66	Heating Value						
67	Density						
68	Chlorine	939326	941898.7				
69	Antimony	30232	30146.3				
70	Arsenic	2309	2299.3				
71	Barium	4081	4019.3				
72	Beryllium	901	897.3				
73	Cadmium	1205	1200.0				
74	Chromium	10787	10706.7				
75	Lead	45542	45370.0				
76	Mercury	30	29.0				
77	Nickel	2007	1920.0				
78	Selenium	23	22.3				
79	Silver	24	23.0				
80	Thallium	6.9	6.6				
81	Zinc	4485	4281.3				
82							
83	Stack Gas Flowrate	72439	72626				
84	Oxygen	7.4	7.4				
85							
86	Thermal Feedrate						
87	Estimated Firing Rate	312.8	313.6				
88							
89	<i>Feedrate MTEC Calculations</i>						
90	Chlorine	7841112	7862587				
91	Antimony	57248	57632				
92	Arsenic	19275	19194				
93	Barium	34067	33552				
94	Beryllium	7521	7491				
95	Cadmium	10059	10017				
96	Chromium	90045	89375				
97	Lead	380166	378730				
98	Mercury	250	242				
99	Nickel	16754	16027				
100	Selenium	192	186				
101	Silver	200	192				
102	Thallium	58	55				
103	Zinc	37439	35739				
104	SVM	390225	388747				
105	LVM	116841	116059				
106							
107	609C12A	R3	Cond Avg				
108							
109	Feedstream Number	F3	F3				
110	Feed Class	Total	Total				
111	Feed Class 2	Total	Total				
112	Feedstream Description	Total	Total				
113	Feed Rate	27162	26664				
114	Thermal Feedrate						
115	Heating Value						
116	Density						
117	Ash	9825	9778.0				
118	Chlorine	4321	4087.0				
119							
120	Stack Gas Flowrate	59746	56932				

	B	C	D	AT	AV	AX	AZ	BB	BD	BF	BH	BJ	BL	BL
121	Oxygen		%	10.3									10.6	10.1
122														
123	Thermal Feedrate		MMBtu/hr											
124	Estimated Firing Rate		MMBtu/hr										172.61	203.36
125														
126	<i>Feedrate MTEC Calculations</i>													
127	Ash		mg/dscm	58279	53428	55419	55709	3118	4680	4766	4188	61397	58108	
128	Chlorine		ug/dscm	24079954	24557755	26468959	25035556					24079954	24557755	
129														
130	609C12B		Trial burn	R1	R2	R3	Cond Avg	R1	R2	R3	Cond Avg	R1	R2	
131														
132	Feedstream Number			F1	F1	F1	F1	F2	F2	F2	F2	F3	F3	
133	Feed Class													
134	Feed Class 2			HW	HW	HW	HW							
135	Feedstream Description			Haz wastes	Haz wastes	Haz wastes	Haz wastes	ABC	ABC	ABC	ABC	RR	RR	
136	Feed Rate		lb/hr	18142	17492	15675	17103.0	11300	11775	12309	11794.7	14174	12164	
137	Thermal Feedrate		MM Btu/hr											
138	Heating Value		Btu/lb											
139	Density		kg/L											
140	Ash		lb/hr	16497	14888	15580	15655.0	664	781	883	776.0			
141	Chlorine		lb/hr	4369	4543	5116	4676.0							
142														
143	Stack Gas Flowrate		dscfm	48213.3										
144	Oxygen		%	9.4										
145														
146	Thermal Feedrate		MMBtu/hr											
147	Estimated Firing Rate		MMBtu/hr											
148														
149	<i>Feedrate MTEC Calculations</i>													
150	Ash		mg/dscm	110733	99933	104578	105081	4457	5242	5927	5209			
151	Chlorine		ug/dscm	29326003	30493941	34340085	31386676							

	B	BN	BP	BR	BT	BV	BX
121	Oxygen	10.1	10.3				
122							
123	Thermal Feedrate						
124	Estimated Firing Rate	206.74	193.99				
125							
126	<i>Feedrate MTEC Calculations</i>						
127	Ash	60185	59897				
128	Chlorine	26468959	25035556				
129							
130	609C12B	R3	Cond Avg	R1	R2	R3	Cond Avg
131							
132	Feedstream Number	F3	F3	F4	F4	F4	F4
133	Feed Class			Total	Total	Total	Total
134	Feed Class 2			Total	Total	Total	Total
135	Feedstream Description	RR	RR	Total	Total	Total	Total
136	Feed Rate	14315	13551.0	43616	41431	42299	42449
137	Thermal Feedrate						
138	Heating Value						
139	Density						
140	Ash			17161	15669	16463	16431
141	Chlorine			4369	4543	5116	4676
142							
143	Stack Gas Flowrate			46090	48513	47653	47419
144	Oxygen			9.6	9	9.7	9.4
145							
146	Thermal Feedrate						
147	Estimated Firing Rate			166.80	184.81	170.95	174.12
148							
149	<i>Feedrate MTEC Calculations</i>						
150	Ash			115190	105175	110504	110290
151	Chlorine			29326003	30493941	34340085	31386676

	B	C	D	E	F	G	H	I	J	K	L
1	Feedstream 2										
2											
3											
4	609C1				R1		R2		R3		Cond Avg
5											
6	Feedstream Number				F1		F1		F1		F1
7	Feed Class				Total		Total		Total		Total
8	Feed Class 2				Total		Total		Total		Total
9	Feedstream				Total		Total		Total		Total
10	Chlorine		lb/hr		1250		865		683		
11			Train I + Train II								
12	Gas Flowrate				89407		82658		75251		82438.67
13	Oxygen				8.13		7.65		7.98		7.92
14											
15	Estimated Firing Rate		MMBtu/hr		365.3		350.3		311.0		342.3
16											
17	Feedrate MTECs										
18	Chlorine		ug/dscm		4066363		2934244		2609418		3203341

	B	C	D	E	F	G
1	Process Information					
2						
3	609C10			R1	R2	R3
4						
5	Train I					
6	Combustion Chamber Temp (min)	°F		1815	1807	1838
7	AB Temperature	°F		213	2141	2138
8	Water Flow Saturator	gpm		1008.0	1007	1008
9	Water Flow Condenser	gpm		4370.00	4374	4375
10	Water Flow Calvert	gpm		1005	989	1013
11	Calvert Pressure	in H2O		47.4	47.3	47.6
12	Train II					
13	Combustion Chamber Temp (min)	°F		1843	1887	1909
14	RR Temperature	°F		1207	1191	1167
15	AB Temperature	°F		1865.0	1902	1871
16	Water Flow Saturator	gpm		922.00	922	922
17	Water Flow Condenser	gpm		4515	4518	4527
18	Water Flow Calvert	gpm		819	851	811
19	Calvert Pressure	in H2O		48.7	49.7	49.5
20						
21	609C11			R1	R2	R3
22						
23	Train I					
24	Combustion Chamber Temp (min)	°F		1910.00	1939	1960
25	AB Temperature	°F		2273	2248	2256
26	Water Flow Saturator	gpm		1008	1009	1007
27	Water Flow Condenser	gpm		4364.0	4366	4363
28	Water Flow Calvert	gpm		1020	1009	1012
29	Calvert Pressure	in H2O		47.9	48.6	48.7
30	Train II					
31	Combustion Chamber Temp (min)	°F		2182	2170	2152
32	RR Temperature	°F		1265	1271	1245
33	AB Temperature	°F		2139.0	2155	2128
34	Water Flow Saturator	gpm		918.00	918	919
35	Water Flow Condenser	gpm		4509.0	4516	4510
36	Water Flow Calvert	gpm		759	775	775
37	Calvert Pressure	in H2O		49.8	48.9	49
38						
39	609C13			R1	R2	R3
40						
41	Train I					
42	Combustion Chamber Temp (min)	°F		2068	2072	2011
43	AB Temperature	°F		2241	2241	2233
44	Water Flow Saturator	gpm		900	903	896
45	Water Flow Condenser	gpm		3974	3972	3968
46	Water Flow Calvert	gpm		885	918	956
47	Calvert Pressure	in H2O		43.7	44.5	45.5
48	Train II					
49	Combustion Chamber Temp (min)	°F		2275	2444	2378
50	RR Temperature	°F		1601	1574	1570
51	AB Temperature	°F		2213	2252	2253
52	Water Flow Saturator	gpm		789	786	786
53	Water Flow Condenser	gpm		4071	4064	4062
54	Water Flow Calvert	gpm		626	828	729
55	Calvert Pressure	in H2O		47.8	48.6	48.1
56						
57	609C12A			R1	R2	R3
58						
59	Combustion Chamber Temp (min)	°F		1608	1616	1631
60	AB Temperature	°F		1808	1829	1844
61	Water Flow Saturator	gpm		932	790	785
62	Water Flow Condenser	gpm		3866	3866	3869
63	Water Flow Calvert	gpm		852	758	775
64	Calvert Pressure	in H2O		40.09	41.68	41.77
65						
66	609C12B			R1	R2	R3
67						
68	Combustion Chamber Temp (min)	°F		1627	1580	1675
69	RR Temperature	°F		906	928	908

	B	C	D	E	F	G
70	AB Temperature	°F		1821	1789	1776
71	Water Flow Saturator	gpm		729	728	723
72	Water Flow Condenser	gpm		4010	4021	4026
73	Water Flow Calvert	gpm		826	819	816
74	Calvert Pressure	in H2O		45.37	44.47	45.41

	C	D	E	F	G
1	Process Information 2				
2					
3	609C1		R1	R2	R3
4					
5	Afterburner 1 Temperature	F	2084	2131	2038
6	Afterburner 2 Temperature	F	2246	2207	2300
7	Kiln 1 Temperature	F	1813	2021	1947
8	Kiln 2 Temperature	F	1969	2323	2206
9	Rotary Reactor Temperature	F	1352	1320	1399

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	PCDD/PCDF																	
2	N																	
3	Facility Name and ID:		Safety-Kleen Inc.															
4	Condition ID:		609C10															
5	Condition/Test Date:		Risk burn organics, max RR feed, low temp-Condition 1															
6																		
7	I-TEF		Run 7				Run 8				Run 9							
8	Wght Fact		Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ
9			Full ND	Full ND	1/2 ND	1/2 ND	Full ND	Full ND	1/2 ND	1/2 ND	Full ND	Full ND	1/2 ND	1/2 ND	Full ND	Full ND	1/2 ND	1/2 ND
10	Detected in sample volume (ng)																	
11	2,3,7,8-TCDD	1	nd	0.007	0.007	0.004	0.004	nd	0.003	0.0034	0.0017	0.0017	nd	0.004	0.0041	0.0021	0.0021	
12	1,2,3,7,8-PCDD	0.5	nd	0.008	0.004	0.004	0.002	nd	0.014	0.0070	0.0070	0.0035	nd	0.003	0.0016	0.0016	0.0008	
13	1,2,3,4,7,8-HxCDD	0.1	nd	0.009	0.001	0.005	0.000	nd	0.008	0.0008	0.0039	0.0004	nd	0.011	0.0011	0.0055	0.0006	
14	1,2,3,6,7,8-HxCDD	0.1	nd	0.009	0.001	0.005	0.000	nd	0.008	0.0008	0.0038	0.0004	nd	0.011	0.0011	0.0055	0.0006	
15	1,2,3,7,8,9-HxCDD	0.1	nd	0.009	0.001	0.004	0.000	nd	0.007	0.0007	0.0035	0.0004	nd	0.010	0.0010	0.0050	0.0005	
16	1,2,3,4,6,7,8-HpCDD	0.01	nd	0.007	0.000	0.003	0.000	nd	0.010	0.0001	0.0050	0.0001	nd	0.015	0.0002	0.0075	0.0001	
17	OCDD	0.001	nd	0.052	0.000	0.026	0.000	nd	0.054	0.0001	0.0270	0.0000	nd	0.077	0.0001	0.0385	0.0000	
18	2,3,7,8-TCDF	0.1		0.015	0.002	0.015	0.002		0.018	0.0018	0.0180	0.0018		0.013	0.0013	0.0130	0.0013	
19	1,2,3,7,8-PCDF	0.05	nd	0.011	0.001	0.006	0.000	nd	0.006	0.0003	0.0030	0.0002	nd	0.007	0.0003	0.0033	0.0002	
20	2,3,4,7,8-PCDF	0.5	nd	0.012	0.006	0.006	0.003	nd	0.006	0.0031	0.0031	0.0016	nd	0.007	0.0034	0.0034	0.0017	
21	1,2,3,4,7,8-HxCDF	0.1	nd	0.007	0.001	0.004	0.000	nd	0.018	0.0018	0.0090	0.0009	nd	0.010	0.0010	0.0050	0.0005	
22	1,2,3,6,7,8-HxCDF	0.1	nd	0.012	0.001	0.006	0.001	nd	0.018	0.0018	0.0090	0.0009	nd	0.003	0.0003	0.0016	0.0002	
23	2,3,4,6,7,8-HxCDF	0.1	nd	0.013	0.001	0.007	0.001	nd	0.019	0.0019	0.0095	0.0010	nd	0.004	0.0004	0.0018	0.0002	
24	1,2,3,7,8,9-HxCDF	0.1	nd	0.014	0.001	0.007	0.001	nd	0.022	0.0022	0.0110	0.0011	nd	0.004	0.0004	0.0020	0.0002	
25	1,2,3,4,6,7,8-HpCDF	0.01	nd	0.024	0.000	0.012	0.000	nd	0.015	0.0002	0.0075	0.0001	nd	0.024	0.0002	0.0120	0.0001	
26	1,2,3,4,7,8,9-HpCDF	0.01	nd	0.006	0.000	0.003	0.000	nd	0.004	0.0000	0.0018	0.0000	nd	0.011	0.0001	0.0055	0.0001	
27	OCDF	0.001	nd	0.029	0.000	0.015	0.000	nd	0.017	0.0000	0.0085	0.0000	nd	0.024	0.0000	0.0120	0.0000	
28	Total TCDD	0		0.043	0.000	0.043	0.000		0.011	0.0000	0.0110	0.0000		0.014	0.0000	0.0140	0.0000	
29	Total PCDD	0	nd	0.010	0.000	0.005	0.000	nd	0.014	0.0000	0.0070	0.0000	nd	0.015	0.0000	0.0075	0.0000	
30	Total HxCDD	0	nd	0.009	0.000	0.005	0.000	nd	0.008	0.0000	0.0039	0.0000	nd	0.011	0.0000	0.0055	0.0000	
31	Total HpCDD	0	nd	0.013	0.000	0.007	0.000	nd	0.010	0.0000	0.0050	0.0000	nd	0.017	0.0000	0.0085	0.0000	
32	Total TCDF	0		0.460	0.000	0.460	0.000		0.130	0.0000	0.1300	0.0000		0.080	0.0000	0.0800	0.0000	
33	Total PCDF	0	nd	0.024	0.000	0.012	0.000	nd	0.014	0.0000	0.0070	0.0000	nd	0.011	0.0000	0.0055	0.0000	
34	Total HxCDF	0	nd	0.014	0.000	0.007	0.000	nd	0.022	0.0000	0.0110	0.0000	nd	0.010	0.0000	0.0050	0.0000	
35	Total HpCDF	0	nd	0.024	0.000	0.012	0.000	nd	0.015	0.0000	0.0075	0.0000	nd	0.024	0.0000	0.0120	0.0000	
36																		
37	Gas sample volume (dscl)				130.31	130.31	130.31			130.31	130.31	130.31			130.70	130.70	130.70	
38	O2 (%)				8.5	8.5	8.5			8.2	8.2	8.2			8.40	8.40	8.40	
39																		
40	PCDD/PCDF (ng in sample)				0.03	0.6	0.01			0.026	0.2	0.014			0.02	0.2	0.01	
41	PCDD/PCDF (ng/dscm @ 7% O2)		94.5		0.0082	0.18	0.0043	93.0		0.0077	0.06	0.0041	92.1		0.0050	0.06	0.0027	
42																		
43	TEQ Cond Avg		0.0037															
44	Total Cond Avg		0.10															

	C	D	E	F	G	H	I	J	K	L	M	N	O	P	
1	609C1														
2					R1				R2				R3		
3	ng/dscm	I-TEF		Total	Total	TEQ		Total	Total	TEQ		Total	Total	TEQ	
4		Wt Fact		Full ND	1/2 ND	1/2 ND		Full ND	1/2 ND	1/2 ND		Full ND	1/2 ND	1/2 ND	
5	4D 2378	1	1	0.002	0.001	0.001	1	0.001	0.000	0.000	1	0.002	0.001	0.001	
6	4D Other	0	1	0.000	0.000	0.000		0.001	0.001	0.000	1	0.003	0.001	0.000	
7	4D Total	0	1	0.002	0.001	0.000		0.002	0.002	0.000	1	0.005	0.002	0.000	
8	5D 12378	0.5	1	0.002	0.001	0.001	1	0.001	0.001	0.000	1	0.002	0.001	0.001	
9	5D Other	0	1	0.000	0.000	0.000	1	0.000	0.000	0.000	1	0.005	0.002	0.000	
10	5D Total	0	1	0.002	0.001	0.000	1	0.001	0.001	0.000	1	0.007	0.003	0.000	
11	6D 123478	0.1	1	0.006	0.003	0.000	1	0.002	0.001	0.000	1	0.007	0.003	0.000	
12	6D 123678	0.1	1	0.006	0.003	0.000	1	0.002	0.001	0.000	1	0.007	0.003	0.000	
13	6D 123789	0.1	1	0.006	0.003	0.000	1	0.002	0.001	0.000	1	0.007	0.003	0.000	
14	6D Other	0	1	-0.002	-0.001	0.000	1	0.013	0.006	0.000		0.012	0.012	0.000	
15	6D Total	0	1	0.017	0.008	0.000	1	0.019	0.009	0.000		0.033	0.033	0.000	
16	7D 1234678	0.01	1	0.025	0.012	0.000	1	0.019	0.009	0.000	1	0.033	0.016	0.000	
17	7D Other	0	1	0.048	0.024	0.000	1	0.048	0.024	0.000	1	0.104	0.052	0.000	
18	7D Total	0	1	0.073	0.036	0.000	1	0.067	0.033	0.000	1	0.137	0.068	0.000	
19	8D	0.001		0.146	0.146	0.000		0.122	0.122	0.000		0.281	0.281	0.000	
20	4F 2378	0.1		0.004	0.004	0.000	1	0.002	0.001	0.000		0.007	0.007	0.001	
21	4F Other	0	1	-0.002	-0.001	0.000		0.010	0.010	0.000	1	0.054	0.027	0.000	
22	4F Total	0	1	0.002	0.001	0.000		0.013	0.013	0.000	1	0.061	0.030	0.000	
23	5F 12378	0.05	1	0.002	0.001	0.000	1	0.001	0.000	0.000	1	0.002	0.001	0.000	
24	5F 23478	0.5	1	0.002	0.001	0.000	1	0.001	0.000	0.000	1	0.002	0.001	0.000	
25	5F Other	0		0.002	0.002	0.000	1	0.009	0.004	0.000		0.015	0.015	0.000	
26	5F Total	0		0.006	0.006	0.000	1	0.010	0.005	0.000		0.019	0.019	0.000	
27	6F 123478	0.1	1	0.004	0.002	0.000	1	0.001	0.001	0.000	1	0.002	0.001	0.000	
28	6F 123678	0.1	1	0.021	0.010	0.001	1	0.001	0.001	0.000	1	0.002	0.001	0.000	
29	6F 123789	0.1	1	0.004	0.002	0.000	1	0.001	0.001	0.000	1	0.005	0.002	0.000	
30	6F 234678	0.1	1	0.004	0.002	0.000		0.002	0.002	0.000	1	0.002	0.001	0.000	
31	6F Other	0		-0.029	-0.029	0.000	1	0.011	0.005	0.000	1	0.000	0.000	0.000	
32	6F Total	0		0.004	0.004	0.000	1	0.017	0.008	0.000	1	0.012	0.006	0.000	
33	7F 1234678	0.01	1	0.004	0.002	0.000		0.006	0.006	0.000		0.007	0.007	0.000	
34	7F 1234789	0.01	1	0.006	0.003	0.000	1	0.002	0.001	0.000	1	0.007	0.003	0.000	
35	7F Other	0	1	-0.006	-0.003	0.000	1	0.000	0.000	0.000	1	-0.002	-0.001	0.000	
36	7F Total	0	1	0.004	0.002	0.000	1	0.009	0.004	0.000	1	0.012	0.006	0.000	
37	8F	0.001	1	0.012	0.006	0.000	1	0.009	0.004	0.000		0.009	0.009	0.000	
38	Total PCDD/PCDF			0.268	0.212			0.267	0.202			0.574	0.458		
39	TEQ		94.4	0.010		0.005	88.5	0.003		0.002	87.7	0.008		0.005	