

US EPA ARCHIVE DOCUMENT

	B	C
1	<b>Source Description</b>	
2		
3	Phase II ID No.	818
4	EPA ID No.	LAD010390599
5	Facility Name	Westvaco
6	Facility Location	
7	City	DeRidder
8	State	LA
9	Unit ID Name/No.	Boilers No. 2 and 3 (common ESP and stack)
	Other Sister Facilities	None (Boiler No. 4 also shares common ESP and stack but does not burn haz waste)
10		
11	Number of Sister Facilities	0
12	Combustor Class	Liquid-fired boiler
13	Combustor Type	Liquid injection
	Combustor Characteristics	Watertube boilers. Both units identical, Combustion Engineering Stirling type boilers (Model VA-X) with Coen burners, watertube, single wall fired, 60,000 lb/hr steam
14		
15	Capacity (MMBtu/hr)	86
	Soot Blowing	
16		Yes, every 8 hrs (6 blowers activated for 15 sec each, duration 15 min)
17	APCS Detailed Acronym	ESP
18	APCS General Class	ESP
19	APCS Characteristics	3 fields
20	Hazardous Wastes	Liq, solid
	Haz Waste Description	Resinate filer cake, HC920/spage oil, acrylic process spent organics and overheads
21		
22	Supplemental Fuel	natural gas, oil, misc. fuel
23		Tall oil pitch and heads fuel, fuel oil, natural gas
24	Stack Characteristics	
25	Diameter (ft)	8
26	Height (ft)	250
27	Gas Velocity (ft/sec)	46.5
28	Gas Temperature (°F)	383
29		
	Permitting Status	
30		Has Low Risk Waste Exemption (no PM/DRE), Tier I for metals/chlorine
	HWC Burn Status (Date if Terminated)	
31		

	B	C
1	<b>Cond Description</b>	
2		
3	<b>818C10</b>	
4		
5	Report Name/Date	Risk Burn Report, February 1998
6	Report Prepar	Westvaco Chemical Division, Deridder, LA facility
7	Testing Firm	METCO
8	Testing Dates	September 10-12, 1997
9	Cond Dates	September-97
10	Cond. Description	Risk burn
11	Content	Non D/F organics (no PM, chlorine, metals, volatiles, semi-vol, TOC)
12		
13	<b>818C11</b>	
14		
15	Report Name/Date	Recertification Test Report
16	Report Prepar	Westvaco
17	Testing Firm	Emission Testing Services, Inc.
18	Testing Dates	June 29-30, 1995
19	Cond Dates	Jun-95
20	Cond Description	CoC
21	Content	D/F
22		
23	<b>818C12</b>	
24		
25	Report Name/Date	CoC Testing
26	Report Prepar	Walk, Haydel & Associates
27	Testing Firm	TRC Environmental Corp.
28	Testing Dates	April 29-30, 1992
29	Cond Dates	Apr-92
30	Cond Description	Coc testing
31	Content	D/F, PM
32		
33	<b>818C13</b>	
34		
35	Report Name/Date	Recertification of Compliance Test Report
36	Report Prepar	Westvaco
37	Testing Firm	Metco Environmental
38	Testing Dates	June 24-26, 1998
39	Cond Dates	Jun-98
40	Cond Description	Coc testing
41	Content	D/F
42		
43	<b>818C14</b>	
44		
45	Report Name/Date	Air Quality Compliance Test
46	Report Prepar	Westvaco
47	Testing Firm	Emission Testing Services, Inc.
48	Testing Dates	7/5/1995
49	Cond Dates	Jul-95
50	Cond Description	Air Permit
51	Content	PM, CO, THC

	B	C	D	E	F	G	H	I	J	K	L	M
1	<b>Stack Gas Emissions</b>											
2												
3		Comments	Units	7% O2								
4												
5												
6	<b>818C10</b>	<b>(Risk Burn)</b>				R1		R2		R3		Cond Avg
7												
8	CO (RA)	E1	ppmv	y		27.7		10.1		12.2		16.7
9												
10	Sampling Train	SVOC	E1									
11	Stack Gas Flowrate		dscfm			63580		70941		70458		68326
12	O2		%			17		16.8		17.8		17.2
13	Moisture		%			8.96		7.25		6.58		7.6
14	Temperature		°F			376		371		371		372.7
15												
16												
17	<b>818C11</b>	<b>(COC test 6/29-30/95)</b>				R1		R2		R3		Cond Avg
18												
19	PM	E1	gr/dscf	y								0.0239
20	CO (RA)	E1	ppmv	y		1.7		1.6		1.3		1.5
21												
22	Sampling Train	PM	E1									
23	Stack Gas Flowrate		dscfm	y		75473		76481		72603		74852
24	O2		%			13.2		11.7		14.3		13.1
25	Moisture		%			4.94		5.03		5.75		5.24
26	Temperature		°F			354		359		358		357
27												
28												
29	<b>818C13</b>	<b>(COC test 6/24-26/98)</b>				R1		R2		R3		Cond Avg
30												
31	CO (RA)	E1	ppmv	y		4		0.9		5.1		3.3
32												
33	Sampling Train	CO	E1									
34	Stack Gas Flowrate		dscfm	y		77932		77091		78975		77999
35	O2		%			13.4		13.9		13.8		13.7
36	Moisture		%			4.54		5.27		5.9		5.236666667
37	Temperature		°F			361		356		348		355
38												
39												
40	<b>818C14</b>	<b>(COC test 7/5/95)</b>				R1		R2		R3		Cond Avg
41												
42	HC (RA)	E1	ppmv	y								3.1
43												
44	Sampling Train		E1									
45	Stack Gas Flowrate		dscfm	y								77862
46	O2		%									13.2
47	Moisture		%									5.8
48	Temperature		°F									383

	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
1	<b>Feedstreams</b>																			
2																				
3																				
4	<b>818C10</b>																			
5	Feedstream Number																			
6	Feed Class																			
7	Feed Class 2																			
8	Feedstream Description																			
9	Feed Rate																			
10	Heating Value																			
11	Ash																			
12	Chlorine																			
13	Mercury																			
14	Lead																			
15	Cadmium																			
16	Arsenic																			
17	Beryllium																			
18	Chromium																			
19	Nickel																			
20	Antimony																			
21	Selenium																			
22	Thallium																			
23	Silver																			
24	Stack Gas Flowrate																			
25	O2																			
26	Thermal Feedrate																			
27	Estimated Firing Rate																			
28																				
29																				
30																				
31																				
32																				
33																				
34																				
35																				
36																				
37																				
38																				
39																				
40																				
41																				
42																				
43																				
44																				
45																				
46																				
47																				
48																				
49																				
50																				
51																				
52																				
53																				
54																				
55																				
56																				

	B	V	W	X	Y	Z	AA	AB	AC
1	<b>Feedstreams</b>								
2									
3									
4	<b>818C10</b>	R1	R2	R3				Cond Avg	
5									
6	Feedstream Number	F3	F3	F3	F3	F3	F3	F3	
7	Feed Class	Total	Total	Total	Total	Total	Total	Total	
8	Feed Class 2	Total	Total	Total	Total	Total	Total	Total	
9	Feedstream Description	Total	Total	Total	Total	Total	Total	Total	
10	Feed Rate								
11	Heating Value								
12	Ash								
13	Chlorine								
14	Mercury								
15	Lead								
16	Cadmium								
17	Arsenic								
18	Beryllium								
19	Chromium								
20	Nickel								
21	Antimony								
22	Selenium								
23	Thallium								
24	Silver								
25									
26	Stack Gas Flowrate								
27	O2								
28									
29	Thermal Feedrate	69.4	70.7	70.3				70.1	
30	Estimated Firing Rate							82.4	
31									
32	<i>Feedrate MTEC Calculi</i>								
33	Ash	158.3	140.0	185.6				161.3	
34	Chlorine	30785.4	27226.9	36084.9				31365.7	
35	Mercury	27.9	100	32.6	100			28.4	
36	Lead	58.6	100	68.7	100			59.7	
37	Cadmium	58.6	100	68.7	100			59.7	
38	Arsenic	58.6	100	68.7	100			59.7	
39	Beryllium	58.6	100	68.7	100			59.7	
40	Chromium	58.6	100	68.7	100			59.7	
41	Nickel	58.6	100	68.7	100			59.7	
42	Antimony	146.6	100	171.8	100			149.4	
43	Selenium	58.6	100	68.7	100			59.7	
44	Thallium	58.6	100	68.7	100			59.7	
45	Silver	146.6	100	171.8	100			149.4	
46									
47									
48	SVM	117.3	100	137.5	100			119.5	
49	LVM	175.9	100	206.2	100			179.2	
50									
51	<b>BIF Feedrate Limits</b>								
52									
53	Chlorine								
54	Mercury								
55	Lead								
56	Cadmium								

	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
57	Arsenic		g/hr								120									
58	Beryllium		g/hr								220									
59	Chromium		g/hr								43									
60	Antimony		g/hr								15000									
61																				
62																				
63	<b>818C11</b>																			
64																				
65	Feedstream Number																			
66	Feed Class																			
67	Feed Class 2																			
	Feedstream Description																			
68	Feed Rate		lb/hr																	
69	Heat Content		Btu/lb																	
70																				
71	Ash																			
72	Chlorine		g/hr																	
73	Antimony		g/hr																	
74	Arsenic		g/hr																	
75	Barium		g/hr																	
76	Beryllium		g/hr																	
77	Cadmium		g/hr																	
78	Chromium		g/hr																	
79	Lead		g/hr																	
80	Mercury		g/hr																	
81	Silver		g/hr																	
82	Thallium		g/hr																	
83																				
84	Stack Gas Flowrate		dscfm																	
85	O2		%																	
86																				
87	Thermal Feedrate		MMBtu/hr																	
88	Estimated Firing Rate		MMBtu/hr																	
89																				
90	Feedrate MTEC Calculations																			
91	Chlorine		µg/dscm																	
92	Antimony		µg/dscm																	
93	Arsenic		µg/dscm																	
94	Barium		µg/dscm																	
95	Beryllium		µg/dscm																	
96	Cadmium		µg/dscm																	
97	Chromium		µg/dscm																	
98	Lead		µg/dscm																	
99	Mercury		µg/dscm																	
100	Silver		µg/dscm																	
101	Thallium		µg/dscm																	
102																				
103	SVM		µg/dscm																	
104	LVM		µg/dscm																	
105																				
106																				
107	<b>818C13</b>																			
108																				
109	Feedstream Number																			
110	Feed Class																			
111	Feed Class 2																			

	B	V	W	X	Y	Z	AA	AB	AC
57	Arsenic								
58	Beryllium								
59	Chromium								
60	Antimony								
61									
62									
63	<b>818C11</b>							Cond Avg	
64									
65	Feedstream Number								
66	Feed Class							F3	
67	Feed Class 2							Total	
	Feedstream							Total	
68	Description								
69	Feed Rate								
70	Heat Content								
71	Ash								
72	Chlorine								
73	Antimony								
74	Arsenic								
75	Barium								
76	Beryllium								
77	Cadmium								
78	Chromium								
79	Lead								
80	Mercury								
81	Silver								
82	Thallium								
83									
84	Stack Gas Flowrate								
85	O2								
86									
87	Thermal Feedrate							48.5	
88	Estimated Firing Rate							189	
89									
90	<i>Feedrate MTEC Calcult</i>								
91	Chlorine						100	6512	
92	Antimony						100	81	
93	Arsenic						100	81	
94	Barium						0	33	
95	Beryllium						100	16	
96	Cadmium						100	16	
97	Chromium						100	16	
98	Lead						0	49	
99	Mercury						100	3	
100	Silver						100	16	
101	Thallium						100	81	
102									
103	SVM						25	57.0	
104	LVM						100	56.9	
105									
106									
107	<b>818C13</b>								
108									
109	Feedstream Number								
110	Feed Class							F3	
111	Feed Class 2							Total	



B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	
Feedstream Description				Haz waste fuel/tail oil heads (Blr 2)	Haz waste fuel/tail oil heads (Blr 2)	Haz waste fuel/tail oil heads (Blr 2)	Haz waste fuel/tail oil heads (Blr 2)	Haz waste fuel/tail oil heads (Blr 2)	Haz waste fuel/tail oil heads (Blr 2)	Haz waste fuel/tail oil heads (Blr 2)	Tall oil pitch (Blr 3)	Tall oil pitch (Blr 3)	Tall oil pitch (Blr 3)	Tall oil pitch (Blr 3)	Tall oil pitch (Blr 3)	Tall oil pitch (Blr 3)	Tall oil pitch (Blr 3)	Tall oil pitch (Blr 3)		
112																				
113	Feed Rate	lb/hr		2790	2808	2838						2040	2220	2220		2220				
114	Heating Value	Btu/lb		16900	17300	17100						17600	17100	17100		16900				
115	Ash	% wt		1.06	0.92	1.28						1.181	2.91	2.91		3.11				
116	Chlorine	ppmw	nd	400	764 nd	668					nd	904 nd	867 nd	867 nd		458				
117	Antimony	ppmw	nd	5 nd	5 nd	5					nd	5 nd	5 nd	5 nd		5				
118	Arsenic	ppmw	nd	5 nd	5 nd	5					nd	5 nd	5 nd	5 nd		5				
119	Barium	ppmw	nd	5 nd	5	30					nd	5	8	8		5				
120	Beryllium	ppmw	nd	5 nd	5 nd	5					nd	5 nd	5 nd	5 nd		5				
121	Cadmium	ppmw	nd	5 nd	5 nd	5					nd	5 nd	5 nd	5 nd		5				
122	Chromium	ppmw	nd	5 nd	5 nd	5					nd	5 nd	5 nd	5 nd		5				
123	Lead	ppmw	nd	5 nd	5 nd	5					nd	5 nd	5 nd	5 nd		5				
124	Mercury	ppmw	nd	0.98 nd	0.77 nd	0.81					nd	0.58 nd	0.72 nd	0.72 nd		0.71				
125	Silver	ppmw	nd	5 nd	5 nd	5					nd	5 nd	5 nd	5 nd		5				
126	Thallium	ppmw	nd	10 nd	10 nd	10					nd	10 nd	10 nd	10 nd		10				
127																				
128	Stack Gas Flowrate	dscfm		77932	77091	78975					77999	77932	77091	77091		78975				
129	O2	%		13.4	13.9	13.8					14	13.4	13.9	13.9		13.8				
130																				
131	Thermal Feedrate	MMBtu/hr		47.2	48.6	48.5					48.1	35.9	38.0	38.0		37.5				
132	Estimated Firing Rate	MMBtu/hr																		
133																				
134	Feedrate MTEC Calculations																			
135	Ash	mg/dscm		186.9	176.7	239.1					201	152.3	441.8	441.8		454.5				
136	Chlorine	µg/dscm	100	7053.1	14671.5	12480.0					11402	11655.1	13163.0	13163.0		6693.3				
137	Antimony	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
138	Arsenic	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
139	Barium	µg/dscm	100	88.2	96.0	560.5					248	64.5	121.5	121.5		116.9				
140	Beryllium	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
141	Cadmium	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
142	Chromium	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
143	Lead	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
144	Mercury	µg/dscm	100	17.3	14.8	15.1					16	7.5	10.9	10.9		10.4				
145	Silver	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
146	Thallium	µg/dscm	100	176.3	192.0	186.8					185	128.9	151.8	151.8		146.1				
147																				
148	SVM	µg/dscm	100	88.2	96.0	93.4					93	64.5	75.9	75.9		73.1				
149	LVM	µg/dscm	100	132.2	144.0	373.7					217	96.7	136.6	136.6		131.5				
150																				
151																				
152																				
153	<b>818C14</b>																			
154																				
155	Feedstream Number																			
156	Feed Class																			
157	Feed Class 2																			
	Feedstream Description																			
158																				
159	Feed Rate	lb/hr																		

Cond Avg  
 F1  
 Liq HW  
 HW  
 Haz waste fuel/Tall oil heads (Blr 2)  
 Cond Avg  
 F2  
 Liq non-HW  
 Non-HW  
 Tall derived fuel (Blr 3)  
 3027

	B	V	W	X	Y	Z	AA	AB	AC
Feedstream Description	Total	Total	Total	Total	Total	Total	Total	Total	
112									
113									
114									
115									
116									
117									
118									
119									
120									
121									
122									
123									
124									
125									
126									
127									
128									78975
129									13.8
130									
131	Thermal Feedrate	83.1		86.5		86.0			85.2
132	Estimated Firing Rate								180.5
133									
134	Feedrate MTEC Calculk								
135	Ash	339.2	0	618.5	0	693.6	0	550.4	
136	Chlorine	18708.2	47	27834.5	100	19173.3	78	21905.3	
137	Antimony	152.6	100	171.9	100	166.5	100	163.7	
138	Arsenic	152.6	100	171.9	100	166.5	100	163.7	
139	Barium	152.6	44	217.5	0	677.4	24	349.2	
140	Beryllium	152.6	100	171.9	100	166.5	100	163.7	
141	Cadmium	152.6	100	171.9	100	166.5	100	163.7	
142	Chromium	152.6	100	171.9	100	166.5	100	163.7	
143	Lead	152.6	100	171.9	100	166.5	100	163.7	
144	Mercury	24.8	100	25.7	100	25.5	100	25.3	
145	Silver	152.6	100	171.9	100	166.5	100	163.7	
146	Thallium	305.3	100	343.9	100	333.0	100	327.4	
147									
148	SVM	152.6	100	171.9	100	166.5	100	163.7	#
149	LVM	228.9	100	280.7	100	505.2	100	338.3	#
150									
151									
152									
153	<b>818C14</b>								
154									
155	Feedstream Number								
156	Feed Class								
157	Feed Class 2								
	Feedstream Description								
158									
159	Feed Rate								

	A	B
1	<b>Process Information</b>	
2		
3	Cond ID No.	Units
4		
5	All	For each test boiler #2 operating with Haz Waste fuel and boiler #3 with tall oil pitch
6		
7		Each boiler routed to common ESP and stack.
8		BIF sampling point for BIF CO and O2 is the boiler #2 duct.
9		Sampling points for (PM, D/F, THC, TOC, vol, semi-vol) are in the duct after ESP.

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	PCDD/PCDF																
2	N																
3	Facility Name and ID:	Westvaco (DeRidder, LA)															
4	Condition ID:	818C11															
5	Condition/Test Date:	CoC testing. December 1996 (1995?)															
6																	
7		I-TEF			Run 1					Run 2						Run 3	
8		Wght Fact	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total	TEQ	Total
9			Full ND	1/2 ND	Full ND	1/2 ND	Full ND	1/2 ND	Full ND	1/2 ND	Full ND	1/2 ND	Full ND	1/2 ND	Full ND	1/2 ND	Full ND
10	Detected in sample volume (ng)																
11	2,3,7,8-TCDD	1	nd	0.0010	0.0010	0.0005	0.0005	0.0005	0.0005	0.0060	0.0060	0.0030	nd	0.0020	0.0020	0.0010	0.0010
12	Total TCDD	0		0.0500	0.0000	0.0500	0.0000	0.0000	0.0000	0.1100	0.0000	0.0000	0.0000	0.010	0.0000	0.010	0.0000
13	1,2,3,7,8-PCDD	0.5		0.0030	0.0015	0.0030	0.0015	nd	0.0100	0.0050	0.0050	0.0025	0.003	0.0015	0.003	0.0015	0.0015
14	Total PCDD	0		0.0300	0.0000	0.0300	0.0000		0.1100	0.0000	0.1100	0.0000	0.005	0.0000	0.005	0.0000	0.0000
15	1,2,3,4,7,8-HxCDD	0.1	nd	0.0020	0.0002	0.0010	0.0001		0.0070	0.0007	0.0070	0.0007	0.004	0.0004	0.004	0.0004	0.0004
16	1,2,3,6,7,8-HxCDD	0.1		0.0060	0.0006	0.0060	0.0006		0.0200	0.0020	0.0200	0.0020	0.003	0.0003	0.003	0.0003	0.0003
17	1,2,3,7,8,9-HxCDD	0.1		0.0060	0.0006	0.0060	0.0006		0.0200	0.0020	0.0200	0.0020	0.003	0.0003	0.003	0.0003	0.0003
18	Total HxCDD	0		0.0600	0.0000	0.0600	0.0000		0.1500	0.0000	0.1500	0.0000	0.007	0.0000	0.007	0.0000	0.0000
19	1,2,3,4,6,7,8-HpCDD	0.01		0.0500	0.0005	0.0500	0.0005		0.0800	0.0008	0.0800	0.0008	0.020	0.0002	0.020	0.0002	0.0002
20	Total HpCDD	0		0.1000	0.0000	0.1000	0.0000		0.1600	0.0000	0.1600	0.0000	0.040	0.0000	0.040	0.0000	0.0000
21	OCDD	0.001		0.3900	0.0004	0.3900	0.0004		0.2700	0.0003	0.2700	0.0003	0.110	0.0001	0.110	0.0001	0.0001
22	2,3,7,8-TCDF	0.1		0.0500	0.0050	0.0500	0.0050		0.9200	0.0920	0.9200	0.0920	0.190	0.0190	0.190	0.0190	0.0190
23	Total TCDF	0		0.1900	0.0000	0.1900	0.0000		6.6000	0.0000	6.6000	0.0000	1.400	0.0000	1.400	0.0000	0.0000
24	1,2,3,7,8-PCDF	0.05	nd	0.0100	0.0005	0.0050	0.0003		0.2100	0.0105	0.2100	0.0105	0.050	0.0025	0.050	0.0025	0.0025
25	2,3,4,7,8-PCDF	0.5		0.0100	0.0050	0.0100	0.0050		0.2100	0.1050	0.2100	0.1050	0.050	0.0250	0.050	0.0250	0.0250
26	Total PCDF	0		0.1900	0.0000	0.1900	0.0000		2.5000	0.0000	2.5000	0.0000	0.590	0.0000	0.590	0.0000	0.0000
27	1,2,3,4,7,8-HxCDF	0.1	nd	0.0200	0.0020	0.0100	0.0010		0.1600	0.0160	0.1600	0.0160	0.020	0.0020	0.020	0.0020	0.0020
28	1,2,3,6,7,8-HxCDF	0.1	nd	0.0080	0.0008	0.0040	0.0004		0.0600	0.0060	0.0600	0.0060	0.009	0.0009	0.009	0.0009	0.0009
29	2,3,4,6,7,8-HxCDF	0.1		0.0200	0.0020	0.0200	0.0020		0.0500	0.0050	0.0500	0.0050	0.010	0.0010	0.010	0.0010	0.0010
30	1,2,3,7,8,9-HxCDF	0.1		0.0030	0.0003	0.0030	0.0003	nd	0.0080	0.0008	0.0080	0.0008	0.003	0.0003	0.003	0.0003	0.0003
31	Total HxCDF	0		0.0500	0.0000	0.0500	0.0000		0.4800	0.0000	0.4800	0.0000	0.070	0.0000	0.070	0.0000	0.0000
32	1,2,3,4,6,7,8-HpCDF	0.01		0.0300	0.0003	0.0300	0.0003		0.1600	0.0016	0.1600	0.0016	0.010	0.0001	0.010	0.0001	0.0001
33	1,2,3,4,7,8,9-HpCDF	0.01		0.0070	0.0001	0.0070	0.0001		0.0300	0.0003	0.0300	0.0003	0.003	0.0000	0.003	0.0000	0.0000
34	Total HpCDF	0		0.0400	0.0000	0.0400	0.0000		0.2700	0.0000	0.2700	0.0000	0.020	0.0000	0.020	0.0000	0.0000
35	OCDF	0.001		0.0400	0.0000	0.0400	0.0000		0.2100	0.0002	0.2100	0.0002	0.020	0.0000	0.020	0.0000	0.0000
36																	
37	Gas sample volume (dscf)			156.54	156.54	156.54	156.54		128.98	128.98	128.98	128.98	122.26	122.26	122.26	122.26	122.26
38	O2 (%)			13.20	13.20	13.20	13.20		11.70	11.70	11.70	11.70	14.30	14.30	14.30	14.30	14.30
39																	
40	PCDD/PCDF (ng in sample)			1.1400	0.0208	1.1400	0.0186		10.8600	0.2542	10.8600	0.2483	2.2720	0.0557	2.2720	0.0546	0.0546
41	PCDD/PCDF (ng/dscm @ 7% O2)		21.6	0.4619	0.0084	0.4619	0.0075	4.6	4.4790	0.1048	4.4790	0.1024	3.6	1.3721	0.0336	1.3721	0.0330
42																	
43	TEQ Cond Avg			0.048													
44	Total Cond Avg			2.10													

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	PCDD/PCDF																
2	N																
3	Facility Name and ID:	Westvaco															
4	Condition ID:	818C12															
5	Condition/Test Date:	CoC testing, April 29-30, 1992															
6																	
7		I-TEF															
8		Wght Fact															
9																	
10	Detected in sample volume (pg)																
11	2,3,7,8-TCDD	1	nd	3.3	3.3	1.7	1.7	1.7	2.6	2.6	1.3	1.3	1.3	3.0	3.0	1.5	1.5
12	Total TCDD	0		47	0.0	47	0.0	47	34.0	0.0	34.0	0.0	34.0	75.0	0.0	75.0	0.0
13	1,2,3,7,8-PCDD	0.5	nd	13	6.5	7	3.3	3.3	6.5	6.5	6.5	3.3	3.3	13.0	6.5	6.5	3.3
14	Total PCDD	0	nd	250	0.0	125	0.0	125	230.0	0.0	115	0.0	115	240.0	0.0	120	0.0
15	1,2,3,4,7,8-HxCDD	0.1	nd	18	1.8	9	0.9	0.9	1.2	1.2	6	0.6	0.6	11.0	1.1	5.5	0.6
16	1,2,3,6,7,8-HxCDD	0.1	nd	12	1.2	6	0.6	0.6	8.4	0.8	4	0.4	0.4	8.9	0.9	4.5	0.4
17	1,2,3,7,8,9-HxCDD	0.1	nd	14	1.4	7	0.7	0.7	10.0	1.0	5	0.5	0.5	11.0	1.1	5.5	0.6
18	Total HxCDD	0	nd	52	0.0	26	0.0	26	29.0	0.0	15	0.0	15	20.0	0.0	20	0.0
19	1,2,3,4,6,7,8-HpCDD	0.01		66	0.7	66	0.7	66	25.0	0.3	25	0.3	25	29.0	0.3	29	0.3
20	Total HpCDD	0		120	0.0	120	0.0	120	53.0	0.0	53	0.0	53	59.0	0.0	59	0.0
21	OCDD	0.001		340	0.3	340	0.3	340	150.0	0.2	150	0.2	150	140.0	0.1	140	0.1
22	2,3,7,8-TCDF	0.1		63	6.3	63	6.3	63	14.0	1.4	14	1.4	14	21.0	2.1	21	2.1
23	Total TCDF	0		620	0.0	620	0.0	620	230.0	0.0	230	0.0	230	410.0	0.0	410	0.0
24	1,2,3,7,8-PCDF	0.05		39	2.0	39	2.0	39	14.0	0.7	7	0.4	7	15.0	0.8	15	0.8
25	2,3,4,7,8-PCDF	0.5		47	23.5	47	23.5	47	12.0	6.0	12	6.0	12	25.0	12.5	25	12.5
26	Total PCDF	0		450	0.0	450	0.0	450	120.0	0.0	120	0.0	120	280.0	0.0	280	0.0
27	1,2,3,4,7,8-HxCDF	0.1		50	5.0	50	5.0	50	18.0	1.8	18	1.8	18	27.0	2.7	27	2.7
28	1,2,3,6,7,8-HxCDF	0.1		34	3.4	34	3.4	34	14.0	1.4	14	1.4	14	27.0	2.7	27	2.7
29	2,3,4,6,7,8-HxCDF	0.1		54	5.4	54	5.4	54	20.0	2.0	20	2.0	20	46.0	4.6	46	4.6
30	1,2,3,7,8,9-HxCDF	0.1	nd	11	1.1	5.5	0.6	0.6	8.1	0.8	4.1	0.4	4.1	12.0	1.2	6	0.6
31	Total HxCDF	0		430	0.0	430	0.0	430	130.0	0.0	130	0.0	130	240.0	0.0	240	0.0
32	1,2,3,4,6,7,8-HpCDF	0.01		180	1.8	180	1.8	180	46.0	0.5	46	0.5	46	72.0	0.7	72	0.7
33	1,2,3,4,7,8,9-HpCDF	0.01	nd	17	0.2	9	0.1	0.1	10.0	0.1	5	0.1	5	13.0	0.1	6.5	0.1
34	Total HpCDF	0		180	0.0	180	0.0	180	46.0	0.0	46	0.0	46	72.0	0.0	72	0.0
35	OCDF	0.001		98	0.1	98	0.1	98	28.0	0.0	28	0.0	28	29.0	0.0	29	0.0
36																	
37	Gas sample volume (dscf)			122	122	122	122	122	137	137	137	137	137	132.6	132.6	132.6	132.6
38	O2 (%)			15.5	15.5	15.5	15.5	15.5	14.4	14.4	14.4	14.4	14.4	14.5	14.5	14.5	14.5
39																	
40	PCDD/PCDF (pg in sample)			2587	64	3013	56	56	1050	27	1109	20	20	1565	40	1743	33
41	PCDD/PCDF (ng/dscm @ 7% O2)		24.2	1.9073	0.0471	2.2215	0.0414	50.5	0.5745	0.0149	0.6065	0.0111	34.4	0.8983	0.0232	1.0004	0.0192
42																	
43	TEQ Cond Avg	0.0239															
44	Total Cond Avg	1.28															

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	
PCDD/PCDF																				
N																				
Facility Name and ID:		Westvaco																		
Condition ID:		818C13																		
Condition/Test Date:		CoC testing June 24-26, 1998																		
		I-TEF			Run 1			Run 2			Run 3			Avg						
		Wght Fact			Total			TEQ			Total			TEQ			Total			
		Full ND			1/2 ND			1/2 ND			Full ND			1/2 ND			1/2 ND			
10	Detected in sample volume (ng)																			
11	2,3,7,8-TCDD	1	nd	0.003	0.003	0.002	0.002	nd	0.003	0.003	0.002	0.002	nd	0.002	0.002	0.001	0.001	0.001	0.001	
12	Total TCDD	0		0.012	0.000	0.012	0.000		0.018	0.000	0.018	0.000		0.004	0.000	0.004	0.000	0.000	0.011	
13	1,2,3,7,8-PCDD	0.5	nd	0.006	0.003	0.003	0.002	nd	0.005	0.003	0.003	0.001	nd	0.004	0.002	0.002	0.001	0.003	0.003	
14	Total PCDD	0	nd	0.006	0.000	0.003	0.000		0.017	0.000	0.017	0.000	nd	0.004	0.000	0.002	0.000	0.007	0.007	
15	1,2,3,4,7,8-HxCDD	0.1	nd	0.003	0.000	0.002	0.000		0.005	0.001	0.005	0.001	nd	0.004	0.000	0.002	0.000	0.003	0.003	
16	1,2,3,6,7,8-HxCDD	0.1		0.008	0.001	0.008	0.001		0.012	0.001	0.012	0.001	nd	0.004	0.000	0.002	0.000	0.007	0.007	
17	1,2,3,7,8,9-HxCDD	0.1		0.007	0.001	0.007	0.001		0.008	0.001	0.008	0.001	nd	0.004	0.000	0.002	0.000	0.006	0.006	
18	Total HxCDD	0		0.035	0.000	0.035	0.000		0.075	0.000	0.075	0.000		0.014	0.000	0.014	0.000	0.041	0.041	
19	1,2,3,4,6,7,8-HpCDD	0.01		0.029	0.000	0.029	0.000		0.083	0.001	0.083	0.001		0.022	0.000	0.022	0.000	0.045	0.045	
20	Total HpCDD	0		0.042	0.000	0.042	0.000		0.100	0.000	0.100	0.000		0.035	0.000	0.035	0.000	0.059	0.059	
21	OCDD	0.001		0.140	0.000	0.140	0.000		0.420	0.000	0.420	0.000		0.170	0.000	0.170	0.000	0.243	0.243	
22	2,3,7,8-TCDF	0.1		0.008	0.001	0.008	0.001		0.011	0.001	0.011	0.001	nd	0.003	0.000	0.002	0.000	0.007	0.007	
23	Total TCDF	0		0.038	0.000	0.038	0.000		0.044	0.000	0.044	0.000	nd	0.003	0.000	0.002	0.000	0.028	0.028	
24	1,2,3,7,8-PCDF	0.05		0.016	0.001	0.016	0.001		0.022	0.001	0.022	0.001		0.006	0.000	0.006	0.000	0.015	0.015	
25	2,3,4,7,8-PCDF	0.5		0.012	0.006	0.012	0.006		0.016	0.008	0.016	0.008		0.005	0.003	0.005	0.003	0.011	0.011	
26	Total PCDF	0		0.076	0.000	0.076	0.000		0.120	0.000	0.120	0.000		0.012	0.000	0.012	0.000	0.069	0.069	
27	1,2,3,4,7,8-HxCDF	0.1		0.060	0.006	0.060	0.006		0.074	0.007	0.074	0.007		0.021	0.002	0.021	0.002	0.052	0.052	
28	1,2,3,6,7,8-HxCDF	0.1		0.028	0.003	0.028	0.003		0.038	0.004	0.038	0.004		0.011	0.001	0.011	0.001	0.026	0.026	
29	2,3,4,6,7,8-HxCDF	0.1		0.023	0.002	0.023	0.002		0.030	0.003	0.030	0.003		0.009	0.001	0.009	0.001	0.021	0.021	
30	1,2,3,7,8,9-HxCDF	0.1		0.017	0.002	0.017	0.002		0.021	0.002	0.021	0.002		0.007	0.001	0.007	0.001	0.015	0.015	
31	Total HxCDF	0		0.210	0.000	0.210	0.000		0.290	0.000	0.290	0.000		0.077	0.000	0.077	0.000	0.192	0.192	
32	1,2,3,4,6,7,8-HpCDF	0.01		0.290	0.003	0.290	0.003		0.360	0.004	0.360	0.004		0.110	0.001	0.110	0.001	0.253	0.253	
33	1,2,3,4,7,8,9-HpCDF	0.01		0.052	0.001	0.052	0.001		0.053	0.001	0.053	0.001		0.015	0.000	0.015	0.000	0.040	0.040	
34	Total HpCDF	0		0.430	0.000	0.430	0.000		0.520	0.000	0.520	0.000		0.160	0.000	0.160	0.000	0.370	0.370	
35	OCDF	0.001		0.600	0.001	0.600	0.001		0.560	0.001	0.560	0.001		0.220	0.000	0.220	0.000	0.460	0.460	
36																				
37	Gas sample volume (dscf)			3.84	3.84	3.84	3.84		3.96	3.96	3.96	3.96		3.98	3.98	3.98	3.98			
38	O2 (%)			17.3	17.3	17.3	17.3		17.1	17.1	17.1	17.1		17.0	17.0	17.0	17.0			
39																				
40	PCDD/PCDF (ng in sample)			1.59	0.03	2.14	0.03		2.16	0.04	2.90	0.04		0.70	0.01	0.91	0.01			
41	PCDD/PCDF (ng/dscm @ 7% O2)		19.3	1.5657	0.0322	2.1106	0.0291	13.6	1.9617	0.0367	2.6298	0.0342	36.8	0.6147	0.0132	0.8020	0.0107			
42																				
43	TEQ Cond Avg																			
44	Total Cond Avg																			