

US EPA ARCHIVE DOCUMENT

**FINAL**

**Coal Combustion Waste Impoundment  
Round 7 - Dam Assessment Report**

*Meramec Power Station*

*Ameren Missouri*  
**St. Louis, Missouri**

**Prepared for:**

United States Environmental Protection Agency  
Office of Resource Conservation and Recovery

**Prepared by:**

Dewberry & Davis, LLC  
Fairfax, Virginia



Under Contract Number: EP-09W001727

**June 2011**

# FINAL

## INTRODUCTION, SUMMARY, CONCLUSION AND RECOMMENDATIONS

The release of over five million cubic yards of coal combustion waste from the Tennessee Valley Authority's Kingston, Tennessee facility in December 2008 flooded more than 300 acres of land, damaging homes and property. In response the U.S. EPA is assessing the stability and functionality of coal combustion ash impoundments and other management units across the country and, as necessary, identifying any needed corrective measures.

This assessment of the stability and functionality of the Meramec Power Station coal combustion waste (CCW) management units is based on a review of available documents and on the site assessment conducted by Dewberry personnel on September 29, 2010. We found the supporting technical information to be limited (Section 1.1.3). As detailed in Section 1.2 there are several recommendations that may help to maintain a safe and trouble-free operation.

In summary, the Meramec Power Station CCW ponds are rated **POOR** for continued safe and reliable operation (Section 1.1.8). The rating is influenced by the results of the November 2010 Ash Pond Dam Stability Analysis conducted by Reitz & Jens, Inc. Evaluation of the CCW pond embankments show the CCW pond embankments do not meet the minimum required Missouri DNR safety factor for the steady seepage loading conditions. Ameren Missouri has initiated a project to be implemented in 2011 to flatten the existing slopes on the downstream side of Ponds 1, 2, and 4 to improve the factor of safety; the CCW ponds would be rated **SATISFACTORY** upon completion of the project.

### PURPOSE AND SCOPE

The U. S. Environmental Protection Agency (EPA) is embarking on an initiative to investigate the potential for catastrophic failure of Coal Combustion Surface Impoundments (i.e. management units) from occurring at electric utilities in an effort to protect lives and property from the consequences of a dam failure or the improper release of impoundment contents. The EPA initiative is intended to identify conditions that may adversely affect the structural stability and functionality of a management unit and its appurtenant structures (if present); to note the extent of deterioration (if present); status of maintenance and/or a need for immediate repair; to evaluate conformity with current design and construction practices, and to determine the hazard potential classification for units not currently classified by the management unit owner or by a state or federal agency. The initiative will address management units that are classified a Less-than-Low, Low, Significant or High Hazard Potential ranking. (For Classification, see pp. 3-8 of the 2004 Federal Guidelines for Dam Safety.)

In early 2009 the USEPA sent its first wave of letters to coal-fired electric utilities seeking information on the safety of surface impoundments and similar facilities that receive liquid-borne material that store or dispose of coal combustion waste. This letter was issued under the

# FINAL

authority of the Comprehensive Environmental Response, Compensation and Liability Act (CERCLA) Section 104(e), to assist the Agency in assessing the structural stability and functionality of such management units, including which facilities should be visited to perform a safety assessment of the berms, dikes, and dams used in the construction of these impoundments.

EPA asked utility companies to identify all management units, such as surface impoundments or similar diked or bermed structures and landfills receiving liquid-borne materials, that store or dispose of coal-combustion residuals or by-products, including, but not limited to, fly ash, bottom ash, boiler slag, and flue gas emission control residuals. Utility companies responded with information on the size, design, age, and the amount of material placed in the units so that EPA could gauge which management units had or potentially could rank as having High Hazard Potential. The USEPA and its contractors used the following definitions for this study:

“Surface Impoundment or impoundment means a facility or part of a facility which is a natural topographic depression, man-made excavation, or diked area formed primarily of earthen materials (although it may be lined with man-made materials), which is designed to hold an accumulation of liquid wastes or wastes containing free liquids, and which is not an injection well. Examples of surface impoundments are holding, storage, settling and aeration pits, ponds, and lagoons.”

For this study, the earthen materials could include coal combustion residuals. EPA did not provide an exclusion for small units based on whether the placement was temporary or permanent. Furthermore, the study covers not only waste units designated as surface impoundments, but also other units designated as landfills which receive free liquids.

EPA is addressing any land-based units that receive fly ash, bottom ash, boiler slag, or flue gas emission control wastes along with free liquids. If the landfill is receiving coal combustion wastes with liquids limited to that for proper compaction, then there should not be free liquids present and the EPA did not seek information on such units which are appropriately designated a landfill.

In some cases coal combustion wastes are separated from the water, and the water containing de minimus levels of fly ash, bottom ash, boiler slag, or flue gas emission control wastes are sent to an impoundment. EPA is including such impoundments in this study, because chemicals of concern may have leached from the solid coal combustion wastes into the water, and the suspended solids from the coal combustion wastes remain.

The purpose of this report is to evaluate the condition and potential of waste release from management units and to determine their hazard potential classification. A two-person team reviewed the information submitted to EPA, reviewed any relevant publicly available

# FINAL

information from state or federal agencies regarding the unit potential hazard classification (if any) and accepted information provided via telephone communication with a management unit representative.

EPA sent two engineers, one licensed in the State of Missouri, for a one-day visit. The two-person team met with technical and management representatives of the utility to discuss the engineering characteristics of the unit as part of the site visit. During the site visit the team collected additional information about the management unit(s) to be used to determine the hazard potential classifications. Subsequent to the site visit the management unit owner provided additional engineering data on the Meramec Power Station to the USEPA and its contractor.

Factors considered in determining the hazard potential classification of the management unit(s) included the age and size of the impoundment, the quantity of coal combustion residuals or by-products that were stored or disposed in the these impoundments, its past operating history, and its geographic location relative to down gradient population centers and/or sensitive environmental systems.

This report presents the opinion of the assessment team as to the potential of catastrophic failure and reports on the condition of the management unit(s). For evaluating the dams, the team considered criteria under the National Inventory of Dams.

## LIMITATIONS

The assessment of dam safety reported herein is based on field observations and review of readily available information provided by the owner/operator of the subject coal combustion waste management unit(s). Qualified Dewberry engineering personnel performed the field observations and review and made the assessment in conformance with the required scope of work and in accordance with reasonable and acceptable engineering practices. No other warranty, either written or implied, is made with regard to our assessment of dam safety.

# FINAL

## TABLE OF CONTENTS

INTRODUCTION, SUMMARY, CONCLUSION AND RECOMMENDATIONS.....	II
PURPOSE AND SCOPE .....	II
<b>1.0 CONCLUSIONS AND RECOMMENDATIONS.....</b>	<b>1-1</b>
1.1 CONCLUSIONS .....	1-1
1.1.1 <i>Conclusions Regarding the Structural Soundness of the Management Unit(s)</i> .....	1-1
1.1.2 <i>Conclusions Regarding the Hydrologic/Hydraulic Safety of the Management Unit(s)</i> .....	1-1
1.1.3 <i>Conclusions Regarding the Adequacy of Supporting Technical Documentation</i> .....	1-1
1.1.4 <i>Conclusions Regarding the Description of the Management Unit(s)</i> .....	1-2
1.1.5 <i>Conclusions Regarding the Field Observations</i> .....	1-2
1.1.6 <i>Conclusions Regarding the Adequacy of Maintenance and Methods of Operation</i> .....	1-2
1.1.7 <i>Conclusions Regarding the Adequacy of the Surveillance and Monitoring Program</i> .....	1-2
1.1.8 <i>Classification Regarding Suitability for Continued Safe and Reliable Operation</i> .....	1-3
1.2 RECOMMENDATIONS.....	1-3
1.2.1 <i>Recommendations Regarding the Structural Stability</i> .....	1-3
1.2.2 <i>Recommendations Regarding the Hydrologic/Hydraulic Safety</i> .....	1-4
1.2.3 <i>Recommendations Regarding the Description of the Management Unit(s)</i> .....	1-4
1.2.4 <i>Recommendations Regarding the Maintenance and Methods of Operation</i> .....	1-4
1.2.5 <i>Recommendations Regarding the Surveillance and Monitoring Program</i> .....	1-4
1.2.6 <i>Recommendations Regarding Continued Safe and Reliable Operation</i> .....	1-4
1.3 PARTICIPANTS AND ACKNOWLEDGEMENT .....	1-5
1.3.1 <i>List of Participants</i> .....	1-5
1.3.2 <i>Acknowledgement and Signature</i> .....	1-5
<b>2.0 DESCRIPTION OF THE COAL COMBUSTION WASTE MANAGEMENT UNIT(S).....</b>	<b>2-1</b>
2.1 LOCATION AND GENERAL DESCRIPTION.....	2-1
2.2 SIZE AND HAZARD CLASSIFICATION .....	2-3
2.3 AMOUNT AND TYPE OF RESIDUALS CURRENTLY CONTAINED IN THE UNIT(S) AND MAXIMUM CAPACITY..	2-5
2.4 PRINCIPAL PROJECT STRUCTURES .....	2-6
2.4.1 <i>Earth Embankment Dam</i> .....	2-6
2.4.2 <i>Outlet Structures</i> .....	2-8
2.5 CRITICAL INFRASTRUCTURE WITHIN FIVE MILES DOWN GRADIENT.....	2-9
<b>3.0 SUMMARY OF RELEVANT REPORTS, PERMITS AND INCIDENTS.....</b>	<b>3-1</b>
3.1 SUMMARY OF REPORTS ON THE SAFETY OF THE MANAGEMENT UNIT(S) .....	3-1
3.2 SUMMARY OF LOCAL, STATE AND FEDERAL ENVIRONMENTAL PERMITS.....	3-2
3.3 SUMMARY OF SPILL/RELEASE INCIDENTS (IF ANY) .....	3-2
<b>4.0 SUMMARY OF HISTORY OF CONSTRUCTION AND OPERATION .....</b>	<b>4-1</b>
4.1 SUMMARY OF CONSTRUCTION HISTORY.....	4-1
4.1.1 <i>Original Construction</i> .....	4-1
4.1.2 <i>Significant Changes/Modifications in Design since Original Construction</i> .....	4-2
4.1.3 <i>Significant Repairs/Rehabilitation since Original Construction</i> .....	4-3
4.2 SUMMARY OF OPERATIONAL HISTORY .....	4-3
4.2.1 <i>Original Operational Procedures</i> .....	4-3
4.2.2 <i>Significant Changes in Operational Procedures since Original Startup</i> .....	4-3
4.2.3 <i>Current Operational Procedures</i> .....	4-3
4.2.4 <i>Other Notable Events since Original Startup</i> .....	4-4

# FINAL

<b>5.0</b>	<b>FIELD OBSERVATIONS .....</b>	<b>5-1</b>
5.1	PROJECT OVERVIEW AND SIGNIFICANT FINDINGS .....	5-1
5.2	PONDS .....	5-1
5.2.1	<i>Embankment Dam and Basin Area .....</i>	<i>5-1</i>
5.2.2	<i>Outlet Structures.....</i>	<i>5-3</i>
5.3	FIELD PHOTOGRAPHS .....	5-5
<b>6.0</b>	<b>HYDROLOGIC/HYDRAULIC SAFETY .....</b>	<b>6-1</b>
6.1	SUPPORTING TECHNICAL DOCUMENTATION .....	6-1
6.1.1	<i>Floods of Record.....</i>	<i>6-1</i>
6.1.2	<i>Inflow Design Flood.....</i>	<i>6-1</i>
6.1.3	<i>Spillway Rating.....</i>	<i>6-1</i>
6.1.4	<i>Downstream Flood Analysis.....</i>	<i>6-1</i>
6.2	ADEQUACY OF SUPPORTING TECHNICAL DOCUMENTATION .....	6-2
6.3	ASSESSMENT OF HYDROLOGIC/HYDRAULIC SAFETY .....	6-2
<b>7.0</b>	<b>STRUCTURAL STABILITY .....</b>	<b>7-1</b>
7.1	SUPPORTING TECHNICAL DOCUMENTATION .....	7-1
7.1.1	<i>Stability Analyses and Load Cases Analyzed .....</i>	<i>7-1</i>
7.1.2	<i>Design Properties and Parameters of Materials .....</i>	<i>7-1</i>
7.1.3	<i>Uplift and/or Phreatic Surface Assumptions .....</i>	<i>7-1</i>
7.1.4	<i>Factors of Safety and Base Stresses .....</i>	<i>7-2</i>
7.1.5	<i>Liquefaction Potential.....</i>	<i>7-2</i>
7.1.6	<i>Critical Geological Conditions and Seismicity.....</i>	<i>7-2</i>
7.2	ADEQUACY OF SUPPORTING TECHNICAL DOCUMENTATION .....	7-3
7.3	ASSESSMENT OF STRUCTURAL STABILITY .....	7-3
<b>8.0</b>	<b>ADEQUACY OF MAINTENANCE AND METHODS OF OPERATION .....</b>	<b>8-1</b>
8.1	OPERATIONAL PROCEDURES .....	8-1
8.2	MAINTENANCE OF THE DAM AND PROJECT FACILITIES .....	8-1
8.3	ASSESSMENT OF MAINTENANCE AND METHODS OF OPERATION .....	8-1
8.3.1	<i>Adequacy of Operational Procedures .....</i>	<i>8-1</i>
8.3.2	<i>Adequacy of Maintenance .....</i>	<i>8-2</i>
<b>9.0</b>	<b>SURVEILLANCE AND MONITORING PROGRAM .....</b>	<b>9-1</b>
9.1	SURVEILLANCE PROCEDURES .....	9-1
9.2	INSTRUMENTATION MONITORING .....	9-1
9.2.1	<i>Instrumentation Plan .....</i>	<i>9-1</i>
9.2.2	<i>Instrumentation Monitoring Results.....</i>	<i>9-1</i>
9.2.3	<i>Dam Performance Data Evaluation .....</i>	<i>9-1</i>
9.3	ASSESSMENT OF SURVEILLANCE AND MONITORING PROGRAM .....	9-1
9.3.1	<i>Adequacy of Inspection Program .....</i>	<i>9-1</i>
9.3.2	<i>Adequacy of Instrumentation Monitoring Program .....</i>	<i>9-1</i>
<b>EXHIBIT 1:</b>	<b>REPRESENTATIVE POND 1 EMBANKMENT SECTIONS .....</b>	<b>E-1</b>
<b>EXHIBIT 2:</b>	<b>REPRESENTATIVE POND 2 EMBANKMENT SECTIONS .....</b>	<b>E-2</b>
<b>EXHIBIT 3:</b>	<b>REPRESENTATIVE POND 3 EMBANKMENT SECTIONS .....</b>	<b>E-4</b>
<b>EXHIBIT 4:</b>	<b>REPRESENTATIVE POND 4 EMBANKMENT SECTION .....</b>	<b>E-5</b>

# FINAL

## TEXT PHOTOS

Photo 1: Looking west from access road at levee embankment at Pond 2. ....	5-5
Photo 2: Looking east along internal side slope and crest of levee embankment of Pond 2. ....	5-5
Photo 3: Looking south along embankment between railroad and Pond 2. ....	5-5
Photo 4: Looking Southwest at top of levee embankment of Pond 2 from access road .....	5-6
Photo 5: Repaired erosion area along levee embankment at Pond 8.....	5-6
Photo 6: Looking at gully erosion along top of levee embankment from runoff at Pond 2 .....	5-6
Photo 7: Gully runoff erosion from edge of crest of access road at Pond 2.....	5-7
Photo 8: Looking at gully erosion on down side of levee embankment at edge of crest of access road at Pond 8 .....	5-7
Photo 9: Looking northwest at outside slope of Pond 2 levee embankment.....	5-7
Photo 10: Outside slope of levee embankment at Pond 2. An unknown pipe was observed at the location, see Photo 14. ....	5-8
Photo 11: Looking southeast along outside slope of levee embankment of Pond 2. ....	5-8
Photo 12: Looking at outside slope of levee embankment at Pond 8.....	5-8
Photo 13: Looking northeast along outside slope and toe of the levee embankment along the Tributary to Meramec River .....	5-9
Photo 14: Looking at unknown pipe at the outside toe of Pond 2 levee embankment. ....	5-9
Photo 15: Looking southeast at railroad bridge. Location of submerged perimeter access road .....	5-9
Photo 16: Looking southeast along perimeter levee embankment.....	5-10
Photo 17: Looking southeast at tree line adjacent to submerged perimeter access road.....	5-10
Photo 18: Looking southwest along toe of levee embankment where floodplain is flooded.....	5-10
Photo 19: Looking north at perimeter access road gate. ....	5-11
Photo 20: Looking south along outside toe of Pond 7. ....	5-11
Photo 21: Looking northwest along outside toe and slope of levee embankment of Pond 7.....	5-11
Photo 22: Looking northwest along outside toe of levee embankment at Pond 7 .....	5-12
Photo 23: Looking north along outside toe of levee embankment at Pond 7.....	5-12
Photo 24: Looking northeast along outside toe of levee embankment at Pond 7 .....	5-12
Photo 25: Looking southwest along Meramec River just outside from Pond 1 (retention pond) outlet .....	5-13
Photo 26: Evidence of repair to outside slope of levee embankment due to erosion.....	5-13

# FINAL

Photo 27: Looking towards Pond 4 (Bottom Ash Pond) at outside toe and slope of levee embankment.....	5-13
Photo 28: Looking southeast at Pond 1 .....	5-14
Photo 29: Looking northwest at Pond 2 .....	5-14
Photo 30: Looking north at Pond 2 .....	5-14
Photo 31: Looking southeast along inside side slope of embankment.....	5-15
Photo 32: Looking at Pond 2 toward coal storage area.....	5-15
Photo 33: Looking north at overflow pipes and coal storage area .....	5-15
Photo 34: Looking at the Pond 3 (“New” Fly Ash Pond) area in the distance and the fill Fly Ash area to the northeast of Pond 1 .....	5-16
Photo 35: Looking through railroad track at southeast side of Pond 4 .....	5-16
Photo 36: Looking through railroad tracks at southeast side of pond area of Pond 4.....	5-16
Photo 37: Looking north at northwest side of Pond 4.....	5-17
Photo 38: Looking southeast at railroad tracks between northwest & southeast Pond 4.....	5-17
Photo 39: Looking southwest from railroad track at northwest Pond 4.....	5-17
Photo 40: Looking north at southeast Pond 4 from railroad tracks.....	5-18
Photo 41: Looking towards Pond 5 and 6 .....	5-18
Photo 42: Looking northeast at completely filled and deactivated Pond 8.....	5-18
Photo 43: Looking at retention pond inlet.....	5-19
Photo 44: Looking at Pond 2 (#489) inlet structure .....	5-19
Photo 45: Looking northeast at outfall pipe from Pond 1 .....	5-19
Photo 46: Looking west at outfall #009 at Pond 2 toward Meramec River .....	5-20
Photo 47: Outfall #009 from Pond 2 .....	5-20
Photo 48: Plunge pool at outfall #009.....	5-20

# FINAL

## APPENDICES

### APPENDIX A - REFERENCE DOCUMENTS

- Doc 1.1: Meramec Power Station Vicinity Map (5-Mile)
- Doc 1.2: Meramec Power Station Map
- Doc 1.3: Meramec Plant Plans
- Doc 1.4: Ameren Missouri Response to EPA's RFI
- Doc 1.5: Ash Pond #494 Drilling and Piezometer Installation Figures and Logs
- Doc 1.6: Available Information Checklists
- Doc 1.7: Missouri State Operating Permit
- Doc 1.8: 1995 FEMA Flood Insurance Rate Map
- Doc 1.9: Excerpt from Appendix D of the 2004 USACE Upper Mississippi River System Flow Frequency Study
- Doc 1.10: Letter to USEPA from Ameren Missouri March 2, 2011, including Reitz & Jens Stability Report, November 16, 2010
- Doc 1.11: Preliminary Sketches
- Doc 1.12: Reitz & Jens Revised Stability Report, March 29, 2011
- Doc 1.13: Ameren Missouri Plans and Description of Dike Reconfiguration (to be inserted at later date)

### APPENDIX B - FIELD OBSERVATION CHECKLISTS

- Unit 1 (Pond 3)
- Unit 2 (Pond 2)
- Unit 3 (Ponds 4, 5, & 6)
- Unit 4 (Pond 1)

### APPENDIX C - MISCELLANEOUS NOTES AND CORRESPONDENCE

References

## 1.0 CONCLUSIONS AND RECOMMENDATIONS

### 1.1 CONCLUSIONS

Conclusions are based on visual observations from the one-day site visit to the Meramec Power Station and review of technical and historical documentation provided by Ameren Missouri.

#### 1.1.1 Conclusions Regarding the Structural Soundness of the Management Unit(s)

Results from the November 2010 Ash Pond Dam Stability Analysis conducted by Reitz & Jens, Inc. indicate the CCW embankments currently do not meet the minimum required safety factors for steady seepage loading. (See Table 7.1 for the steady seepage Factors of Safety values.) Therefore, the structural soundness of the CCW embankments are currently rated **Poor**. Ameren Missouri has subsequently initiated a project to be completed in 2011 to flatten the existing slopes on the downstream side of Ponds 1, 2, and 4 to improve the factor of safety, see Table 7.2 and Appendix A, Docs 1.11 and 1.12. CCW ponds would be rated **Satisfactory** upon completion of the project.

#### 1.1.2 Conclusions Regarding the Hydrologic/Hydraulic Safety of the Management Unit(s)

The hydrologic and hydraulic data provided concludes that the 100-year, 24-hour storm event will overtop embankment levees of Pond 1 and Pond 2. Based on 2004 Army Corps of Engineers (USACE) 100-year Mississippi River flood elevation and FEMA August 2, 1995 Flood Insurance Rate Map 29189C0415 H, Meramec Power Station would be inundated during a 100-year flood. There have been no apparent issues with safe containment of water in the basins during significant flooding events in the 45-year experience record of the ash ponds. Based on the history and future downstream slope improvement project, failures of the embankment levees are not anticipated.

#### 1.1.3 Conclusions Regarding the Adequacy of Supporting Technical Documentation

The original design documentation was partially illegible and the design sequence was not identified. No other technical documentation about the design of the existing facility is available. Hydrologic/hydraulic analysis was provided for the CCW ponds. An Ash Pond Dam Stability Analysis, conducted by Reitz & Jens, Inc., was provided in 2011 to verify the structural stability of the embankments.

# FINAL

## 1.1.4 Conclusions Regarding the Description of the Management Unit(s)

Documents describing the CCW ponds were not provided. Ameren Missouri employee descriptions of the CCW ponds were appropriate and sufficient.

## 1.1.5 Conclusions Regarding the Field Observations

The embankment levee appeared well-maintained, safe, and structurally sound. There are no apparent indications of any unsafe conditions. The visible parts of the embankment levee and outlet structures were observed to have no signs of overstress, significant settlement, shear failure, or other signs of instability. Erosion on the inside slope and wooden retaining wall failure were observed at Pond 1. Runoff erosion was observed on the outside slope of the perimeter levee embankment. The outside slope of the levee embankment was observed to be covered in tall grass and brush. An indication of seepage was observed at the outside toe of Pond 4, although visual observations were severely hampered by the presence of tall vegetation. Runoff erosion is being managed through a maintenance program. The seepage area is being monitored and inspected per weekly inspection reports.

## 1.1.6 Conclusions Regarding the Adequacy of Maintenance and Methods of Operation

No evidence of major repairs to the embankments or prior releases was observed during the field assessment. Evidence of slope repair due to erosion on the outside slope of the perimeter levee was observed. Maintenance and methods of operation are adequate.

## 1.1.7 Conclusions Regarding the Adequacy of the Surveillance and Monitoring Program

The surveillance program is generally adequate. The informal weekly and formal annual internal inspections by Ameren Missouri engineers are of sufficient frequency and should continue. Internal inspection of the outlet structures should be performed at a frequency of at least once every 5 years and documented. There is no dam monitoring program in place that includes such instruments as observation wells/piezometers, settlement monitoring points, inclinometers, seepage monitoring points, etc. However, piezometers were installed on the embankment of Pond 7 for ash excavation purposes. Program pond discharge monitoring is in place and will continue in accordance with Missouri Department of Natural Resources (MDNR) Division of Environmental Quality permit requirements.

# FINAL

## 1.1.8 Classification Regarding Suitability for Continued Safe and Reliable Operation

In accordance with EPA criteria CCW ponds are currently rated **POOR** for continued safe and reliable operation. The rating is based on the results of the steady seepage loading reported in the November 2010 Ash Pond Dam Stability Analysis conducted by Reitz & Jens, Inc.. The minimum required safety factor for steady seepage loading under static conditions was not met. See Table 1.1 for structural stability rating. Implementation of recommendations as presented below would improve the rating to **SATISFACTORY** based upon subsequent information provided by Ameren Missouri.

Table 1.1: Structural Stability Rating	
Category	Description
<b>Satisfactory</b>	No existing or potential management unit safety deficiencies are recognized. Acceptable performance is expected under all applicable loading conditions (static, hydrologic, seismic) in accordance with the applicable criteria. Minor maintenance items may be required.
<b>Fair</b>	Acceptable performance is expected under all applicable loading conditions (static, hydrologic, seismic) in accordance with the applicable safety regulatory criteria. Minor deficiencies may exist that require remedial action and/or secondary studies or investigations.
<b>Poor</b>	A management unit safety deficiency is recognized for any required loading condition (static, hydrologic, seismic) in accordance with the applicable dam safety regulatory criteria. Remedial action is necessary. POOR also applies when further critical studies or investigations are needed to identify any potential dam safety deficiencies.
<b>Unsatisfactory</b>	Considered unsafe. A dam safety deficiency is recognized that requires immediate or emergency remedial action for problem resolution. Reservoir restrictions may be necessary.

*Modified from the New Jersey Department of Environmental Protection Dam Safety Guidelines for the Inspection of Existing Dams, January 2008.*

## 1.2 RECOMMENDATIONS

### 1.2.1 Recommendations Regarding the Structural Stability

The minimum factor of safety for steady seepage required by MDNR and USEPA is not met. Ameren Missouri has initiated a project to be implemented in 2011 to flatten the existing slopes on the downstream side of Pond 1, 2, and 4 to improve the factor of safety to meet and exceed minimum Factors of Safety (see Appendix A, Docs 1.11 and 1.12). According to Ameren Missouri the project cannot begin until river levels recede to normal levels (i.e., Summer 2011). We strongly recommend the dikes be re-configured as quickly as possible.

# FINAL

## 1.2.2 Recommendations Regarding the Hydrologic/Hydraulic Safety

The data provided indicates the 100-year, 24-hour storm event will overtop embankment levees of Pond 1 and Pond 2, and the 100-year Mississippi River flood will inundate Meramec Power Station. However, based on the history (including the 2011 flooding) and future downstream slope improvement project, failures of the embankment levees are not anticipated. It is recommended to monitor 100-year, 24-hour storm events for overtopping of the embankment levees and make repairs from potential erosion caused by overtopping.

## 1.2.3 Recommendations Regarding the Description of the Management Unit(s)

Documented descriptions of the CCW ponds and operational procedures were not provided. An Operation & Maintenance manual for the Meramec PS to provide a summary of the purpose and processes within the CCW ponds is planned by Ameren Missouri in 2011.

## 1.2.4 Recommendations Regarding the Maintenance and Methods of Operation

It is recommended to continue to monitor the seepage area observed at the outside toe of Pond 4 for changed conditions.

It is recommended to continue to monitor the inside slope and retaining wall of Pond 1.

As recommended in the engineer's report of November 2010, Ameren Missouri must continue to ensure positive drainage is maintained from the inactive ponds.

## 1.2.5 Recommendations Regarding the Surveillance and Monitoring Program

Internal inspections of the outlet structures with a remote camera or by personnel using confined-space procedures should be conducted on a frequency of at least once every 5 years.

## 1.2.6 Recommendations Regarding Continued Safe and Reliable Operation

Continued safe and reliable ash management is dependent upon completing the proposed modifications to the downstream side of the dikes for Ponds 1, 2 and 4 as soon as possible. Ameren Missouri should notify USEPA upon completion of the re-configuration project.

# FINAL

## 1.3 PARTICIPANTS AND ACKNOWLEDGEMENT


### 1.3.1 List of Participants

- \*Jeffrey Crabtree, Dewberry
- \*James Filson, Dewberry
- \*Matthew Frerking, Ameren Missouri
- \*Paul Pike, Ameren Missouri
- \*Richard Fleschner, Ameren Missouri
- \*Steve Weiss, Ameren Missouri

\*Participated in field dam inspections.

### 1.3.2 Acknowledgement and Signature

We acknowledge that the management units referenced herein at Meramec Power Station have been assessed on September 29, 2010.



Jeffrey Crabtree, P.E. MO E-2001000889  
6/1/2011



James Filson

# FINAL

## 2.0 DESCRIPTION OF THE COAL COMBUSTION WASTE MANAGEMENT UNIT(S)

### 2.1 LOCATION AND GENERAL DESCRIPTION

The Meramec Power Station (Meramec PS) is physically located north of the confluence of the Mississippi and Meramec River on the southern point of St. Louis County, Missouri, approximately 2.8 miles southeast of Arnold. The Meramec PS is located on Fine Road, Saint Louis, Missouri 63129. The Missouri Pacific railroad is to the southeast of Meramec PS. See Appendix A – Doc. 1.1 for location of the Meramec PS on an aerial map.

Meramec PS has ten impoundments used for managing coal combustion waste (CCW) that are designated as Retention Pond (Pond 1), Old Fly Ash Pond #489 (Pond 2), New Fly Ash Pond #498 (Pond 3), Bottom Ash Pond #493 (Pond 4), Bottom Ash Pond #492 (Pond 5), Bottom Ash Pond #496 (Pond 6), Fly Ash Pond #494 (Pond 7), Fly Ash Pond #495 (Pond 8), Fly Ash Pond #490 (Pond 9), Fly Ash Pond #491 (Pond 10).

A single perimeter levee creates the impoundment around the west and south sides, and ties into high existing ground on the northeast and southeast side. The perimeter levee forms the embankments of Pond 1, 2, 4, 7, and 8. A private railroad embankment is within the perimeter levee of the plant, and connects to the Missouri Pacific railroad. No offsite drainage enters the impoundment. (Note: The terms “dike” and “dam” are used interchangeably in this report, as are the terms “pond” and “basin.”)

The Meramec PS ponds are characterized as follows:

- Pond 1 is active and receives surface stormwater and discharge from Ponds 3 and 4 .
- Pond 2 is active and receives fly ash and wastewater residual wastes.
- Pond 3 is active, receives fly ash from coal-fired units, and discharges into the Retention Pond.
- Basins designated as Bottom Ash Ponds (Ponds 4, 5, and 6) are in series, and receive bottom ash from coal-fired units, which discharge into the Retention Pond.
- Four inactive fly ash ponds (Ponds 7, 8, 9, and 10) are filled to capacity with coal combustion ash and are no longer active.

See Appendix A – Doc. 1.2 for relative locations of the basins on an aerial view map of the Meramec PS. The basins highlighted in yellow are currently active. Numbered bullets correspond to the location of the photos shown in Section 5.3.

**Pond 1** has a surface area of approximately 0.7 acres. The pond is an incised pond with a perimeter dike. The northwest portion of the dike is a relatively short section of outer perimeter levee. The edge of water within the pond is approximately 30 feet from the centerline of the perimeter levee. The design top elevation of the perimeter levee is 418.0 feet (Appendix A – Doc. 1.3). According to the August 2007 Ameren UE Dam Inventory and Inspection Program Phase I Presentation of Field Observation, Analysis and Recommendations, the lowest top of dam elevation - the top of the perimeter levee at Pond 1- is 414.3 feet; the lowest elevation of the

# FINAL

outside toe adjacent to the embankment is 389.6 feet (Reitz & Jens, Inc., 2007). The dike is slightly lower than the perimeter levee; it is noted on furnished drawings (Appendix A – Doc. 1.3) to be at an elevation of 416.7 feet at the drainage structure between Ponds 1 and 3, and Ponds 1 and 7. The bottom elevation of Pond 1 is unknown but appears to have been 396.0 feet, based on design information on the furnished drawings (Appendix A – Doc. 1.3). Approximate height of the perimeter dike at Pond 1 is 25 feet according to the November 2010 Ash Pond Dam Stability Analysis conducted by Reitz & Jens, Inc. (Reitz & Jens, Inc., 2010).

The Pond 1 retention pond is an unlined basin that receives onsite surface runoff from Ponds 7 and 8, and discharge from Ponds 3 and Pond 4. Pond 1 was designed to be used for water treatment and chemical stabilization.

**Pond 2** has a surface area of approximately 17.6 acres. The pond is diked and bound on the southwest by a relatively short section of the outer perimeter levee. According to furnished drawings (Appendix A – Doc. 1.3), the design top elevation of the perimeter levee is 420.0 feet and the elevation of the top of the concrete base of the outfall structure is 398.0 feet. The bottom elevation of Pond 2 according to furnished drawings (Appendix A – Doc.1.3) is 400.0 feet. Approximate height of the perimeter dike at Pond 2 is 24.5 feet according to the November 2010 Ash Pond Dam Stability Analysis conducted by Reitz & Jens, Inc. (Reitz & Jens, Inc., 2010).

The Pond 2 ash pond is a lined basin that receives onsite surface runoff, fly ash, bottom ash, and wastewater residual wastes. Overflow from Pond 2 discharges into the deactivated Pond 8 fly ash pond. Pond 2 is used for fly ash sedimentation, water treatment, and chemical stabilization.

**Pond 3** has a surface area of approximately 13.5 acres. The pond is an incised pond with a perimeter dike, bound on the northeast by the bottom ash ponds, the southwest by the deactivated Pond 7, and to the southeast by the deactivated Pond 9. According to furnished drawings (Appendix A – Doc. 1.3), the design top elevation of the perimeter dike is 425.0 feet and the elevation of the bottom of Pond 2 is 400.0 feet. Thus, the maximum height of the perimeter dike at Pond 3 is approximately 25 feet above the outside toe. The bottom elevation of Pond 3 according to furnished drawings (Appendix A – Doc. 1.3) is 395.0 feet. Thus, the dike may approach a 30-foot height above the Pond 3 bottom.

The Pond 3 ash pond is a lined basin that receives fly ash. Discharge from Pond 3 flows into the Pond 1 retention pond.

Bottom Ash Ponds (**Ponds 4, 5, and 6**) have a combined surface area of approximately 14 acres. Coal combustion residue is sluiced into Pond 6. Drainage from Pond 6 to Pond 4 is conveyed through excavated interior ditches within the ash. Pond 4 is a partially incised pond bound on the west by a relatively short section of the outer perimeter levee. The internal rail road embankment crosses through Pond 4 from the west to the east corner. The incised Ponds 5 and 6 are bound on the northeast by the internal rail road embankment. According to a furnished drawings (Appendix A – Doc. 1.3), the design top elevation of the perimeter levee is 411.5 feet, and Pond 3 embankment dike between Ponds 3 and 4 is at an elevation of 418.0 feet. The

# FINAL

elevation of the top of the abandoned outfall pipe is 397.4 feet. Thus, the maximum height of the perimeter levee at Pond 4 is 14.1 feet above the outside toe. Ameren Missouri has listed the maximum height of the perimeter levee as 25 feet. The bottom elevation of Pond 4 is 398.0 feet, based from the May 2010 Steam Electric Questionnaire (OMB Control Number: 2040-0281).

The Ponds 4, 5, and 6 ash ponds are unlined basins that receive bottom ash. Discharge from Pond 4 discharges into Pond 1 retention pond.

**Pond 7** and **Pond 8** are diked and bound on the west by the outer perimeter levee. Pond 7 is bound by Pond 8 to the south, and to the east by the plant structures, Pond 1 and Pond 3. Ponds 7 and 8 are filled to capacity by fly ash and are no longer active. The southern portion of Pond 7 is currently used for coal storage. Approximate height of the perimeter dike at Pond 7 is 20.8 feet according to the November 2010 Ash Pond Dam Stability Analysis conducted by Reitz & Jens, Inc. (Reitz & Jens, 2010).

Incised ponds, **Pond 9** and **Pond 10**, are filled and deactivated. Presently, the filled and deactivated areas of the ponds support plant equipment, a portion of the internal railroad tracks, and coal storage. Pond 9 is at the center of the site and is bound on the northwest by Pond 3. Pond 10 is bound on the southwest by Pond 2 and the coal storage area on the southeast.

## 2.2 SIZE AND HAZARD CLASSIFICATION

In the following paragraphs, a hazard potential determination is given on the basis of the Federal Emergency Management Agency (FEMA) hazard potential classification, which has been adopted by USEPA; this classification system and the hazard potential determination and basis are presented on the field observation checklists for the Meramec PS CCW ponds included in Appendix B. The classification for size is given on the basis of the USACE Recommended Guidelines for Safety Inspection of Dams ER 1110-2-106 criteria, based on the height of the embankment and the impoundment storage capacity.

Physical data for the six ponds below are summarized in Table 2.1. For each of the six ponds no dwellings are downstream of the levee, therefore the levee should be classified Environmental Zone Class III per the MDNR criteria for Environmental Zone classification (Table 2.2). The levee currently has an undetermined hazard potential rating. Failure of the levee would discharge mostly water and some CCW into a tributary to the Meramec River. The failure would not likely cause loss of life, but would cause relatively minor environmental damage. Therefore, per the USEPA classification (Table 2.3) each pond levee should be given a Low (Class III) Hazard Potential Classification, but it should be reviewed periodically to evaluate status of CCW stored in the basin. The USACE size classification is presented in Table 2.4. For each of the six ponds the classification for size, based on the height of the embankment and the basin storage capacity, is Small.

*Pond 1* – Maximum dam height is 19.5 feet, according to furnished information. The total storage capacity is 10 acre-feet. The amount of CCW stored in Pond 1 is minor.

# FINAL

*Pond 2* - Maximum dam height is 24.5 feet, according to furnished information. The total storage capacity is 300 acre-feet.

*Pond 3* - Maximum dam height is 25 feet, according to furnished information. The total storage capacity is 230 acre-feet.

*Ponds 4, 5, & 6* - Maximum dam height is 25 feet, according to furnished information, but it appears to be more on the order of 14.1 feet, as previously discussed. The total combined storage capacity of Ponds 4, 5, and 6 is 280 acre-feet.

	Pond 1	Pond 2	Pond 3	Ponds 4, 5, & 6
<b>Dam Height</b>	25' **	25' **	25' **	25' **
<b>Crest Width</b>	15'	15'	15'	10'
<b>Length</b>	~79'***	~854'***	~3,320'	~679'***
<b>Side Slopes (inside)</b>	1.5:1*, 3:1	3:1	4:1	---
<b>Side Slopes (outside)</b>	1.5:1	3:1	3:1	2:1
<b>Hazard Classification****</b>	Class III (Low)	Class III (Low)	Class III (Low)	Class III (Low)

\*Embankment slope above incised elevation.

\*\*Based on data in Ameren Missouri's response to EPA's RFI dated March 26, 2009 (See Doc. 1.4 of Appendix A); review of furnished data indicates 19.5' for Pond 1, and 24.5' for Pond 2.

\*\*\*Perimeter levee embankment length; total perimeter levee length is approximately 5,400'.

\*\*\*\*Based on available information and USEPA classification

<b>Class I</b>	10 or more permanent dwellings or any public building downstream.
<b>Class II</b>	1-9 permanent dwellings, 1 or more campgrounds with permanent water, sewer and electrical services or 1 or more industrial buildings downstream.
<b>Class III</b>	Everything else.

MDNR Division 22 Reservoir Safety Council Rules and Regulations.

# FINAL

Table 2.3: Hazard Potential Classification	
Category	Hazard Potential
<b>High Hazard (Class I)</b>	Dams located where failure will likely cause loss of life or serious damage to home(s), industrial and commercial facilities, important public utilities, main highway(s) or railroad(s).
<b>Significant Hazard (Class II)</b>	Dams located where failure will not likely cause loss of life but may damage home(s), industrial and commercial facilities, secondary highway(s) or railroad(s) or cause interruption of use or service of relatively important public utilities.
<b>Low Hazard (Class III)</b>	Dams located where failure may cause minimal property damage to others. Loss of life is not expected.

USEPA Hazard Potential Classification

Table 2.4: Size Classification		
Category	Impoundment	
	Storage (Ac-ft)	Height (ft)
<b>Small</b>	50 and < 1,000	25 and < 40
<b>Intermediate</b>	1,000 and < 50,000	40 and < 100
<b>Large</b>	> 50,000	> 100

USACE ER 1110-2-106

## 2.3 AMOUNT AND TYPE OF RESIDUALS CURRENTLY CONTAINED IN THE UNIT(S) AND MAXIMUM CAPACITY

The amount of CCW residuals currently stored in the units and maximum capacities are summarized in Table 2.5.

*Pond 1* - Based on information from Ameren Missouri, this basin contains a minimal amount of fly ash and bottom ash deposited over 33 years. This basin is currently active and remaining storage volume is unknown. The total storage capacity is 10 acre-feet. A normal pool of water is maintained at about elevation 405.0 feet.

*Pond 2* - Based on information from Ameren Missouri, this basin contains fly ash, bottom ash, and wastewater residual wastes deposited over 10 years. This basin is currently active and remaining storage volume varies due to the dredging of ash. A total of 260 acre-feet of fly ash and bottom ash material were contained within Pond 2, according to the Ameren Missouri response to EPA's RFI dated March 26, 2009. As of 2009, Pond 2 had an estimated 13 percent remaining storage capacity. Expected closure for Pond 2 is 2012, based on the May 2010 Steam Electric Questionnaire. A normal pool of water is maintained at about elevation 416.5 feet.

# FINAL

*Pond 3* - Based on information from Ameren Missouri, this basin contains fly ash deposited over 7 years. This basin is currently active and remaining storage volume varies due to the dredging of ash. A total of 190 acre-feet of fly ash material is contained within Pond 3, according to the Ameren Missouri response to EPA's RFI dated March 26, 2009. As of 2009, Pond 3 had an estimated 17 percent remaining storage capacity. Closure for Pond 3 is estimated to be 2014, based on the May 2010 Steam Electric Questionnaire. A normal pool of water is maintained at about elevation 418.0 feet.

*Ponds 4, 5 & 6* - Based on information from Ameren Missouri, this basin contains bottom ash deposited over 60 years. These basins are currently active and remaining storage volume varies due to the dredging of ash. A total of 171 acre-feet of bottom ash material is contained within Ponds 4, 5, and 6 according to the Ameren Missouri response to EPA's RFI dated March 26, 2009. As of 2009, Ponds 4, 5, and 6 had an estimated 39 percent remaining storage capacity. The expected closure for Pond 4 is 2014, per the approved May 2010 Steam Electric Questionnaire. A normal pool of water is maintained at about elevation 408.0 feet.

**Table 2.5: Amount of Residuals and Maximum Capacity of Unit\***

	Pond 1	Pond 2	Pond 3	Ponds 4, 5 & 6
<b>Surface Area (acre)</b>	0.7	17.6	13.5	14
<b>Current Volume of Stored Ash (acre-feet)</b>	minimal	260	190	171
<b>Total Storage Capacity (acre-feet)</b>	10	300	230	280

\*Based on data in Ameren Missouri response to EPA's RFI dated March 26, 2009

## 2.4 PRINCIPAL PROJECT STRUCTURES

### 2.4.1 Earth Embankment Dam

Based on boring information for Pond 7 piezometer installation (Appendix A – Doc. 1.5), the perimeter levee at Pond 7 is constructed of silty clay, clay with silt, sand layers, clay with gravel and sand with gravel. The source and type of soils used for the original fill is unknown. The perimeter levee forming the impoundment is approximately 5,400 feet. The ponds are impounded by a perimeter levee and do not receive offsite surface runoff. Doc. 1.3 of Appendix A reflects embankment geometry summarized below.

*Pond 1* – A perimeter dike along the north, east, and south sides of Pond 1 ties into the perimeter levee on the northwest side. The basin does not receive offsite surface runoff. Runoff from Ponds 7 and 8 is ditched to Pond 1. Discharges from Pond 3 and Pond 4 flow into Pond 1. The embankment around the basin was raised using compacted clay as fill material. Perimeter levee elevations were raised to an elevation of 418.0 feet, and the perimeter dike to 416.7 feet. Operator records indicate the lowest top of levee elevation is at 414.0 feet. The geometry

# FINAL

of Pond 1 consists of 3 horizontal (H) to 1 vertical (V) inside incised slope, 1.7 H to 1 V inside embankment slope, and 1.5 H to 1 V outside slope. Representative sections of the perimeter levee and the perimeter dike are shown in Exhibit 1. As shown in this exhibit, the perimeter levee is 15-foot wide, and the perimeter dike is 8-foot wide. The designs of the perimeter dike and levee are shown in Appendix A – Doc. 1.3. The pond is not lined and no internal drainage measures or toe drains were included in the embankment design for seepage control.

*Pond 2* – A perimeter dike along the northeast and southwest of Pond 2 ties into the perimeter levee on the south side and high ground on the southeast side. The basin receives surface runoff from the power station plant facilities area and the basin area. Overflow from Pond 2 discharges into Pond 8 and ultimately flows into Pond 1. The perimeter levee and dike embankment around the basin was raised to an elevation of 420.0 feet. Operator records indicate the lowest top of levee elevation is at 420.2 feet. Compacted ash fill material was used to construct the berm over an existing soil embankment on the interior side of the pond. Pond 2 is lined with 60 MIL HDPE slope liner and a 40 MIL HDPE bottom liner. The geometry of Pond 2 is 3 H to 1 V inside slope, and 1.9 H to 1 V outside slope. Representative sections of the perimeter levee and the perimeter dike are shown in Exhibit 2. As shown in this exhibit, the berms are 15-foot wide. The designs of the perimeter dike and levee are shown in Appendix A – Doc. 1.3. There are no internal drainage measures or toe drains included in the embankment design for seepage control.

*Pond 3* – The basin is an incised pond with a perimeter dike. The basin does not receive surface runoff from outside the basin area. Drainage area for the basin is the basin itself. Pond 3 discharges into Pond 1. Pond 3 is lined with 60 MIL HDPE slope liner and 40 MIL HDPE bottom liner. The geometry of Pond 3 consists of 2.5 horizontal (H) to 1 vertical (V) outside slope, and 4 H to 1 V inside slope. The top of the perimeter dike embankment around the basin is at elevation of 423.0 feet. Representative sections of the perimeter dike are shown in Exhibit 3. As shown in this exhibit, the perimeter dike is 15-foot wide. The design of the perimeter dike is shown in Appendix A – Doc. 1.3. There were no internal drainage measures or toe drains included in the embankment design for seepage control.

*Ponds 4, 5, & 6* – Pond 4 is bound on the northwest by the perimeter levee, and on the southwest by Pond 3 dike. Ponds 6 and 5 are combined, and a cross dike divides Pond 5 from Pond 4. Flow is conveyed from Pond 5 to Pond 4. The embankment from the Meramec PS internal railroad crosses from the west corner to the east corner of Pond 4. Culvert crossings control flow within Pond 4. Culvert crossings were not observed during the site visit due to heavy vegetation around Pond 4.

# FINAL

The drainage area for the basin is the surface area of Ponds 4, 5, and 6. Pond 4 discharges into Pond 1. A portion of the perimeter levee was raised to an elevation of 411.5 feet. Compacted clay was used for fill material to raise the top of the levee. Operator records indicate the lowest top of levee elevation is at 417.4 feet. The geometry of Pond 4 consists of 2 H to 1 V outside slope. A representative section of the perimeter levee is shown in Exhibit 4. As shown in this exhibit, the perimeter levee is 10-feet wide. The design of the perimeter levee is shown in Appendix A – Doc. 1.3. The ponds are not lined and no internal drainage measures or toe drains were included in the embankment design for seepage control.

## 2.4.2 Outlet Structures

*Pond 1* – Drainage from Pond 3 and Pond 4 are discharged into Pond 1. Water passes through outlet works located at the northwest embankment of Pond 1. The outlet works consist of a skimmer, a seal boom fastened to three pipes at 7.3 feet from the center of the riser pipe which drains to a 24-inch diameter carbon steel (CS) discharge pipe. The discharge pipe projects from the perimeter levee into the tributary to the Meramec River with a 90 degree bend at the end. The skimmer box is used to block entry of floating ash particles. Inverts of the outlet are shown in Appendix A – Doc. 1.3.

The water in the basin, based on operator records, was at a level of 404.0 feet, which is 10.0 feet below the perimeter dam crest. Based on the lowest dam crest elevation based on operator records is 414.0 feet. Basin Information Checklist was provided by Ameren Missouri at the time of site visit, see Appendix A Doc. 1.6.

*Pond 2* - The outlet works are located near the northwest corner of the basin and consist of a 10-ft diameter corrugated steel decant structure outlet with seal booms. The decant tower is shown in Appendix A – Doc. 1.3. The outlet pipe is a 36-inch high density polyethylene (HDPE) pipe that extends through the west portion of the perimeter levee and discharges into the Meramec River. The top of the decant tower is at elevation 420 feet, the same as the top of dam elevation, and is accessed by a steel footbridge extending from the dam crest to the top of the decant tower. The level of water in the basin recorded from a staff gauge at the time of the site visit was at elevation 416.5 feet, which is 3.5 feet below design dam crest. The lowest dam crest elevation, based on operator records, is 420.2 feet; available freeboard is 3.7 feet. Basin Information Checklist was provided by Ameren Missouri at the time of site visit, see Appendix A Doc. 1.6.

Overflow from Pond 2 drains into Pond 7 via four 12-inch diameter polyvinyl chloride (PVC) pipes, and ultimately into Pond 1.

# FINAL

*Pond 3* – Drainage from Pond 3 is discharged into Pond 1. Water passes through outlet works located at the northwest dike of Pond 3. Outlet works consist of a skimmer, and a drop inlet with a 24-inch HDPE pipe. The discharge pipe projects into the retention pond, Pond 1. The skimmer box is used to block entry of floating debris and ash particles. Inverts of the outlet are shown in Appendix A – Doc. 1.3.

The water in the basin based on operator records was at a level of 418 feet, which is 5.0 feet below the perimeter dam crest. Basin Information Checklist was provided by Ameren Missouri at the time of site visit, see Appendix A Doc. 1.6.

*Pond 4* – Drainage from Pond 4 is discharged into Pond 1. Water passes through outlet works located at the northwest dike of Pond 4. The outlet works consist of a drop inlet and an 18-inch diameter CS pipe. The discharge pipe projects into the retention pond, Pond 1. Inverts of the outlet are shown in Appendix A – Doc. 1.3. Inverts and structure information for culvert crossings were not provided.

The water in the basin based on operator records was at a level of 408.0 feet, which is 3.5 feet below the design perimeter dam crest. Lowest dam crest elevation based on operator records is 420.2 feet, available freeboard is 9.4 feet. The Basin Information Checklist was provided by Ameren Missouri at the time of site visit, see Appendix A Doc. 1.6.

## **2.5 CRITICAL INFRASTRUCTURE WITHIN FIVE MILES DOWN GRADIENT**

Using Google Maps dated 2010, no critical infrastructure was observed within a 5-mile radius. A regional map showing Meramec PS and ash ponds in relationship to “critical” infrastructure within a 5-mile radius is included as Doc. 1.1 of Appendix A. “Critical” infrastructure includes facilities such as schools and hospitals. There are 52 schools and no hospitals located within the 5 mile radius. These facilities are noted on the 5-mile radius map. In general, the confluence of the Meramec River and Mississippi River is immediately downstream of the facilities.

Flood impacts from postulated failure of the perimeter levee at the Meramec PS would primarily impact the Meramec River, but could impact the Mississippi River.

# FINAL

## 3.0 SUMMARY OF RELEVANT REPORTS, PERMITS AND INCIDENTS

The Meramec PS levee (dike) is not regulated for dam safety by a federal or state agency, and currently does not have federal or state hazard classifications. The CCW Pond 1 and Pond 2 discharges are regulated by the Missouri Department of Natural Resources (MDNR) Division of Environmental Quality. Meramec PS dam height is less than 35 feet (i.e., 25 ft) therefore the dams do not require MDNR registration permits for continued operation.

### 3.1 SUMMARY OF REPORTS ON THE SAFETY OF THE MANAGEMENT UNIT(S)

Ameren Missouri created an internal Dam Safety Group composed of civil and geotechnical engineers supervised by a professional engineer. The group implements and oversees the Ameren Missouri Dam Safety Program. Ameren Missouri also developed an Emergency Implementing Procedure (EIT) for emergencies involving dam failures or loss of integrity. The EIT contains response procedures to three severity levels of incidents.

*Pond 1* – Annual inspections are conducted by Ameren Missouri. No major problems were observed for the 2008 and 2009. No significant deterioration was indicated in the documentation reviewed. A 2007 inspection report, conducted as a part of the AmerenUE Dam Inventory and Inspection Program, identified retention wall and upstream slope failures at Pond 1 (Reitz & Jens, Inc., 2007).

*Pond 2* – Weekly inspections conducted by Ameren Missouri were provided for the period September 7, 2010 through September 23, 2010. Wash outs and erosion along several areas on the side of the access roads were identified as needing immediate maintenance. Annual inspections are conducted by Ameren Missouri. No major problems were observed for the 2008 and 2009 inspections. No significant deterioration was indicated in the documentation reviewed. The 2007 inspection report indicated no significant deterioration for Pond 2 in the documentation reviewed (Reitz&Jens, Inc., 2007).

*Pond 3* – Annual inspections are conducted by Ameren Missouri. No major problems were observed for 2008 or 2009. No significant deterioration was indicated in the documentation reviewed. The 2007 inspection report indicated no significant deterioration for Pond 3 in the documentation reviewed (Reitz & Jens, Inc., 2007).

*Pond 4* – Annual inspections are conducted by Ameren Missouri. No major problems were observed for 2008 or 2009. It is noted that seepage was reported in both inspection reports. No significant deterioration was indicated in the documentation reviewed. The 2007 inspection report indicated no significant deterioration for Pond 4 in the documentation reviewed (Reitz & Jens, Inc., 2007).

# FINAL

## 3.2 SUMMARY OF LOCAL, STATE AND FEDERAL ENVIRONMENTAL PERMITS

The Meramec PS is currently regulated under the State Operating Permit No. MO-0000361 (see Doc. 1.7 of Appendix A). This permit was effective on May 19, 2000 and expired on May 18, 2005, according to the furnished documentation. Information regarding the pursuit or receipt of permit renewal was not provided.

The facilities at the Meramec PS are regulated for water quality by the Missouri Department of Natural Resources (MDNR) Division of Environmental Quality. Water sampling at the outlet structure of Ponds 1 and 2 are conducted to monitor the quality of the discharge that reaches the Meramec River, and ultimately the Mississippi River.

## 3.3 SUMMARY OF SPILL/RELEASE INCIDENTS (IF ANY)

There have been no reported spill/release incidents at the Meramec PS CCW basins.

# FINAL

## 4.0 SUMMARY OF HISTORY OF CONSTRUCTION AND OPERATION

### 4.1 SUMMARY OF CONSTRUCTION HISTORY

#### 4.1.1 Original Construction

Original construction records are not available, and design dates on the provided Meramec PS design plans are illegible (see Appendix A, Doc. 1.3). Therefore, little is known of original construction or the sequence of construction of the CCW ponds, other than the year each pond was brought online.

*Pond 1* – The basin was brought online in 1977. The incised basin was constructed on the northwest side of the plant within a portion of the original Pond 3. A perimeter dike around the basin ties into the outer perimeter levee. It is bounded on the northeast side by a filled portion of the original Pond 3, on the northeast side by the outer perimeter levee, on the southwest side by a filled portion of the original Pond 7, and on the southeast side by the internal railroad. The lowest elevation on the basin floor is approximately 396.0 feet. The basin was not lined.

*Pond 2* – The basin was brought online in 2000. According to provided plans (Appendix A, Doc. 1.3), stormwater from Pond 2 originally was drained into Pond 8. The diked basin was constructed on the southeast side of the plant. It is bounded on the northwest side by Pond 8, southeast side by the internal railroad, the west by the outer perimeter levee, and northeast side by the filled Pond 10 and the coal storage area. The lowest elevation on the basin floor is approximately 400.0 feet.

*Pond 3* – The basin was brought online in 2003. The incised basin was constructed on the west side of the plant within the original Pond 3 location. It is bounded on the northwest side by the internal railroad, southwest side by Pond 7, the east by Ponds 4 and 5, southwest side by the coal storage area, and the south by the filled Pond 9. The lowest elevation on the basin floor is approximately 395.0 feet.

*Ponds 4, 5, & 6* – The basin was brought online in the 1950s. The basin was constructed adjacent to high ground to the east. The basin is bounded on the east by an access road, on the northwest side by the perimeter levee, on the southwest by Pond 3 and filled original Pond 9, and on the south by the plant facilities. The lowest elevation on the basin floor is unknown. The basin was not lined.

*Pond 7* – The basin was brought online in 1965. The basin was constructed at the northwest side of the plant. The basin is bounded on the east side by Pond 3 and Pond 9, on the west side by the perimeter levee, and on the south by Pond 8. The lowest elevation on the basin floor is unknown.

# FINAL

*Pond 8* – The basin was brought online in 1965. The basin was constructed between Pond 2 and Pond 7. The basin is bounded on the east side by Pond 10, on the west side by the perimeter levee, on the north by Pond 7, and on the south by Pond 2. The lowest elevation on the basin floor is unknown.

*Pond 9* – The basin was brought online in 1965. The basin is bounded on the north side by Pond 3, on the west side by Pond 7, on the south by Pond 10, and on the east by Pond 6. The lowest elevation on the basin floor is unknown.

*Pond 10* – The basin was brought online in 1965. The basin is bounded on the east side by Pond 2, on the north side by Pond 9, on the south by a coal storage area, and on the west by plant facilities. The lowest elevation on the basin floor is unknown.

#### **4.1.2 Significant Changes/Modifications in Design since Original Construction**

*Pond 1* – Based on design information provided (Appendix A, Doc. 1.3), the perimeter levee has been raised to elevation 418.0 feet and the perimeter dike to 416.7 feet. Pond 1 receives surface runoff from Ponds 7 and 8, discharge from Pond 3 and Pond 4, and overflow from Pond 2.

*Pond 2* – Based on design information provided (Appendix A, Doc. 1.3), the perimeter levee has been raised to elevation 420.0 feet. A decant structure has been installed since original construction, and Pond 2 discharges directly into the Meramec River. Overflow from Pond 2 discharges into Pond 8 and is ultimately ditched into Pond 1.

*Pond 3* – The original basin was filled to capacity. Portions of the original pond support plant equipment and a coal storage area. Pond 1 and the New Fly Ash Pond (Pond 3) are incised within the original Pond 3 basin. Pond 3 discharges directly into Pond 1.

*Ponds 4, 5, & 6* – The original outlet structure to the tributary to Meramec River has been abandoned and discharge is directed into Pond 1 via an 18-inch diameter CS pipe. A portion of the perimeter levee at Pond 4 has been raised to elevation 411.5 feet.

*Pond 7* – The basin has been filled to capacity and is no longer active. The southern portion of the original basin has been converted into a coal storage area. An internal railroad embankment has been constructed along the outer perimeter levee of the basin.

# FINAL

*Pond 8* – The basin has been filled to capacity and is no longer active. A railroad track has been constructed on the dike between Pond 7 and Pond 8.

*Pond 9* – The original basin has been filled to capacity and closed. Presently, the basin area supports plant equipment and a portion of the basin area is used for coal storage. A portion of the filled original pond has been incised for Pond 3.

*Pond 10* – The original basin has been filled to capacity and closed. Presently, the basin area supports plant equipment and internal railroad tracks.

### **4.1.3 Significant Repairs/Rehabilitation since Original Construction**

There have been no significant repairs/rehabilitation made to the Meramec PS basins since the original construction. Slope repairs have been made along the perimeter levee outside slope due to runoff erosion.

## **4.2 SUMMARY OF OPERATIONAL HISTORY**

### **4.2.1 Original Operational Procedures**

The furnished documents do not include the original operational procedures.

### **4.2.2 Significant Changes in Operational Procedures since Original Startup**

No documents were provided to indicate that basic operational procedures have significantly changed since original startup.

### **4.2.3 Current Operational Procedures**

The Meramec PS CCW ponds are operated and monitored for water quality under a MDNR approved operating permit.

*Pond 1* operates mainly as a clarifying pond. Pond 3 and Pond 4 CCW basins decant structures discharge into the basin. A series of ditches directs surface runoff into Pond 1. Water quality is monitored for acceptable pH levels prior to discharge from Pond 1.

*Pond 2* operations consist of fly ash sedimentation, water treatment, and chemical stabilization. Ash waste (predominantly bottom ash and fly ash) is mixed with water at the plant and the slurry is pumped to the basin. The CCW slurry is pumped into excavated channels within the basin and gravity settling separates the fine from the coarser materials. Once the channels become full, the ash is excavated. The water flows through channels excavated in the ash to a pond area at the west end of the basin. At the outlet structure in the northwest corner of Pond 2, the water flows to a 10.0-ft diameter corrugated pipe decant structure,

# FINAL

then through a 36-in diameter HDPE pipe to the Meramec River. Water quality is monitored for acceptable pH levels prior to discharge from Pond 2.

*Pond 3* operation consists of mixing fly ash waste with water at the plant and pumping the slurry to the basin. The CCW slurry is pumped into excavated channels within the basin and gravity settling separates the fine from the coarser materials. Once the channels become full, the ash is excavated. The water flows through channels excavated in the ash to a pond area at the northwest end of the basin. At the outlet structure in the northwest corner of Pond 3, the water flows through a 24-inch diameter HDPE pipe to Pond 1.

*Ponds 4, 5, & 6* operation consists of mixing bottom ash waste with water at the plant and pumping the slurry to the basins. The CCW slurry is pumped into excavated channels within Ponds 5 and 6, and gravity settling separates the fine from the coarser materials. Once the channels become full, the ash is excavated. The water flows through channels excavated in the ash to a pond area at Pond 4. At the outlet structure in the northwest corner of Pond 4, the water flows through an 18-inch diameter CS pipe to Pond 1.

#### **4.2.4 Other Notable Events since Original Startup**

Based on furnished information, there are no notable events since original startup of Meramec PS basins to report at this time.

# FINAL

## 5.0 FIELD OBSERVATIONS

### 5.1 PROJECT OVERVIEW AND SIGNIFICANT FINDINGS

Dewberry personnel Jeffrey Crabtree, PE and James Filson, PE collected available data and documents and made field observations during a site visit on September 29, 2010, in company with the participants listed in Section 1.3. The design engineer of record for Meramec PS CCW ponds was not present or available to assist with answering questions about these basins.

The site visit began at 1:30 PM. Weather conditions during the visit were 85 degrees Fahrenheit, sunny, and dry. Photographs were taken of conditions observed. Photographs referenced below are contained in Section 5.3 following the text descriptions.

**The overall visual assessment is that the earthen levee embankment that impounds the Meramec PS CCW ponds is in good condition.** No visual signs of imminent instability or inadequacy of the principal structures at these basins that would require emergency remedial action were observed. No evidence of past repairs was observed. No significant findings were noted.

### 5.2 PONDS

#### 5.2.1 Embankment Dam and Basin Area

##### Crest

A single perimeter levee creates the impoundment around the west and south sides, and ties into high existing ground on the northeast and southeast side. The outer slope of the levee is tiered. The second tier, the top of the crest, is enclosed within a chain linked fence. Typical views of the crest are shown in Photos 1 and 2. The first tier, the crest of the access road, is on the outer perimeter of the crest and is accessible by automobile from the Meramec PS plant. The gravel and ash-surfaced access road along Pond 2 was observed to be in good condition (Photos 3 and 4). Evidence of a repaired erosion area along the embankment is shown in Photo 5. No major depressions, sags, tension cracks or other signs of significant settlement or mass soil movement were observed. No tension cracks which might suggest soil shear failure were observed in the crest. Gulley erosion was observed at the edge of the first tier crest and downstream slope of the access road and the edge of the second tier crest, see Photos 6 to 8.

##### Outside Slope and Toe

The outside slope of the second tier of the levee embankment was observed to be maintained free of grass and vegetation, see Photos 1 and 6. The outside slope of the first tier of the levee embankment at Pond 2 is visible in Photos 9 to 11. As shown, the grass and woody vegetation on the outside slope typically was

# FINAL

observed to be unmaintained. The outside slope of the first tier of the levee embankment at Pond 8 is visible in Photo 12. As shown, the grass on the outside slope typically was observed to be unmaintained. Evidence of slope erosion repair was observed. The outside slope of the levee embankment at Pond 1 is visible in Photo 13. As shown, the grass and vegetation on the outside slope typically was observed to be unmaintained. The lower part of the outside slope was observed to be submerged by the water. No areas of significant erosion were observed. No obvious signs of slumps, slides, bulges, tension cracks, seepage, or animal holes were observed.

A perimeter access road at the toe of the levee embankment was submerged at the time of inspection. The submerged perimeter access road is shown in Photos 14 to 19. Photo 14 shows the submerged access road at the toe crossing under the railroad bridge. Photos 20 to 24 show a relatively flat area, approximately 5 feet wide, between the toe of the embankment and the tree line at the outside toe of Pond 7. Organic debris was observed at the outside toe of the levee embankment of Pond 7. A tributary to Meramec River is at the downstream toe along the northwest levee embankment, shown in Photos 25 and 26. The toe of the levee is submerged. Photo 26 shows evidence of outside slope erosion repair. Minor seepage was observed at the outside toe of Pond 4. Photo 27 shows cattails at the outside toe, indicating standing water or consistent moist conditions. No active erosion was observed along the outside toe.

## Inside Slope and Basin Area

The inside slope of Pond 1 perimeter dike was observed to be covered in tall vegetation on three sides, and sparse vegetation on the southeast side. Erosion was observed in the inside slope of the perimeter dike. Photo 28 shows wooden retaining wall failure on the west inside slope. The water surface elevation at the time of the inspection was 405.0 feet.

The inside slope of Pond 2 perimeter dike is lined with 60 MIL HDPE slope liner, shown in Photos 29 to 32. Sparse vegetation growth is observed on the slope liner, see Photo 31. Ash build-up was observed at the south side of the pond shown in Photos 29, 30, and 32. The surface of the exposed ash fill is generally covered with brush and woody vegetation. The water surface elevation at the time of the inspection was 416.5 feet. No significant erosion was noted.

The water surface elevation in Pond 3 at the time of the inspection was 413.0 feet. Photo 34 shows the filled fly ash area between Pond 1 and Pond 3. Filled fly ash area was a part of the original Pond 3.

The inside slope of the Pond 4 perimeter embankments were observed to be generally covered in tall vegetation on three sides. The inside slope of the railroad embankment crossing the pond from the west to the east corner of Pond 4

# FINAL

was observed to be generally covered in tall vegetation. See Photos 34 to 39 for inside slope and pond area. Ash build up was not observed within Pond 4 basin area. The water surface elevation within Pond 4 at the time of the inspection was 408.0 feet. Photo 40 shows ash build up with sparse brush vegetation within Ponds 5 and 6. No significant erosion was noted.

The inside basin area of Pond 8 has been filled to capacity with fly ash and is no longer active. Photo 41 shows ash build-up with sparse brush vegetation within Pond 8. No significant erosion was noted.

## Abutments and Groin Areas

The abutment and groin areas where the perimeter levee ties into high ground was not observed.

### 5.2.2 Outlet Structures

#### Overflow Structure

*Pond 1* outflow structure consists of a 24-inch diameter carbon steel (CS) pipe drop inlet with a seal boom skimmer. Photo 42 shows the skimmer and inlet of the outflow structure. A steel footbridge access to the structure is shown in Photo 28. There was no sign of clogging and the water exiting the outlet was observed to be flowing clear.

*Pond 2* outflow structure consists of a 10-ft diameter corrugated steel decant structure outlet with seal booms. Photo 43 shows the skimmer, decant tower, and the steel footbridge access to the structure. Pond 2 has four 12-inch PVC pipes that convey overflow from Pond 2 into Pond 8. Photo 32 shows the PVC pipes that pass through the northwest perimeter dike. There was no sign of clogging and the water exiting the outlet was observed to be flowing clear.

*Pond 3* outflow structure consists of a drop inlet with a 24-inch HDPE and a skimmer. Pond 3 outflow structure was not observed.

*Pond 4* outflow structure consists of a decant structure outlet. Photo 35 shows a portion of the decant structure. Observation of the structure was obstructed by tall vegetation.

#### Outlet Conduit

The outlet conduit at Pond 1 is a 24-inch diameter carbon steel (CS) pipe that extends through the perimeter levee and into the tributary to the Meramec River with a 90 degree bend at the end, see Photo 44. The outlet end appeared to be in

# FINAL

good condition and operating normally. There was no sign of clogging and the water exiting the outlet was observed to be flowing clear.

The outlet conduit at Pond 2 is a 36-inch high density polyethylene (HDPE) pipe that extends through the west portion of the perimeter levee and discharges into the Meramec River with an upward bend at the end, see Photos 45 and 46. Photo 47 shows the outlet conduit discharging into a plunge pool. The outlet end appeared to be in good condition and operating normally. There was no sign of clogging and the water exiting the outlet was observed to be flowing clear.

The Pond 3 24-inch HDPE pipe outlet conduit is submerged and was not observed. The outlet structure discharges into Pond 1.

The Pond 4 18-inch diameter CS pipe outlet conduit is submerged and was not observed. The outlet structure discharges into Pond 1.

## Emergency Spillway

There is no emergency spillway.

## Low Level Outlet

There is no low level outlet.

# FINAL

## 5.3 FIELD PHOTOGRAPHS



1. Looking west from access road at levee embankment at Pond 2.



2. Looking east along internal side slope and crest of levee embankment of Pond 2. Note – liner in place.



3. Looking south along embankment between railroad and Pond 2 (#489).

# FINAL



4. Looking Southwest at top of levee embankment of Pond 2 from access road.



5. Repaired erosion area along levee embankment at Pond 8.



6. Looking at runoff erosion along top of levee embankment from runoff at Pond 2.

# FINAL



7. Runoff erosion from edge of crest of access road at Pond 2.



8. Looking at runoff erosion on down side of levee embankment at edge of crest of access road at Pond 8.



9. Looking northwest at outside slope of Pond 2 levee embankment. Note – High water was observed in the Meramec River during site visit. Perimeter access road was submerged.

# FINAL



10. Outside slope of levee embankment at Pond 2. An unknown pipe was observed at the location, see Photo 14.

11. Looking southeast along outside slope of levee embankment of Pond 2. Note - High water was observed in the Meramec River during site visit.



12. Looking at outside slope of levee embankment at Pond 8. Note - Repaired erosion area at edge of crest.

# FINAL



13. Looking northeast along outside slope and toe of the levee embankment along the tributary to Meramec River.



14. Looking at unknown pipe at the outside toe of Pond 2 levee embankment.



15. Looking southeast at railroad bridge. Location of submerged perimeter access road.

# FINAL

16. Looking southeast along perimeter levee embankment. Note - High water was observed in the Meramec River during site visit.



17. Looking southeast at tree line adjacent to submerged perimeter access road.



18. Looking southwest along toe of levee embankment where floodplain is flooded.

# FINAL



19. Looking north at perimeter access road gate. Road under water.



20. Looking south along outside toe of Pond 7.



21. Looking northwest along outside toe and slope of levee embankment of Pond 7. Note - railroad tracks adjacent to top of embankment.

# FINAL



22. Looking northwest along outside toe of levee embankment at Pond 7.



23. Looking north along outside toe of levee embankment at Pond 7.  
Note - gate for perimeter access road is submerged.



24. Looking northeast along outside toe of levee embankment at Pond 7.

# FINAL



25. Looking southwest along Meramec River just outside from Pond 1 (retention pond) outlet.



26. Evidence of repair to outside slope of levee embankment due to erosion.



27. Looking towards Pond 4 (Bottom Ash Pond) at outside toe and slope of levee embankment. Note - Cat tails.

# FINAL



28. Looking southeast at Pond 1 (retention pond).



29. Looking northwest at Pond 2. Note – Unit has a slope liner.



30. Looking north at Pond 2. Note – Unit has a slope liner.

# FINAL



31. Looking at Pond 2 toward coal storage area. Note - liner with some vegetation.



32. Looking north at overflow pipes and coal storage area. Note - pipe in water for taking water samples.



33. Looking at the Pond 3 ("New" Fly Ash Pond) area in the distance and the fill Fly Ash area to the northeast of Pond 1.

# FINAL



34. Looking through railroad track at southeast side of Pond 4 (Bottom Ash Pond).



35. Looking through railroad tracks at southeast side of pond area of Pond 4.



36. Looking north at northwest side of Pond 4.

# FINAL



37. Looking southeast at railroad tracks between northwest & southeast Pond 4.



38. Looking southwest from railroad track at northwest Pond 4.



39. Looking north at southeast Pond 4 from railroad tracks.

# FINAL



40. Looking towards Pond 5 and 6 (Bottom Ash Pond).



41. Looking northeast at completely filled and deactivated Pond 8 (Fly Ash Pond #495).



42. Looking at retention pond inlet.

# FINAL



43. Looking at Pond 2 (#489) inlet structure.



44. Looking northeast at outfall pipe from Pond 1.



45. Looking west at outfall #009 at Pond 2 toward Meramec River.

# FINAL



46. Outfall #009 from Pond 2.



47. Plunge pool at outfall #009.

## 6.0 HYDROLOGIC/HYDRAULIC SAFETY

### 6.1 SUPPORTING TECHNICAL DOCUMENTATION

#### 6.1.1 Floods of Record

Flood record information was not provided for these facilities. The 2007 inspection report referenced the 1995 Federal Emergency Management Agency (FEMA) Mississippi River base flood elevation as 417.4 feet NGVD at the confluence with Meramec River. The 1995 FEMA Flood Insurance Rate Map of the confluence of the Mississippi and Meramec River is shown in Doc. 1.8 of Appendix A. The reported 100-year flood elevation of the Mississippi River at the Meramec PS in Appendix D of the 2004 Army Corps of Engineers (USACE) Upper Mississippi River System Flow Frequency Study is approximately 415.1 feet NGVD (see Doc. 1.9 of Appendix A).

#### 6.1.2 Inflow Design Flood

As previously mentioned, the Meramec PS dam heights are less than 35 feet, and do not require MDNR registration permits. Based on Environmental Zone Classification III, if safety standards closely follow those given in the Missouri dam safety requirements, the spillway design flood (SDF) criterion is the 100-year frequency rainfall event.

#### 6.1.3 Spillway Rating

No spillway ratings were provided for the outlet works.

#### 6.1.4 Downstream Flood Analysis

No downstream flood analysis has been provided. A qualitative analysis based on field observations and review of available data follows.

Failure by flood overtopping would occur at the lowest elevation at the perimeter levee at Pond 1; this scenario would release an insignificant volume of ash into the Meramec River. A breach of the perimeter levee (considered an unlikely scenario at Ponds 1 and 3) at either Pond 2 or Pond 4 would release water into the Meramec River and could release ash into the Meramec River. Ash in the Meramec River would cause minor environmental impact and may disrupt navigation. The water and ash released by a breach of the perimeter dikes within the levee would be contained within the levee embankment.

# FINAL

## 6.2 ADEQUACY OF SUPPORTING TECHNICAL DOCUMENTATION

A summary of the analysis of the ability to safely store and pass the inflow design flood was provided in the 2007 AmerenUE Dam Inventory and Inspection Program – Phase I report by Reitz & Jens, Inc.. Basin elevation-storage curves, spillway rating curves, and a dam break analysis are not available for the basins.

Based on assumptions and variables in the referenced analysis in the 2007 Reitz & Jens, Inc. and current reported storage volumes, Pond 2 dike would be overtopped by the 100-year frequency rainfall event. Overflow from Pond 2 discharges into the retention pond, Pond 1.

Pond 3, if assumptions and variables in the referenced analysis in the 2007 Reitz & Jens, Inc. report are currently valid, is able to safely store and pass the 100-year frequency rainfall event. If the current available storage is less than assumed and/or the normal pool is greater than assumed, then the 100-year frequency rainfall event will overtop the dike and discharge into the retention pond, Pond 1.

The Bottom Ash Ponds (Pond 4, 5, and 6), if assumptions and variables in the referenced analysis in the 2007 Reitz & Jens, Inc. report are currently valid, is able to safely store and pass the 100-year frequency rainfall event. If the normal pool is greater than assumed, then the 100-year frequency rainfall event will overtop the dike and discharge into the retention pond, Pond 1.

Deactivated Ponds 7 and 8 are able to provide overflow storage volume for Pond 1. However, during the 100-year frequency rainfall event, the perimeter dike will be overtopped. Available storage within Pond 1 is less than the total contributing runoff from the 100-year frequency rainfall event.

Based on lowest top of levee elevation and the 2004 USACE 100-year flood elevation of 415.0 feet NGVD, Pond 1, Pond 4, and Pond 7 would be inundated during the 100-year frequency rainfall event.

## 6.3 ASSESSMENT OF HYDROLOGIC/HYDRAULIC SAFETY

The ability to safely store and pass the 100-year frequency rainfall event in the active ponds, based on the summary and assumptions referenced in 2007 AmerenUE Dam Inventory and Inspection Program – Phase I report by Reitz & Jens, Inc., is adequate for Ponds 3, 4, 5, and 6. Pond 1 and Pond 2 are not adequate to store and pass the 100-year frequency rainfall event.

# FINAL

There are no records that address containment of water in the basins during significant flooding events that have occurred. Ameren Missouri did report to Dewberry that during the current 2011 major floods along the Meramec and Mississippi Rivers, there has been no overtopping of the levee and the dikes have held. Based on the history and future downstream slope improvement project, failures of the embankment levees are not anticipated. The CCW ponds appear to have satisfactory hydrologic/hydraulic safety.

## 7.0 STRUCTURAL STABILITY

### 7.1 SUPPORTING TECHNICAL DOCUMENTATION

#### 7.1.1 Stability Analyses and Load Cases Analyzed

No stability analyses were provided for the original design and construction of the perimeter levee. An Ash Pond Dam Stability Analysis was conducted by Reitz & Jens, Inc. in November 2010 after the site visit (Doc 1.10). A subsequent analysis was performed in March 2011 (Doc 1.12).

#### 7.1.2 Design Properties and Parameters of Materials

**Pond 2** – In the 2010 Ash Pond Dam Stability Analysis borings of the embankment consists of fly ash, bottom ash, silty clay, and high plastic clay (Reitz&Jens, Inc., 2010). The embankment soils have a computed friction angle of 29°. Foundation soils of Pond 2 consist of silty and moderate to high plasticity clay. The first 9 feet of the foundation soils have a computed friction angle of 23° to 24°. Underlying the silty and moderate to high plasticity clay soils is clay, silt and sand.

**Pond 7** – In the 2010 Ash Pond Dam Stability Analysis borings of the embankment consists of clay, silty clay, and clayey silt (Reitz&Jens, Inc., 2010). The embankment and the first 6 feet of the foundation soils have a computed friction angle of 23°. Foundation soils consist of silty soft clay. Underlying soils are stiff clay and silty clay with a computed friction angle of 27°. Sand and silt soils were encountered at 22 feet into the foundation soil, computed friction angle of 30°.

**Pond 1 and Pond 3** – In the 2010 Ash Pond Dam Stability Analysis borings of the embankment consists of sandy silt, clayey silt, and silt clay (Reitz&Jens, Inc., 2010). Embankment soils have a computed friction angle of 26°. Foundation soils of Pond 1 and 3 consist of silty clay. The computed friction angle compression of the top 12 feet of the foundation soil is 27°. Underlying soils are stiff clays to clayey silt, silt clay, and sandy silt. The computed friction angle of the underlying soils is 26° to 25°.

#### 7.1.3 Uplift and/or Phreatic Surface Assumptions

Phreatic surface assumptions are taken from the November 2010 Ash Pond Dam Stability Analysis. The downstream sides of the CCW pond embankments were analyzed for steady seepage and seismic seepage loading conditions at full and maximum pond capacity. Piezometer readings from the November 2010 Ash Pond Dam Stability Analysis, show the groundwater elevation to be above the downstream toe elevation. The phreatic line is low through the embankment.

# FINAL

Pond 2 is lined, therefore a phreatic line does not occur through the embankment. From visual observations in the field, the phreatic surface does not crop out on the outside slope of the perimeter levee.

## 7.1.4 Factors of Safety and Base Stresses

A slope stability analysis conducted in the November 2010 Ash Pond Dam Stability Analysis by Reitz & Jens, Inc. shows the perimeter dike does not meet the MDNR minimum required factor of safety of 1.5 for steady seepage loading (Doc 1.10). The factor of safety results of the seismic loading show the perimeter dike factor of safety is greater than the minimum required factor of safety of 1.0. See tables in Section 7.3.

## 7.1.5 Liquefaction Potential

This coefficient represents the fraction of the gravitational acceleration applied horizontally to the soil mass directed away from the slope to approximate the lateral forces on the dike mass that occur during an earthquake. Seismic stability analysis was performed for the downstream slope only. A horizontal acceleration of 0.05g or 0.25 of the probable maximum acceleration was added to the steady state seepage model. See summary of results of seismic stability analysis in section 7.3.

## 7.1.6 Critical Geological Conditions and Seismicity

The reviewed documents did not include any information regarding the critical geological conditions and seismicity used in the original design of perimeter levee or embankment dikes that impound CCW ponds. Minimal subsurface information was provided by the boring log profiles developed during the drilling and piezometer installation within Pond 7 (see Doc. 1.5 in Appendix A). The pertinent boring logs show that the virgin soils in the vicinity (along Pond 7) generally consisted of silty clay and clayey silt underlain by clay and silty clay.

Static water level readings indicate the depth to groundwater to be less than 40 feet. The types of soils within the perimeter levee, shown in the Pond 7 soil boring logs, would not typically be susceptible to liquefaction. However, due to the location of the Meramec PS within the Meramec River floodplain, high static water level in the area, and its proximity to the New Madrid and Wabash Valley seismic zones, the susceptibility of surrounding ground to liquefaction is moderate.

Seismicity – The site of the ash basins is in an area of moderate seismic hazard, however the site is within 150 miles of two known active seismogenic source areas (New Madrid and Wabash Valley seismic zones). Based on USGS Seismic-Hazard Maps for Central and Eastern United States, dated 2008, the Meramec

# FINAL

Power Station, is located in an area anticipated to experience 0.20g or higher peak ground acceleration with a 2-percent probability of exceedance in 50-years.

## 7.2 ADEQUACY OF SUPPORTING TECHNICAL DOCUMENTATION

The structural stability documentation is adequate.

## 7.3 ASSESSMENT OF STRUCTURAL STABILITY

Per Table 7.1 below, structural stability under static loading conditions of the perimeter levee embankment is currently unsatisfactory based on the steady seepage loading safety factor results in the November 2010 Ash Pond Dam Stability Analysis (Reitz & Jens, Inc., 2010). The steady seepage loading safety factors do not meet the minimum required safety factor of 1.5 along the perimeter levee for any of the investigated pond dikes. The Reitz & Jens November 2010 report indicates the unsatisfactory Factors of Safety are “due to the steep outside slopes of the perimeter levee”. Therefore, the structural soundness of the CCW embankments are rated **UNSATISFACTORY in their current configuration**.

Table 7.1: Factor of Safety (Reitz & Jens, Inc., November 16, 2010)						
Load Case	Required Factor of Safety	Cross Section 1	Cross Section 2	Cross Section 3	Cross Section 4	Cross Section 5
Steady Seepage	1.5	1.3	1.4	1.3	1.4	1.2
Earthquake, Steady Seepage	1.0	1.1	1.2	1.1	1.2	1.1

Ameren Missouri has subsequently initiated a project to be completed in late 2011 to flatten the existing slopes on the downstream side of Ponds 1, 2, and 4 to improve the factor of safety, see Table 7.2. Specifically, the proposed project will increase the embankment cross sectional area and improve the factor of safety of the perimeter levee in the cross sections listed in Table 7.2. The Factor of Safety will be increased with these improvements per March 29, 2011 Revised Meramec Plant Stability Analysis. The Factor of Safety will improve for cross sections 1, 3, and 5 to exceed the required 1.5 minimum Factor of Safety. The cross section 6, Pond 4, Factor of Safety for short term is “conditionally marginal” at a value of 1.46. Cross sections 1, 3, 5, and 6 represent Ponds 1, 2, and 4.

# FINAL

**Table 7.2: Factor of Safety (Reitz & Jens, Inc., March 29, 2011)**

Cross Sections and Pond	Long-term, Static (Min FoS = 1.5)	Seismic, (Min FoS = 1.0)
Cross Section 1, Pond 1	1.8	1.5
Cross Section 3, Pond 2	1.6	1.3
Cross Section 5, Pond 1	2.1	1.7
Cross Section 6, Pond 4	1.5	1.2

Given the improvement in the Factors of Safety, once the CCW ponds are re-configured then their rating would change to **SATISFACTORY**. Preliminary sketches of the flattened dikes are available in this report ( Doc 1.11). However, the current river levels of the Mississippi and Meramec Rivers have prevented Ameren from completing the topographical survey along the toe. Based on current river level projections, the survey can not start until July 2011. The current schedule is as follows:

**2011 Proposed Schedule for Dike Re-Configuration**

- Complete Construction Drawings - end of July (Floodwaters recede)
- Submit Plans to USACE for approval
- Construction commences in Sept-Oct 2011

# FINAL

## 8.0 ADEQUACY OF MAINTENANCE AND METHODS OF OPERATION

### 8.1 OPERATIONAL PROCEDURES

*Pond 1* – This basin is mainly used for water treatment and chemical stabilization prior to discharge to a tributary to the Meramec River. Ash waste material from production operations is not placed directly in the basin. Pond 3 and Pond 4 discharge directly into the basin. Surface runoff from Pond 7 and 8 is ditched to Pond 1. Overflow from Pond 2 discharges into surface ditches of Pond 8. Water is monitored and discharged when pH is within permit limits.

*Pond 2* – This basin is currently used for fly ash sedimentation, water treatment, and chemical stabilization. Pond 2 receives onsite surface runoff, fly ash, bottom ash, and wastewater residual wastes. Ash waste material is sluiced into the basin. The ash is excavated and placed in windrowed stockpiles to allow the material to drain prior to loading and transport offsite.

*Pond 3* – This basin is currently used for storage and disposal of fly ash. Ash waste material is sluiced into the basin. The slurry is pumped into excavated channels within the basin and gravity settling separates the fine from the coarser materials. Once the channels become full, the ash is excavated. The water flows through channels excavated in the ash to a pond area.

*Pond 4* – This basin is currently used for storage and disposal of bottom ash. Ash waste material is sluiced into Ponds 5 and 6. The slurry is pumped into excavated channels within the basin and gravity settling separates the fine from the coarser materials. Once the channels become full, the ash is excavated. The water flows through channels excavated in the ash to a pond area in Pond 4.

### 8.2 MAINTENANCE OF THE DAM AND PROJECT FACILITIES

Maintenance of the impounding embankments and outlet works of the CCW Ponds is performed as needed, as determined by routine (weekly) inspections performed by operating personnel. Vegetation on the embankment slopes and crest is mowed or cut twice a year or whenever it becomes necessary.

### 8.3 ASSESSMENT OF MAINTENANCE AND METHODS OF OPERATION

#### 8.3.1 Adequacy of Operational Procedures

Operational procedures at the CCW ponds appear to be appropriate and adequate.

# FINAL

## 8.3.2 Adequacy of Maintenance

No major maintenance issues were observed during the site visit and no major maintenance issues were noted from review of dam inspection reports and checklists. Maintenance of the impounding embankments and outlet works of the CCW ponds appears to be adequate.

# FINAL

## 9.0 SURVEILLANCE AND MONITORING PROGRAM

### 9.1 SURVEILLANCE PROCEDURES

Ameren Missouri formed a Dam Safety Group and associated Dam Safety Program supervised by a licensed professional engineer. The program requires Meramec PS to conduct weekly, annual, and special inspections. Employees trained in dam safety, overseen by civil and geotechnical engineers, inspect the CCW embankments following inspection procedures based on the type of dam safety inspection conducted. The weekly and annual inspections are documented on Inspection Checklists.

### 9.2 INSTRUMENTATION MONITORING

#### 9.2.1 Instrumentation Plan

There is no dam performance monitoring instrumentation in place in the impounding levee embankment. Staff gauges have been installed to measure the water surface elevation.

#### 9.2.2 Instrumentation Monitoring Results

There are no dam performance monitoring instruments.

#### 9.2.3 Dam Performance Data Evaluation

Not applicable.

## 9.3 ASSESSMENT OF SURVEILLANCE AND MONITORING PROGRAM

### 9.3.1 Adequacy of Inspection Program

The inspection program is generally adequate based on field observations and the data reviewed by Dewberry. However, internal inspections of the outlet structures with a remote camera or by personnel using confined-space procedures should be conducted on a frequency of at least once every 5 years.


### 9.3.2 Adequacy of Instrumentation Monitoring Program

There is no dam performance monitoring instrumentation in place. No problem or suspect condition, such as excessive settlement, seepage, shear failure, or displacement was observed in the field that might be reason for installation of instrumentation. In the absence of stability problems or seepage issues, there is no need for performance monitoring instrumentation at this time.




# FINAL

## EXHIBIT 2: REPRESENTATIVE POND 2 EMBANKMENT SECTIONS




# FINAL

## EXHIBIT 2 CONTINUED: REPRESENTATIVE POND 2 EMBANKMENT SECTIONS




E-E  
SECTION LOOKING WEST THRU LEVEE  
BETWEEN POND 491 & COAL PILE



# FINAL


## EXHIBIT 3: REPRESENTATIVE POND 3 EMBANKMENT SECTIONS




US EPA ARCHIVE DOCUMENT

# FINAL

## EXHIBIT 4: REPRESENTATIVE POND 4 EMBANKMENT SECTION




TYPICAL SECTION THRU DIKE  
AT NORTH BOTTOM ASH POND  
SCALE:  $\frac{1}{8}'' = 1'-0''$




APPENDIX A

DOC 1.1 MERAMEC POWER STATION VICINITY MAP (5-MILE)



APPENDIX A

DOC 1.2 MERAMEC POWER STATION MAP





LEGEND CONTINUED:  
 21. BOTTOM ASH  
 22. CARBON DIOXIDE  
 23. TRASH DUMPSTER  
 24. ELECTRICAL OIL  
 25. UNBURNED FUEL OIL

APPENDIX A

DOC 1.3 MERAMEC PLANT PLANS

REVISIONS  
 REV. NO. 0  
 DATE 12/26/88  
 FIRST ISSUE



**CONFIDENTIAL INFORMATION**

**NOTES:**

- 1) DEPRESSED SECTIONS OF POND #489 LEVEES SHALL FIRST BE RESTORED TO THEIR ORIGINAL TOP-OF-LEVEE ELEVATION 415', AS SHOWN IN SECTION A-A.
- 2) FLYASH SHALL BE RECLAIMED FROM POND #495 BY APPROPRIATE METHODS. FLYASH SHALL BE DRIED, PLACED AND COMPACTED IN POND #489, TO AN CL. OF 414'-6".
- 3) METHODS OF DRYING (IE. MOISTURE REDUCTION) SHALL BE RESTRICTED SUCH THAT ANY RESULTING RUNOFF BE KEPT WITHIN EXISTING ASH POND LIMITS AND BE ROUTED TO THE EXISTING PERMITTED DISCHARGE.
- 4) RECLAIMED FLYASH SHALL BE PLACED IN LOOSE LIFTS NOT TO EXCEED 8-12 INCHES, AND IMMEDIATELY COMPACTED AT OPTIMUM MOISTURE CONTENT BY MEANS OF A VIBRATORY ROLLER. SEE SPECIFICATION FOR COMPACTION REQUIREMENT. (SEE ALSO NOTE #9)
- 5) EARTHEN MATERIAL, REQUIRED FOR EROSION PROTECTION AND CONTAINMENT SHALL CONFORM TO CL. CH. ML. OR MH SOIL. CL ASSIFICATIONS, AS GIVEN BY ASTM DESIGNATION D-2487. THIS MATERIAL SHALL BE COMPACTED WITH A SHEEPS-FOOT TYPE COMPACTOR. SEE SPECIFICATION FOR COMPACTION REQUIREMENT. (SEE ALSO NOTE #9)
- 6) SEE TOPOGRAPHIC MAP DRAWING 8020-W-122627 FOR EXISTING ELEVATIONS.
- 7) REBUILD ACCESS ROADS TO RENOVATED LEVEE TO PROVIDE SMOOTH TRANSITIONS FOR SMALL VEHICLES.
- 8) TWO NEW CULVERTS WILL BE INSTALLED AS SHOWN TO PROVIDE STORMWATER DRAINAGE FROM POND #489 INTO POND #495.
- 9) COMPACTION SPECIFICATIONS SHOULD YIELD PERMEABILITIES WITHIN THE REQUIRED LEVEE AS FOLLOWS:  
 CLAY FILL - LESS THAN 10<sup>-7</sup> CM/SEC.  
 FLYASH - LESS THAN 10<sup>-9</sup> CM/SEC.
- 10) SURVEY MONUMENT #2 SHALL BE RAISED TO ELEVATION 415'-0"±2". SEE DRAWING 8020 W-122627 FOR LOCATION.
- 11) S.B. #5/7 - SOIL BORINGS (SEE U.S. SPEC. FC-2392, APPENDIX E)
- 12) RENOVATED LEVEE SHOWN THUS
- 13) ALL WORK SHALL BE DONE IN ACCORDANCE WITH U.S. SPECIFICATION LC 2392.

REFERENCE DRAWING: TOPOGRAPHIC MAP 8020-W-122627




NOTICE OF LIMITED RESPONSIBILITY  
 THE PROFESSIONAL ENGINEER'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT DESCRIBED IN THIS DRAWING. THE ENGINEER DOES NOT WARRANT THE ACCURACY OF THE INFORMATION PROVIDED BY THE CLIENT OR THE RESULTS OF THE PROJECT. THIS DOES NOT WAIVE THE ENGINEER'S LIABILITY FOR NEGLIGENCE OR OTHER PROFESSIONAL MALPRACTICE.



Drawn By: J.M. Scott	Checked By: J.M. Scott	Supv: S-7-77	App'd: S-7-77	Location: MERAMEC PLANT	Scale: AS SHOWN
PROPERTY PLAN ASH RETENTION PONDS		ST. LOUIS, MO.		8020-Y-122626	REV. 0

REVISED  
 DATE 12/24  
 BY E124  
 FIRST ISSUE

R:\Meramec\STR144271.dgn 09/14/2010 8:57:40 AM



**CONFIDENTIAL  
 INFORMATION**

NOTE:  
 SEE MERHEC DRAWING NUMBER 0029-9-144270 FOR ASH POND AND MODIFICATIONS



LEGEND

SideWalk	300' Interim Contour	Spot Elevation	Railroad
Building	Intermediate Contour	Single Tree	Paved Road
Foundation	Depression Contour	Locating Object	Unpaved Road
Fence	Guard Rail	Catch Basin	Traffic Sign
Wall	Stream Symptom	Manhole	Pipe Line
Tree Line	Control Point	Soil	Driveway
Stream		Sign	
Brush/Shrub Line		Fire Hydrant	
		Light Pole	

NOTE: DASHED CONTOURS MAY BE UNRELIABLE.




PREPARED FOR: AMERICA

PROJECT	PROPERTY TOPO MAP	SCALE	1" = 200'
DATE	ASH PONDS	DATE	02/09
DRAWN	001005	PROJECT	MERAMEC PLANT
CHECKED		DATE	02/09

Amernu ST. LOUIS, MO 63102 8020-X-144271 0

R:\Meramec\STR\144580.dgn 09/14/2010 9:02:05 AM

REVISED  
DATE  
BY  
FIRST ISSUE  
DATE  
BY



**CONFIDENTIAL  
INFORMATION**

1. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.  
2. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.  
3. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.  
4. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.

1. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.  
2. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.  
3. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.  
4. ALL DIMENSIONS SHOWN ON THIS PLAN ARE TO BE CONSIDERED AS APPROXIMATE UNLESS OTHERWISE NOTED.



LEGEND

Stream	300	Inter Contour	X 325.6	Spot Elevation	—
Building	—	Intermediate Contour	—	Single Tree	—
Foundation	—	Depression Contour	—	Clotted Object	—
Fence	—	Guard Rail	—	Catch Basin	—
Well	—	Quarry Symbol	—	Manhole	—
Tree Line	—	Contour of Pond	—	Pole	—
Stream	—			Sign	—
Brush/Strub Line	—			Fire Hydrant	—
				Light Pole	—

NOT: DASHED CONTOURS MAY BE UNRELIABLE.

PREPARED FOR: **AMTRIP**

DATE: 09/14/2010

PROJECT: **PIPING-PLAN  
DRAINS TO ASH POND 489  
1998 MODIFICATIONS**

DRAWN BY: **DO1005**

CHECKED BY: **DO1005**

DATE: 09/14/2010

PROJECT: **MERAMEC PLANT**

SCALE: **AS SHOWN**




ST. LOUIS, MISSOURI

8020-X-144580

0

R:\Meramec\STR\144288.dgn 09/14/2010 9:07:02 AM

NO.	DATE	BY	DESCRIPTION
1	09/14/2010	...	FIRST ISSUE



**CONFIDENTIAL INFORMATION**

**BENCHMARK NOTES:**  
 1. ELEVATIONS BASED ON U.S.G.S. BENCHMARKS LOCATED ON THE SOUTHEAST ABUTMENT OF THE MISSOURI PACIFIC RAILROAD BRIDGE OVER THE MERAMEC RIVER. SPOTS TABLE ELEVATION = 418.487'  
 2. LOCAL BENCHMARK, CUT SQUARE ON THE SOUTHEAST CORNER OF LOADING DOCK WALL, ELEVATION = 414.88'

**EARTHWORK QUANTITIES:**  
 CUT-118,888 CUBIC YARDS  
 FILL-118,888 CUBIC YARDS

**CLIENT ADDRESS:**  
 AMEREN UE  
 ONE AMERICAN PLAZA  
 3901 CHATEAU AVE.  
 ST. LOUIS, MO 63103

**CONTRACT ADDRESS:**  
 AMEREN UE  
 P.O. BOX 68348  
 ST. LOUIS, MO 63166-0489

**OWNER ADDRESS:**  
 AMEREN UE  
 MERAMEC PLANT  
 6300 FINE ROAD  
 ST. LOUIS COUNTY, MO 63109



<ul style="list-style-type: none"> <li>Embankment</li> <li>Building</li> <li>Foundation</li> <li>Face</li> <li>Tree Line</li> <li>Stream</li> <li>Brush/Grass Line</li> </ul>	<ul style="list-style-type: none"> <li>300'</li> <li>Intermediate Contour</li> <li>Depression Contour</li> <li>Quard Rod</li> <li>Sump Symbol</li> <li>Control Point</li> </ul>	<ul style="list-style-type: none"> <li>Spot Elevation</li> <li>Single Trap</li> <li>Locating Object</li> <li>Loose Item</li> <li>Structure</li> <li>Sign</li> <li>Fire Hydrant</li> <li>Light Pole</li> </ul>	<ul style="list-style-type: none"> <li>Railroad</li> <li>Power Road</li> <li>Impaved Road</li> <li>Pipe Line</li> <li>Driveway</li> </ul>
---	---	---	---

<b>PROPERTY - PLAN</b> <b>FLYASH POND 489</b> <b>RECLAMATION AND NEW LINER</b>	
PREPARED FOR: AMEREN UE	PROJECT NO.: 8020-X-144288
DRAWN BY: W. RESNAINA	CHECKED BY: J. B. ...
DATE: 02/10/10	SCALE: AS SHOWN

**CONFIDENTIAL  
INFORMATION**

APPROX. 50,000 CU YDS OF ASH  
TO BE EXCAVATED FROM POND 495  
AND PLACED IN FILL AREA

FLOODWAY 1ST. LOUIS COUNTY FBFM


APPROX. OVERHEAD HIGH VOLTAGE LINES

OVERHEAD HIGH VOLTAGE LINES

ALL WATERSHED AREAS TO BE EXCAVATED OR  
FILLED DRAIN TO THE EXISTING SETTLING BASIN  
AT THE NORTH END OF POND 498. NO SILT  
FENCES, STAKED BALES OR OTHER EROSION  
CONTROL MEASURES WILL BE UTILIZED IN THIS  
PLAN.

APPROX. 50,000 CU YDS OF ASH  
TO BE EXCAVATED FROM POND 491  
AND PLACED IN FILL AREA

PROPOSED FILL AREA  
FINAL ELEVATION 418±  
APPROX. 100,000 CU YDS



EXISTING TOPOGRAPHY COMPILED FROM AERIAL SURVEY  
CONDUCTED BY WALKER & ASSOCIATES, FLOMO 4-28-94

NOTICE OF LIMITED RESPONSIBILITY  
BY THE BOARD OF PROFESSIONAL ENGINEERS AND SURVEYORS  
OF THE STATE OF MISSOURI  
I, THE UNDERSIGNED, HEREBY CERTIFY THAT THE ABOVE  
MENTIONED PROJECT HAS BEEN REVIEWED AND APPROVED  
FOR THE PURPOSES OF THIS STATEMENT OF WORK.  
DATE OF REVIEW: \_\_\_\_\_  
SIGNATURE: \_\_\_\_\_  
OFFICE: \_\_\_\_\_


SEPTEMBER 18, 1994

PROJECT	FLYASH POND 491 & 495 INTERIM GRADING PLAN		
CLIENT	HERAPEC POWER PLANT		
DESIGNER	UNION ELECTRIC COMPANY ST. LOUIS, MO.		
SCALE	DATE	BY	CHECKED
0.80" = 1'-0"			
PROJECT NO.		8020-X-13559	



**CONFIDENTIAL  
INFORMATION**

REVISED  
8/1/2004  
FIRST ISSUE



SHEET 1 OF 2  
JULY 13, 1995

- LEGEND**
- Sidepath
  - Building
  - Foundation
  - Fence
  - Well
  - Tree Line
  - Stream
  - Index Contour
  - Inter-mediate Contour
  - Depression Contour
  - Approximate Contour
  - Grid of Spot
  - Spot Elevation
  - Single Tree
  - Locust Object
  - Catch Basin
  - Highpole
  - Pole
  - Railroad
  - Gravel Road
  - Impaved Road
  - Trail
  - Power Line
  - Fire Hydrant
  - Light Pole



NOTE: ELEVATIONS SHOWN BY POINT AND BY LINE ARE APPROXIMATE AND BY LINE LINES ARE APPROXIMATE TO THE LINE. LINES SHALL BE SUBJECT TO A 10' LEAK FOR TYPICAL CROSS SECTION.

EXISTING TOPOGRAPHY FROM PHOTOGRAPHIC DATA, NOTES FROM FIELD SURVEY AND 1995.

\*ASH PONDS HAVE NOT BEEN MODIFIED TO THIS DESIGN

00100002010	
0020-X-135356	
PREPARED FOR: <i>[Signature]</i>	
FLYASH PONDS 489 AND 495 RECLAMATION	
DATE: 07/13/95	SCALE: AS SHOWN
MERAMEC POWER PLANT	
ST. LOUIS, MISSOURI	8828-X-135356

R:\Meramec\STR\135356.dgn 09/14/2010 9:32:39 AM



- Owner's Notes**
- 1) Place fill for levee, form from inside of pond area, in 6' layers of compact with sheepsfoot roller until the roller "walks out".
  - 2) Fill to be free of debris, vegetation and trash.
  - 3) Spiral pipe to be 1000' in length, as manufactured by Memphis Pipe Co. of Chicago Ill. or equivalent equal with cast for coating of heavy duty weathering couplings.
  - 4) Embank area outside of ash pond shall drain with no low areas that would result in ponding.

**CONFIDENTIAL  
INFORMATION**

SEE REVISIONS UNDER LIST


NO.	DESCRIPTION	DATE	BY	CHKD.
1	ADD REVISIONS UNDER LIST			
2	ADD REVISIONS UNDER LIST			
3	ADD REVISIONS UNDER LIST			
4	ADD REVISIONS UNDER LIST			
5	ADD REVISIONS UNDER LIST			

SOIL BORINGS - FA 100578  
REP. (MEX. POND) DRAWN 8/30/64 YRS



NO.	DESCRIPTION	DATE	BY	CHKD.
1	ADD REVISIONS UNDER LIST			
2	ADD REVISIONS UNDER LIST			
3	ADD REVISIONS UNDER LIST			
4	ADD REVISIONS UNDER LIST			
5	ADD REVISIONS UNDER LIST			

PROPERTY PLAN  
ASH SLURRY POND  
MERAMEC PLANT  
UNION ELECTRIC COMPANY  
8000-X-61041



**LEGEND**

ROAD	RAILROAD	WATER	VEGETATION
...	...	...	...

**TOPOGRAPHIC DESIGN**



...

EX. CONTROL POINT  
 ...  
 ...


**SYMBOLS**

...

**CONFIDENTIAL  
 INFORMATION**



KEY PLAN



MERAMEC RIVER

POND	AREA, SQ. FT.	
	TOP OF LEVEE	TOE OF LEVEE
1 FLY ASH POND IN USE	1,330,000	1,185,400
2 NORTH FILLED FLY ASH POND	1,051,000	933,500
3 SOUTH FILLED FLY ASH POND	930,400	864,500
4 REFUSE BURNING ASH POND	429,200	380,700
5 NORTH BOTTOM ASH POND	249,900	214,400
6 SOUTH BOTTOM ASH POND	698,000	620,000

REFERENCE SURDEX CORP PHOTOGRAPH 111 NO 708-135 AND 708-136 DATED 12-1-72




**CONFIDENTIAL INFORMATION**

PREPARED FOR  
 UNION ELECTRIC COMPANY  
 SCALE: 1"=200'  
 5' CONTOURS  
 BY  
 SURDEX CORP. CHESTERFIELD MO.

PROPERTY PLAN ASH PONDS				
DATE	DESCRIPTION	CHKD	APPR	
UNION ELECTRIC SYSTEM	ST. LOUIS, MO.			8000-Y73581
LOCATION	MERAMEC PLANT			

REV.	BY	DATE	DESCRIPTION
1	...	...	...
2	...	...	...
3	...	...	...
4	...	...	...
5	...	...	...
6	...	...	...
7	...	...	...
8	...	...	...
9	...	...	...
10	...	...	...



**REVISIONS**

1. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

2. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

3. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

4. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

5. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

6. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

7. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

8. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

9. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>




10. 0-1-1 J-B, ADDP  
 DET. 'D' REVISED  
 SIZE & SHAPE OF  
 MANHOLE IN SECT.  
 2-2, 3-3 & 4-4.  
 @ A (B-1) THRU 3  
 RELOCATED NEW  
 24\"/>

**CONFIDENTIAL  
 INFORMATION**



**FLUOR PIONEER INC.**

REV.	NO.	DATE	BY	CHKD.
1	1	07/27/00	ML	ML
2	1	08/01/00	ML	ML
3	1	08/01/00	ML	ML
4	1	08/01/00	ML	ML
5	1	08/01/00	ML	ML
6	1	08/01/00	ML	ML
7	1	08/01/00	ML	ML
8	1	08/01/00	ML	ML
9	1	08/01/00	ML	ML
10	1	08/01/00	ML	ML
11	1	08/01/00	ML	ML
12	1	08/01/00	ML	ML
13	1	08/01/00	ML	ML
14	1	08/01/00	ML	ML
15	1	08/01/00	ML	ML
16	1	08/01/00	ML	ML
17	1	08/01/00	ML	ML
18	1	08/01/00	ML	ML
19	1	08/01/00	ML	ML
20	1	08/01/00	ML	ML



**NOTE:**  
EXISTING TOPOGRAPHICAL CONDITIONS MAY REQUIRE PIPE SUPPORT MODIFICATION. FOR ALTERNATE "1" SEE DWG. X-01924. FOR ALTERNATE PREFERENCE SEE D.E.

**NOTES:**  
1. FOR GENERAL NOTES AND MATERIAL LIST IN DWG. X-11324 SEE DWG. X-01925.  
2. ALL WORK BY STRUCTURAL/PILE CONSTRUCTION CONTRACTOR UNLESS OTHERWISE NOTED.

**REFERENCE DWG'S:**  
1. RETENTION/MIXING POND AREA - PLAN & ELEVATIONS... 8030-X-91920

11 REVISIONS

1. REVISED DIM. 4076 IN DET. "A" REVISYD SEE "G" 4-4 (S-B, S-C) (S-C) DELTYS SECTION R-R. E.H.2 ADDED NOTE DWG. CHECKED, SIGNED, APPROVED & RELEASED FOR CONSTRUCTION. CHK'D: S.A.C./E.S. APPROV'D: M.H. 7-17-07 FILMED: 7-17-07

2. J-2: DENIED NOTE G-3: INDICATED LEAST SLOPE OF 2% WAS 2-2.5% IN DENIED MARK. WAS ABOUT. H-9: INDICATED NORMAL WALL EL. 404.0' & DELETED MAX. WALL EL. 404.3'. G-5: INCREASED 6" PIPE POST. DIMEN BY 10'-0" & ADDED 2 1/2" PIPE BRACING. CHK'D: E.S. APPROV'D: M.H. 8-5-07 FILMED: 8-5-07

3. C-4: RELEASED FROM DENIED 11'-0" PIPE 11'-0" & INDICATED HELP WITH CLIP - REVISED 3000' LOCATION. C-5: ADDED 11'-0" x 4" GFR ANCHORS & DET. C-5: RELEASED FROM DENIED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

4. I-1: ADDED SECTION 11-11. J-R: CHANGED LENGTH OF PIPE. CHK'D: S.A.C. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

5. J-1: PIPE BRACED SHOWN AS ADDED IN SECTION 2-2. I-1: DENIED. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

6. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

7. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

8. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

9. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

10. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

11. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

12. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

13. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

14. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

15. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

16. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

17. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

18. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

19. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07

20. E-1: ADDED 6" RIP-RAP AS ENCLOSED. CHK'D: E.S. APPROV'D: M.H. 8-7-07 FILMED: 8-7-07


**CONFIDENTIAL INFORMATION**

Prepared by **FLUOR PIONEER INC.**  
131600 HILWA ROAD



DATE OF MEETING	08/14/00
PROJECT NO.	8030-X-91920
DESIGNER	ROBERT A. CARRAZ
CHECKER	MARKUS
DATE	08/14/00
SCALE	AS SHOWN
BY	ML
CHKD.	ML
DATE	08/14/00


REVISIONS  
REV. NO. DATE  
1 1/11/10




**PLAN OF VALVE WATER OPERATIONS**  
OVERLOOK EXIT

20" PIPE  
2 1/2" S.W. FLANGE  
THREADED ROD ONLY - TOP WITH NUT AND WASHER PIPE HELL FOR 20" PIPE  
NOTE: FOR CONCRETE SECTION SEE 9000-1-120400


**SECTION "D-D"**




**SECTION "E-E"**




**SECTION "F-F"**



**DETAIL OF SAMPLE PIPE ATTACHMENT**




**DETAIL OF NON-POND DRAIN EXIT TO RIVER**



**ELEVATION OF VALVE WATER OPERATIONS**

**SECTION "G-G"**



**DETAIL OF CO INJECTION**



- NOTES**
1. THIS WORK TO BE DONE IN ACCORDANCE WITH U.S. SPEC. NO. EC-4002
  2. ALL 2" SCH. 80 PIPE ABOVE GROUND TO BE GALVANIZED.
  3. ALL 2" SCH. 80 PIPING BELOW GROUND SHALL BE CORROS. RESISTANT CARBON STEEL.
  4. ALL PIPING 2" & SMALLER TO BE SCHEDULE 80.
  5. CONTRACTOR TO WELD PIPE FLANGES TO PERMIT FREE OPERATION OF 20" BUTTERFLY VALVES. ALSO TYP. ON REMOVED 2" SAMPLE LINE PER SAME CRITERIA.
  6. INSTALL 2" INSULATION AND HEAT TRACE ON 20" PIPE FROM CONCRETE WALL TO LAST PIPE HELL. INSULATE 2" SAMPLE PUMP SECTION FROM 20" PIPE TO PUMP & 2" SAMPLE TO CONTROL HOUSE FROM PUMP TO RIVER.
  7. ALL WELD PIPE CONNECTIONS SHALL BE FUSION WELDED.
  8. SUPPLY BY ARCHITECT AND INSTALLED BY CONTRACTOR.

**REFERENCE DRAWINGS:**  
PROPERTY PLAN: 9000-1-120400

**CONFIDENTIAL INFORMATION**

PREPARED FOR: [Redacted]  
 PROJECT: [Redacted]  
 SHEET: [Redacted]  
 DATE: [Redacted]

REVISED	DATE	BY	REASON
REV 1	08/11/04	MM	REVISED
REV 2	08/11/04	MM	REVISED



**CONFIDENTIAL  
INFORMATION**



DESIGN	08/11/04
CHECK	08/11/04
APPROVE	08/11/04
DATE	08/11/04

REV. 1 SEALED BY: [Signature]


PROPERTY: SITE PLAN  
NEW ASH POND #89  
DISCHARGE STRUCTURE






REVISIONS	
REV. NO.	W.O. NO.
1	1000






DISCHARGE STRUCTURE RUNNING EAST-WEST TO BE LOCATED AT 8750 AND PERPENDICULAR TO DIVE. THE DIVE IS ASSUMED TO BE 20'-0" WIDE. FIELD CONDITIONS AT EXACT LOCATION MAY VARY. ADJUST LOCATION OF SUPPORT AS REQUIRED.




- NOTE:
- CIP TO BE GARMENTED WITH TRENCHED 757-L20-768 ELASTOMERIC RESILIENT TAPE. 1/4" WIDE AND 1/2" THICK OR APPROVED EQUAL.
  - FIELD COAT WELDS AND EXTERIOR FACE OF CIP WITH ROOFING MEMBRANE.



- GENERAL STRUCTURAL NOTES
- ALL CONCRETE USED SHALL DEVELOP A MINIMUM STRENGTH OF 4000 P.S.I. IN 28 DAYS.
  - ALL CONCRETE SHALL BE AIR ENTRAINED AND CONTAIN FLY ASH FROM THE LAMBERT PLANT.
  - ALL EXPOSED EDGES OF CONCRETE SHALL HAVE 1" CHAMFER.
  - THE THICKNESS OF CONCRETE COVERING OVER REINFORCING STEEL SHALL BE IN THE FOLLOWING INSTANCES NOT LESS THAN SPECIFIED BELOW OR AS OTHERWISE SHOWN:
    - A) CAST AGAINST AND PERMANENTLY EXPOSED TO WEAR - 2
    - B) EXPOSED TO LAUNCH OR HEAVY WATER FORMS AND REQUIRED - 2
  - ALL REINFORCING STEEL SHALL CONFORM TO A-315 GRADE 60 STEEL.
  - ALL WELDED WIRE FABRIC SHALL CONFORM TO ASTM A193.
  - STRUCTURAL STEEL SHALL CONFORM TO ASTM A-36 SPECIFICATION AND ELECTION SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE AISC MANUAL OF STEEL CONSTRUCTION.
  - REINFORCING STEEL SHALL BE IN ACCORDANCE WITH THE AISC MANUAL OF STANDARD PRACTICE FOR DETAILING REINFORCED CONCRETE ACI STANDARD 318-89. ALL HOOPS SHALL BE STANDARD UNLESS NOTED OR SHOWN OTHERWISE.
  - ALL DESIGN AND CONSTRUCTION WORK FOR THIS PROJECT SHALL CONFORM TO THE REQUIREMENTS OF THE 1996 BOCA CODE.
  - DESIGN LOADS ARE AS FOLLOWS:
    - A) WIND LOADS ARE CALCULATED AND APPLIED BASED ON A 70 MPH WIND VELOCITY WITH AN IMPORTANCE FACTOR - 1.0 EXPOSURE C.
    - B) BELTIC WIND STRUCTURES ZONE 11-2 3-0' 1-10 6-10
  - A TOTAL OF 44 C818-5 2-1/2" DIA. BOLTS SHALL BE FABRICATED AND 176 3/4" DIA. ANCHOR BOLTS SUPPLIED. A TOTAL OF 8 C818-5 AND 24 BOLTS SHALL BE INSTALLED PER EAST ELEVATION. THE REMAINING C818-5 AND BOLTS SHALL BE DELIVERED TO THE OWNER FOR STORAGE.
  - ALL WELDS CHANNELS AND PLATES SHOWN IN SECTIONS D & E TO BE OMINITIZED.
  - LINER TO BE ATTACHED TO CONCRETE PER MANUFACTURER'S SPECIFICATIONS.



**CONFIDENTIAL INFORMATION**



NOTICE OF LIMITED LIABILITY



















PREPARED FOR: **AMERICAN**

STRUCTURE: CONCRETE  
DISCHARGE STRUCTURE FOUNDATION  
NSM POND ADD

APP. LOCATION: WERAMEC PLANT

DATE: 08/14/2010

REVISIONS	
REV. NO.	W.O. NO.
1	1078
FIRST ISSUE	



NOTE: FINAL STEEL FRAMING AT BENT 2 PLATFORM LEVEL MAY CHANGE DEPENDING ON FINAL PUMP SPECIFICATION CLEARANCE FOR PUMP WILL DICTATE FINAL FRAMING

**CONFIDENTIAL INFORMATION**

- CONNECTION NOTES**
- ALL BOLTS ARE 3/4" DIA A-325 U.B.O.
  - ALL CLIP ANGLES TO BE 3" THICK
  - ALL CONNECTION PLATES TO BE 3/8" THICK
  - FIN CONNECTIONS SHALL BE 2" DIA A-325 BOLTS U.B.O.


NOTICE OF LIMITED RESPONSIBILITY	
DESIGNED BY	STRUCTURE
DRAWN BY	STEEL FRAMING & DETAILS
CHECKED BY	DISCHARGE STRUCTURE
APPROVED BY	ARM POND 488
DATE	PREPARED FOR
10/10/00	ARM POND 488
SCALE	AS SHOWN
REV.	




PREPARED FOR ARM POND 488

A  
B  
C





SECTION E-E ROAD PROFILE  
 SCALE 1" = 100'H  
 1" = 5V



SECTION F-F  
 (TYPICAL)  
 SCALE 1" = 5H  
 1" = 5V


SECTION G-G  
 (TYPICAL)  
 SCALE 1" = 5H  
 1" = 5V

SECTION H-H  
 (TYPICAL AT PERIMETER ROAD)  
 SCALE 1" = 5H  
 1" = 5V


**CONFIDENTIAL INFORMATION**

		SEPTEMBER 14, 1994	
FLYASH POND 489 RECLAMATION		CLASS 02010	
UNION ELECTRIC COMPANY ST. LOUIS, MO.		8020-X-135358	

REV.	NO.	DATE	DESCRIPTION
C	1		FIRST ISSUE




FOR CONTROL HOUSE LOCATION, SEE X-135405



EQUIPMENT BILL OF MATERIAL			
ITEM NO.	ITEM QTY.	DESCRIPTION	REMARKS
1	1	#PH400-P-U-1#A/U MICROPROCESSOR PH ANALYZER YOKOGAWA	MOUNT ON STL. PANEL SEE NOTE-4 BY MERAMEC
2	1	110V AIR CONDITIONER - SEE SPECIFICATION FOR DESIGN CRITERIA	
3	1	EXHAUST FAN - NEW YORK BLOWER MODEL E82-H 1/2 HP MOTOR SIDE FAN GUARD, AUTOMATIC SHUTTER, 115V, 1 Ø MOTOR.	
4	1	THERMOSTAT (EXHAUST FAN) BARBER-COLEMAN #TC-4111. MOUNT SENSING BULB ON EXHAUST FAN GUARD.	
5	1	UNIT HEATER - MARLEY "Q-MARK" MODEL MUH-03-B1. 3.0 KW, 480V, 3 Ø, WITH WALL & CEILING MOUNTING BRACKET #MMB-5, WITH POWER DISCONNECT SWITCH MPDS-25.	
6	1	THERMOSTAT (UNIT HEATER) MARLEY "Q-MARK" MODEL WR-1E30-S.	MOUNT ON WALL 3'6" AFF.
7	1	#UT37-A13301#A/SPD CONTROLLER YOKOGAWA	MOUNT ON STL. PNL SEE NOTE-4 BY MERAMEC
8	1	SWITCH BOX	MOUNT ON STL. PNL. SEE NOTE-4 BY MERAMEC
9	2	FLOW-THROUGH SENSOR ASSEMBLY #FF20-533-FNU-C2-54-T YOKOGAWA	MOUNT ON STL. PNL SEE NOTE-4 BY MERAMEC

DOOR SCHEDULE		
DOOR NO.	DOOR SIZE	DESCRIPTION
A	1-3'x7'x1 3/4"	HOLLOW METAL FLUSH TYPE DOOR (INSULATED) W/ PRESSED METAL FRAME (5/8" STD.), 1 1/2" PAIR FULL MORTISED 2 B.B HINGE-4 1/2" x 4 1/2" x 0.134 GA. HOSPITAL TYPE. PROVIDE "LCN" HOHO DOOR CLOSER, LOCKSET 66B, BEST CYLINDER & CONSTRUCTION CORE. PROVIDE FLOOR MOUNTED STOP W/HOLD OPEN IYES 449. DOOR TO BE FULLY WEATHERSTRIPPED. HAVE ALUMINUM THRESHOLD (NATIONAL GUARD #525) & DOOR BOTTOM SEAL (NATIONAL GUARD #19). ALL HARDWARE US 26D FINISH.

NOTES:  
 1) ALL HARDWARE TO BE US 26D FINISH.  
 2) LOCKSETS TO RECEIVE "BEST" CYLINDERS. PERMANENT CORES TO BE PROVIDED BY UNION ELECTRIC CO.  
 3) CONSTRUCTION CORES TO BE PROVIDED BY CONTRACTOR.



NOTE:  
FOR BUILDING FDN. SEE X-135521

**CONFIDENTIAL INFORMATION**


- NOTES:
- THIS WORK TO BE DONE IN ACCORDANCE WITH U.E. SPEC. NO. EG-4022.
  - (DELETED)
  - (DELETED)
  - 24" x 48" STEEL PANEL AND ITEMS 1, 7, 8 & 9 FURNISHED BY U.E. CO & INSTALLED BY CONTRACTOR. PIPING & ELECTRICAL CONNECTIONS SUPPLIED BY CONTRACTOR.
  - VALVES FOR 1/2" COPPER TUBING TO SENSORS TO BE WHITNEY NEEDLE VALVES, BRONZE BODY, TYPICAL.
  - COPPER TUBING CONNECTIONS TO BE MADE WITH SWAGLOK FITTINGS.

REFERENCE DRAWINGS:  
8030-X-135405 - - - - PROPERTY PLAN

THIS DRAWING HAS NO SCALE

DRAWN 8-12-59 M. ENGLUND CHECKED NOT SUPV. 10/21/59 11/4	BUILDING-PLAN SAMPLE CONTROL BUILDING ASH POND 489	CLASS 02010 REV. 0
UNION ELECTRIC COMPANY ST. LOUIS, MO.	MERAMEC PLANT 8030-Y-135407	





**CONFIDENTIAL  
 INFORMATION**

ASH PONDS HAVE NOT BEEN MODIFIED TO THIS DESIGN


SHEET 2 OF 2  
 JULY 13, 1995

PREPARED FOR:	
FLYASH PONDS 489 AND 495 RECLAMATION	
DRAWN BY:	DATE:
CHECKED BY:	SCALE:
PROJECT NO.:	SHEET NO.:
HERAEC POWER PLANT	8020-Y-135357
BY: LOUIE	8/20/95

REVISIONS	
REV.	W.C.
1	

First Issue

Note: El. 126.66 Water Edge & Discharge Pond # 495



**CONFIDENTIAL INFORMATION**

Note: N. 604.668, W. 1079.186 Plant Coordinates

Prop Plan Ash Slurry Ponds 8000-Z-61041

DRAWN BY: J. Weber	PROPERTY PLAN SURVEY
CHECKED: J. Weber	CROSS SECTIONS
SUPV: J. Weber	ASH POND 491
APPD: 001005	LOCATION: MERAMEC PLANT
UNION ELECTRIC COMPANY	ST. LOUIS, MO.
8000-Y-54505	REV. 0

2011.10.18

REV.	DATE	BY	CHKD.	DESCRIPTION
1	12/15/50	J. W. MILLER	J. W. MILLER	PREPARED
2	1/10/51	J. W. MILLER	J. W. MILLER	REVISED
3	1/10/51	J. W. MILLER	J. W. MILLER	REVISED

CHAS. W. MILLER  
 CIVIL ENGINEER  
 24 S. 28. CHAS.  
 RE. EDWARDS  
 REY. GRID.

SCALE: 1" = 100'  
 NORTH: AS SHOWN

PROPERTY PLAN SURVEY  
 ASH POND #492 THRU #496  
 INSTRUMENT PT. LOCATION

UNION ELECTRIC COMPANY  
 ST. LOUIS, MO.

8000-X-92766

REV. 3

DATE: 1/10/51

BY: J. W. MILLER

CHKD.: J. W. MILLER

DESCRIPTION: PREPARED

REVISED

REVISED


12/15/50

1/10/51

J. W. MILLER

J. W. MILLER

PREPARED




**CONFIDENTIAL INFORMATION**

PROPERTY PLAN SURVEY ASH POND #492 THRU #496 INSTRUMENT PT. LOCATION	DATE: 1/10/51
UNION ELECTRIC COMPANY ST. LOUIS, MO.	8000-X-92766




REV.	NO.
1	0
DATE	05/22/98
BY	RWV
CHECKED	DAG
DATE	
BY	
APPROVED	
DATE	
BY	



**SECTION A**  
8020-Y-01041

**CONFIDENTIAL INFORMATION**



**DETAIL 1**  
ENLARGED VIEW OF DECANT STRUCTURE

NOTES:  
1. THIS WORK TO BE DONE IN ACCORDANCE WITH U.E. SPEC. NO. EC-2072

REFERENCE DRAWINGS:  
8020-Y-01041... SITE PLAN  
8020-Y-01028... PARTIAL PLAN & SECTIONS  
8020-Y-01028... MISC. DETAILS

<b>NOTICE OF LIMITED LIABILITY</b>	
THE LIABILITY OF THE UNDERSIGNED ENGINEER IS LIMITED TO THE SCOPE OF THE WORK ON WHICH THIS DOCUMENT IS PREPARED.	
REV. 0 SEALED BY	
DATE	05/22/98
BY	RWV
CHECKED	DAG
DATE	
BY	
APPROVED	
DATE	
BY	



8020-Y-141535

PROJECT	PIPELINE POND DISCHARGE
NO.	404 & 405
DATE	1998 ADDITION
DESIGNER	STEVE GUY
APP'D	1/20/98
LOCATION	VERMONT PLANT
CLASS	05070
UNION ELECTRIC COMPANY	8020-Y-141535
ST. LOUIS, MO.	REV. 1


REV.	DATE	BY	CHKD.
1			
2			
3			
4			
5			




**CONFIDENTIAL  
INFORMATION**




**DETAIL "A"**



**SECTION "A"**



**SECTION "B"**



**SECTION "C"**

NOTE  
THIS WORK TO BE DONE IN ACCORDANCE WITH U.S. SPEC. NO. 52-1022.

STEEL TRIMMING - WALKWAY & DISCHARGE PLATFORM	0000-N-125446
CONCRETE DETAILS - MIN FLOOR DISCHARGE	0000-N-125447
BUILDING - CONTROL HOUSE	0000-N-125448
PIPES - MIN FLOOR DISCHARGE	0000-N-125449
PIPES - CO2 REGULATING STATION	0000-N-125450

00100502010

0000-N-147376



PREPARED FOR: **AMERICAN**

REV. SEALED BY: **AMERICAN**








DESIGNED BY: **AMERICAN**

ST. LOUIS, MO. 63102

REV.	NO.	DATE	BY	CHKD.	APPD.
1	0				
2	1	01/11/08	...	...	...
3	2	01/11/08	...	...	...



**CONFIDENTIAL INFORMATION**




REFERENCE DRAWINGS:  
ASH POND AND FILL AREA 8030-Y-154541

PROPERTY - SECTIONS NEW ASH POND AND GRADING OVER PONDS 490, 494 & 498
MERAMEC PLANT
8030-X-152542

REVISIONS	
REV. NO.	DATE
1	10-14-09
2	11-11-09
3	12-11-09
4	01-14-10
5	02-11-10
6	03-11-10
7	04-11-10
8	05-11-10
9	06-11-10
10	07-11-10
11	08-11-10
12	09-11-10
13	10-11-10
14	11-11-10
15	12-11-10
16	01-11-11
17	02-11-11
18	03-11-11
19	04-11-11
20	05-11-11
21	06-11-11
22	07-11-11
23	08-11-11
24	09-11-11
25	10-11-11
26	11-11-11
27	12-11-11
28	01-11-12
29	02-11-12
30	03-11-12
31	04-11-12
32	05-11-12
33	06-11-12
34	07-11-12
35	08-11-12
36	09-11-12
37	10-11-12
38	11-11-12
39	12-11-12
40	01-11-13
41	02-11-13
42	03-11-13
43	04-11-13
44	05-11-13
45	06-11-13
46	07-11-13
47	08-11-13
48	09-11-13
49	10-11-13
50	11-11-13
51	12-11-13
52	01-11-14
53	02-11-14
54	03-11-14
55	04-11-14
56	05-11-14
57	06-11-14
58	07-11-14
59	08-11-14
60	09-11-14
61	10-11-14
62	11-11-14
63	12-11-14
64	01-11-15
65	02-11-15
66	03-11-15
67	04-11-15
68	05-11-15
69	06-11-15
70	07-11-15
71	08-11-15
72	09-11-15
73	10-11-15
74	11-11-15
75	12-11-15
76	01-11-16
77	02-11-16
78	03-11-16
79	04-11-16
80	05-11-16
81	06-11-16
82	07-11-16
83	08-11-16
84	09-11-16
85	10-11-16
86	11-11-16
87	12-11-16
88	01-11-17
89	02-11-17
90	03-11-17
91	04-11-17
92	05-11-17
93	06-11-17
94	07-11-17
95	08-11-17
96	09-11-17
97	10-11-17
98	11-11-17
99	12-11-17
100	01-11-18
101	02-11-18
102	03-11-18
103	04-11-18
104	05-11-18
105	06-11-18
106	07-11-18
107	08-11-18
108	09-11-18
109	10-11-18
110	11-11-18
111	12-11-18
112	01-11-19
113	02-11-19
114	03-11-19
115	04-11-19
116	05-11-19
117	06-11-19
118	07-11-19
119	08-11-19
120	09-11-19
121	10-11-19
122	11-11-19
123	12-11-19
124	01-11-20
125	02-11-20
126	03-11-20
127	04-11-20
128	05-11-20
129	06-11-20
130	07-11-20
131	08-11-20
132	09-11-20
133	10-11-20
134	11-11-20
135	12-11-20
136	01-11-21
137	02-11-21
138	03-11-21
139	04-11-21
140	05-11-21
141	06-11-21
142	07-11-21
143	08-11-21
144	09-11-21
145	10-11-21
146	11-11-21
147	12-11-21
148	01-11-22
149	02-11-22
150	03-11-22
151	04-11-22
152	05-11-22
153	06-11-22
154	07-11-22
155	08-11-22
156	09-11-22
157	10-11-22
158	11-11-22
159	12-11-22
160	01-11-23
161	02-11-23
162	03-11-23
163	04-11-23
164	05-11-23
165	06-11-23
166	07-11-23
167	08-11-23
168	09-11-23
169	10-11-23
170	11-11-23
171	12-11-23
172	01-11-24
173	02-11-24
174	03-11-24
175	04-11-24
176	05-11-24
177	06-11-24
178	07-11-24
179	08-11-24
180	09-11-24
181	10-11-24
182	11-11-24
183	12-11-24
184	01-11-25
185	02-11-25
186	03-11-25
187	04-11-25
188	05-11-25
189	06-11-25
190	07-11-25
191	08-11-25
192	09-11-25
193	10-11-25
194	11-11-25
195	12-11-25
196	01-11-26
197	02-11-26
198	03-11-26
199	04-11-26
200	05-11-26
201	06-11-26
202	07-11-26
203	08-11-26
204	09-11-26
205	10-11-26
206	11-11-26
207	12-11-26
208	01-11-27
209	02-11-27
210	03-11-27
211	04-11-27
212	05-11-27
213	06-11-27
214	07-11-27
215	08-11-27
216	09-11-27
217	10-11-27
218	11-11-27
219	12-11-27
220	01-11-28
221	02-11-28
222	03-11-28
223	04-11-28
224	05-11-28
225	06-11-28
226	07-11-28
227	08-11-28
228	09-11-28
229	10-11-28
230	11-11-28
231	12-11-28
232	01-11-29
233	02-11-29
234	03-11-29
235	04-11-29
236	05-11-29
237	06-11-29
238	07-11-29
239	08-11-29
240	09-11-29
241	10-11-29
242	11-11-29
243	12-11-29
244	01-11-30
245	02-11-30
246	03-11-30
247	04-11-30
248	05-11-30
249	06-11-30
250	07-11-30
251	08-11-30
252	09-11-30
253	10-11-30
254	11-11-30
255	12-11-30
256	01-11-31
257	02-11-31
258	03-11-31
259	04-11-31
260	05-11-31
261	06-11-31
262	07-11-31
263	08-11-31
264	09-11-31
265	10-11-31
266	11-11-31
267	12-11-31
268	01-12-01
269	02-12-01
270	03-12-01
271	04-12-01
272	05-12-01
273	06-12-01
274	07-12-01
275	08-12-01
276	09-12-01
277	10-12-01
278	11-12-01
279	12-12-01
280	01-12-02
281	02-12-02
282	03-12-02
283	04-12-02
284	05-12-02
285	06-12-02
286	07-12-02
287	08-12-02
288	09-12-02
289	10-12-02
290	11-12-02
291	12-12-02
292	01-12-03
293	02-12-03
294	03-12-03
295	04-12-03
296	05-12-03
297	06-12-03
298	07-12-03
299	08-12-03
300	09-12-03
301	10-12-03
302	11-12-03
303	12-12-03
304	01-12-04
305	02-12-04
306	03-12-04
307	04-12-04
308	05-12-04
309	06-12-04
310	07-12-04
311	08-12-04
312	09-12-04
313	10-12-04
314	11-12-04
315	12-12-04
316	01-12-05
317	02-12-05
318	03-12-05
319	04-12-05
320	05-12-05
321	06-12-05
322	07-12-05
323	08-12-05
324	09-12-05
325	10-12-05
326	11-12-05
327	12-12-05
328	01-12-06
329	02-12-06
330	03-12-06
331	04-12-06
332	05-12-06
333	06-12-06
334	07-12-06
335	08-12-06
336	09-12-06
337	10-12-06
338	11-12-06
339	12-12-06
340	01-12-07
341	02-12-07
342	03-12-07
343	04-12-07
344	05-12-07
345	06-12-07
346	07-12-07
347	08-12-07
348	09-12-07
349	10-12-07
350	11-12-07
351	12-12-07
352	01-12-08
353	02-12-08
354	03-12-08
355	04-12-08
356	05-12-08
357	06-12-08
358	07-12-08
359	08-12-08
360	09-12-08
361	10-12-08
362	11-12-08
363	12-12-08
364	01-12-09
365	02-12-09
366	03-12-09
367	04-12-09
368	05-12-09
369	06-12-09
370	07-12-09
371	08-12-09
372	09-12-09
373	10-12-09
374	11-12-09
375	12-12-09
376	01-12-10
377	02-12-10
378	03-12-10
379	04-12-10
380	05-12-10
381	06-12-10
382	07-12-10
383	08-12-10
384	09-12-10
385	10-12-10
386	11-12-10
387	12-12-10
388	01-12-11
389	02-12-11
390	03-12-11
391	04-12-11
392	05-12-11
393	06-12-11
394	07-12-11
395	08-12-11
396	09-12-11
397	10-12-11
398	11-12-11
399	12-12-11
400	01-12-12
401	02-12-12
402	03-12-12
403	04-12-12
404	05-12-12
405	06-12-12
406	07-12-12
407	08-12-12
408	09-12-12
409	10-12-12
410	11-12-12
411	12-12-12
412	01-12-13
413	02-12-13
414	03-12-13
415	04-12-13
416	05-12-13
417	06-12-13
418	07-12-13
419	08-12-13
420	09-12-13
421	10-12-13
422	11-12-13
423	12-12-13
424	01-12-14
425	02-12-14
426	03-12-14
427	04-12-14
428	05-12-14
429	06-12-14
430	07-12-14
431	08-12-14
432	09-12-14
433	10-12-14
434	11-12-14
435	12-12-14
436	01-12-15
437	02-12-15
438	03-12-15
439	04-12-15
440	05-12-15
441	06-12-15
442	07-12-15
443	08-12-15
444	09-12-15
445	10-12-15
446	11-12-15
447	12-12-15
448	01-12-16
449	02-12-16
450	03-12-16
451	04-12-16
452	05-12-16
453	06-12-16
454	07-12-16
455	08-12-16
456	09-12-16
457	10-12-16
458	11-12-16
459	12-12-16
460	01-12-17
461	02-12-17
462	03-12-17
463	04-12-17
464	05-12-17
465	06-12-17
466	07-12-17
467	08-12-17
468	09-12-17
469	10-12-17
470	11-12-17
471	12-12-17
472	01-12-18
473	02-12-18
474	03-12-18
475	04-12-18
476	05-12-18
477	06-12-18
478	07-12-18

REV	DATE	BY	CHKD	DESCRIPTION
1	08/14/10	SAH	SAH	ISSUED FOR PERMITS
2	08/14/10	SAH	SAH	REVISED PER COMMENTS
3	08/14/10	SAH	SAH	REVISED PER COMMENTS
4	08/14/10	SAH	SAH	REVISED PER COMMENTS
5	08/14/10	SAH	SAH	REVISED PER COMMENTS
6	08/14/10	SAH	SAH	REVISED PER COMMENTS
7	08/14/10	SAH	SAH	REVISED PER COMMENTS
8	08/14/10	SAH	SAH	REVISED PER COMMENTS
9	08/14/10	SAH	SAH	REVISED PER COMMENTS
10	08/14/10	SAH	SAH	REVISED PER COMMENTS



FOR AREA A SEE 8030-X-149715

FOR AREA B SEE 8030-X-149715

FOR AREA C SEE 8030-X-149716

FOR AREA D SEE 8030-X-149717

FOR AREA E SEE 8030-X-149718

**AREA KEY PLAN**

TOTAL CUT 220,000yd<sup>3</sup>

TOTAL FILL 221,800yd<sup>3</sup>

**CONFIDENTIAL**  
**INFORMATION**

**GRADING PLAN**  
SCALE: 1"=30'

PREPARED FOR: AMTRAK

**SITE GRADING PLAN**

**AREA B**

PROJECT: MERAMEC RAIL FACILITY







DATE: 08/14/10

ST. LOUIS, MISSOURI

8030-X-149715



REV.	DATE	BY	CHKD.
0	12/21/00		
1	03/08/01		
2	03/08/01		
3	03/08/01		
4	03/08/01		
5	03/08/01		
6	03/08/01		
7	03/08/01		
8	03/08/01		
9	03/08/01		
10	03/08/01		
11	03/08/01		
12	03/08/01		
13	03/08/01		
14	03/08/01		
15	03/08/01		
16	03/08/01		
17	03/08/01		
18	03/08/01		
19	03/08/01		
20	03/08/01		



**CONFIDENTIAL  
INFORMATION**


- NOTES
1. THIS DRAWING IS TO BE USED IN ACCORDANCE WITH U.S. SPEC. FOR CONCRETE.
  2. ALL DIMENSIONS UNLESS OTHERWISE NOTED ARE IN FEET AND INCHES.
  3. CHECK FOR ALL DIMENSIONS AND REVISIONS BEFORE CONSTRUCTION.

REV. 0 SEALED


STRUCTURE - CONCRETE  
ASH POND - DISCHARGE STRUCT.

MEMEC PLANT


UNION ELECTRIC COMPANY




TYPICAL PIPE SUPPORT  
 NOT TO SCALE  
 8020-X-61041




SECTION  
 SCALE 1/4\"/>




UPPER GUIDE RAIL BRACKET DETAIL  
 NOT TO SCALE  
 8020-X-61041




PIPE GUIDE-ONE REQUIRED  
 PLAN NOT TO SCALE  
 8020-X-M4580




(TYP.) PIPE RESTRAINTS SECTION  
 NOT TO SCALE  
 (FOR PIPE GUIDE)




CONN. TO EXIST. 2\"/>
 NOT TO SCALE  
 8020-X-61041




(TYP.) SADDLE SECTION FOR PIPE ANCHOR  
 NOT TO SCALE



ELEVATION OF PIPE ANCHOR  
 NOT TO SCALE  
 8020-X-61041




ELEVATION OF PIPE ANCHOR  
 NOT TO SCALE  
 8020-X-61041




CONCRETE DRAIN SUMP DISCHARGE  
 NOT TO SCALE  
 8020-X-M4580

DISCHARGE PUMPS FOR NEW ASH POND-MERAMEC PLANT							
PLAN MARK	MANUFACTURER	MODEL	WEIGHT	CAPACITY	MOTOR	POWER SUPPLY TO MOTOR	REMARKS/ MANUFACTURER'S ACCESSORIES TO PROVIDED
PUMP A AND PUMP B	FLYGT SUBMERSIBLE PUMP WITH DISCHARGE ASSEMBLY AND GUIDE RAIL SYSTEM	C-3110 2\"/>					


- FURNISH 8\"/>
- FURNISH DISCHARGE ASSEMBLY FOR CONNECT-DISCONNECT FROM ABOVE SUMP AND GUIDE RAIL SYSTEM WITH PUMP - FLYGT 214 TO 85\"/>
- FURNISH DUPLEX PUMP CONTROL PANEL WITH BENT IN ENCLOSURE. ALL PUMP CONTROLS, STARTERS, CONTROLS, TRANSFORMERS, VALVES AND ACCESSORIES SHALL BE FACTORY INSTALLED IN THE PANEL. ALL START, STOP AND OVERLOAD PROTECTION SHALL BE INCLUDED. CONTROLS AND WIRING SHALL INCLUDE THERMAL AND LEAK DETECTION ON MAIN WIRING AND SIGNALING. CONTACTS SHALL BE INCLUDED. CONTROLS SHALL AUTOMATICALLY RESET UPON LOSS OF POWER AND RESTART AFTER POWER IS RESTORED. FOUR LIQUID LEVEL SENSORS SHALL BE INSTALLED IN THE SUMP - FROM BOTTOM TO TOP - 1ST SENSOR SHALL STOP ALL PUMPS WHEN WATER IS LOWER THAN TOP OF WALKWAY. 2ND SENSOR SHALL START LEAD PUMP WHEN LEVEL IS ABOVE TOP OF WALKWAY. 3RD SENSOR SHALL START LEAD PUMP WHEN LEVEL IS ABOVE TOP OF WALKWAY. 4TH SENSOR SHALL START LEAD PUMP WHEN LEVEL IS ABOVE TOP OF WALKWAY. 5TH SENSOR SHALL START LEAD PUMP WHEN LEVEL IS ABOVE TOP OF WALKWAY. FLYGT 1-3000 3\"/>
- FURNISH FLYGT 8\"/>
- LIFTING CHAIN AND SAFETY CABLE.




ASH POND DISCHARGE STRUCTURE  
 NOT TO SCALE



FLY ASH POND DISCHARGE STRUCTURE  
 SCALE 1/4\"/>




DISCHARGE FLOW FOUNDATION DETAIL  
 NOT TO SCALE  
 8020-X-61041



INTERMEDIATE GUIDE RAIL BRACKET DETAIL  
 NOT TO SCALE  
 8020-X-61041

**CONFIDENTIAL INFORMATION**



ASH POND DISCHARGE FLOW CHART  
 NOT TO SCALE

8020-X-144585

PREPARED FOR: AMERICAN

DATE: 05/20/09

PROJECT: FLY ASH-ASH POND DRAIN PIPING PLAN & DETAILS


CLIENT: 1998 ASH HANDLING MOOS.

LOCATION: MERAMEC PLANT

ST. LOUIS, MISSOURI

8020-X-144585

CONFIDENTIAL INFORMATION



PLAN SCALE 1"=50'-0"

NOTE: MINIMUM SLOPES INDICATED ON DRAWINGS FOR TEMPORARY EXCAVATION ARE RECOMMENDED VALUES...

LEGEND: C.C.C. INDICATES STRUCTURAL/CIVIL - CONSTRUCTION CONTRACTOR...

- INDEX OF FLUOR PIONEER DRAWINGS
1. 8030-X-91925 PLANT DRAINAGE PLAN - STRUCTURAL COMPONENTS...

- LIST OF UNION ELECTRIC REFERENCE DRAWINGS
1. 0000-W-20288 PROPERTY - GENERAL YARD PLAN...

- GENERAL NOTES
1. FOR SPECIFICATION, SEE SPECIFICATION NO. MER-207...


REVISIONS table with columns for revision number, description, and date.

RELEASED FOR PERMITS AS REQUESTED BY M. BECKER...



Project information block including company name (Fluor Pioneer Inc.), project name (Plant Drainage Plan), and drawing number (8030-X-91925-0).

CONFIDENTIAL INFORMATION



**REVISIONS**

2] 420'-5 WAS	RELEASED FOR
420'-2 (H-4) 8' 4"	INFORMATION &
WAS 6'-0 3/4 (J-8) 1'	REVIEW ONLY
DOWN: E.L. 9-3-77	FILMED: 11-9-76
CAKDD: RW 8/11/77	
APPD: 2/2-1-77	A] REDRAWN &
FILMED: 5-5-77	RELEASED FOR
	INFORMATION &
	REVIEW ONLY
	FILMED: 2-15-79
	B] REVISED PIPE
	ROUTING OF 24" &
	6" ABS TO ASH
	POND & 6" ABS TO
	AVOID EXIST. PIPE
	NEAR CLARIFIER
	"A" (E-9) ADDED
	SECT. "3-3" (A-5) &
	SECT. "4-4" (F-1) &
	UPDATED SECT.
	"1-1" (B-1) & SECT.
	"2-2" (D-1) REVISED
	LINE TO DEMIN.
	DRAIN SUMP (E-9)
	ISSUED FOR BIDS.
	FILMED: 4-23-79
	C] ADDED 1" BEARING
	LUBRICATION LINE
	FROM WTR. TRTMT.
	BLDG. TO COMB.
	DRAIN SUMP (E-4)
	& DEMIN. DRAIN
	SUMP (E-1) UPDATED
	SECT. "2-2" (D-4) &
	REROUTED 24" &
	6" ABS (E-2-4-5-6) &
	UPDATED SECT. "1-1"
	(B-1) & SECT. "4-4"
	(F-1). DELETED
	SECT. "3-3" (B-9)
	ADDED NOTE 6 (H-1)
	REISSUED FOR BIDS
	FILMED: 5-23-79
	D] ADDED NOTE 7
	(H-1). 20" PIPE WAS
	24" (C-1, C-3, E 4-5)
	F-5
	COORD. N. 1130.66
	WAS W. 1130.66,
	W. 1124.45 WAS
	N. 1124.45 (C-1)
	W. 1113.04 WAS
	W. 1102.84 (E-4),
	EL. 419'-2 1/2" WAS
	414'-0" (C-1), EL.
	419'-4 7/8" WAS
	417'-0" (C-3), EL.
	419'-1 1/4" WAS 418'-0"
	(E-4), EL. 419'-1 7/8"
	WAS 418'-6" (E-4),
	EL. 420'-2 1/2" WAS
	419'-0" (F-5).
	UPDATED SECT.
	"1-1" (B-1) & "4-4"
	(F-1). SUMP
	DISCH. WAS 16"
	(J-3) ADDED NOTE
	10 6 (F-7) & SECT.
	"5-5" (A-5)
	ISSUED FOR
	CONSTRUCTION
	(PERMIT)
	FILMED: 4-30-79
	E] 20" FIBERCAST WAS
	FIBERGLASS (C-1, D-1,
	C-3, E-4, F-5). REROUTED
	6" ABS TO CONNECT TO
	20" FIBERCAST (E-5). BLDG.
	DELETED 6" ABS FROM
	CULVERT PIPE (E-2).
	ADDED HEAT TRACE
	TO 4" LINE & EXTENDED
	HEAT TRACE BELOW
	GROUND FOR WTR. (F-8)
	ISSUED FOR
	CONSTRUCTION
	DOWN: DW 1-13-77
	CIRCD: DW 1/27/77
	APPD: 2/2-1-77
	FILMED: 7-24-79

**GENERAL NOTES:**

1. ALL NEW PIPING SHOWN SOLID LINES ONLY.
2. ALL COORDINATES AND EXISTING PIPE ELEVATIONS TO BE VERIFIED IN FIELD.
3. YARD GRADE EL. 418'-0".
4. PIPE ELEVATIONS ARE & UNLESS OTHERWISE NOTED.
5. CORRUGATED CULVERT PIPE TO BE 14 GA ASTM A-44.
6. 6" ABS TO BE COVERED, MUST NOT BE EXPOSED TO SUNLIGHT.
7. 12" WIDE X VARIABLE HEIGHT WOOD SUPPORT LOCATED ON 30 FT MAX. CENTERS. DO NOT LOCATE SUPPORTS UNDER PIPE COUPLINGS.

**ASSOCIATED DWGS**

8020-X-91920 FLOW DIAGRAM  
 8020-X-91922 PIPING PLANS & SECTIONS  
 8020-X-91923 DRAINING FROM DEMIN BLDG

**REFERENCE DWGS**

8000-W-20288  
 8000-X-21494  
 8000-X-27412  
 8011-X-7607  
 8012-X-8684  
 8013-X-16878  
 8014-X-23506  
 8020-X-6354  
 8020-X-14289  
 8020-X-27029  
 8020-X-25291  
 C-11-18 PAGE 3-13  
 8020-X-96105  
 8020-X-53849

**ENLARGED PLAN**  
 SCALE: 1"=10'


**PLAN**  
 SCALE: 1"=50'

**SECTION "4-4"**  
 TYPICAL VIEW BENEATH THE ROAD  
 SCALE: 3/8"=1'-0"

**SECTION "2-2"**  
 SCALE: 3/8"=1'-0"

**SECTION "1-1"**  
 SCALE: 3/8"=1'-0"

**SECTION "5-5"**  
 SCALE: 3/8"=1'-0"



**UNION ELECTRIC COMPANY**  
 ST. LOUIS, MISSOURI  
 MERAMEC PLANT


**FLUOR PIONEER INC.**

PROJECT NO. 104192

DWG NO. 8020-X-91921

DATE 7

REVISED SYSTEMS  
ADDED BUBBLER SYSTEMS



REVISIONS
1. 20" FIBERCAST WAS FIBERGLASS (E4E5), REROUTED DEMIN. DRAIN SUMP DISCH. (F8 & E6). IDENT. COMB. DRAIN SUMP INLET OVERFLOW AS BY STRUCT. CONTR. (F5). 3/6" DRAIN TO COMB. DR. SUMP & DEMIN. DR. SUMP WAS 1/2" (E5 & G6). ADDED 1/2" PIPED FLY ASH POND LINE (H). SHOWED MAIN BREAK IN 1" BEARING OVERFLOW DISCH. SUMP (G6).
2. 1" TO FLOATING SKIMMER WAS 1/2" (G5 & H5). 1" SAFETY VALVE WAS 1/2" (G5) REVISED CO2 SYSTEM SUPPLIED BY CO2 CONTR. (G1-G4) DOWN BW 1/2" (G7) CHKD: MW 9/27/77 APPD: MW 10/1/77 FILMED: 11-9-77
3. ADDED NO. CO2 CONTR. TO PI (G2) REV. VALVE FCV-GSC-Z-1106 (H3) 4550 GPM WAS 5000 GPM. ADDED RED TO COMB. DR. SUMP PUMP (E6) DOWN BW 3/4" (G7) CHKD: MW 9/6/77 APPD: MW 9/6/77 FILMED: 9-6-77
4. ADDED 1" BEARING LUBRICATION LINE TO COMB. DRAIN SUMP (F-7) & DEMIN. DRAIN SUMP (G-9). CHANGED COORD. N. 1124.45 WAS N. 1176 & W. 1130.66 WAS W. 1059.06 (E-2 (F8)). CHANGED LINE SIZE 24" WAS 20" (J-3). REISSUED FOR BIDS. FILMED: 5-13-79
5. RELOCATED RELIEF VALVE TO BE ADJACENT TO ROTOMETER # 11 & 12. TO BE UPSTREAM OF ROTOMETER (E-4). RELOCATE SUCT. FOR SAMPLE PUMP (H) TRAPHOSE (J-6). ADDED EVO NUMBERS (E-8). 20" DISCH. WAS 24" (E-4). ADDED NOTE (E-7) COORD. W. 1124.45 WAS N. 1124.45 & N. 1130.66 WAS W. 1130.66 (E-7 (F-8)). COMB. DRAIN SUMP PUMPS WERE 6000 GPM & 16" DISCH. (E-1 (F7)). DEMIN. DRAIN SUMP PUMPS HAD 3" DISCH. (F8 (10)). ADDED FIBERGLASS NOTE (E-8) ADDED 1/2" DRAIN LINE CONN. (E-4 (G-12)).
ISSUED FOR CONSTRUCTION. (PERMIT) FILMED: 4-30-79



UNION ELECTRIC COMPANY  
ST. LOUIS, MISSOURI 63103

**FLOW DIAGRAM  
WASTE WATER TREATMENT**

Prepared by  
**FLUOR PIONEER INC.**  
CHICAGO, ILLINOIS


DESIGNED BY	DATE	PROJECT NO.	SHEET NO.
REVIEWED BY	DATE	PROJECT NO.	SHEET NO.
APPROVED BY	DATE	PROJECT NO.	SHEET NO.

PROJECT NO. 104198  
SHEET NO. 4

ASSOCIATED DWG.  
8020-X-91921 PIPING PLOT PLAN

8020-X-91920

REV 6	DATE	BY	CHKD	APPD
REV 7	DATE	BY	CHKD	APPD
REV 8	DATE	BY	CHKD	APPD
REV 9	DATE	BY	CHKD	APPD
REV 10	DATE	BY	CHKD	APPD
REV 11	DATE	BY	CHKD	APPD



DRAWING 1

- 1. CHANGES TO BE MADE TO THIS DRAWING.
- 2. PUMP AND PRESSURE AS SHOWN ON THIS DRAWING.
- 3. CHANGES TO BE MADE TO THIS DRAWING AS SHOWN ON THIS DRAWING.

NO. 01	NOT CHD	NO. 01	NO. 01
NPOES FLOW DIAGRAM WATER BALANCE FOLLOWING PROPOSED MODIFICATION			
M. BOLLINGER		MERAMEC PLANT	
ST. LOUIS, MISSOURI		8000-X-53973	

APPENDIX A

DOC 1.4 AMERENUE RESPONSE TO EPA'S RFI

**AmerenUE Response**

Meramec Power Station  
8200 Fine Road  
St. Louis, Missouri 63129

1. Coal-combustion by-product surface impoundments at this Station are not classified as dams by State or Federal regulatory agencies so they have not been rated.
2. See table below.

Management Unit	Year Commissioned or Expanded
Old Fly Ash Pond	2000
Retention Pond	1977
Bottom Ash Ponds (3)	1950s
New Fly Ash Pond	2003

None of these units have been expanded.

3. See table below.

Management Unit	Materials Contained in Unit*
Old Fly Ash Pond	1, 5
Retention Pond	1, 2
Bottom Ash Ponds	2
New Fly Ash Pond	1

- other ?

\*Use the following categories to respond to this question: (1) fly ash; (2) bottom ash; (3) boiler slag; (4) flue gas emission control residuals; (5) other.

Other types of materials that are temporarily or permanently contained in the unit(s) include, but are not limited to residual wastes remaining following treatment of wastewater from these systems: primary water treatment; boiler water make-up treatment; laboratory and sampling streams; boiler blowdown; floor drains; coal pile run off; house service water systems; and pyrites.

4. The management units at this facility were designed by a Professional Engineer. The construction of the management units were done under the supervision of a Professional Engineer. And, inspection and monitoring of the safety of the waste management units is under the supervision of a Professional Engineer.
5. The most recent annual internal professional engineering inspection of the management units occurred in 2009. Since these management units are not classified by regulation as dams the evaluation only included a visual inspection of the units. AmerenUE has formed a Dam Safety Group consisting of civil and geotechnical engineers who oversee the implementation of the company Dam Safety Program and this Group is supervised by a licensed Professional Engineer. The Dam Safety Program requires routine, annual and special inspection of the ash ponds and employees performing these inspections receive dam safety training. If maintenance issues are identified in these visual inspections, then corrective actions are taken by either plant employees or contractors to remedy the issue and final acceptance of the work is reviewed and evaluated by Dam Safety Group personnel.
6. No State, or Federal regulatory official has inspected or evaluated the safety (structural integrity) of the management unit(s), and we are not aware of a planned state or federal inspection or evaluation in the future.
7. Not applicable, see response to Question 6.
8. See table below.

Management Unit	Surface Area (Acres)	Total Storage Capacity (Acre-ft)	Volume of Stored Ash (Acre-ft)	Maximum Height of Unit (ft.)
Old Fly Ash Pond #914, 495	17.6	300	260	25
Retention Pond ✓	0.7	10	minimal	25
Bottom Ash Ponds 492, 496, 493	14	280	171	25
New Fly Ash Pond 498 -	13.5	230	190	25

9. Assuming that brief history means incident(s) which could have occurred in the last ten (10) years, we are not aware of any spills or unpermitted releases of coal-combustion by-products from our surface impoundments to surface water or to the land.
10. The current legal owner and operator at the facility is AmerenUE

*Ameren Services*

*Environmental Services*  
314.554.2388 (Phone)  
314.554.4182 (Facsimile)  
ppike@ameren.com

One Ameren Plaza  
1901 Chouteau Avenue  
PO Box 66149  
St. Louis, MO 63166-6149

May 4, 2009

Mr. Richard Kinch  
US Environmental Protection Agency (53306P)  
1200 Pennsylvania Avenue, NW  
Washington, DC 20460



RE: Request for Information under Section 104 (e) of the Comprehensive Environmental Response, Compensation, and Liability Act, 42 U.S.C. 9604(e)

Dear Mr. Kinch:

This letter is in response to the letter sent to Mr. Thomas Voss who is the Chief Executive Officer of AmerenUE regarding the United States Environmental Protection Agency's request for information relating to the surface impoundments or similar diked or bermed management unit(s) or management units designated as landfills which receive liquid-borne material from a surface impoundment used for the storage or disposal of residuals or by-products from the combustion of coal, including, but not limited to, fly ash, bottom ash, boiler slag, or flue gas emission control residuals.

AmerenUE operates four coal-fired power stations in Missouri and responses for those facilities were sent to you within the required ten (10) business days of receipt of their letters. AmerenUE has no additional facilities which have surface impoundments or similar diked or bermed management unit(s) or management units designated as landfills which receive liquid-borne material from a surface impoundment used for the storage or disposal of residuals or by-products from the combustion of coal, including, but not limited to, fly ash, bottom ash, boiler slag, or flue gas emission control residuals.

Although our surface impoundments are not considered to be dams by State or Federal regulations, we are subject to State and Federal NPDES regulations and have had Agency personnel inspect these units. We are providing a full and complete response to each separate request for information set forth in your Enclosure A (attached) with responses corresponding to numbering in your questions. If you have any further questions please feel free to contact Paul Pike at (314) 554-2388.

I certify that the information contained in this response to EPA's request for information and the accompanying documents is true, accurate, and complete. As to the identified portions of this response for which I cannot personally verify their accuracy, I certify under penalty of law that this response and all attachments were prepared in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael L. Menne". The signature is written in a cursive style with a large initial "M".

Michael L. Menne  
Vice President – Environmental Services

*Ameren Services*

*Environmental Services*  
314.554.2388 (Phone)  
314.554.4182 (Facsimile)  
ppike@ameren.com

One Ameren Plaza  
1901 Chouteau Avenue  
PO Box 66149  
St. Louis, MO 63166-6149

March 26, 2009

Mr. Richard Kinch  
US Environmental Protection Agency (53306P)  
1200 Pennsylvania Avenue, NW  
Washington, DC 20460



RE: Request for Information under Section 104 (e) of the Comprehensive Environmental Response, Compensation, and Liability Act, 42 U.S.C. 9604(e)

Dear Mr. Kinch:

This letter and attachments are AmerenUE's response to the United States Environmental Protection Agency's request for information relating to the surface impoundments or similar diked or bermed management unit(s) or management units designated as landfills which receive liquid-borne material from a surface impoundment used for the storage or disposal of residuals or by-products from the combustion of coal, including, but not limited to, fly ash, bottom ash, boiler slag, or flue gas emission control residuals.

AmerenUE operates four coal-fired power stations in Missouri. Although our surface impoundments are not considered to be dams by State or Federal regulations, we are subject to State and Federal NPDES regulations and have had Agency personnel inspect these units. We are providing a full and complete response to each separate request for information set forth in your Enclosure A (attached) with responses corresponding to numbering in your questions. If you have any further questions please feel free to contact Paul Pike at (314) 554-2388.

I certify that the information contained in this response to EPA's request for information and the accompanying documents is true, accurate, and complete. As to the identified portions of this response for which I cannot personally verify their accuracy, I certify under penalty of law that this response and all attachments were prepared in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, those persons directly responsible for gathering the information, the information submitted is, to the best of my

knowledge, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael L. Menne". The signature is written in a cursive style with a large initial "M".

Michael L. Menne  
Vice President – Environmental Services

## Enclosure A

Please provide the information requested below for each surface impoundment or similar diked or bermed management unit(s) or management units designated as landfills which receive liquid-borne material for the storage or disposal of residuals or by-products from the combustion of coal, including, but not limited to, fly ash, bottom ash, boiler slag, or flue gas emission control residuals. This includes units that no longer receive coal combustion residues or by-products, but still contain free liquids.

1. Relative to the National Inventory of Dams criteria for High, Significant, Low, or Less-than-Low, please provide the potential hazard rating for each management unit and indicate who established the rating, what the basis of the rating is, and what federal or state agency regulates the unit(s). If the unit(s) does not have a rating, please note that fact.
2. What year was each management unit commissioned and expanded? ;
3. What materials are temporarily or permanently contained in the unit? Use the following categories to respond to this question: (1) fly ash; (2) bottom ash; (3) boiler slag; (4) flue gas emission control residuals; (5) other. If the management unit contains more than one type of material, please identify all that apply. Also, if you identify "other," please specify the other types of materials that are temporarily or permanently contained in the unit(s).
4. Was the management unit(s) designed by a Professional Engineer? Is or was the construction of the waste management unit(s) under the supervision of a Professional Engineer? Is inspection and monitoring of the safety of the waste-management unit(s) under the supervision of a Professional Engineer?
5. When did the company last assess or evaluate the safety (i.e., structural integrity) of the management unit(s)? Briefly describe the credentials of those conducting the structural integrity assessments/evaluations. Identify actions taken or planned by facility personnel as a result of these assessments or evaluations. If corrective actions were taken, briefly describe the credentials of those performing the corrective actions, whether they were company employees or contractors. If the company plans an assessment or evaluation in the future, when is it expected to occur?
6. When did a State or a Federal regulatory official last inspect or evaluate the safety (structural integrity) of the management unit(s)? If you are aware of a planned state or federal inspection or evaluation in the future, when is it expected to occur? Please identify the Federal or State regulatory agency or department which conducted or is planning the inspection or evaluation. Please provide a copy of the most recent official inspection report or evaluation.
7. Have assessments or evaluations, or inspections conducted by State or Federal regulatory officials conducted within the past year uncovered a safety issue(s) with the management unit(s), and, if so, describe the actions that have been or are being taken to deal with the issue or issues. Please provide any documentation that you have for these actions.

**8. What is the surface area (acres) and total storage capacity of each of the management units? What is the volume of materials currently stored in each of the management unit(s)? Please provide the date that the volume measurement(s) was taken. Please provide the maximum height of the management unit(s). The basis for determining maximum height is explained later in this Enclosure.**


**9. Please provide a brief history of known spills or unpermitted releases from the unit within the last ten years, whether or not these were reported to State or federal regulatory agencies. For purposes of this question, please include only releases to surface water or to the land (do not include releases to groundwater).**

**10. Please identify all current legal owner(s) and operator(s) at the facility.**

APPENDIX A

DOC 1.5 ASH POND #494 DRILLING AND PIEZOMETER INSTALLATION FIGURES  
AND LOGS

**FIGURES**



FENCE & CARLING  
8020-X-155783

Existing Settling Pond  
area = 14434.007 sq ft

PROPOSED  
AREA OF FULL-  
DEPTH ASH  
EXCAVATION

POND 494  
CLASS F ASH

Excavation around towers to  
be performed evenly such  
that unequal loading of ash  
does not occur

**LEGEND**



**NOTES**

1.) BASE MAP AND AERIAL IMAGE PROVIDED BY AmerenUE.

REV	DATE	DES	REVISION DESCRIPTION	CADD	CHK	RW

PROJECT  
**AMEREN SERVICES  
MERAMEC ASH POND 494 MONITORING**  
Meramec Plant, Missouri

TITLE  
**PIEZOMETER LOCATIONS & SITE LAYOUT**

PROJECT No.	073-84012	FILE No.	07384012A001
DESIGN	MNH 07/02/07	SCALE	AS SHOWN
CADD	JCW 07/03/07	REV.	0
CHECK	MSL 02/08/08		
REVIEW	MNH 02/26/08		



**TABLES**

TABLE 1  
PIEZOMETER CONSTRUCTION DETAILS - MERAMEC POWER PLANT

Piezometer ID	Ground Surface Elevation (ft MSL)	Borehole Depth (ft BGS)	Top of Piezometer Casing Elevation (ft MSL)	Piezometer Screen Length (feet)	Piezometer Screen Depth (ft BGS)		Piezometer Screen Elevation (ft MSL)		Static Water Level 10/25/07 ft MSL
					Top	Bottom	Top	Bottom	
PZ-1	413.25	41.5	416.30	9.6	31.6	41.2	381.7	372.1	392.80
PZ-2	416.20	25.0	419.05	9.6	15.1	24.7	401.1	391.5	400.26
PZ-3	414.30	45.0	417.36	9.9	34.7	44.6	379.6	369.7	385.85
PZ-4	414.57	25.0	417.27	9.6	15.1	24.7	399.5	389.9	400.80
PZ-5	420.32	25.0	423.39	9.5	15.1	24.7	405.2	395.6	405.55

Notes:

ft BGS - feet Below Ground Surface

ft MSL - Mean Sea Level

Wells surveyed by Sterling Co. Engineers & Surveyors.

Checked by: JCW

Reviewed by: MNH

**TABLE 2**  
**SUMMARY OF GEOTECHNICAL LABORATORY RESULTS - MERAMEC POWER PLANT**

Sample Identification	Sample Type	Sample Depth (ft)	Soil Classification	Natural Moisture %	Atterberg Limits				Unit Weight		Additional Tests Conducted (See Abbreviations)
					L.L.	P.L.	P.I.	L.I.	Moisture %	Dry (lb/cuft)	
PZ-1 S-002	SS	9 - 10.5	CL	25.7	40	21	19	0.23	NA	NA	
PZ-1 S-003	ST	14.5 - 16.5	CH	32.5	61	23	38	0.24	37.1	83.8	T
PZ-1 S-007	SS	29.5 - 31	CH	31.8	67	24	43	0.18	NA	NA	
PZ-3 S-002	SS	9 - 10.5	CH	39.8	67	24	43	0.36	NA	NA	
PZ-3 S-003	ST	14 - 16	CH	37.8	77	27	50	0.22	37.9	81.2	T
PZ-3 S-007	SS	29 - 30.5	CH	38.5	59	22	37	0.45	NA	NA	

ABBREVIATIONS: LIQUID LIMIT (L.L.)  
 PLASTIC LIMIT (P.L.)  
 PLASTICITY INDEX (P.I.)  
 LIQUIDITY INDEX (L.I.)  
 TRIAXIAL COMPRESSIVE STRENGTH (T)  
 NOT APPLICABLE (NA)

Checked By: MNH

**APPENDICIES**

**APPENDIX A  
PIEZOMETER BOREHOLE LOGS**

# RECORD OF BOREHOLE PZ-1

SHEET 1 of 3  
ELEVATION: 413.25  
INCLINATION: -90

PROJECT: Ameren - Meramec Fly Ash  
PROJECT NUMBER: 073-84012  
LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 inch ID HSA  
DRILLING DATE: 8/14/2007  
DRILL RIG: CME 75D

DATUM: LOCAL  
AZIMUTH: N/A  
COORDINATES: N: E:

DEPTH (feet)	BORING METHOD	SOIL PROFILE			SAMPLES				PENETRATION RESISTANCE BLOWS / ft		REMARKS				
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV. DEPTH (ft)	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT		WATER CONTENT (PERCENT)			
												W <sub>p</sub>	W <sub>L</sub>		
0	4.25 inch ID HSA	(0-9.5) Firm, medium gray (N5) to black (N1) with mottled appearance, CLAYEY SILT, trace fine sand, moist (ML)	ML		403.8 9.5										
5		1				SS	2 calitic	11	1.3 1.5						
							HSA	N/A	N/A	N/A 4.5					
10		(9.5-39.5) Soft, medium gray (N5), SILTY CLAY, trace F-C sand, moist (CL)	CL		398.8 14.5	2	SS	1 calitic	4	0.8 1.5					
							HSA	N/A	N/A	N/A 3.5					
15		below 14.5, predominantly CLAY (CH)	CH		393.8 19.5	3	SH	N/A	N/A	1.8 2.0					
									4	SS	2 3	5	0.9 1.5		
							HSA	N/A	N/A	N/A 1.5					
20		19.5-21.0, trace organics				5	SS		13	0.5 1.5					

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR\_CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
DRILLING CONTRACTOR: Lane Western  
DRILLER: D. Mahurin

LOGGED: MRF  
CHECKED: MNH  
DATE: 2/26/08



Log continued on next page

# RECORD OF BOREHOLE PZ-1

SHEET 2 of 3  
ELEVATION: 413.25  
INCLINATION: -90

PROJECT: Ameren - Meramec Fly Ash  
PROJECT NUMBER: 073-84012  
LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 inch ID HSA    DATUM: LOCAL  
DRILLING DATE: 8/14/2007    AZIMUTH: N/A  
DRILL RIG: CME 75D    COORDINATES: N: E:

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES				PENETRATION RESISTANCE BLOWS / ft		REMARKS	
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV. DEPTH (ft)	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)		
											W <sub>p</sub>		W <sub>L</sub>
20	4.25 inch ID HSA	below 14.5, predominantly CLAY (CH) <i>(Continued)</i>	CH			5	SS	2 1.5	13	0.5 1.5			
					HSA	N/A	N/A	N/A 3.5					
25					6	SS	2 1.5	4	1.2 1.5				
					HSA	N/A	N/A	N/A 3.5					
30		below 29.5, moderate reddish brown (10R 4/6) mottling, wet				7	SS	2 4	6	1.5 1.5			
					HSA	N/A	N/A	N/A 3.5					
35		below 34.5, very soft, trace fine sand				8	SS	N/A WH 2	2	1.5 1.5			
					HSA	N/A	N/A	N/A 3.5					
40		Log continued on next page	ML		9	SS		2	1.5 1.5				

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR\_CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
DRILLING CONTRACTOR: Lane Western  
DRILLER: D. Mahurin

LOGGED: MRF  
CHECKED: MNH  
DATE: 2/26/08



# RECORD OF BOREHOLE PZ-1

SHEET 3 of 3  
ELEVATION: 413.25  
INCLINATION: -90

PROJECT: Ameren - Meramec Fly Ash  
PROJECT NUMBER: 073-84012  
LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 Inch ID HSA  
DRILLING DATE: 8/14/2007  
DRILL RIG: CME 75D

DATUM: LOCAL  
AZIMUTH: N/A  
COORDINATES: N: E:

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES				PENETRATION RESISTANCE BLOWS / FT				REMARKS		
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV.	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)					
					DEPTH (ft)						10	20	30		40	
40		39.8-40.0 & 40.4-40.6, F-C sand & F gravel seams (39.5-41.0) Very soft, medium gray (N5), CLAYEY SILT, little F-C sand & F gravel, wet (ML) (Continued) END BOREHOLE AT 41.0 FEET BGS.	ML		39.8 372.3 41.0	9	SS	1 1 1	2	1.5 1.5	■	20	40	60	80	

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR\_CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
DRILLING CONTRACTOR: Lane Western  
DRILLER: D. Mahurin

LOGGED: MRF  
CHECKED: MNH  
DATE: 2/26/08





# RECORD OF BOREHOLE PZ-2

SHEET 2 of 2  
ELEVATION: 416.20  
INCLINATION: -90

PROJECT: Ameren - Meramec Fly Ash  
PROJECT NUMBER: 073-84012  
LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 Inch ID HSA  
DRILLING DATE: 8/15/2007  
DRILL RIG: CME 75D

DATUM: LOCAL  
AZIMUTH: N/A  
COORDINATES: N: E:

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES					PENETRATION RESISTANCE BLOWS / ft				REMARKS
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV. DEPTH (ft)	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)				
											W <sub>p</sub>	W <sub>L</sub>	W <sub>P</sub>	W <sub>U</sub>	
20	4.25 INCH HSA	(0.0-26.5) Soft, medium gray (N5), FLY ASH, moist (FILL) (Continued)	N/A		389.7 26.5	4	SS	N/A WH WH	WH	1.5 1.5					Rods heaving. Added ~20gals of water.
						HSA	N/A	N/A	N/A 4.0						
25						5	SS	N/A WH WH	WH	1.5 1.5					
		END BOREHOLE @ 26.5 FEET BGS.													
30															
35															
40															

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR\_CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
DRILLING CONTRACTOR: Lane Western  
DRILLER: D. Mahurin

LOGGED: MRF  
CHECKED: MNH  
DATE: 2/26/08



# RECORD OF BOREHOLE PZ-3

SHEET 1 of 3

PROJECT: Ameren - Meramec Fly Ash  
 PROJECT NUMBER: 073-84012  
 LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 Inch ID HSA  
 DRILLING DATE: 8/13/2007  
 DRILL RIG: CME 75D

DATUM: LOCAL  
 AZIMUTH: N/A  
 COORDINATES: N: E:

ELEVATION: 414.30  
 INCLINATION: -90

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES				PENETRATION RESISTANCE BLOWS / ft				REMARKS		
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV.	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)					
					DEPTH (ft)						$W_p$ ——— $W_L$ 10 20 30 40 20 40 60 80					
0	4.25 INCH ID HSA	GW	(0.0-9.0) Compact, medium gray (N5) to light gray (N7), SANDY F-C GRAVEL, dry (GW)		405.3											
5						1	SS	clini	11		0.9 1.5		■			
						HSA	N/A	N/A	N/A	3.5						
10		CH	(9.0-35.2) Soft, medium gray (N5) to dark yellowish brown (10YR 4/2), SILTY CLAY, trace F-C sand, moist (CH)		9.0											
	2				SS	1 fin	3		0.8 1.5		■	—○—				
					HSA	N/A	N/A	N/A	3.5							
					3	SH	N/A	N/A	1.5 2.0			—○—				
					4	SS	1 fin	4	0.6 1.5		■					
20																

Log continued on next page

SCALE: 1 in = 2.5 ft  
 DRILLING CONTRACTOR: Lane Western  
 DRILLER: D. Mahurin

LOGGED: MNH  
 CHECKED: MNH  
 DATE: 2/26/08



GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR\_CO.GDT 2/26/08



# RECORD OF BOREHOLE PZ-3

SHEET 3 of 3  
ELEVATION: 414.30  
INCLINATION: -90

PROJECT: Ameren - Meramec Fly Ash  
PROJECT NUMBER: 073-84012  
LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 Inch ID HSA  
DRILLING DATE: 8/13/2007  
DRILL RIG: CME 75D

DATUM: LOCAL  
AZIMUTH: N/A  
COORDINATES: N: E:

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES				PENETRATION RESISTANCE BLOWS / ft				REMARKS	
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV. DEPTH (ft)	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)				
											W, $\frac{G_w}{G_s} W$				
40	4.25 INCH ID HSA	(36.0-42.0) Soft, medium gray (N5) and dark yellowish brown (10YR 4/2) mottling, SILTY CLAY, wet (CL) <i>(Continued)</i>	CL		372.3	9	SS		4	$\frac{1.5}{1.5}$					@ -42 Feet, encountered C SAND and F GRAVEL, sand heaved to 41 feet BGS after drilling to 44 feet BGS. Collected sample of heave material representative of 42-44 feet BGS material.
						HSA	N/A	N/A	$\frac{N/A}{1.5}$						
		(42.0-45.5) C SAND & F GRAVEL, wet, (GP-SP)		42.0	10	SS		N/A	N/A	$\frac{1.5}{1.5}$					
45					HSA	N/A	N/A	$\frac{N/A}{2.0}$							
		END BOREHOLE AT 45.5 FEET BGS.													
50															
55															
60															

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
DRILLING CONTRACTOR: Lane Western  
DRILLER: D. Mahurin

LOGGED: MNH  
CHECKED: MNH  
DATE: 2/26/08





# RECORD OF BOREHOLE PZ-4

SHEET 2 of 2  
ELEVATION: 414.57  
INCLINATION: -90

PROJECT: Ameren - Meramec Fly Ash  
PROJECT NUMBER: 073-84012  
LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 Inch ID HSA  
DRILLING DATE: 8/15/2007  
DRILL RIG: CME 75D

DATUM: LOCAL  
AZIMUTH: N/A  
COORDINATES: N: E:

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES					PENETRATION RESISTANCE BLOWS / R				REMARKS	
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV.	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)					
					DEPTH (ft)						20	40	60	80		
20	4.25 INCH HSA	(0.0-26.5) Very soft, medium gray (N5), FLY ASH, moist (FILL) <i>(Continued)</i>		[Cross-hatched pattern]												
					4	SS		1	1.5 1.5							
						HSA	N/A	N/A	N/A 4.5							
25					5	SS	N/A WH WH	WH	1.5 1.5							
		END BOREHOLE AT 26.5 FEET BGS.			388.1 26.5											
30																
35																
40																

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
DRILLING CONTRACTOR: Lane Western  
DRILLER: D. Mahurin

LOGGED: MRF  
CHECKED: MNH  
DATE: 2/26/08



# RECORD OF BOREHOLE PZ-5

SHEET 1 of 2  
ELEVATION: 420.32  
INCLINATION: -90

PROJECT: Ameren - Meramec Fly Ash  
PROJECT NUMBER: 073-84012  
LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 Inch ID HSA  
DRILLING DATE: 8/15/2007  
DRILL RIG: CME 75D

DATUM: LOCAL  
AZIMUTH: N/A  
COORDINATES: N: E:

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES				PENETRATION RESISTANCE BLOWS / R ■				REMARKS				
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV.	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)							
					DEPTH (ft)						10 20 30 40 W, ———— W <sub>v</sub> ———— W <sub>l</sub>							
0	4.25 INCH HSA	(0.0-26.5) Firm, medium gray (N5), FLY ASH, moist (FILL)	XXXXX															
5								1	SS	4 ———— 8	16		1.3 1.5					
10		Below 9.0, Very soft, medium gray (N5) to dark gray (N3) striations. Below 10.0, wet		411.3 9.0	2	SS	1 ———— 1	2		1.0 1.5								
				410.3 10.0														
15					3	SS	1 ———— 1	2		1.5 1.5								
20					4	SS	N/A ———— 1	2		1.5 1.5								

Log continued on next page

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR\_CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
DRILLING CONTRACTOR: Lane Western  
DRILLER: D. Mahurin

LOGGED: MRF  
CHECKED: MNH  
DATE: 2/26/08



# RECORD OF BOREHOLE PZ-5

SHEET 2 of 2

PROJECT: Ameren - Meramec Fly Ash  
 PROJECT NUMBER: 073-84012  
 LOCATION: Ash Pond #494

DRILLING METHOD: 4.25 Inch ID HSA  
 DRILLING DATE: 8/15/2007  
 DRILL RIG: CME 75D

DATUM: LOCAL  
 AZIMUTH: N/A  
 COORDINATES: N: E:

ELEVATION: 420.32  
 INCLINATION: -90

DEPTH (feet)	BORING METHOD	SOIL PROFILE				SAMPLES				PENETRATION RESISTANCE BLOWS / ft ■				REMARKS			
		DESCRIPTION	USCS	GRAPHIC LOG	ELEV. DEPTH (ft)	NUMBER	TYPE	BLOWS per 6 in 140 lb hammer 30 inch drop	N	REC ATT	WATER CONTENT (PERCENT)						
											W <sub>p</sub> ← ———— W <sub>L</sub> → 20 40 60 80						
20	4.25 INCH HSA	(0.0-26.5) Firm, medium gray (N5), FLY ASH, moist (FILL) (Continued)	[Cross-hatched pattern]	393.8 26.5	4	SS			2	1.5 1.5							
25					HSA	N/A				N/A 4.5							
26.5					SS	N/A WH WH	WH	1.5 1.5									
		END BOREHOLE AT 26.5 FEET BGS.															
30																	
35																	
40																	

GOLDER STL RECORD OF BOREHOLE MERAMEC FLY ASH BORING LOGS.GPJ GLDR\_CO.GDT 2/26/08

SCALE: 1 in = 2.5 ft  
 DRILLING CONTRACTOR: Lane Western  
 DRILLER: D. Mahurin

LOGGED: MRF  
 CHECKED: MNH  
 DATE: 2/26/08




**APPENDIX B  
PIEZOMETER CONSTRUCTION LOGS AND  
MDNR CERTIFICATION RECORDS**



# ABOVE GROUND PIEZOMETER CONSTRUCTION LOG PZ-1

PROJECT NAME: Ameren/Meramec Fly Ash		PROJECT NUMBER: 073-84012
SITE NAME: Meramec Plant		LOCATION: Meramec Plant Pond# 494, St. Louis, MO
CLIENT: AmerenUE		SURFACE ELEVATION: 413.25 feet MSL
GEOLOGIST: MRF	NORTHING:	EASTING:
DRILLER: Dale Mahurin	STATIC WATER LEVEL: 392.80 feet MSL	COMPLETION DATE: 8/14/2007
DRILLING COMPANY: Layne Western		DRILLING METHODS: 4.25-inch HSA



TOTAL DEPTH OF BOREHOLE: 41.5 ft BGS

ADDITIONAL NOTES: Water level at ~23.38 feet BGS on 8/14/2007 @ 1115


CHECKED BY: JCW  
 DATE CHECKED: 2/26/08

PREPARED BY: MRF



# ABOVE GROUND PIEZOMETER CONSTRUCTION LOG PZ-2

PROJECT NAME: Ameren/Meramec Fly Ash		PROJECT NUMBER: 073-84012	
SITE NAME: Meramec Plant		LOCATION: Meramec Plant Pond# 494, St. Louis, MO	
CLIENT: AmerenUE		SURFACE ELEVATION: 416.20 feet MSL	
GEOLOGIST: MRF	NORTHING:	EASTING:	
DRILLER: Dale Mahurin	STATIC WATER LEVEL: 400.26 feet MSL	COMPLETION DATE: 8/15/2007	
DRILLING COMPANY: Layne Western		DRILLING METHODS: 4.25-inch HSA	



TOTAL DEPTH OF BOREHOLE: 25.0 ft BGS.

ADDITIONAL NOTES: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_


CHECKED BY: JCW  
 DATE CHECKED: 2/26/08

PREPARED BY: MRF



# ABOVE GROUND PIEZOMETER CONSTRUCTION LOG PZ-3

PROJECT NAME: Ameren/Meramec Fly Ash		PROJECT NUMBER: 073-84012
SITE NAME: Meramec Plant		LOCATION: Meramec Plant Pond# 494, St. Louis, MO
CLIENT: AmerenUE		SURFACE ELEVATION: 414.30 feet MSL
GEOLOGIST: MNH	NORTHING:	EASTING:
DRILLER: Dale Mahurin	STATIC WATER LEVEL: 385.85 feet MSL	COMPLETION DATE: 8/14/2007
DRILLING COMPANY: Layne Western		DRILLING METHODS: 4.25-inch HSA



ADDITIONAL NOTES: Water level ~37.3 feet BGS  
Water level @ 32.55 feet BGS on 8/14/2007 @1055


CHECKED BY: JCW  
DATE CHECKED: 2/26/08

PREPARED BY: MNH



# ABOVE GROUND PIEZOMETER CONSTRUCTION LOG PZ-4

PROJECT NAME: Ameren/Meramec Fly Ash		PROJECT NUMBER: 073-84012
SITE NAME: Meramec Plant		LOCATION: Meramec Plant Pond# 494, St. Louis, MO
CLIENT: AmerenUE		SURFACE ELEVATION: 414.57 feet MSL
GEOLOGIST: MRF	NORTHING:	EASTING:
DRILLER: Dale Mahurin	STATIC WATER LEVEL: 400.8 feet MSL	COMPLETION DATE: 8/15/2007
DRILLING COMPANY: Layne Western		DRILLING METHODS: 4.25-inch HSA



TOTAL DEPTH OF BOREHOLE: 25.0 ft BGS.

ADDITIONAL NOTES: Water level at ~23.38 feet BGS on 8/14/2007 @ 1115


CHECKED BY: JCW  
DATE CHECKED: 2/26/08

PREPARED BY: MRF



# ABOVE GROUND PIEZOMETER CONSTRUCTION LOG PZ-5

PROJECT NAME: Ameren/Meramec Fly Ash		PROJECT NUMBER: 073-84012
SITE NAME: Meramec Plant		LOCATION: Meramec Plant Pond# 494, St. Louis, MO
CLIENT: AmerenUE		SURFACE ELEVATION: 420.32 feet MSL
GEOLOGIST: MRF	NORTHING:	EASTING:
DRILLER: Dale Mahurin	STATIC WATER LEVEL: 405.55 feet MSL	COMPLETION DATE: 8/15/2007
DRILLING COMPANY: Layne Western		DRILLING METHODS: 4.25-inch HSA



TOP OF CASING ELEVATION: 423.39 feet MSL

PROTECTIVE CASING (yes / no): Yes

PEA GRAVEL OR SAND

WEEP HOLE

GROUND SURFACE ELEVATION: 420.32 feet MSL

DIAMETER OF RISER PIPE (in.): 2.0

DIAMETER OF BOREHOLE (in.): ~6

CONCRETE SEAL DEPTH (ft. bgs): 3.0

TYPE AND AMOUNT OF ANNULAR SEAL: N/A

TOP OF BENTONITE SEAL DEPTH (ft. bgs): 3.0

TYPE AND AMOUNT OF BENTONITE SEAL: 2 bag Enviroplug (50 lbs each)

TOP OF SAND PACK DEPTH (ft. bgs): 12.0

CENTRALIZER (yes / no) - TYPE: N/A

TOP OF SCREEN DEPTH (ft. bgs): 15.1

TYPE OF SCREEN: Boart Longyear Machine Slotted (Schedule 40)

SCREEN SLOT SIZE (in.): 0.010

SIZE OF SAND PACK: 20/40 Silica (NSF)

AMOUNT OF SAND: 7 bags (50 lbs each) Unimin Filter Silica

BOTTOM OF SCREEN DEPTH (ft. bgs): 24.7

BOTTOM OF WELL DEPTH (ft. bgs): 25.0

BOTTOM OF FILTER PACK (ft. bgs): 25.0

TYPE AND AMOUNT OF BACKFILL: N/A

TOTAL DEPTH OF BOREHOLE: 25.0 ft BGS

ADDITIONAL NOTES: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

CHECKED BY: JCW  
 DATE CHECKED: 2/26/08

PREPARED BY: MRF



MISSOURI DEPARTMENT OF  
NATURAL RESOURCES  
(573) 368-2165  
**MONITORING WELL  
CERTIFICATION RECORD**

<b>OFFICE USE ONLY</b>		DATE RECEIVED	
REF. NO. <b>383660</b>			
C.R. NO.		CHECK NO.	
STATE WELL NUMBER		REVENUE NO.	
ENTERED Ph 1      Ph 2      Ph 3	APPROVED BY	ROUTE	

**INFORMATION SUPPLIED BY PRIMARY CONTRACTOR OR DRILLING CONTRACTOR**

OWNER NAME <i>Ameren UE</i>		WELL NUMBER <i>PZ-1</i>		VARIANCE GRANTED BY THE D.N.R.	
OWNER ADDRESS <i>1901 Chouteau</i>		CITY <i>St. Louis</i>	STATE <i>MO</i>	ZIP CODE <i>63103</i>	<input type="checkbox"/> NO
SITE NAME <i>Ameren UE - Mexamec Plant</i>		CONTACT NAME <i>Kevin Gerhardt</i>		<input type="checkbox"/> YES, ATTACH A COPY OF THE VARIANCE	
SITE ADDRESS <i>Fine Rd</i>		CITY <i>St. Louis</i>	STATE <i>MO</i>	ZIP CODE <i>63129</i>	VARIANCE NUMBER

PROPOSED USE OF WELL		TYPE OF POTENTIAL SITE		MONITORING FOR: (CHECK ALL THAT APPLY)	
<input type="checkbox"/> GAS MONITORING WELL	<input type="checkbox"/> MONITORING	<input type="checkbox"/> HAZARDOUS MATERIAL	<input type="checkbox"/> LANDFILL	<input type="checkbox"/> RADIONUCLIDES	<input type="checkbox"/> PETROLEUM PRODUCTS ONLY
<input type="checkbox"/> EXTRACTION WELL	<input checked="" type="checkbox"/> PIEZOMETERS	<input type="checkbox"/> INITIAL SITE ASSESSMENT	<input type="checkbox"/> L.U.S.T.	<input type="checkbox"/> EXPLOSIVES	<input type="checkbox"/> METALS <input type="checkbox"/> V.O.C.
		<input checked="" type="checkbox"/> WATER LEVEL DRAWDOWN		<input type="checkbox"/> SVOCs	<input type="checkbox"/> PESTICIDES/HERBICIDES

SKETCH LOCATION OF WELL INCLUDING MILEAGE ON ALL ROADS TRAVELLED FROM NEAREST TOWNS.		LOCATION OF WELL		AREA	ELEV
		LAT. <i>38.24.14</i>	LONG. <i>90.20.42</i>	COUNTY <i>St. Louis</i>	
		SMALLEST _____ LARGEST _____			
		SEC. <i>3</i>	TWN. <i>42</i>	N. RNG. <i>6</i>	E OR W <i>E</i>

DESCRIBE LOCATION OF THE WELL SO WE WOULD BE ABLE TO VISIT THE WELL SITE <i>Fly Ash Pond</i>	DRILLER NOTES:
---	----------------

TYPE OF SURFACE COMPLETION	<input checked="" type="checkbox"/> ABOVE GROUND	LENGTH OF PROTECTIVE CASING	DIAMETER OF PROTECTIVE CASING	DIAMETER AND DEPTH OF THE HOLE PROTECTIVE CASING WAS PLACED	PROTECTIVE CASING MATERIAL	<input checked="" type="checkbox"/> STEEL	LOCKING CAP?
	<input type="checkbox"/> FLUSH MOUNT	<i>5</i> FT.	<i>4 x 4</i> IN.	<i>12</i> IN. <i>2.5</i> FT.	<input type="checkbox"/> ALUMINUM	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
					<input type="checkbox"/> PLASTIC		

WEEP HOLE?	VENTED CAP?	LENGTH OF FLUSH MOUNT	DIAMETER OF FLUSH MOUNT	DIAMETER AND DEPTH OF THE HOLE FLUSH MOUNT WAS PLACED	SURFACE COMPLETION GROUT	<input checked="" type="checkbox"/> CONCRETE <i>24" x 24"</i>
<input checked="" type="checkbox"/> YES	<input type="checkbox"/> YES	<i>N/A</i> FT.	<i>N/A</i> IN.	<i>N/A</i> IN. FT.	<input type="checkbox"/> OTHER	
<input type="checkbox"/> NO	<input checked="" type="checkbox"/> NO					

RISER PIPE DETAIL	LENGTH	DIAMETER	WEIGHT OR SDR#	DIAMETER OF DRILL HOLE	MATERIAL	BENTONITE SEAL	LENGTH OF SEAL	MATERIAL
	<i>34</i> FT.	<i>2</i> IN.	<i>40</i>	<i>8</i> IN.	<input checked="" type="checkbox"/> THERMOPLASTIC (PVC)		<i>3</i> FT.	<input type="checkbox"/> SLURRY <input type="checkbox"/> PELLETS
	GLUED	SECONDARY FILTER PACK			DEPTH		FORMATION DESCRIPTION	
		<input type="checkbox"/> SATURATED ZONE <input type="checkbox"/> UNSATURATED ZONE HYDRATED <input type="checkbox"/> YES <input type="checkbox"/> NO			FROM	TO	<i>Silty gumbo clay</i> <i>30 41.5 Gumbo clay w/ silt &amp; sand layers</i>	
	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	<input type="checkbox"/> BOTH ZONES <input type="checkbox"/> IF YES, HYDRATED <input type="checkbox"/> YES <input type="checkbox"/> NO <i>N/A</i>			<i>0</i>	<i>30</i>		

PRIMARY FILTER PACK	LENGTH	DEPTH TO TOP OF PRIMARY FILTER PACK	SECONDARY FILTER PACK LENGTH
	<i>12.5</i> FT.	<i>29</i> FT.	<i>N/A</i> FT.

ANNULAR SEAL	<input checked="" type="checkbox"/> BENTONITE SLURRY	<input type="checkbox"/> CEMENT/BENTONITE SLURRY	LENGTH
	<input type="checkbox"/> NON SLURRY BENTONITE TYPE	BAGS OF CEMENT USED _____	<i>23.5</i> FT.
	<i>GROUTWELL</i>	% OF BENTONITE USED _____	
		WATER USED/BAG _____ GAL	

WELL SCREEN	LENGTH	DIAMETER	DIAMETER OF DRILL HOLE	DEPTH TO TOP OF SCREEN	MATERIAL
	<i>10</i> FT.	<i>2</i> IN.	<i>8</i> IN.	<i>31.5</i> FT.	<input checked="" type="checkbox"/> THERMOPLASTIC (PVC)
					<input type="checkbox"/> STEEL <input type="checkbox"/> OTHER

MULTIPLE CASED WELLS	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	PUMP INSTALLED FOR REMEDIATION	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
SUBMIT ADDITIONAL AS BUILT DIAGRAMS SHOWING WELL CONSTRUCTION DETAILS INCLUDING TYPE AND SIZE OF ALL CASING, HOLE DIAMETERS AND GROUT USED			
SIGNATURE (PRIMARY CONTRACTOR)		PERMIT NUMBER	STATIC WATER LEVEL
		<i>1251 WPM</i>	<i>25.5</i>
			FEET FROM MEASURING POINT
			<i>B-16-07</i>

I HEREBY CERTIFY THAT THE MONITORING WELL HEREIN DESCRIBED WAS CONSTRUCTED IN ACCORDANCE WITH THE DEPARTMENT OF NATURAL RESOURCES REQUIREMENTS FOR THE CONSTRUCTION OF MONITORING WELLS.					
SIGNATURE (WELL DRILLER)	PERMIT NUMBER	DATE	SIGNATURE (PUMP INSTALLER)	PERMIT NUMBER	DATE
<i>X [Signature]</i>	<i>1252 WPM</i>	<i>8/31/07</i>	<i>N/A</i>	<i>N/A</i>	<i>8/31/07</i>

TOTAL DEPTH: <i>41.5'</i>					
---------------------------	--	--	--	--	--

MO 780-1415 (2-06) DISTRIBUTION: WHITE/DIVISION CANARY/CONTRACTOR PINK/OWNER  
MAIL WHITE COPY TO: DEPARTMENT OF NATURAL RESOURCES, P.O. BOX 250, ROLLA, MO 65402  
ENCLOSE \$75 MONITORING WELL CERTIFICATION FEE WITHIN 60 DAYS AFTER WELL COMPLETION



MISSOURI DEPARTMENT OF  
NATURAL RESOURCES  
(573) 368-2165  
**MONITORING WELL  
CERTIFICATION RECORD**

<b>OFFICE USE ONLY</b>		DATE RECEIVED	
REF. NO. <b>383851</b>			
C.R. NO.		CHECK NO.	
STATE WELL NUMBER		REVENUE NO.	
ENTERED Ph 1      Ph 2      Ph 3	APPROVED BY	ROUTE	

**INFORMATION SUPPLIED BY PRIMARY CONTRACTOR OR DRILLING CONTRACTOR**

OWNER NAME <b>Ameren UE</b>	WELL NUMBER <b>PZ-2</b>	VARIANCE GRANTED BY THE D.N.R. <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES, ATTACH A COPY OF THE VARIANCE
--------------------------------	----------------------------	---

OWNER ADDRESS <b>1901 Chouteau</b>	CITY <b>St. Louis</b>	STATE <b>MO</b>	ZIP CODE <b>63103</b>
---------------------------------------	--------------------------	--------------------	--------------------------

SITE NAME <b>Ameren UE - Meramec Plant</b>	CONTACT NAME <b>Kevin Gerhardt</b>
---	---------------------------------------

SITE ADDRESS <b>Fine Rd</b>	CITY <b>St. Louis</b>	STATE <b>MO</b>	ZIP CODE <b>63129</b>	VARIANCE NUMBER
--------------------------------	--------------------------	--------------------	--------------------------	-----------------

PROPOSED USE OF WELL <input type="checkbox"/> GAS MONITORING WELL <input type="checkbox"/> EXTRACTION WELL <input type="checkbox"/> MONITORING <input checked="" type="checkbox"/> PIEZOMETERS	TYPE OF POTENTIAL SITE <input type="checkbox"/> HAZARDOUS MATERIAL <input type="checkbox"/> INITIAL SITE ASSESSMENT <input checked="" type="checkbox"/> WATER LEVEL DRAWDOWN	<input type="checkbox"/> LANDFILL <input type="checkbox"/> L.U.S.T.	MONITORING FOR: (CHECK ALL THAT APPLY) <input type="checkbox"/> RADIONUCLIDES <input type="checkbox"/> EXPLOSIVES <input type="checkbox"/> SVOCS	<input type="checkbox"/> PETROLEUM PRODUCTS ONLY <input type="checkbox"/> METALS <input type="checkbox"/> V.O.C. <input type="checkbox"/> PESTICIDES/HERBICIDES
--	---	--	---	--

SKETCH LOCATION OF WELL INCLUDING MILEAGE ON ALL ROADS TRAVELLED FROM NEAREST TOWNS. 	LOCATION OF WELL LAT. <b>38.24.15.</b> LONG. <b>90.20.40.</b>	AREA	ELEV
	SMALLEST 1/4	LARGEST 1/4	1/4
	SEC. <b>3</b>	TWN. <b>42</b>	N. RING. <b>6</b>

DESCRIBE LOCATION OF THE WELL SO WE WOULD BE ABLE TO VISIT THE WELL SITE <b>Fly Ash Pond</b>	DRILLER NOTES:
---	----------------

TYPE OF SURFACE COMPLETION <input checked="" type="checkbox"/> ABOVE GROUND <input type="checkbox"/> FLUSH MOUNT	LENGTH OF PROTECTIVE CASING <b>5</b> FT.	DIAMETER OF PROTECTIVE CASING <b>4x4</b> IN.	DIAMETER AND DEPTH OF THE HOLE PROTECTIVE CASING WAS PLACED <b>12</b> IN. <b>2.5</b> FT.	PROTECTIVE CASING MATERIAL <input checked="" type="checkbox"/> STEEL <input type="checkbox"/> ALUMINUM <input type="checkbox"/> PLASTIC	LOCKING CAP? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
--	---	---	---	--	--

WEEP HOLE? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	VENTED CAP? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	LENGTH OF FLUSH MOUNT <b>N/A</b> FT.	DIAMETER OF FLUSH MOUNT <b>N/A</b> IN.	DIAMETER AND DEPTH OF THE HOLE FLUSH MOUNT WAS PLACED <b>N/A</b> IN. <b>N/A</b> FT.	SURFACE COMPLETION GROUT <input checked="" type="checkbox"/> CONCRETE <b>34"x34"</b> <input type="checkbox"/> OTHER
--	---	---	---	--	---

RISER PIPE DETAIL LENGTH <b>17.5</b> FT. DIAMETER <b>2</b> IN. WEIGHT OR SDR# <b>40</b>	DIAMETER OF DRILL HOLE <b>8</b> IN.	MATERIAL <input type="checkbox"/> STEEL <input checked="" type="checkbox"/> THERMOPLASTIC (PVC) <input type="checkbox"/> OTHER	BENTONITE SEAL LENGTH OF SEAL <b>3</b> FT. MATERIAL <input type="checkbox"/> SLURRY <input type="checkbox"/> GRANULAR <input checked="" type="checkbox"/> CHIPS
--	--	---	--

GLUED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	SECONDARY FILTER PACK <input type="checkbox"/> SATURATED ZONE <input type="checkbox"/> UNSATURATED ZONE <input type="checkbox"/> BOTH ZONES	DEPTH FROM <b>0</b> TO <b>35</b>	FORMATION DESCRIPTION <b>Fly ash</b>
---	--	-------------------------------------	---

PRIMARY FILTER PACK LENGTH <b>12</b> FT.	DEPTH TO TOP OF PRIMARY FILTER PACK <b>13</b> FT.	SECONDARY FILTER PACK LENGTH <b>N/A</b> FT.
---	--	--

ANNULAR SEAL <input checked="" type="checkbox"/> BENTONITE SLURRY <input type="checkbox"/> NON SLURRY BENTONITE TYPE <b>GROUT Well</b>	<input type="checkbox"/> CEMENT/BENTONITE SLURRY BAGS OF CEMENT USED _____ % OF BENTONITE USED _____ WATER USED/BAG _____ GAL	LENGTH <b>7.5</b> FT.
---	--	--------------------------

WELL SCREEN LENGTH <b>10</b> FT. DIAMETER <b>2</b> IN. DIAMETER OF DRILL HOLE <b>8</b> IN. DEPTH TO TOP OF SCREEN <b>15</b> FT.	MATERIAL <input type="checkbox"/> STEEL <input checked="" type="checkbox"/> THERMOPLASTIC (PVC) <input type="checkbox"/> OTHER
---	---

MULTIPLE CASED WELLS <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	PUMP INSTALLED FOR REMEDIATION <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TOTAL DEPTH: <b>35'</b>
--	--	-------------------------

SIGNATURE (PRIMARY CONTRACTOR)	PERMIT NUMBER <b>1251 WPM</b>	STATIC WATER LEVEL <b>12.5'</b> FEET FROM MEASURING POINT	DATE WELL DRILLING WAS COMPLETED <b>8-16-07</b>
--------------------------------	----------------------------------	---	--

I HEREBY CERTIFY THAT THE MONITORING WELL HEREIN DESCRIBED WAS CONSTRUCTED IN ACCORDANCE WITH THE DEPARTMENT OF NATURAL RESOURCES REQUIREMENTS FOR THE CONSTRUCTION OF MONITORING WELLS.

SIGNATURE (WELL DRILLER) <b>X. Thomas H. Mahoney Jr.</b>	PERMIT NUMBER <b>1258 WPM</b>	DATE <b>8/31/07</b>	SIGNATURE (PUMP INSTALLER) <b>X N/A</b>	PERMIT NUMBER <b>N/A</b>	DATE <b>N/A</b>
---	----------------------------------	------------------------	--	-----------------------------	--------------------



MISSOURI DEPARTMENT OF  
NATURAL RESOURCES  
(573) 368-2165  
**MONITORING WELL  
CERTIFICATION RECORD**

<b>OFFICE USE ONLY</b>		DATE RECEIVED
REF. NO. <b>383862</b>		
C.R. NO.	CHECK NO.	
STATE WELL NUMBER	REVENUE NO.	
ENTERED Ph 1      Ph 2      Ph 3	APPROVED BY	ROUTE /      /

**INFORMATION SUPPLIED BY PRIMARY CONTRACTOR OR DRILLING CONTRACTOR**

OWNER NAME <i>Ameren UE</i>		WELL NUMBER <i>PZ-3</i>		VARIANCE GRANTED BY THE D.N.R.	
OWNER ADDRESS <i>1901 Chouteau</i>		CITY <i>St. Louis</i>	STATE <i>MO</i>	ZIP CODE <i>63103</i>	<input checked="" type="checkbox"/> NO
SITE NAME <i>Ameren UE - Meramec Plant</i>		CONTACT NAME <i>Kevin Gerhardt</i>			
SITE ADDRESS <i>Fine Rd</i>		CITY <i>St. Louis</i>	STATE <i>MO</i>	ZIP CODE <i>63109</i>	VARIANCE NUMBER
PROPOSED USE OF WELL <input type="checkbox"/> GAS MONITORING WELL <input type="checkbox"/> MONITORING <input type="checkbox"/> EXTRACTION WELL <input checked="" type="checkbox"/> PIEZOMETERS		TYPE OF POTENTIAL SITE <input type="checkbox"/> HAZARDOUS MATERIAL <input type="checkbox"/> LANDFILL <input type="checkbox"/> INITIAL SITE ASSESSMENT <input type="checkbox"/> L.U.S.T. <input checked="" type="checkbox"/> WATER LEVEL DRAWDOWN		MONITORING FOR: (CHECK ALL THAT APPLY) <input type="checkbox"/> RADIONUCLIDES <input type="checkbox"/> PETROLEUM PRODUCTS ONLY <input type="checkbox"/> EXPLOSIVES <input type="checkbox"/> METALS <input type="checkbox"/> V.O.C. <input type="checkbox"/> SVOCs <input type="checkbox"/> PESTICIDES/HERBICIDES	

SKETCH LOCATION OF WELL INCLUDING MILEAGE ON ALL ROADS TRAVELLED FROM NEAREST TOWNS. <i>July 23</i> <i>Meramec River</i> (1.3 mi) <i>Fine Rd</i>		LOCATION OF WELL LAT. <i>38° 24' 25"</i> LONG. <i>90° 20' 41"</i>		AREA	ELEV
		COUNTY <i>St. Louis</i>			
		SMALLEST SEC. <i>3</i>	LARGEST TWN. <i>42</i>	N. RNG. <i>6</i> (E OR W)	

DESCRIBE LOCATION OF THE WELL SO WE WOULD BE ABLE TO VISIT THE WELL SITE <i>Fly Ash Parcel</i>	DRILLER NOTES:
---	----------------

TYPE OF SURFACE COMPLETION <input checked="" type="checkbox"/> ABOVE GROUND <input type="checkbox"/> FLUSH MOUNT	LENGTH OF PROTECTIVE CASING <i>5</i> FT.	DIAMETER OF PROTECTIVE CASING <i>4x4</i> IN.	DIAMETER AND DEPTH OF THE HOLE PROTECTIVE CASING WAS PLACED <i>12</i> IN. <i>2.5</i> FT.	PROTECTIVE CASING MATERIAL <input checked="" type="checkbox"/> STEEL <input type="checkbox"/> ALUMINUM <input type="checkbox"/> PLASTIC	LOCKING CAP? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
--	---	---	---	--	--

WEEP HOLE? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	VENTED CAP? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	LENGTH OF FLUSH MOUNT <i>n/a</i> FT.	DIAMETER OF FLUSH MOUNT <i>n/a</i> IN.	DIAMETER AND DEPTH OF THE HOLE FLUSH MOUNT WAS PLACED <i>n/a</i> IN. <i>n/a</i> FT.	SURFACE COMPLETION GROUT <input checked="" type="checkbox"/> CONCRETE <i>24" x 24"</i> <input type="checkbox"/> OTHER
--	---	---	---	--	---

RISER PIPE DETAIL	LENGTH <i>37.5</i> FT.	DIAMETER <i>2</i> IN.	WEIGHT OR SDR# <i>40</i>	DIAMETER OF DRILL HOLE <i>8</i> IN.	MATERIAL <input type="checkbox"/> STEEL <input checked="" type="checkbox"/> THERMOPLASTIC (PVC) <input type="checkbox"/> OTHER	BENTONITE SEAL <i>3</i> FT.	LENGTH OF SEAL <i>3</i> FT.	MATERIAL <input type="checkbox"/> SLURRY <input type="checkbox"/> PELLETS <input type="checkbox"/> GRANULAR <input checked="" type="checkbox"/> CHIPS
-------------------	---------------------------	--------------------------	-----------------------------	--	--	--------------------------------	--------------------------------	---

GLUED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	SECONDARY FILTER PACK				DEPTH		FORMATION DESCRIPTION
	<input type="checkbox"/> SATURATED ZONE	<input type="checkbox"/> UNSATURATED ZONE	HYDRATED	<input type="checkbox"/> YES <input type="checkbox"/> NO	FROM	TO	
	<input type="checkbox"/> BOTH ZONES	<input type="checkbox"/> IF YES, HYDRATED	<input type="checkbox"/> YES <input type="checkbox"/> NO	<i>n/a</i>	<i>0</i>	<i>2</i>	<i>Silty clay</i>

PRIMARY FILTER PACK	LENGTH <i>12</i> FT.	DEPTH TO TOP OF PRIMARY FILTER PACK <i>33</i> FT.	SECONDARY FILTER PACK LENGTH <i>n/a</i> FT.
---------------------	-------------------------	--	--

ANNULAR SEAL	<input checked="" type="checkbox"/> BENTONITE SLURRY <input type="checkbox"/> CEMENT/BENTONITE SLURRY	LENGTH <i>27.5</i> FT.
	BAGS OF CEMENT USED _____ % OF BENTONITE USED _____ WATER USED/BAG _____ GAL	

WELL SCREEN	LENGTH <i>10</i> FT.	DIAMETER <i>2</i> IN.	DIAMETER OF DRILL HOLE <i>8</i> IN.	DEPTH TO TOP OF SCREEN <i>35</i> FT.	MATERIAL <input type="checkbox"/> STEEL <input checked="" type="checkbox"/> THERMOPLASTIC (PVC) <input type="checkbox"/> OTHER
-------------	-------------------------	--------------------------	--	---	--

MULTIPLE CASED WELLS <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	PUMP INSTALLED FOR REMEDIATION <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	SUBMIT ADDITIONAL AS BUILT DIAGRAMS SHOWING WELL CONSTRUCTION DETAILS INCLUDING TYPE AND SIZE OF ALL CASING, HOLE DIAMETERS AND GROUT USED		TOTAL DEPTH: <i>45'</i>
---	---	--	--	-------------------------

SIGNATURE (PRIMARY CONTRACTOR)	PERMIT NUMBER <i>1251 WPM</i>	STATIC WATER LEVEL <i>325</i> FEET FROM MEASURING POINT	DATE WELL DRILLING WAS COMPLETED <i>8/16/07</i>
--------------------------------	----------------------------------	--	--

I HEREBY CERTIFY THAT THE MONITORING WELL HEREIN DESCRIBED WAS CONSTRUCTED IN ACCORDANCE WITH THE DEPARTMENT OF NATURAL RESOURCES REQUIREMENTS FOR THE CONSTRUCTION OF MONITORING WELLS.

SIGNATURE (WELL DRILLER) <i>X Thomas A. Mah Jr.</i>	PERMIT NUMBER <i>1258 WPM</i>	DATE <i>8/31/07</i>	SIGNATURE (PUMP INSTALLER) <i>X n/a</i>	PERMIT NUMBER <i>n/a</i>	DATE <i>n/a</i>
--	----------------------------------	------------------------	--	-----------------------------	--------------------



MISSOURI DEPARTMENT OF  
NATURAL RESOURCES  
(573) 368-2165  
**MONITORING WELL  
CERTIFICATION RECORD**

<b>OFFICE USE ONLY</b>			DATE RECEIVED		
REF. NO. <b>383863</b>					
C.R. NO.			CHECK NO.		
STATE WELL NUMBER			REVENUE NO.		
ENTERED Ph 1      Ph 2      Ph 3		APPROVED BY		ROUTE	

**INFORMATION SUPPLIED BY PRIMARY CONTRACTOR OR DRILLING CONTRACTOR**

OWNER NAME <i>Ameron UE</i>			WELL NUMBER <i>PZ-4</i>			VARIANCE GRANTED BY THE D.N.R.			
OWNER ADDRESS <i>1901 Chouteau</i>			CITY <i>St. Louis</i>		STATE <i>MO</i>		ZIP CODE <i>63103</i>	<input checked="" type="checkbox"/> NO	
SITE NAME <i>Ameron UE - Meramec Plant</i>			CONTACT NAME <i>Kevin Gerhardt</i>					<input type="checkbox"/> YES, ATTACH A COPY OF THE VARIANCE	
SITE ADDRESS <i>Fine Rd</i>			CITY <i>St. Louis</i>		STATE <i>MO</i>		ZIP CODE <i>63129</i>	VARIANCE NUMBER	

PROPOSED USE OF WELL		TYPE OF POTENTIAL SITE			MONITORING FOR: (CHECK ALL THAT APPLY)			
<input type="checkbox"/> GAS MONITORING WELL <input type="checkbox"/> MONITORING		<input type="checkbox"/> HAZARDOUS MATERIAL <input type="checkbox"/> LANDFILL			<input type="checkbox"/> RADIONUCLIDES <input type="checkbox"/> PETROLEUM PRODUCTS ONLY			
<input type="checkbox"/> EXTRACTION WELL <input checked="" type="checkbox"/> PIEZOMETERS		<input type="checkbox"/> INITIAL SITE ASSESSMENT <input type="checkbox"/> L.U.S.T.			<input type="checkbox"/> EXPLOSIVES <input type="checkbox"/> METALS <input type="checkbox"/> V.O.C.			
		<input checked="" type="checkbox"/> WATER LEVEL DRAWDOWN			<input type="checkbox"/> SVOCS <input type="checkbox"/> PESTICIDES/HERBICIDES			

SKETCH LOCATION OF WELL INCLUDING MILEAGE ON ALL ROADS TRAVELLED FROM NEAREST TOWNS.			LOCATION OF WELL			AREA			ELEV		
			LAT. <i>38.24.24.</i>			COUNTY <i>St. Louis</i>					
			LONG. <i>90.20.40.</i>			SMALLEST			LARGEST		
						1/4			1/4		
			SEC. <i>3</i>			TWN. <i>42</i>			N. RNG. <i>6</i> <b>EQRW</b>		

DESCRIBE LOCATION OF THE WELL SO WE WOULD BE ABLE TO VISIT THE WELL SITE <i>Fly Ash Pond</i>						DRILLER NOTES:					
---	--	--	--	--	--	----------------	--	--	--	--	--

TYPE OF SURFACE COMPLETION		<input checked="" type="checkbox"/> ABOVE GROUND		LENGTH OF PROTECTIVE CASING		DIAMETER OF PROTECTIVE CASING		DIAMETER AND DEPTH OF THE HOLE PROTECTIVE CASING WAS PLACED		PROTECTIVE CASING MATERIAL		<input checked="" type="checkbox"/> STEEL		LOCKING CAP?	
<input type="checkbox"/> FLUSH MOUNT		<i>5</i> FT.		<i>4x4</i> IN.		<i>12</i> IN. <i>2.5</i> FT.				<input type="checkbox"/> ALUMINUM		<input checked="" type="checkbox"/> YES		<input type="checkbox"/> NO	
										<input type="checkbox"/> PLASTIC					

WEEP HOLE?		VENTED CAP?		LENGTH OF FLUSH MOUNT		DIAMETER OF FLUSH MOUNT		DIAMETER AND DEPTH OF THE HOLE FLUSH MOUNT WAS PLACED		SURFACE COMPLETION GROUT		<input checked="" type="checkbox"/> CONCRETE <i>24" x 24"</i>			
<input checked="" type="checkbox"/> YES		<input type="checkbox"/> YES		<i>n/a</i> FT.		<i>n/a</i> IN.		<i>n/a</i> IN. FT.		<input type="checkbox"/> OTHER					
<input type="checkbox"/> NO		<input checked="" type="checkbox"/> NO													

RISER PIPE DETAIL		LENGTH		DIAMETER		WEIGHT OR SDR#		DIAMETER OF DRILL HOLE		MATERIAL		BENTONITE SEAL		LENGTH OF SEAL		MATERIAL	
		<i>17.5</i> FT.		<i>2</i> IN.		<i>40</i>		<i>8</i> IN.		<input type="checkbox"/> STEEL <input checked="" type="checkbox"/> THERMOPLASTIC (PVC) <input type="checkbox"/> OTHER		<i>3</i> FT.				<input type="checkbox"/> SLURRY <input type="checkbox"/> PELLETS <input checked="" type="checkbox"/> GRANULAR <input checked="" type="checkbox"/> CHIPS	

GLUED		SECONDARY FILTER PACK						DEPTH		FORMATION DESCRIPTION					
<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		<input type="checkbox"/> SATURATED ZONE		<input type="checkbox"/> UNSATURATED ZONE		HYDRATED <input type="checkbox"/> YES <input type="checkbox"/> NO		FROM		TO		<i>0 35 Fly ash</i>			
		<input type="checkbox"/> BOTH ZONES		<input type="checkbox"/> IF YES, HYDRATED		<input type="checkbox"/> YES <input type="checkbox"/> NO <i>n/a</i>									

PRIMARY FILTER PACK		LENGTH		DEPTH TO TOP OF PRIMARY FILTER PACK		SECONDARY FILTER PACK LENGTH	
		<i>12</i> FT.		<i>13</i> FT.		<i>n/a</i> FT.	

ANNULAR SEAL		<input checked="" type="checkbox"/> BENTONITE SLURRY		<input type="checkbox"/> CEMENT/BENTONITE SLURRY		LENGTH	
		<input type="checkbox"/> NON SLURRY BENTONITE TYPE		BAGS OF CEMENT USED		<i>7.5</i> FT.	
<i>Grout Well</i>				% OF BENTONITE USED			
				WATER USED/BAG		GAL	

WELL SCREEN		LENGTH		DIAMETER		DIAMETER OF DRILL HOLE		DEPTH TO TOP OF SCREEN		MATERIAL	
		<i>10</i> FT.		<i>2</i> IN.		<i>8</i> IN.		<i>15</i> FT.		<input type="checkbox"/> STEEL <input checked="" type="checkbox"/> THERMOPLASTIC (PVC) <input type="checkbox"/> OTHER	

MULTIPLE CASED WELLS <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO						PUMP INSTALLED FOR REMEDIATION <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO							
SUBMIT ADDITIONAL AS BUILT DIAGRAMS SHOWING WELL CONSTRUCTION DETAILS INCLUDING TYPE AND SIZE OF ALL CASING, HOLE DIAMETERS AND GROUT USED												TOTAL DEPTH: <i>25'</i>	

SIGNATURE (PRIMARY CONTRACTOR)				PERMIT NUMBER <i>1251 WPM</i>				STATIC WATER LEVEL <i>12.5</i>				DATE WELL DRILLING WAS COMPLETED <i>2/16/07</i>			
								FEET FROM MEASURING POINT							

I HEREBY CERTIFY THAT THE MONITORING WELL HEREIN DESCRIBED WAS CONSTRUCTED IN ACCORDANCE WITH THE DEPARTMENT OF NATURAL RESOURCES REQUIREMENTS FOR THE CONSTRUCTION OF MONITORING WELLS.

SIGNATURE (WELL DRILLER)		PERMIT NUMBER		DATE		SIGNATURE (PUMP INSTALLER)		PERMIT NUMBER		DATE	
<i>X [Signature]</i>		<i>1258 WPM</i>		<i>3/31/07</i>		<i>X [Signature]</i>		<i>n/a</i>		<i>n/a</i>	



MISSOURI DEPARTMENT OF  
NATURAL RESOURCES  
(573) 368-2165  
**MONITORING WELL  
CERTIFICATION RECORD**

<b>OFFICE USE ONLY</b>		DATE RECEIVED	
REF. NO. <b>383864</b>		CHECK NO.	
C.R. NO.		REVENUE NO.	
STATE WELL NUMBER		APPROVED BY	
ENTERED Ph 1    Ph 2    Ph 3	ROUTE		

**INFORMATION SUPPLIED BY PRIMARY CONTRACTOR OR DRILLING CONTRACTOR**

OWNER NAME <i>Ameren UE</i>		WELL NUMBER <i>P2-5</i>		VARIANCE GRANTED BY THE D.N.R.	
OWNER ADDRESS <i>1901 Chouteau</i>		CITY <i>St. Louis</i>	STATE <i>MO</i>	ZIP CODE <i>63103</i>	<input checked="" type="checkbox"/> NO
SITE NAME <i>Ameren UE - Meramec Plant</i>		CONTACT NAME <i>Kevin Gerhardt</i>		<input type="checkbox"/> YES, ATTACH A COPY OF THE VARIANCE	
SITE ADDRESS <i>Fine Rd</i>		CITY <i>St. Louis</i>	STATE <i>MO</i>	ZIP CODE <i>63129</i>	VARIANCE NUMBER

PROPOSED USE OF WELL		TYPE OF POTENTIAL SITE		MONITORING FOR: (CHECK ALL THAT APPLY)	
<input type="checkbox"/> GAS MONITORING WELL	<input type="checkbox"/> MONITORING	<input type="checkbox"/> HAZARDOUS MATERIAL	<input type="checkbox"/> LANDFILL	<input type="checkbox"/> RADIONUCLIDES	<input type="checkbox"/> PETROLEUM PRODUCTS ONLY
<input type="checkbox"/> EXTRACTION WELL	<input checked="" type="checkbox"/> PIEZOMETERS	<input type="checkbox"/> INITIAL SITE ASSESSMENT	<input type="checkbox"/> L.U.S.T.	<input type="checkbox"/> EXPLOSIVES	<input type="checkbox"/> METALS <input type="checkbox"/> V.O.C.
		<input checked="" type="checkbox"/> WATER LEVEL DRAWDOWN		<input type="checkbox"/> SVOCs	<input type="checkbox"/> PESTICIDES/HERBICIDES

SKETCH LOCATION OF WELL INCLUDING MILEAGE ON ALL ROADS TRAVELLED FROM NEAREST TOWNS.		LOCATION OF WELL		AREA	ELEV
		LAT. <i>38.24.21.</i>	LONG. <i>90.20.33.</i>	COUNTY <i>St. Louis</i>	
		SMALLEST	LARGEST		
		1/4	1/4	1/4	
		SEC. <i>3</i>	TWN. <i>42</i>	N. RNG. <i>6</i> E OR W	

DESCRIBE LOCATION OF THE WELL SO WE WOULD BE ABLE TO VISIT THE WELL SITE <i>Fly 15th Pond</i>	DRILLER NOTES:
--	----------------

TYPE OF SURFACE COMPLETION	<input checked="" type="checkbox"/> ABOVE GROUND	LENGTH OF PROTECTIVE CASING	DIAMETER OF PROTECTIVE CASING	DIAMETER AND DEPTH OF THE HOLE PROTECTIVE CASING WAS PLACED	PROTECTIVE CASING MATERIAL	<input checked="" type="checkbox"/> STEEL	LOCKING CAP?
	<input type="checkbox"/> FLUSH MOUNT	<i>5</i> FT.	<i>4x4</i> IN.	<i>12</i> IN. <i>2.5</i> FT.	<input type="checkbox"/> ALUMINUM	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO
					<input type="checkbox"/> PLASTIC	<input type="checkbox"/> NO	

WEEP HOLE?	VENTED CAP?	LENGTH OF FLUSH MOUNT	DIAMETER OF FLUSH MOUNT	DIAMETER AND DEPTH OF THE HOLE FLUSH MOUNT WAS PLACED	SURFACE COMPLETION GROUT
<input checked="" type="checkbox"/> YES	<input type="checkbox"/> YES	<i>n/a</i> FT.	<i>n/a</i> IN.	<i>n/a</i> IN. FT.	<input checked="" type="checkbox"/> CONCRETE <i>24" x 24"</i>
<input type="checkbox"/> NO	<input checked="" type="checkbox"/> NO				<input type="checkbox"/> OTHER

RISER PIPE DETAIL	LENGTH	DIAMETER	WEIGHT OR SDR#	DIAMETER OF DRILL HOLE	MATERIAL	BENTONITE SEAL	LENGTH OF SEAL	MATERIAL
	<i>17.5</i> FT.	<i>2</i> IN.	<i>40</i>	<i>8</i> IN.	<input checked="" type="checkbox"/> THERMOPLASTIC (PVC)		<i>3</i> FT.	<input type="checkbox"/> SLURRY <input type="checkbox"/> PELLETS
					<input type="checkbox"/> OTHER			<input type="checkbox"/> GRANULAR <input checked="" type="checkbox"/> CHIPS

PRIMARY FILTER PACK	LENGTH	DEPTH TO TOP OF PRIMARY FILTER PACK	SECONDARY FILTER PACK LENGTH	FORMATION DESCRIPTION
	<i>12</i> FT.	<i>13</i> FT.	<i>n/a</i> FT.	
<input type="checkbox"/> SATURATED ZONE <input type="checkbox"/> UNSATURATED ZONE <input type="checkbox"/> HYDRATED <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO BOTH ZONES <input type="checkbox"/> IF YES, HYDRATED <input type="checkbox"/> YES <input type="checkbox"/> NO <i>n/a</i>				

ANNULAR SEAL	<input checked="" type="checkbox"/> BENTONITE SLURRY	<input type="checkbox"/> CEMENT/BENTONITE SLURRY	LENGTH
	<input type="checkbox"/> NON SLURRY BENTONITE TYPE	BAGS OF CEMENT USED	<i>7.5</i> FT.
	<i>Grout Well</i>	% OF BENTONITE USED	
		WATER USED/BAG	GAL

WELL SCREEN	LENGTH	DIAMETER	DIAMETER OF DRILL HOLE	DEPTH TO TOP OF SCREEN	MATERIAL
	<i>10</i> FT.	<i>2</i> IN.	<i>8</i> IN.	<i>15</i> FT.	<input checked="" type="checkbox"/> THERMOPLASTIC (PVC)
					<input type="checkbox"/> STEEL <input type="checkbox"/> OTHER

MULTIPLE CASED WELLS  YES  NO PUMP INSTALLED FOR REMEDIATION  YES  NO

SUBMIT ADDITIONAL AS BUILT DIAGRAMS SHOWING WELL CONSTRUCTION DETAILS INCLUDING TYPE AND SIZE OF ALL CASING, HOLE DIAMETERS AND GROUT USED

TOTAL DEPTH: *25'*

SIGNATURE (PRIMARY CONTRACTOR)	PERMIT NUMBER	STATIC WATER LEVEL	DATE WELL DRILLING WAS COMPLETED
	<i>1251 WPM</i>	<i>12.5'</i> FEET FROM MEASURING POINT	<i>8/14/07</i>

I HEREBY CERTIFY THAT THE MONITORING WELL HEREIN DESCRIBED WAS CONSTRUCTED IN ACCORDANCE WITH THE DEPARTMENT OF NATURAL RESOURCES REQUIREMENTS FOR THE CONSTRUCTION OF MONITORING WELLS.

SIGNATURE (WELL DRILLER)	PERMIT NUMBER	DATE	SIGNATURE (PUMP INSTALLER)	PERMIT NUMBER	DATE
<i>X Thomas H. Mat...</i>	<i>1258 WPM</i>	<i>8/31/07</i>	<i>X n/a</i>	<i>n/a</i>	<i>n/a</i>

**APPENDIX C**  
**GEOTECHNICAL ANALYSIS FORMS**

# ATTERBERG LIMITS

ASTM D 4318

PROJECT NAME: AMEREN / MERAMEC  
 PROJECT NUMBER: 073-84012  
 SAMPLE ID: PZ-1 S-002  
 SAMPLE TYPE: BAG

SAMPLE DEPTH: 9 - 10.5'

**SAMPLE PREPARATION**

Wet or Dry

Wet

Minus #40 Sieve

Yes

**PLASTIC LIMIT DETERMINATION**

**LIQUID LIMIT DETERMINATION**

**NATURAL MOISTURE**

Number of Blows

Weight of Wet Soil & Tare (gm)

Weight of Dry Soil & Tare (gm)

Weight of Tare (gm)

Weight of Water (gm)

Weight of Dry Soil (gm)

Water Content %

26.86	26.96
25.07	25.14
16.69	16.66
1.79	1.82
8.38	8.48
21.36	21.46

28	28
55.37	55.55
45.51	45.78
20.23	20.69
9.86	9.77
25.28	25.09
39.00	38.94

BLOWS:

TRIAL 1	TRIAL 2
28	28
1.014	1.014

K VALUE:

69.92
59.62
19.49
10.30
40.13
25.67

PLASTIC LIMIT (PL)

21

LIQUID LIMIT (LL)

40

PLASTICITY INDEX (PI)

19

LIQUIDITY INDEX (LI)

0.23


NOTE:

DESCRIPTION

Grayish brown, silty CLAY, trace sand

USCS

CL



TECH	FC
DATE	20-Aug-07
CHECK	PCM
REVIEW	MNH

# ATTERBERG LIMITS

ASTM D 4318

PROJECT NAME: AMEREN / MERAMEC  
 PROJECT NUMBER: 073-84012  
 SAMPLE ID: PZ-1 S-003  
 SAMPLE TYPE: SHELBY TUBE

SAMPLE DEPTH: 14.5 - 16.5'

**SAMPLE PREPARATION**

Wet or Dry

Wet

Minus #40 Sieve

Yes

**PLASTIC LIMIT DETERMINATION**

**LIQUID LIMIT DETERMINATION**

**NATURAL MOISTURE**

Number of Blows

Weight of Wet Soil & Tare (gm)	26.95	27.49
Weight of Dry Soil & Tare (gm)	24.99	25.50
Weight of Tare (gm)	16.62	17.02
Weight of Water (gm)	1.96	1.99
Weight of Dry Soil (gm)	8.37	8.48
Water Content %	23.42	23.47

23	23
54.47	54.40
41.95	41.88
21.50	21.44
12.52	12.52
20.45	20.44
61.22	61.25

	TRIAL 1	TRIAL 2	
	23	23	104.39
BLOWS:	23	23	83.57
			19.53
			20.82
K VALUE:	0.99	0.99	64.04
			32.51

PLASTIC LIMIT (PL)

23

LIQUID LIMIT (LL)

61

PLASTICITY INDEX (PI)

38

LIQUIDITY INDEX (LI)

0.24


NOTE:

DESCRIPTION

Brown & Gray, CLAY, some sand pockets

USCS

CH



TECH	FC
DATE	21-Aug-07
CHECK	PCM
REVIEW	MNH

# ATTERBERG LIMITS

ASTM D 4318

PROJECT NAME: AMEREN / MERAMEC  
 PROJECT NUMBER: 073-84012  
 SAMPLE ID: PZ-1 S-007  
 SAMPLE TYPE: BAG

SAMPLE DEPTH: 29.5 - 31'

**SAMPLE PREPARATION**

Wet or Dry

Wet

Minus #40 Sieve

Yes

**PLASTIC LIMIT DETERMINATION**

Number of Blows

Weight of Wet Soil & Tare (gm)	26.85	26.70
Weight of Dry Soil & Tare (gm)	24.86	24.75
Weight of Tare (gm)	16.69	16.59
Weight of Water (gm)	1.99	1.95
Weight of Dry Soil (gm)	8.17	8.16
Water Content %	24.36	23.90

**LIQUID LIMIT DETERMINATION**

30	30
50.91	51.66
39.01	39.78
20.87	21.64
11.90	11.88
18.14	18.14
65.60	65.49

BLOWS:

TRIAL 1	TRIAL 2
30	30
K VALUE:	1.022

**NATURAL MOISTURE**

68.72
56.83
19.42
11.89
37.41
31.78

PLASTIC LIMIT (PL)

24

LIQUID LIMIT (LL)

67

PLASTICITY INDEX (PI)

43

LIQUIDITY INDEX (LI)

0.18


NOTE:

DESCRIPTION

Brown, CLAY, some silt

USCS

CH



TECH	FC
DATE	20-Aug-07
CHECK	PCM
REVIEW	MNH

# ATTERBERG LIMITS

ASTM D 4318

PROJECT NAME: AMEREN / MERAMEC  
 PROJECT NUMBER: 073-84012  
 SAMPLE ID: PZ-3 S-002  
 SAMPLE TYPE: BAG

SAMPLE DEPTH: 9 - 10.5'

**SAMPLE PREPARATION**

Wet or Dry

Wet

Minus #40 Sieve

Yes

**PLASTIC LIMIT DETERMINATION**

**LIQUID LIMIT DETERMINATION**

**NATURAL MOISTURE**

Number of Blows

Weight of Wet Soil & Tare (gm)	31.68	31.89
Weight of Dry Soil & Tare (gm)	29.66	29.94
Weight of Tare (gm)	21.41	21.83
Weight of Water (gm)	2.02	1.95
Weight of Dry Soil (gm)	8.25	8.11
Water Content %	24.48	24.04

	30	30
	46.05	45.87
	34.52	34.31
	16.91	16.68
	11.53	11.56
	17.61	17.63
	65.47	65.57

BLOWS:

	TRIAL 1	TRIAL 2
	30	30
K VALUE:	1.022	1.022

K VALUE:

	53.83
	43.90
	18.97
	9.93
	24.93
	39.83

PLASTIC LIMIT (PL)

24

LIQUID LIMIT (LL)

67

PLASTICITY INDEX (PI)

43

LIQUIDITY INDEX (LI)

0.36

NOTE:


DESCRIPTION

Brown, CLAY, some silt

USCS

CH

## PLASTICITY CHART



TECH	FC
DATE	20-Aug-07
CHECK	PCM
REVIEW	MNH

# ATTERBERG LIMITS

ASTM D 4318

PROJECT NAME: AMEREN / MERAMEC  
 PROJECT NUMBER: 073-84012  
 SAMPLE ID: PZ-3 S-003  
 SAMPLE TYPE: SHELBY TUBE

SAMPLE DEPTH: 14 - 16'

**SAMPLE PREPARATION**

Wet or Dry

Wet

Minus #40 Sieve

Yes

**PLASTIC LIMIT DETERMINATION**

Number of Blows

Weight of Wet Soil & Tare (gm)

Weight of Dry Soil & Tare (gm)

Weight of Tare (gm)

Weight of Water (gm)

Weight of Dry Soil (gm)

Water Content %

27.16	27.25
24.98	25.00
16.74	16.72
2.18	2.25
8.24	8.28
26.46	27.17

**LIQUID LIMIT DETERMINATION**

20	20
53.89	54.34
39.61	40.15
21.42	22.11
14.28	14.19
18.19	18.04
78.50	78.66

BLOWS:

TRIAL 1	TRIAL 2
20	20
0.974	0.974

K VALUE:

**NATURAL MOISTURE**

89.23
70.11
19.50
19.12
50.61
37.78

PLASTIC LIMIT (PL)

27

LIQUID LIMIT (LL)

77

PLASTICITY INDEX (PI)

50

LIQUIDITY INDEX (LI)

0.22

NOTE:


DESCRIPTION

Brown & Gray, CLAY, trace of sand

USCS

CH

## PLASTICITY CHART



TECH	FC
DATE	21-Aug-07
CHECK	PCM
REVIEW	MNH

# ATTERBERG LIMITS

ASTM D 4318

PROJECT NAME: AMEREN / MERAMEC  
 PROJECT NUMBER: 073-84012  
 SAMPLE ID: PZ-3 S-007  
 SAMPLE TYPE: BAG

SAMPLE DEPTH: 29 - 30.5'

**SAMPLE PREPARATION**

Wet or Dry

Wet

Minus #40 Sieve

Yes

**PLASTIC LIMIT DETERMINATION**

Number of Blows

Weight of Wet Soil & Tare (gm)	27.46	26.96
Weight of Dry Soil & Tare (gm)	25.60	25.12
Weight of Tare (gm)	17.22	16.78
Weight of Water (gm)	1.86	1.84
Weight of Dry Soil (gm)	8.38	8.34
Water Content %	22.20	22.06

**LIQUID LIMIT DETERMINATION**

20	20
51.97	52.54
40.32	40.97
20.91	21.75
11.65	11.57
19.41	19.22
60.02	60.20

BLOWS:

TRIAL 1	TRIAL 2
20	20
K VALUE:	0.974
0.974	0.974

K VALUE:

**NATURAL MOISTURE**

71.27
56.91
19.59
14.36
37.32
38.48

PLASTIC LIMIT (PL)

22

LIQUID LIMIT (LL)

59

PLASTICITY INDEX (PI)

37

LIQUIDITY INDEX (LI)

0.45

NOTE:


DESCRIPTION

Brown, CLAY, some silt

USCS


CH

## PLASTICITY CHART



TECH	FC
DATE	20-Aug-07
CHECK	PCM
REVIEW	MNH


**UNCONSOLIDATED / UNDRAINED COMPRESSIVE STRENGTH  
ASTM D 2850**



Specimen Description		Brown and Gray Clay with some Sand					
LL	61	PI	38	LI	0.4	USCS	CH


Depth (ft)	14.50	Confining Pressure (psi)	13.0
Specimen Height (inch)	5.915	Strain Rate (%/min)	1.0
Specimen Diameter (inch)	2.836	Peak Deviator Stress (tsf)	0.75
Initial Specimen Weight (g)	1127.3	Axial Strain at Peak Stress (%)	7.8
Moist Unit Weight (pcf)	115.0		
Initial Water Content (%)	37.1		
Initial Dry Unit Weight (pcf)	83.8		

Project Title	Ameren / Meramec
Project Number	073-84012
Sample Type	Shelby Tube
Sample ID	PZ-1 S-3
Comments	



Performed by	PN
Date	20-Aug-07
Check	PCM
Review	MNH


**UNCONSOLIDATED / UNDRAINED COMPRESSIVE STRENGTH  
ASTM D 2850**



Specimen Description		Brown & Gray Clay with trace of sand					
LL	77	PI	50	LI	0.2	USCS	CH

Depth (ft)	14.00	Confining Pressure (psi)	13.0
Specimen Height (inch)	5.950	Strain Rate (%/min)	1.0
Specimen Diameter (inch)	2.853	Peak Deviator Stress (tsf)	0.78
Initial Specimen Weight (g)	1118.3	Axial Strain at Peak Stress (%)	11.5
Moist Unit Weight (pcf)	112.0		
Initial Water Content (%)	37.9		
Initial Dry Unit Weight (pcf)	81.2		

Project Title	Ameren / Meramec
Project Number	073-84012
Sample Type	Shelby Tube
Sample ID	PZ-3 S-3
Comments	



Performed by	PN
Date	20-Aug-07
Check	PCM
Review	MNH


**APPENDIX D**  
**SLUG TESTING ANALYSIS FORMS**

**HVORSLEV SLUG TEST ANALYSIS  
RISING HEAD TEST PZ-1**

$$K = \frac{r_c^2}{2L_e} \ln \frac{L_e}{R_e} \left[ \frac{\ln \left( \frac{h_1}{h_2} \right)}{(t_2 - t_1)} \right] 30.48$$

where:  $r_c$  = casing radius (feet)  
 $R_e$  = filter pack radius (feet)  
 $L_e$  = length of screened interval (feet)  
 $t$  = time (seconds)  
 $h_t$  = head at time  $t$  (feet)

INPUT PARAMETERS	RESULTS
$r_c = 0.08$	$K = 1.03E-04$ cm/sec $K = 2.92E-01$ ft/day
$R_e = 0.25$	
$L_e = 9.6$	
$t_1 = 4.75$	
$t_2 = 9.75$	
$h_1/h_0 = 0.41$	
$h_2/h_0 = 0.19$	



Project Name: Meramec Fly Ash  
 Project No.: 073-84012  
 Test Date: 08/17/07


Analysis By: JCW  
 Checked By: MSL  
 Analysis Date: 2/26/2008

HVORSLEV SLUG TEST ANALYSIS  
 RISING HEAD TEST PZ-2

$$K = \frac{r_c^2}{2L_e} \ln \frac{L_e}{R_e} \left[ \frac{\ln \left( \frac{h_1}{h_2} \right)}{(t_2 - t_1)} \right] 30.48$$

where:  $r_c$  = casing radius (feet)  
 $R_e$  = filter pack radius (feet)  
 $L_e$  = length of screened interval (feet)  
 $t$  = time (seconds)  
 $h_t$  = head at time  $t$  (feet)

INPUT PARAMETERS	RESULTS
$r_c = 0.08$	$K = 4.09E-04$ cm/sec $K = 1.16E+00$ ft/day
$R_e = 0.25$	
$L_e = 6.17$	
$t_1 = 0$	
$t_2 = 4.75$	
$h_1/h_0 = 1.00$	
$h_2/h_0 = 0.12$	



Project Name: Meramec Fly Ash  
 Project No.: 073-84012  
 Test Date: 08/17/07


Analysis By: JCW  
 Checked By: MSL  
 Analysis Date: 2/26/2008

HVORSLEV SLUG TEST ANALYSIS  
 RISING HEAD TEST PZ-3

$$K = \frac{r_c^2}{2L_e} \ln \frac{L_e}{R_e} \left[ \frac{\ln \left( \frac{h_1}{h_2} \right)}{(t_2 - t_1)} \right] 30.48$$

where:  $r_c$  = casing radius (feet)  
 $R_e$  = filter pack radius (feet)  
 $L_e$  = length of screened interval (feet)  
 $t$  = time (seconds)  
 $h_t$  = head at time  $t$  (feet)

INPUT PARAMETERS	RESULTS		
$r_c = 0.08$	<table border="1"> <tr> <td>K= 8.00E-04 cm/sec</td> </tr> <tr> <td>K= 2.27E+00 ft/day</td> </tr> </table>	K= 8.00E-04 cm/sec	K= 2.27E+00 ft/day
K= 8.00E-04 cm/sec			
K= 2.27E+00 ft/day			
$R_e = 0.25$			
$L_e = 3.59$			
$t_1 = 0.25$			
$t_2 = 3.75$			
$h_1/h_0 = 0.85$			
$h_2/h_0 = 0.10$			



Project Name: Meramec Fly Ash  
 Project No.: 073-84012  
 Test Date: 08/17/07


Analysis By: JCW  
 Checked By: MSL  
 Analysis Date: 2/26/2008

**HVORSLEV SLUG TEST ANALYSIS  
RISING HEAD TEST PZ-4**

$$K = \frac{r_c^2}{2L_e} \ln \frac{L_e}{R_e} \left[ \frac{\ln\left(\frac{h_1}{h_2}\right)}{(t_2 - t_1)} \right] 30.48$$

where:  $r_c$  = casing radius (feet)  
 $R_e$  = filter pack radius (feet)  
 $L_e$  = length of screened interval (feet)  
 $t$  = time (seconds)  
 $h_t$  = head at time  $t$  (feet)

INPUT PARAMETERS	RESULTS
$r_c = 0.08$	$K = 4.07E-04$ cm/sec $K = 1.15E+00$ ft/day
$R_e = 0.25$	
$L_e = 9.6$	
$t_1 = 0.25$	
$t_2 = 1.75$	
$h_1/h_0 = 0.92$	
$h_2/h_0 = 0.37$	



Project Name: Meramec Fly Ash  
 Project No.: 073-84012  
 Test Date: 08/17/07


Analysis By: JCW  
 Checked By: MSL  
 Analysis Date: 2/26/2008

**HVORSLEV SLUG TEST ANALYSIS  
RISING HEAD TEST PZ-5**

$$K = \frac{r_c^2}{2L_s} \ln \frac{L_s}{R_s} \left[ \frac{\ln \left( \frac{h_1}{h_2} \right)}{(t_2 - t_1)} \right] 30.48$$

where:  $r_c$  = casing radius (feet)  
 $R_s$  = filter pack radius (feet)  
 $L_s$  = length of screened interval (feet)  
 $t$  = time (seconds)  
 $h_t$  = head at time  $t$  (feet)

INPUT PARAMETERS	RESULTS
$r_c = 0.08$	$K = 8.37E-04$ cm/sec $K = 2.37E+00$ ft/day
$R_s = 0.25$	
$L_s = 7.93$	
$t_1 = 0.25$	
$t_2 = 1.75$	
$h_1/h_0 = 0.87$	
$h_2/h_0 = 0.17$	



Project Name: Meramec Fly Ash  
 Project No.: 073-84012  
 Test Date: 08/17/07

Analysis By: JCW  
 Checked By: MSL  
 Analysis Date: 2/26/2008

APPENDIX A

DOC 1.6 AVAILABLE INFORMATION CHECKLISTS

## Available Information Checklist

### Coal Combustion Waste Impoundment (CCWI) Dam MERAMEC RETENTION POND

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>1. Descriptive Information:</b>	X		
a) Impoundment Capacity (Normal & Max) ( 435600 FT <sup>3</sup> ORIGINAL DESIGN)	X		
b) Impoundment Surface Area (0.7 ACRES)	X		
c) Hazard Classification (CLASS III)	X		
d) Freeboard (Normal & Min) (10 FT NORMAL 2 FT MIN)	X		
e) Maximum Dam Height (24.7 FT)	X		
f) Dam Crest Elevation (414 FT)	X		
g) Crest Width (15 FT)	X		
h) Upstream Slope Inclination (3H 1V)	X		
i) Downstream Slope Inclination (3H 1V)	X		
j) Spillway Type, Size, & Crest Elevation			X
k) Outlet Condit Type, Size, & Max Flow Capacity (24 INCH DIAMETER CS PIPE – 30CFS)	X		
l) Historical Maximum Pond Elevation	X		
m) Year Built	X		
n) Design Life (MAY VARY)	X		
o) Specific Wastes Permitted in Impoundment	X		
p) Other (describe)			
<b>2. Regional Map showing CCWI &amp; schools, hospitals, etc. w/i 5 mi downgradient</b>		X	
<b>3. Management Unit Dwgs:</b>			
a) Plans	X		
b) Sections	X		
c) Elevations	X		
d) Other (describe)			
<b>4. Design Information:</b>			
a) Name of Designer of Record	X		
b) Design Assumptions			X
c) Design Analyses			X



## Available Information Checklist (Continued)

### Coal Combustion Waste Impoundment (CCWI) Dam

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>9. Operation, Maintenance, &amp; Surveillance:</b>			
<b>a) Operating Procedures</b>			
<b>b) Maintenance Procedures</b>			
<b>c) Inspection Procedures</b>	X		
<b>d) Third Party Inspection Reports</b>			
<b>e) Other (describe)</b>			
<b>10. Emergency Action Plan</b>		X	
<b>11. Inundation Map</b>			X

*Subball  
 Revised 023  
 489. 009*

<b>Available Information Checklist</b>			
Coal Combustion Waste Impoundment (CCWI) Dam			
<b>MERAMEC POND 489</b>			
ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>1. Descriptive Information:</b>	X		
a) Impoundment Capacity (Normal & Max) (13068000 FT^3 ORIGINAL DESIGN)	X		
b) Impoundment Surface Area (17.6 ACRES)	X		
c) Hazard Classification (CLASS III)	X		
d) Freeboard (Normal & Min) (4.4 FT NORMAL 2 FT MIN)	X		
e) Maximum Dam Height (24.7 FT)	X		
f) Dam Crest Elevation (420.2 FT)	X		
g) Crest Width (15 FT)	X		
h) Upstream Slope Inclination (3H 1V)	X		
i) Downstream Slope Inclination (1.5H:1V)	X		
j) Spillway Type, Size, & Crest Elevation			X
k) Outlet Condit Type, Size, & Max Flow Capacity (36 INCH DIAMETER HDPE - 54 CFS)	X		
l) Historical Maximum Pond Elevation	X		
m) Year Built	X		
n) Design Life (MAY VARY)	X		
o) Specific Wastes Permitted in Impoundment	X		
p) Other (describe)			
<b>2. Regional Map showing CCWI &amp; schools, hospitals, etc. w/i 5 mi downgradient</b>		X	
<b>3. Management Unit Dwgs:</b>			
a) Plans	X		
b) Sections	X		
c) Elevations	X		
d) Other (describe)			
<b>4. Design Information:</b>			
a) Name of Designer of Record	X		
b) Design Assumptions			X
c) Design Analyses			X



## Available Information Checklist (Continued)

### Coal Combustion Waste Impoundment (CCWI) Dam

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>9. Operation, Maintenance, &amp; Surveillance:</b>			
<b>a) Operating Procedures</b>			
<b>b) Maintenance Procedures</b>			
<b>c) Inspection Procedures</b>	X		
<b>d) Third Party Inspection Reports</b>			
<b>e) Other (describe)</b>			
<b>10. Emergency Action Plan</b>		X	
<b>11. Inundation Map</b>			X

## Available Information Checklist

Coal Combustion Waste Impoundment (CCWI) Dam  
MERAMEC FLY ASH POND 498

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>1. Descriptive Information:</b>	X		
<b>a) Impoundment Capacity (Normal &amp; Max) (10018800 FT<sup>3</sup> ORIGINAL DESIGN)</b>	X		
<b>b) Impoundment Surface Area (13.5 ACRES)</b>	X		
<b>c) Hazard Classification (CLASS III)</b>	X		
<b>d) Freeboard (Normal &amp; Min) (5 FT NORMAL 2 FT MIN)</b>	X		
<b>e) Maximum Dam Height (24.7 FT)</b>	X		
<b>f) Dam Crest Elevation (423 FT)</b>	X		
<b>g) Crest Width (15 FT)</b>	X		
<b>h) Upstream Slope Inclination (3H 1V)</b>	X		
<b>i) Downstream Slope Inclination (3H:1V)</b>	X		
<b>j) Spillway Type, Size, &amp; Crest Elevation</b>			X
<b>k) Outlet Condit Type, Size, &amp; Max Flow Capacity (24 INCH DIAMETER HDPE PIPE)</b>	X		
<b>l) Historical Maximum Pond Elevation</b>	X		
<b>m) Year Built</b>	X		
<b>n) Design Life (MAY VARY)</b>	X		
<b>o) Specific Wastes Permitted in Impoundment</b>	X		
<b>p) Other (describe)</b>			
<b>2. Regional Map showing CCWI &amp; schools, hospitals, etc. w/i 5 mi downgradient</b>		X	
<b>3. Management Unit Dwgs:</b>			
<b>a) Plans</b>	X		
<b>b) Sections</b>	X		
<b>c) Elevations</b>	X		
<b>d) Other (describe)</b>			
<b>4. Design Information:</b>			
<b>a) Name of Designer of Record</b>	X		
<b>b) Design Assumptions</b>			X
<b>c) Design Analyses</b>			X

## Available Information Checklist (Continued)

### Coal Combustion Waste Impoundment (CCWI) Dam

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
d) Spillway Design Flood or Design Basis			X
e) Slope Stability Factors of Safety (ONGOING STABILITY ANALYSIS)			X
f) Design Soil Properties and Parameters (ONGOING STABILITY ANALYSIS) ✓			X
g) Other (describe)			
<b>5. Permits:</b>			
a) NPDES? <span style="float: right;">Number? MO-0000361</span>	X		
b) Dam Safety - Operating Permit? <span style="float: right;">Number?</span>			X
c) Other (describe)			
<b>6. Subsurface Information:</b>			
a) Geology	X		
b) Geotechnical Report	X		
c) Test Boring Logs	X		
d) Subsurface Profiles	X		
f) Other (describe)			
<b>7. Monitoring Information:</b>			
a) Observation Wells/Piezometer Readings			X
b) Seepage Readings		X	
c) Settlement Readings		X	
d) Alignment Readings		X	
e) Inclinator Readings			X
f) Time vs Reading Graphs			X
g) Other (describe)			
<b>8. Instrumentation Dwgs:</b>			
a) Location Plan			X
b) Section Views			X
c) Other (describe)			

## Available Information Checklist (Continued)

### Coal Combustion Waste Impoundment (CCWI) Dam

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>9. Operation, Maintenance, &amp; Surveillance:</b>			
<b>a) Operating Procedures</b>			
<b>b) Maintenance Procedures</b>			
<b>c) Inspection Procedures</b>	X		
<b>d) Third Party Inspection Reports</b>			
<b>e) Other (describe)</b>			
<b>10. Emergency Action Plan</b>		X	
<b>11. Inundation Map</b>			X

## Available Information Checklist

### Coal Combustion Waste Impoundment (CCWI) Dam MERAMEC BOTTOM ASH POND

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>1. Descriptive Information:</b>	X		
a) Impoundment Capacity (Normal & Max) (12196800 FT <sup>3</sup> ORIGINAL DESIGN)	X		
b) Impoundment Surface Area (14 ACRES)	X		
c) Hazard Classification (CLASS III)	X		
d) Freeboard (Normal & Min) (7.9 FT NORMAL 2 FT MIN)	X		
e) Maximum Dam Height (24.7 FT)	X		
f) Dam Crest Elevation (417.4 FT)	X		
g) Crest Width (15 FT)	X		
h) Upstream Slope Inclination (3H 1V)	X		
i) Downstream Slope Inclination (3H:1V)	X		
j) Spillway Type, Size, & Crest Elevation			X
k) Outlet Condit Type, Size, & Max Flow Capacity (18 INCH DIAMETER CS PIPE)	X		
l) Historical Maximum Pond Elevation	X		
m) Year Built	X		
n) Design Life (MAY VARY)	X		
o) Specific Wastes Permitted in Impoundment	X		
p) Other (describe)			
<b>2. Regional Map showing CCWI &amp; schools, hospitals, etc. w/i 5 mi downgradient</b>		X	
<b>3. Management Unit Dwgs:</b>			
a) Plans	X		
b) Sections	X		
c) Elevations	X		
d) Other (describe)			
<b>4. Design Information:</b>			
a) Name of Designer of Record	X		
b) Design Assumptions			X
c) Design Analyses			X

## Available Information Checklist (Continued)

### Coal Combustion Waste Impoundment (CCWI) Dam

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
d) Spillway Design Flood or Design Basis			X
e) Slope Stability Factors of Safety (ONGOING STABILITY ANALYSIS)			X
f) Design Soil Properties and Parameters (ONGOING STABILITY ANALYSIS)			X
g) Other (describe)			
<b>5. Permits:</b>			
a) NPDES? <span style="float: right;">Number? MO-0000361 ✓</span>	X		
b) Dam Safety - Operating Permit? <span style="float: right;">Number?</span>			X
c) Other (describe)			
<b>6. Subsurface Information:</b>			
a) Geology	X		
b) Geotechnical Report	X		
c) Test Boring Logs	X		
d) Subsurface Profiles	X		
f) Other (describe)			
<b>7. Monitoring Information:</b>			
a) Observation Wells/Piezometer Readings			X
b) Seepage Readings		X	
c) Settlement Readings		X	
d) Alignment Readings		X	
e) Inclinator Readings			X
f) Time vs Reading Graphs			X
g) Other (describe)			
<b>8. Instrumentation Dwgs:</b>			
a) Location Plan			X
b) Section Views			X
c) Other (describe)			

**Available Information Checklist (Continued)**  
Coal Combustion Waste Impoundment (CCWI) Dam

ITEM DESCRIPTION	PROVIDED BY UTILITY		
	YES	NO	N/A
<b>9. Operation, Maintenance, &amp; Surveillance:</b>			
<b>a) Operating Procedures</b>			
<b>b) Maintenance Procedures</b>			
<b>c) Inspection Procedures</b>	X		
<b>d) Third Party Inspection Reports</b>			
<b>e) Other (describe)</b>			
<b>10. Emergency Action Plan</b>		X	
<b>11. Inundation Map</b>			X

APPENDIX A

DOC 1.7 MISSOURI STATE OPERATING PERMIT

STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**

Bob Holden, Governor • Stephen M. Malsford, Director

DIVISION OF ENVIRONMENTAL QUALITY  
P.O. Box 176 Jefferson City, MO 65102-0176

February 22, 2002

AmerenUE  
One Ameren Plaza  
PO Box 66149 (MC-602)  
St. Louis, MO 63166

Dear Permittee:

State Operating Permit No. MO-0000361 originally issued on May 19, 2000 is hereby modified as per the enclosed. This modification increases the daily maximum limit on thermal discharges. The attached permit is for your official record.

Please read your permit and attached Standard Conditions. They contain important information on monitoring requirements, effluent limitations, sampling frequencies and reporting requirements.

This modification does not affect any monitoring or analysis of the effluent that may be necessary to comply with other requirements of your permit or other state regulations and does not in any way relieve you of your obligations to achieve the final effluent limitations as provided in the permit.

This permit is both your federal discharge permit and your new state operating permit and replaces all previous state operating permits for this facility. In all future correspondence regarding this facility, please refer to your state operating permit number and facility name as shown on page one of the permit.

If you have any questions concerning this permit, please do not hesitate to call this office or our St. Louis Regional Office, 9200 Watson Road, Suite 201, St. Louis, MO 63127-1017.

Sincerely,

WATER POLLUTION CONTROL PROGRAM

  
Philip A. Schroeder, Chief  
Permit Section

PAS:jc

Enclosure

c: St. Louis Regional Office

STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended.

Permit No. MO-0000361

Owner: Union Electric Company  
Address: One Ameren Plaza, P.O. Box 66149, St. Louis, MO 63166

Continuing Authority: Same as above  
Address: Same as above

Facility Name: Ameren UE, Meramec Power Plant  
Facility Address: 8200 Fine Road, St. Louis, MO 63129

Legal Description: SW ¼, Sec. 3, T42N, R6E, St. Louis County  
Latitude/Longitude: See page 2

Receiving Stream: See page 2  
First Classified Stream and ID: See page 2  
USGS Basin & Sub-watershed No.: See page 2

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:


FACILITY DESCRIPTION


See page 2

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

May 19, 2000      February 22, 2002  
Effective Date      Revised

May 18, 2005  
Expiration Date  
MO-0000361 (01-05)

  
Stephen M. Mohr, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

  
Interim Director of Staff, Clean Water Commission

FACILITY DESCRIPTION (continued)

Outfall #001 - Power Plant - SIC #4911

Non-contact cooling water.  
Design flow is 245 MGD.  
Actual flow is 134 MGD.  
Latitude/Longitude: +3824039/-09019574  
Receiving Stream: Mississippi River (P)  
First Classified Stream and ID: Mississippi River (P) (01707)  
USGS Basin & Sub-watershed No.: (07140101-070004)

Outfall #002 - Power Plant - SIC #4911

Non-contact cooling water.  
Design flow is 405 MGD.  
Actual flow is 251 MGD.  
Latitude/Longitude: +3824039/-09019574  
Receiving Stream: Mississippi River (P)  
First Classified Stream and ID: Mississippi River (P) (01707)  
USGS Basin & Sub-watershed No.: (07140101-070004)

Outfall #003 - Power Plant - SIC #4911

Bottom ash pond/stormwater.  
Design flow is 22.8 MGD.  
Actual flow is 0.95 MGD.  
Latitude/Longitude: +3824289/-09020362  
Receiving Stream: Unnamed Tributary to Meramec River (U)  
First Classified Stream and ID: Meramec River (P) (02183)  
USGS Basin & Sub-watershed No.: (07140102-080004)

Outfall #004 - Domestic (Human) Sewage - SIC #4952

Extended aeration/sewage treatment plant/sludge disposal is by contract hauler.  
Design population equivalent is 238.  
Design flow is 0.046 MGD.  
Actual flow is 0.028 MGD.  
Design sludge production is 4.28 dry tons/year.  
Latitude/Longitude: +3823586/-09020033  
Receiving Stream: Mississippi River (P)  
First Classified Stream and ID: Mississippi River (P) (01707)  
USGS Basin & Sub-watershed No.: (07140101-070004)

Outfall #005

Emergency overflow from combined drain sump.  
Design flow is 2.0 MGD.  
Actual flow is 0.0 MGD.  
Latitude/Longitude: +3823586/-09020033  
Receiving Stream: Mississippi River (P)  
First Classified Stream and ID: Mississippi River (P) (01707)  
USGS Basin & Sub-watershed No.: (07140101-070004)

Outfall #006

Caisson sump/screen wash.  
Design flow is 1.5 MGD.  
Actual flow is 0.43 MGD.  
Latitude/Longitude: +3824037/-09019555  
Receiving Stream: Mississippi River (P)  
First Classified Stream and ID: Mississippi River (P) (01707)  
USGS Basin & Sub-watershed No.: (07140101-070004)

FACILITY DESCRIPTION (continued)

Outfall #007

Storm water runoff from the paved employee parking lot and an area which surrounds the oil storage building.

36-inch concrete pipe.

Design flow is 0.39 MGD.

This outfall will not be monitored during this permit period.

Latitude/Longitude: +3824030/-09019569

Receiving Stream: Mississippi River (P)

First Classified Stream and ID: Mississippi River (P) (01707)

USGS Basin & Sub-watershed No.: (07140101-070004)

Outfall #008

Storm water runoff from the plant access road and adjacent lawn areas.

24-inch corrugated metal pipe.

Design flow is 0.123 MGD.

This outfall will not be monitored during this permit period.

Latitude/Longitude: +3824323/-09020193

Receiving Stream: Unnamed Tributary to Meramec River (U)

First Classified Stream and ID: Meramec River (P) (02183)

USGS Basin & Sub-watershed No.: (07140102-080004)

Outfall #009 - Power Plant - SIC #4911

Flyash pond #489/storm water/low volume waste.

Design flow is 14.9 MGD.

Actual flow is 8.0 MGD.

Latitude/Longitude: +3823565/-09020411

Receiving Stream: Meramec River (P)

First Classified Stream and ID: Meramec River (P) (02183)

USGS Basin & Sub-watershed No.: (07140102-080004)

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

PAGE NUMBER 4 of 12

PERMIT NUMBER MO-0000361

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<b>Outfall #001 - non-contact Cooling water</b>						
Flow	MGD	*		*	once/weekday**	24 hr. estimate
Temperature, Intake	°F	*		*	once/weekday**	grab
Temperature, Outfall	°F	*		*	once/weekday**	grab
Thermal Discharge	btu/hr	1.54x10 <sup>9</sup>		*	once/weekday**	n/a
<b>Outfall #002 - non-contact cooling water</b>						
Flow	MGD	*		*	once/weekday**	24 hr. estimate
Temperature, Intake	°F	*		*	once/weekday**	grab
Temperature, Outfall	°F	*		*	once/weekday**	grab
Thermal Discharge	btu/hr	3.23x10 <sup>9</sup>		*	once/weekday**	n/a
<b>Outfall #003 - ash pond</b>						
Flow	MGD	*		*	once/week	24 hr. estimate
Intake Total Suspended Solids***	mg/L	*		*	once/week	grab
Effluent Total Suspended Solids***	mg/L	*		*	once/week	grab
Net Total Suspended Solids***	mg/L	100		30	once/week	grab
Oils and Grease	mg/L	20		15	once/month	grab
pH - Units	SU	****		****	once/week	grab
Sulfate (as SO <sup>4</sup> )	mg/L	*		*	once/quarter*****	grab

MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY, THE FIRST REPORT IS DUE July 28, 2002.

Whole Effluent Toxicity (WET) Test	% Survival	(See Special Condition #3)	initial/year	grab
------------------------------------	------------	----------------------------	--------------	------

MONITORING REPORTS SHALL BE SUBMITTED ANNUALLY; THE FIRST REPORT IS DUE October 28, 2002. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

**B. STANDARD CONDITIONS**

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III STANDARD CONDITIONS DATED October 1, 1980 and August 15, 1994, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

PERMIT NUMBER MO-0000361

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #004 - Sewage treatment plant</u>						
Flow	MGD	*		*	once/month	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		45	30	once/quarter*****	*****
Total Suspended Solids	mg/L		45	30	once/quarter*****	*****
pH - Units	SU	****		****	once/quarter*****	grab
<u>Aeration Tank Testing</u>						
Total Suspended Solids	mg/L	*		*	once/month	grab
Settleability	mg/L	*		*	once/month	grab
Dissolved Oxygen	mg/L	*		*	once/month	grab
<u>Outfall #005 - emergency sump overflow</u>						
Flow	MGD	*		*	(Note 2)	24 hr. estimate
Total Suspended Solids***	mg/L	100		30	(Note 2)	grab
Oil and Grease	mg/L	20		15	(Note 2)	grab
pH - Units	SU	****		****	(Note 2)	grab
<u>Outfall #006 -caisson sump</u>						
Flow	MGD	*		*	once/quarter*****	24 hr. estimate
Total Suspended Solids***	mg/L	*		*	once/quarter*****	(Note 3)
Oil & Grease	mg/L	20		15	once/quarter*****	(Note 3)
pH - Units	SU	*****		*****	once/quarter*****	(Note 3)

MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY; THE FIRST REPORT IS DUE July 28, 2002.

**B. STANDARD CONDITIONS**

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III STANDARD CONDITIONS DATED October 1, 1980 and August 15, 1994, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

PAGE NUMBER 6 of 12

PERMIT NUMBER MO-0000361

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<b>Outfalls #007 &amp; #008 - (See Special Condition 15)</b> <b>Outfall #009 - Flyash Pond #489</b>						
Flow	MGD	*		*	once/week	24 hr. estimate
Intake Total Suspended Solids***	mg/L	*		*	once/week	grab
Effluent Total Suspended Solids***	mg/L	*		*	once/week	grab
Net Total Suspended Solids***	mg/L	100		30	once/week	grab
Oil and Grease	mg/L	20		15	once/month	grab
pH - Units	SU	****		****	once/week	grab
Sulfate (as SO <sub>4</sub> )	mg/L	*		*	once/quarter*****	grab
Whole Effluent Toxicity (WET) test	% Survival	See Special Condition #3			initial/year	grab

MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY; THE FIRST REPORT IS DUE July 28, 2002. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

**B. STANDARD CONDITIONS**

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III STANDARD CONDITIONS DATED October 1, 1980 and August 15, 1994, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

\* Monitoring requirement only.

\*\* One each weekday means: Monday, Tuesday, Wednesday, Thursday and Friday.

\*\*\* Intake Total Suspended Solids values may be used to calculate "net" limitations, however permittee must continue to maintain the ash pond system for adequate retention time for settling. River solids present in intake water are "treated" in the ash pond system but treatment levels are dependent on concentration and types of river solids present in intake water.

\*\*\*\* pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

\*\*\*\*\* Once per quarter in the months of February, May, August and November.

\*\*\*\*\* A composite sample made up from a minimum of four grab samples collected within a 24 hour period with a minimum of two hours between each grab sample.

\*\*\*\*\* pH is limited to not less than 6.0 nor greater than the source water. A pH analysis of the source water shall accompany the Discharge Monitoring Reports.

Note 1 - Reserved.

Note 2 - Measurement frequency shall be once/day when discharge occurs. Monitor only when discharge occurs. Report as no-discharge when a discharge does not occur during the report period.

Note 3 - Individual grab samples shall be collected from each Cassion sump and immediately composited for analysis. These samples will be collected prior to mixing with river water used for screen washing.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.

C. SPECIAL CONDITIONS (continued)

Whole Effluent Toxicity (WET) tests will be conducted as follows:

SUMMARY OF WET TESTING FOR THIS PERMIT				
OUTFALLS	A.E.C. %	FREQUENCY	SAMPLE TYPE	MONTH
#001, #002, #003 & #009	10%	annually	24 hr. composite	January

At the Ameren UE, Meramec Plant, Whole Effluent Toxicity (WET) tests will be required for Outfalls #001 and #002 only if biocides are used. If the WET test indicates toxicity in the first year of biocide use, the test must be run annually for the duration of the permit or until biocide use is discontinued.

a. Test Schedule and Follow-Up Requirements

- (1) Perform a single-dilution test in the months and at the frequency specified above.

If the test passes the effluent limit do not repeat test until the next test period. Submit results with the annual report.

If the test fails the effluent limit a multiple dilution test shall be performed within 30 days, and biweekly thereafter until one of the following conditions are met:

- (a) THREE CONSECUTIVE MULTIPLE-DILUTION TESTS PASS. No further tests need to be performed until next regularly scheduled test period.
- (b) A TOTAL OF THREE MULTIPLE-DILUTION TESTS FAIL.

- (2) The permittee shall submit a summary of all test results for the test series to the Planning Section of the WPCP, DNR, Box 176, Jefferson City, MO within 14 days of the third failed test. DNR will contact the permittee with initial guidance on conducting a toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE). The permittee shall submit a plan for conducting a TIE or TRE to the Planning Section of the WPCP within 60 days of the date of DNR's letter. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
- (3) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
- (4) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in part b.(1) will be required during this period.
- (5) In addition to the WET test summary report required in part (2), all failing test results shall be reported to DNR within 14 days of the availability of results.
- (6) All WET test results for the reporting period shall be summarized and submitted to DNR by the end of the following October. When WET test sampling is required to run over one DMR period, each DMR report shall contain information generated during the reporting period.

C. SPECIAL CONDITIONS (continued)

1. Whole Effluent Toxicity (WET) tests (continued)

b. PASS/FAIL procedure and effluent limitations

- (1) To pass a single-dilution test, mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the upstream receiving-water control. The appropriate statistical tests of significance will be those outlined in the most current USEPA acute toxicity manual or those specified by the MDNR.
- (2) To pass a multiple-dilution test:
  - (a) the computed percent effluent at the edge of the zone of initial dilution (AEC) must be less than three-tenths (0.3) of the  $LC_{50}$  concentration for the most sensitive of the test organisms, or,
  - (b) all dilutions equal to or greater than the AEC must be nontoxic. Failure of one multiple-dilution test is considered an effluent limit violation.

c. Test Conditions

- (1) Test species: Ceriodaphnia dubia and fathead minnows, Pimephales promelas. Organisms used in WET testing should come from cultures reared for the purpose of conducting toxicity tests and should be cultured in a manner consistent with the most current USEPA guidelines. All test animals should be cultured as described in EPA-600/4-90/027.
- (2) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
- (3) When dilutions are required, upstream receiving stream water will be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used. Procedures for generating reconstituted water will be supplied by the Department of Natural Resources (DNR).
- (4) Tests should be initiated immediately after the sample is collected, but tests must be initiated no later than 36 hours after collection.
- (5) Single-dilution tests will be run with:
  - (a) Effluent at the AEC concentration;
  - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - (c) reconstituted water.
- (6) Multiple-dilution tests will be run with:
  - (a) 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC.
  - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - (c) reconstituted water.
- (7) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.

C. SPECIAL CONDITIONS (continued)

Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
  - (1) One hundred micrograms per liter (100 ug/L);
  - (2) Two hundred micrograms per liter (200 ug/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
  - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

5. Report as no-discharge when a discharge does not occur during the report period.

6. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:

- (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
- (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
- (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
- (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
- (e) There shall be no significant human health hazard from incidental contact with the water;
- (f) There shall be no acute toxicity to livestock or wildlife watering;
- (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
- (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

7. There shall be no discharge of polychlorinated biphenyl compounds.

8. Discharge of wastewater from this facility must not be alone or in combination with other sources cause the receiving stream to violate the following:

- (a) Water temperatures and temperature differentials specified in Missouri Water Quality Standards shall be met.

Any pesticide discharge from any point source shall comply with the requirements of Federal Insecticide, Fungicide and Rodenticide Act, as amended (7 U.S.C. 136 et. seq.) and the use of such pesticides shall be in a manner consistent with its label.

C. SPECIAL CONDITIONS (continued)

10. Neither free available chlorine nor total residual chlorine may be discharged from any unit for more than two hours in any one day.
11. An upset provision, identical to the upset provision set forth at 40 CFR 122.41(n), is hereby incorporated in this permit.
12. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities (Outfall #004)
  - (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions, Part III dated June 22, 1993.
  - (b) Site-Specific conditions applicable to this facility are as follows: N/A
13. Treatment or Storage of Ash from Power Plants
  - (a) Disposal of ash is not authorized by this permit.
  - (b) This permit does not pertain to permits for disposal of ash or exemptions for beneficial uses of ash under the Missouri Solid Waste Management Law and regulations.
  - (c) This permit does not authorize off-site storage, use or disposal of ash in regard to water pollution control permits required under 10 CSR 20-6.015 and 10 CSR 20-6.200.
  - (d) Subsurface discharges from wastewater treatment ponds or ash ponds shall, at the property boundary, meet the effluent limitations for subsurface waters of the state under 10 CSR 20-7.015(7), with appropriate consideration of up-gradient water quality.
14. Permittee is exempt from Clean Water Act section 311 reporting for sulfuric acid and sodium hydroxide as per 40 CFR 117.12.
15. Outfalls #007 & #008 - The company has elected to use best management practices (BMP's) on these outfalls. Monitoring is waived for this permit cycle. If problems occur, monitoring may be reestablished by the department. Periodic inspection of these outfalls will be carried out by AmerenUE to ascertain that BMP's are working.

**SUMMARY OF TEST METHODOLOGY FOR WHOLE-EFFLUENT TOXICITY TESTS**

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless otherwise specified by MDNR, procedures should be consistent with Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, EPA/600/4-90/027.

Test conditions for Ceriodaphnia dubia:

Test duration:	48 h
Temperature:	25 ± 2°C
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light, 8 h dark
Size of test vessel:	30 mL (minimum)
Volume of test solution:	15 mL (minimum)
Age of test organisms:	<24 h old
No. of animals/test vessel:	5
No. of replicates/concentration:	4
No. of organisms/concentration:	20 (minimum)
Feeding regime:	None (feed prior to test)
Aeration:	None
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Mortality (Statistically significant difference from upstream receiving water control at p# 0.05)
Test acceptability criterion:	90% or greater survival in controls


Test conditions for (Pimephales promelas):

Test duration:	48 h
Temperature:	25 ± 2°C
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light/ 8 h dark
Size of test vessel:	250 mL (minimum)
Volume of test solution:	200 mL (minimum)
Age of test organisms:	1-14 days (all same age)
No. of animals/test vessel:	10
No. of replicates/concentration:	4 (minimum) single dilution method 2 (minimum) multiple dilution method
No. of organisms/concentration:	40 (minimum) single dilution method 20 (minimum) multiple dilution method
Feeding regime:	None (feed prior to test)
Aeration:	None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min.
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Mortality (Statistically significant difference from upstream receiving water control at p# 0.05)

Test Acceptability criterion: 90% or greater survival in controls

APPENDIX A

DOC 1.8 1995 FEMA FLOOD INSURANCE RATE MAP



APPROXIMATE SCALE IN FEET  
1000 0 1000

**NATIONAL FLOOD INSURANCE PROGRAM**

**FIRM  
FLOOD INSURANCE RATE MAP**

**ST. LOUIS COUNTY,  
MISSOURI AND  
INCORPORATED AREAS**

**PANEL 415 OF 420**

(SEE MAP INDEX FOR PANELS NOT PRINTED)

CONTAINS:  
COMMUNITY

NUMBER PANEL SUFFIX

ST. LOUIS COUNTY,  
UNINCORPORATED AREAS

290327 0415 H

**MAP NUMBER  
29189C0415 H**

**EFFECTIVE DATE:  
AUGUST 2, 1995**



Federal Emergency Management Agency

This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT On-Line. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. For the latest product information about National Flood Insurance Program flood maps check the FEMA Flood Map Store at [www.msc.fema.gov](http://www.msc.fema.gov)

APPENDIX A

DOC 1.9 EXCERPT FROM APPENDIX D OF THE 2004 USACE UPPER MISSISSIPPI  
RIVER SYSTEM FLOW FREQUENCY STUDY

TABLE D-30 CONTINUED TABULAR RESULTS MISSISSIPPI RIVER FREQUENCY

RIVER MILE	STATION NAME	50.0%	20.0%	10.0%	5.0%	4.0%	2.0%	1.0%	0.5%	0.2%
158.21		397.3	402.8	405.8	408.5	409.4	411.9	413.9	414.9	416.8
158.50	WATERS POINT	397.4	402.9	406.0	408.6	409.6	412.0	414.0	415.0	417.0
158.67		397.5	403.0	406.0	408.7	409.6	412.1	414.1	415.1	417.1
159.23		397.8	403.3	406.3	409.0	410.0	412.4	414.4	415.4	417.4
159.73		398.1	403.6	406.6	409.3	410.2	412.7	414.6	415.7	417.7
160.18		398.3	403.8	406.8	409.6	410.5	413.0	414.9	415.9	417.9
160.71		398.6	404.1	407.1	409.8	410.8	413.3	415.1	416.2	418.2
160.71	MERAMEC RIVER	398.6	404.1	407.1	409.8	410.8	413.3	415.1	416.2	418.2
161.24		398.9	404.3	407.4	410.1	411.1	413.6	415.4	416.4	418.5
161.86		399.2	404.7	407.7	410.5	411.4	413.9	415.7	416.8	418.8
162.38		399.5	404.9	408.0	410.8	411.7	414.2	416.0	417.1	419.1
162.99		399.9	405.2	408.3	411.1	412.0	414.5	416.3	417.4	419.4
163.30		400.0	405.4	408.4	411.3	412.2	414.7	416.5	417.5	419.6
163.80		400.3	405.6	408.7	411.5	412.5	415.0	416.7	417.8	419.8
164.20		400.5	405.8	408.9	411.7	412.7	415.2	416.9	418.0	420.1
164.67		400.8	406.1	409.1	412.0	413.0	415.5	417.2	418.3	420.3
165.25		401.1	406.4	409.4	412.3	413.3	415.8	417.5	418.6	420.6
165.81		401.4	406.7	409.7	412.6	413.6	416.1	417.8	418.9	420.9
166.40		401.7	407.0	410.0	412.9	413.9	416.5	418.1	419.2	421.2
167.03		402.1	407.3	410.4	413.3	414.3	416.8	418.4	419.5	421.6
167.52		402.3	407.5	410.6	413.5	414.6	417.1	418.7	419.8	421.8
168.13		402.7	407.8	410.9	413.9	414.9	417.4	419.0	420.1	422.2
168.75	JEFFERSON BARRACKS	403.0	408.2	411.3	414.2	415.2	417.8	419.3	420.4	422.5
168.80		403.0	408.2	411.3	414.2	415.3	417.8	419.3	420.4	422.5
168.81		403.0	408.2	411.3	414.2	415.3	417.8	419.3	420.5	422.5
168.92		403.1	408.3	411.4	414.3	415.3	417.9	419.4	420.5	422.6

APPENDIX A

DOC 1.10 LETTER TO USEPA FROM AMEREN MISSOURI MARCH 2, 2011,  
INCLUDING REITZ & JENS STABILITY REPORT, NOVEMBER 16, 2010



March 2, 2011

Mr. Stephen Hoffman  
US Environmental Protection Agency (5304P)  
1200 Pennsylvania Avenue, NW  
Washington, DC 20460

**Re: Ameren Missouri  
Meramec Power Station  
Dewberry & Davis, LLC Coal Combustion Waste Impoundment  
Round 7 – Dam Assessment Report**

Dear Mr. Hoffman:

Below are Ameren Missouri's responses to the Dewberry & Davis, LLC draft dam safety assessment of the coal combustion waste (CCW) impoundments at the Meramec Power Station. The draft report was received by Ameren Missouri from the U.S. EPA on February 4, 2011. We have also enclosed a copy of our recently completed stability analysis of the Meramec CCW impoundments as requested by your consultant. Please note that we have recently revised the designation for our Company from AmerenUE to Ameren Missouri.

Recommendations from the Dewberry & Davis, LLC report are presented in **bold faced** type and our responses are provided in regular type.

**1.2.1 Recommendations Regarding the Structural Stability: None appear warranted at this time to satisfy a critical need. An embankment stability analysis is being conducted and will be available at the end of year of 2010. A copy of this analysis is requested.**

Response: The subsurface investigation and stability analysis for the Meramec Power Station mentioned in the assessment has been completed and a copy of the report is enclosed with this letter for the EPA's review. Ameren has initiated a project to be implemented in 2011 which will flatten the existing slopes on the downstream side of Pond 489, Pond 493, and the Retention Pond. This project will increase the embankment cross-sectional area and improve the factor of safety of the perimeter levee in these sections. Based on the implementation of this project and engineering data and evaluation provided in this report, we request the overall condition ratings for the ponds be reevaluated prior to issuing the final report.

**1.2.2 Recommendations Regarding the Hydrologic/Hydraulic Safety: It is recommended that Ameren Missouri review and document the design flood for the CCW basins. It is also recommended that Ameren Missouri review and document the effects of the 100-year frequency rainfall event with the Mississippi River flood elevation on the plant.**

Response: A Hydraulic evaluation of the Meramec Plant was completed as part of the Phase I Report by Reitz & Jens, Inc. dated August 31, 2007. The hydraulic evaluation performed by Reitz & Jens documents the effects of the 100-year, 24-hour rainfall event. This report shows that the ponds have sufficient storage for the 100-year 24-hour storm when the starting pool elevation is at or below normal. This report also states when the Mississippi River is at the 100-year flood elevation reported by FEMA, the Retention Pond and Pond 495 will

be inundated. A copy of this report was sent to your consultants (Dewberry & Davis, LLC) with the "Request for Data" letter dated October 6, 2010.

**1.2.3 Recommendations Regarding the Supporting Technical Documentation: Provide documentation as recommended above in Subsections 1.21 and 1.22**

Response: See the above responses for 1.2.1 & 1.2.2.

**1.2.4 Recommendations Regarding the Description of the Management Unit(s): Documented descriptions of the CCW ponds and operational procedures were not provided. It is recommended that the purpose and processes within the CCW ponds be summarized in an operational manual.**

Response: Currently Ameren Missouri does not have a formal Operation & Maintenance procedure for the Meramec Power Station. Ameren plans to develop an Operation & Maintenance manual for the Meramec Power Station in 2011.

**1.2.5 Recommendations Regarding the Field Observations: None appear warranted at this time.**

Response: No action required.

**1.2.6 Recommendations Regarding the Maintenance and Methods of Operation. The recommendations include the following:**

- **It is recommended that woody vegetation be removed from embankment slopes and groin areas, and embankment slopes and toe areas be mowed at least twice annually**
- **It is recommended that the seepage area observed at the outside of Pond 4 continue to be monitored for changed conditions.**
- **It is recommended that the inside slope and retaining wall of Pond 1 be monitored and maintained.**

Response: The individual bullet items are discussed below in order.

- Woody vegetation was removed from the perimeter levee in October 2009. Routine maintenance of the slopes will be performed to ensure woody vegetation is controlled.
- The seepage area outside Pond 4 is monitored by plant staff during weekly inspections, and annually by Dam Safety. Changed conditions will be evaluated and addressed accordingly.
- The inside slope and retaining wall of Pond 1 is monitored by plant staff during weekly inspections, and annually by Dam Safety. Maintenance will be performed as required.

**1.2.7, Recommendations Regarding the Surveillance and Monitoring Program: It is recommended that internal inspection of the outlet structures be performed at a frequency of at least once every 5 years and be documented with a written report.**

Response: A thorough inspection of the outlet structures is performed annually by Dam Safety and plant personnel. A written report is generated with each annual inspection.

**1.2.8, Recommendations Regarding Continued Safe and Reliable Operation: No additional recommendations for continued safe and reliable operation appear warranted at this time.**

Response: No action required.

**Business Confidentiality Claim**


We request the Draft Dam Safety Assessment Report for the Meramec Power Station prepared by Dewberry & Davis, LLC, as well as our responses to this report remain confidential. We also request the attached Meramec Ash Pond Dam Stability Analysis Report be kept confidential. This request is made in accordance with the procedures described in 40 CFR, Part 2, Subpart B.

When initially submitting support documents to Dewberry & Davis, LLC for preparation of their report we also designated the following materials as confidential:

- Plans of the embankment
- EIP
- Dam Safety Program for AmerenUE Non-Hydro Facilities
- AmerenUE Dam Inventory Inspection Program
- August 31, 2007 Phase I Report
- EPA Questionnaire
- February 26, 2008 Ash Pond #494 Drilling and Piezometer installation
- 2008 and 2009 Annual Inspection Reports
- Weekly Inspection Reports

If you need further information, please feel free to contact me at 314-554-2388.

Sincerely,



Paul R. Pike  
Environmental Science Executive  
Environmental Services  
T 314.554.2388  
F 314.554.4182  
[ppike@ameren.com](mailto:ppike@ameren.com)

Enclosures



**REITZ & JENS, INC.**  
CONSULTING ENGINEERS

1055 corporate square drive  
st. louis, missouri 63132  
phone: 314.993.4132  
fax: 314.993.4177  
www.reitzjens.com

November 16, 2010

**CONFIDENTIAL**

Mr. Matt Frerking  
Managing Supervisor – Dam Safety  
Ameren Missouri  
3700 South Lindberg, MC F-604  
Sunset Hills, Missouri 63127

RE: Ash Pond Dam Stability Analysis  
Meramec Power Station

Dear Mr. Frerking:

This report presents our findings and recommendations from the geotechnical field investigations, laboratory testing, land survey, and slope stability analyses of the dams impounding the ash ponds at the Meramec Power Station. The investigation, testing and analyses was done in general accordance with our proposal dated January 29, 2010, and Ameren Missouri's request for proposal dated December 9, 2009. The purpose of this project is to evaluate the stability of the ash pond dams and conduct the necessary land surveys, subsurface explorations, and laboratory testing to define the critical section at each location. The slope stability analysis conducted was for the load cases required by the Missouri Department of Natural Resources (MDNR). The results of the slope stability analysis were compared to the required safety factors for the type and assumed hazard classification of each dam.

In 2007, Reitz & Jens (RJ) completed the Phase I: AmerenUE Dam Inventory and Inspection Program project. This project was a preliminary study and consisted of determining the existing condition and classification status of the dams at Rush Island, Meramec, Labadie and Sioux Power Stations and developing a site specific inspection program at each power station. The project involved field inspections, surveys, site reconnaissance, research of current registration requirements, and pertinent computations. Site specific recommendations for future inspections were developed which include inspection templates, frequency of monitoring and maintenance recommendations. The study reported that the height of the Meramec dam was approximately 24.7 feet, and that the dams did not fall under the current MDNR regulation that requires all dams 35 feet or more in height to be regulated. The report also found no dwellings downstream of the dams and if regulation were necessary the dams would be categorized within Environmental Site Class III. The MDNR dam safety regulations have not changed since the 2007 report.

### SURVEY

A land survey was conducted to determine the elevation profile along the crest of the dam. The extents of the survey were chosen to include the areas with the greatest elevation difference between the crest and the downstream toe and the segments impounding water or unconsolidated sediment. Cross-

sections were also surveyed at multiple locations at each plant to determine the slope heights and geometry. Zahner and Associates, Inc. conducted the survey, as a subcontractor to RJ. At the Meramec Power Station an elevation survey of the crest was conducted over approximately 4,600 lineal feet. Elevation profile measurements were taken at 100 foot intervals. The extents of the elevation profile are shown in Figure 1 and a plot of the measured elevations is presented in Appendix B. A total of five cross-sections were surveyed, one adjacent to Pond 489, two adjacent to Pond 494 and two on the Retention Pond and Pond 498. Plots of the cross-sections are shown in Appendix A. From the cross-section surveys, the approximate maximum height of the Meramec dam is 24 feet at cross-section 3. The dam height surveyed during this project is in close agreement with that found during the Phase I: AmerenUE Dam Inventory and Inspection Program project. Due to high river levels during most of this project, the survey was not extended far enough to capture the creek running along the north side of the dam. Based on the preliminary findings from the Phase I project, the height of the dam may be increased with additional survey data from this area.

### **GEOTECHNICAL FIELD INVESTIGATION AND LAB TESTING**

Geotechnical field investigations were conducted using rotary drilling and cone penetrometer test (CPT) soundings. The quantity of borings and soundings, and the approximate locations at the power station are shown in Figure 1. The boring locations were selected by RJ based on previous experience at these locations, to fill in gaps where there was no subsurface data, slope geometry and to provide soil profiles representative of as much of the embankment as possible. The elevations of the ground surface at the boring locations were measured by Zahner and Associates, Inc. The borings were made by Terra Drill, Inc. of Dupon, Illinois, as a subcontractor to Reitz & Jens. The borings were advanced through the soil using 4.25-in. I.D. hollow-stem augers. Mud rotary drilling was not necessary in either of the auger drilling locations. Holes were backfilled with cement grout, which was tremmied from the bottom to the top.

The CPT soundings were also made by Terra Drill, Inc. using a Geo-probe rig, under a subcontract with Reitz & Jens. The cone penetrometer consists of a 1.5-inch diameter, 100 MPa capacity, electronic piezocone (CPTu), which records tip pressure, sleeve friction and porewater pressure as it is hydraulically pushed into the ground. The testing was carried out according to ASTM D5778. The holes were backfilled the same day with Bentonite pellets.

The field investigation was done under the direction of a Reitz & Jens' geological engineer or geotechnical technician, who determined the sampling intervals and the termination depths, operated the CPT equipment, and logged the borings. The boring logs for the Meramec Power Station are presented in Figures 2-1 to 2-2. Logs of CPT soundings are presented in Figures 3-1 to 3-8. The keys and notes for the boring logs and CPT soundings are shown in Figures 2-0 and 3-0, in that order.

Samples of subsurface materials were obtained using rotary drilling methods at about 2.5-foot intervals for the first 10 feet, at 5-foot intervals below 10 feet. Two types of samplers were used: 1) a hydraulically pushed, 3-in. O.D., thin-walled Shelby tube sampler (ASTM D-1587); and 2) a 2-in. O.D., split-spoon sampler driven by an automatic hammer in conjunction with a Standard Penetration Test (ASTM D-1586). Published tests have shown that the blow counts from a Standard Penetration Test (SPT) using an automatic hammer are about 75% of the blow counts obtained using a manual 140-lbs. drop hammer, rope and cathead. Manual SPT hammers have been used to develop correlations between SPTs and soil properties, therefore, the blow counts, or N-values, from an automatic hammer should be

increased by about one-third in order to use such correlations. The uncorrected blow counts are shown on the boring logs. The disturbed split-spoon samples obtained were visually classified in the field and sealed in glass jars to prevent loss of moisture, for later testing in the laboratory. The relatively undisturbed Shelby tube samples were sealed in the tubes and were extruded from the tubes immediately prior to testing in the lab.

All of the recovered samples were visually described in our laboratory in general accordance with the Unified Soil Classification System and the Standard Test Method for Classification, Description, and Identification of Soils (ASTM D-2487 and D-2488). Index tests were also performed and included: water content and dry unit weight tests (ASTM D-2216). The results of these index tests appear on the individual boring logs. Unconsolidated undrained (UU) triaxial compression tests (ASTM D2850) and consolidated undrained (CU) triaxial compression tests (ASTM D-4767) with pore pressure measurement were performed on selected Shelby tube samples of the fine grained samples, to obtain better measurements of the *in situ* total and effective shear strength properties. The results of the UU and CU triaxial shear strength tests are presented with the boring logs in Figures 2-3 and 2-4.

The field data from the CPT soundings were analyzed in the office using the program CPT-pro, Ver. 5.49 by Geosoft. The program automatically applies corrections for depth, and post/pre-data collection baseline readings. These corrected field data are plotted in the CPT logs, which are field tip resistance ( $q_c$ ), sleeve friction ( $f_s$ ) and pore water pressure ( $u_2$ ). Soil type was determined based upon the Robertson (1986) method<sup>1</sup>. Undrained shear strength ( $s_u$ ) was calculated for cohesive materials based upon the Lunne (1997) method<sup>2</sup>. Equivalent Standard Penetration Test (SPT)  $N_{60}$  values were calculated using procedures recommended by Robertson (1986)<sup>1</sup>. The equivalent  $N_{60}$  values were used to verify the computed internal friction angle ( $\phi$ ) in sands and  $s_u$  in fine-grain soils. The estimate of  $\phi$  in coarse soils was based upon the measured  $q_c$  values using Bowles (1996).<sup>3</sup> The computed parameters  $N_{60}$ ,  $s_u$  and  $\phi$  are also plotted in the CPT logs.

### **PIEZOMETER INSTALLATION AND MONITORING**

A temporary piezometer was installed to help define the line of seepage through the dam. The piezometer was located at the upstream crest, with the tip located in the lower most embankment fill above the native soils. The location of the piezometer is shown in Figure 1, and a description of the tip elevation is noted in the boring log. PZ-1 was located along the north side of the dam near the Retention Pond.

The piezometer was constructed using 1-inch inside diameter Schedule 40 PVC pipe, 0.010-inch factory machine-slotted screen and was capped with an above grade well protector. The bottom 10 feet of the piezometer was screened and backfilled with filter sand.

Readings were obtained from the piezometer and compared to the pool elevation. A table containing the piezometer readings is shown below. The temporary piezometer was removed after several readings

---

<sup>1</sup> Robertson, P.K., et al. (1986), "Use of Piezometer Cone Data," *Proceedings of the ASCE Specialty Conference In Situ 86: Use of In Situ Tests in Geotechnical Engineering*, ASCE.

<sup>2</sup> Lunne, T., Robertson, P.K. and Powell, J.J.M. (1997). *Cone Penetration Testing in Geotechnical Practice*. Published by Blackie Academic \* Professional.

<sup>3</sup> Bowles, Joseph E. (1996). *Foundation Analysis and Design*. 5<sup>th</sup> ed., McGraw-Hill, page 180.

were obtained and the hole was grouted closed with cement grout. Additional readings were obtained from existing piezometers at the plant. The existing piezometers are generally located on the east side of Pond 494. Existing piezometer PZ-1 is located near cross-section 4 and existing piezometer PZ-3 is located near CPT sounding P-5. Readings from the existing piezometers are presented in the following table.

Meramec Power Station

Date	Piezometer	Reading	Groundwater Elevation (ft)	Ground Surface Elevation (ft)	Tip Elevation (ft)	Pond Elevation (ft)
8/31/2010	PZ-1 (RJ)	17.9	398.6	413.6	386.6	-
9/7/2010	PZ-1 (RJ)	18.8	397.7	413.6	386.6	-
10/8/2010	PZ-1 (RJ)	16.3	400.2	413.6	386.6	-
8/31/2010	PZ-1*	17.7	398.6	413.3	371.8	-
9/7/2010	PZ-1*	18.6	397.7	413.3	371.8	-
8/31/2010	PZ-3*	27.4	390.0	414.3	369.3	-
9/7/2010	PZ-3*	28.6	388.7	414.3	369.3	-

\*Existing permanent piezometer

### MERAMEC POWER STATION

The Meramec Power Station is located at the southern most point in St. Louis County, Missouri near the confluence of the Meramec and Mississippi Rivers. The plant is located south of the City of Oakville and east of the City of Arnold. The Meramec River is adjacent to the plant on the west. To the east is the Mississippi River. The confluence of these two rivers is directly south of the plant. To the north of the plant is a small creek, wooded uplands and Meramec River floodplain.

The Meramec Dam is a single stage industrial dam. The dam impounds an area of approximately 138-acres for coal combustion ash sedimentation and water treatment purposes. The impoundment area was estimated from an aerial photo. The perimeter of the dam has a length of approximately 6,400-lineal-feet (lf). This dam forms the perimeter of several smaller impoundments. These impoundments include the Retention Pond, the New Ash Pond, Pond 489, Ponds 490-496 and Pond 498. All or portions of ponds 490, 491, 494, 495 and 498 have been filled to capacity with coal combustion ash, and are now supporting plant equipment.

An elevation profile was run on the Meramec Dam from the southwest corner of Pond 489 to the railroad track crossing near Pond 493. The total distance of the profile was approximately 4,600 feet and the minimum and maximum crest elevation was 413.3 and 419.5, in that order. A plot of the elevation profile is shown in Appendix C. Five cross-sections were also surveyed and the approximate locations and drawings depicting the sections are shown in Appendix B. The downstream slope angles for the various sections varied from 1.7 (H) to 2.5 (H) on 1 (V). One section was adjacent to Pond 498, 2 were adjacent to Pond 494, and 2 were adjacent to the Retention Pond and Pond 498.

### **Pond 489**

Cross-section 3 was measured near the outfall for Pond 489. The survey showed that the upstream slopes were approximately 3 (H) to 1 (V) and the downstream slopes were approximately 1.9 (H) to 1 (V). The embankment height at this section is approximately 24.5 feet.

At this section an auger boring was drilled at the centerline of the crown and a CPT sounding was conducted at the toe. The drilling revealed that the dam fill generally consists of fly ash, bottom ash, silty clay, and high plastic clay. The coarse grain fill was typically medium dense and the fine grained fill was stiff. A UU test was conducted on a specimen of high plastic clay which was sampled from the fill. The measured  $s_u$  of the material was approximately 1900 psf. For modeling purposes we estimated that the  $\phi$  of the fill is approximately  $29^\circ$ .

The top 18 feet of the foundation soil consisted of silty and moderate to high plasticity clay soils. The stiffness was soft to firm in the top 9 feet and became slightly stiffer from 9 to 18 feet. Based on correlations for N-values in clay and CPT soundings, we estimate that the top 9 feet of the foundation soil has a  $\phi$  of  $23^\circ$  and from 9 to 18 feet the  $\phi$  is  $24^\circ$ . Beneath the clay and to a depth of approximately 43 feet, clay, silt and sand were observed. The soil is generally soft or loose and CPT soundings indicated  $\phi$  values ranging from  $22.5^\circ$  to  $25^\circ$ .

#### **Pond 494**

Cross-sections 2 and 4 were measured adjacent to Pond 494. At section 2 the upstream slopes were very steep in the top half of the dam and were sloped at 1.6 (H) to 1 (V) and became less steep in the lower half of the dam at 2.4 (H) to 1 (V). The approximate height of the dam at this location was 15.3 feet. Cross-section 4 was located to the north of section 2. The slopes at section 4 varied from approximately 1.9 (H) to 2.5 (H) on 1 (V). The height of the dam at this location was approximately 20.8 feet.

Five CPT soundings were conducted near the locations of these sections. Two were located at the crest of the dam and three were located at the toe. The data obtained from the soundings was averaged to come up with a profile representative of both sections. The embankment fill generally consisted of clay, although thin silty clay and clayey silt layers were observed near the top of the embankment. Based on data obtained from the CPT soundings we modeled the embankment fill in these locations with a  $\phi$  of  $23^\circ$  and an effective cohesion of 200 psf.

The top 6 feet of the foundation soil consisted of soft clay. Using the data obtained from the CPT soundings we estimated the  $\phi$  of the clay to be  $23^\circ$ . Underlying the clay was stiff clay and silty clay. Using the shear strengths obtained from a CU test in the silty clay foundation soil, we modeled this stratum with a  $\phi$  of  $27^\circ$  and an effective cohesion of 100 psf. At a depth of approximately 22 feet into the foundation, sand and silt was encountered. The CPT soundings show that the  $\phi$  of these strata are approximately  $30^\circ$ .

#### **Retention Pond and Pond 498**

Cross-sections 1 and 5 were measured near the Retention Pond and Pond 498. The upstream slopes at sections 1 and 5 were 2 (H) on 1 (V) and 1.7 (H) on 1 (V), respectively. Section 1 has a height of approximately 18 feet and the height of section 5 is roughly 19.5 feet. Due to floodwater, the cross-section surveys were stopped prior to reaching the creek which runs adjacent to the ponds on the north. For modeling purposes, survey data from the Phase I project was used to approximate the location, slope angles and elevations of the top of bank and bottom of the creek. The survey data from the Phase I project increases the height of the cross-section to approximately 25 feet.

One auger boring and one CPT sounding were conducted in the crown, and one CPT sounding was conducted at the toe, near these sections. A piezometer was installed at the location of the auger boring. The embankment fill consisted of sandy silt, clayey silt and silty clay. Fly and bottom ash were also observed in the samples obtained from the auger boring. The embankment fill was modeled with a  $\phi$  of  $26^\circ$  based on the N-values and CPT soundings.

The top 12 feet of the foundation soil was silty clay. A CU test was run on a specimen obtained in this stratum. The test data showed that the stratum had a  $\phi$  of  $27^\circ$  and an effective cohesion of 100 psf. Beneath the silty clay 5 feet of stiff clay was observed. Based on the CPT soundings we estimate the  $\phi$  of the clay to be  $26^\circ$ . Clayey silt, silty clay, and sandy silt were observed at a depth of 17 feet in the foundation to the boring termination depth. The coarse grained strata were generally loose to medium dense and the cohesive strata were soft to firm, and using the CPT soundings a  $\phi$  of  $25^\circ$  was used for modeling purposes.

**Slope Stability Analysis Results**

The stability of each cross-section was analyzed for the steady seepage and seismic load cases. The steady seepage case was analyzed using piezometric data obtained from the piezometer installed during this project and from existing piezometers installed adjacent to Pond 494. It was assumed that the piezometric levels will not vary widely because most of the impounded area is filled with ash. Each piezometer was located at the upstream crest of the dam. For Pond 489 no seepage was assumed to occur from the pond because it is lined with high-density polyethylene (HDPE).

For the seismic load case a horizontal acceleration of 0.0575 g or 0.25 of the probable maximum acceleration (PMA) was added to the steady state seepage model. The seismic load was taken from 10 CSR 22-3 for St. Louis County (Zone D) and for an environmental site class III dam.

The analysis show for the steady seepage load case the calculated factor of safety is less than the required factor of safety by the MDNR. This analysis limited the search for critical failure surfaces to those that significantly impact the dam. The factor of safety is lower for shallow slope failures. For the seismic load case the factor of safety exceeded that required by the MDNR.

**Meramec Power Station**

Load Case	Required Factor of Safety	Factor of Safety				
		Cross-Section 1	Cross-Section 2	Cross-Section 3	Cross-Section 4	Cross-Section 5
Steady Seepage	1.5	1.3	1.4	1.3	1.4	1.2
Earthquake, Steady Seepage	1.0	1.1	1.2	1.1	1.2	1.1

**CONCLUSIONS**

The stability of the Meramec Dam was analyzed for steady seepage and seismic load cases. For the seismic load case the calculated factor of safety was greater than the minimum required by MDNR for

an environmental site class III dam, but for the steady seepage load case the factor of safety for all five cross-sections is below the minimum required. The low factor of safeties for the steady seepage case is primarily due to the steep downstream slope angles, which generally are steeper than 2 (H) on 1 (V). In addition, the upper most strata of the foundation soil generally consist of soft clay.

The impounded area of the ponds is generally filled to capacity with coal combustion ash. As a result the line of seepage from the impounded area is relatively low within the embankment. This was confirmed with the piezometric levels measured during this project. Positive drainage should be maintained within the impounded area. Should the line of seepage rise within the embankment, the stability of the slopes and the factor of safety will be less.

Please let us know if you have any questions regarding this report or any aspects of the project. We appreciate this opportunity to continue our working relationship with Ameren Missouri.

Sincerely,  
REITZ & JENS, Inc.



Donald S. Eskridge, P.E.  
Principal



Jeff Bertel, P.E.  
Project Engineer

The following figures are attached and complete this report:

Figure 1	Boring Location Map
Figure 2-0	Key to Boring Logs
Figures 2-1 to 2-2	Logs of Borings
Figures 2-3 to 2-4	Graphs of CU and UU tests
Figure 3-0	Key to CPT Soundings
Figure 3-1 to 3-8	Logs of CPT Soundings
Appendix A	Cross-sections
Appendix B	Elevation Profile
	Graphical Depictions of Slope Stability Models

Copies submitted: 5

# Meramec Power Station



Elevation Profile Survey Limits  
Locations of Cross-sections and Borings

# KEY TO BORING LOGS

Symbol Description

## KEY TO SOIL SYMBOLS



Crushed Limestone



Miscellaneous FILL



Medium to high plastic CLAY



Low plastic Silty CLAY (CL)

## MISCELLANEOUS SYMBOLS



Water table during drilling



Moisture content (%)



N-value from Standard Penetration Test, ASTM D-1586 (blows/ft)



Shear strength from Pocket Penetrometer (tsf)

## SOIL SAMPLERS



2-in. O.D. Split-Spoon



3-in. O.D. Shelby Tube

### Notes:


1. Details of the drilling and sampling program are presented in the general introduction of the report.
2. Stratification lines shown on the logs represent approximate soil boundaries; actual changes in strata may be gradual or occur between samples.

Figure 2-0

PROJECT: Ash Pond Stability  
Meramec Power Plant  
CLIENT: Ameren Missouri

BORING NUMBER: **PZ-1**  
LOCATION:  
COORD. N 937323.42 E 864991.49  
ELEVATION: 413.6 DATUM: NAVD88  
FIGURE: 2-1 SHEET 1 OF 1

DATE DRILLED: 08-09-10



THE STRATIFICATION LINES REPRESENT APPROXIMATE SOIL BOUNDARIES. ACTUAL STRATIFICATION MAY BE GRADUAL.


DRILLER: Terra Drill  
METHOD: HSA  
TYPE OF SPT HAMMER: Automatic  
HAMMER EFFICIENCY (%):  
LOGGED BY: J. Pruett

WATER LEVELS: DURING DRILLING 29 FEET  
BORING DRY AT COMPLETION OF DRILLING  
AT FEET AFTER HOURS  
AT FEET AFTER HOURS  
PIEZOMETER: INSTALLED AT FEET

File:

PROJECT: Ash Pond Stability  
 Meramec Power Plant  
 CLIENT: Ameren Missouri  
 DATE DRILLED: 08-09-10



BORING NUMBER: **B-2**  
 LOCATION:  
 COORD. N 934544.23 E 864910.61  
 ELEVATION: 414.0 DATUM: NAVD88  
 FIGURE: 2-2 SHEET 1 OF 1



THE STRATIFICATION LINES REPRESENT APPROXIMATE SOIL BOUNDARIES: ACTUAL STRATIFICATION MAY BE GRADUAL.

DRILLER: Terra Drill  
 METHOD: HSA  
 TYPE OF SPT HAMMER: Automatic  
 HAMMER EFFICIENCY (%):  
 LOGGED BY: J. Pruett

WATER LEVELS: DURING DRILLING 24 FEET  
 BORING DRY AT COMPLETION OF DRILLING  
 AT FEET AFTER HOURS  
 AT FEET AFTER HOURS  
 PIEZOMETER: INSTALLED AT FEET



Sample No.	1	2	3	
Initial	Water Content,	26.4	26.4	26.4
	Dry Density, pcf	96.8	96.8	96.8
	Saturation,	98.6	98.6	98.6
	Void Ratio	0.7098	0.7098	0.7098
	Diameter, in.	2.84	2.84	2.84
At Test	Height, in.	5.81	5.81	5.81
	Water Content,	26.0	25.4	25.1
	Dry Density, pcf	98.0	98.8	99.4
	Saturation,	100.0	100.0	100.0
	Void Ratio	0.6878	0.6736	0.6647
Test Parameters	Diameter, in.	2.83	2.84	2.86
	Height, in.	5.78	5.70	5.60
	Strain rate, %/min.	0.01	0.01	0.01
	Back Pressure, tsf	3.96	4.32	5.04
	Cell Pressure, tsf	4.32	5.04	6.12
	Fail. Stress, tsf	0.46	0.73	1.11
	Total Pore Pr., tsf	4.15	4.72	5.57
	Ult. Stress, tsf			1.37
	Total Pore Pr., tsf			5.48
	$\sigma_1$ Failure, tsf	0.63	1.05	1.67
$\sigma_3$ Failure, tsf	0.17	0.32	0.55	

**Type of Test:**

CU with Pore Pressures

**Sample Type:** Shelby Tube

**Description:** Silty clay FILL (CL), grey and brownish grey, with pockets of very silty clay and high plastic clay, trace rock

**Assumed Specific Gravity=** 2.65

**Remarks:**

**Client:** Ameren Missouri

**Project:** Ash Pond Stability

**Source of Sample:** PZ-1

**Depth:** 19

**Sample Number:** ST-6

**Proj. No.:** 2010012488



**Date:** 8/9/10



Figure 2-3

Tested By: K. Kocher

Checked By: J. Bertel



Sample No.		1	2
Initial	Water Content,	23.5	26.9
	Dry Density, pcf	99.2	96.2
	Saturation,	91.7	97.6
	Void Ratio	0.6870	0.7385
	Diameter, in.	2.85	2.85
	Height, in.	5.82	5.82
At Test	Water Content,	23.5	26.9
	Dry Density, pcf	99.2	96.2
	Saturation,	91.7	97.6
	Void Ratio	0.6870	0.7385
	Diameter, in.	2.85	2.85
	Height, in.	5.82	5.82
Strain rate, %/min.	0.83	0.83	
Back Pressure, tsf	0.00	0.00	
Cell Pressure, tsf	0.29	0.65	
Fail. Stress, tsf	2.02	1.91	
Ult. Stress, tsf			
$\sigma_1$ Failure, tsf	2.30	2.56	
$\sigma_3$ Failure, tsf	0.29	0.65	

**Type of Test:**  
Unconsolidated Undrained

**Sample Type:** Shelby Tube

**Description:** Clay Fill (CH), mottled gray and dark gray, with trace organics, high plasticity

**Assumed Specific Gravity=** 2.68

**Remarks:**

**Client:** Ameren Missouri

**Project:** Ash Pond Stability

**Source of Sample:** B-2      **Depth:** 14

**Sample Number:** ST-5

**Proj. No.:** 2010012488      **Date:** 08-11-10



Figure 2-4

## LEGEND

Symbol      Description

### KEY TO SOIL SYMBOLS



Organic Material



Clay



Silty Clay to Clay



Clayey Silt to Silty Clay



Sandy Silt to Clayey Silt



Silty Sand to Sandy Silt



Sand to Silty Sand



Sand



Gravelly Sand to Sand

$q_c$  = Cone Tip Pressure, tons/sq. ft.

$f_s$  = Skin Friction, tons/sq. ft.

$R_f$  = Friction ratio ( $f_s/q_c$ ) in %

$u_2$  = Porewater Pressure, psi

$N_{60}$  = Calculated Equivalent N-value, blows/foot, (Standard Penetration Test)

$S_u$  = Calculated Undrained Shear Strength, ksf

$\Phi$  = Friction Angle, degrees

### Notes:

1. Details of the drilling and sampling program are presented in the general introduction of the report.
2. Stratification lines shown on the log represent approximate soil boundaries; actual changes in strata may be gradual.



<sup>1</sup> Robertson et al. (1986) *Use of piezometer cone data*. Proceedings of the ASCE Specialty Conference: In Situ 86: Use of In Situ Tests in Geotechnical Engineering. ASCE 1986

<sup>2</sup> Lunne, T. Robertson, P.K. and Powell, J.J.M. (1997) *Cone Penetration Testing in Geotechnical Practice*. Published by Blackie Academic & Professional.

<sup>3</sup> Bowles, Joseph E. (1996) *Foundation Analysis and Design*. McGraw-Hill. 5<sup>th</sup> ed. Page 180.

Figure 3-0

Classification by  
Robertson 1986




Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sieve area [cm<sup>2</sup>]: 150

Location: Meramec Power Plant	Position: X: 937555.35 ft, Y: 865357.78 ft	Ground level: 417.49	Test no: P-1
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/2010	Scale: 1 : 42
Project: Ameren: Meramec Ash Pond Stability Analysis		Page: 1/2	Fig: 3-1
		File: Meramec P-1.cpd	

**Classification by Robertson 1986**



- Clay (3)
- Silty clay to clay (4)
- Clayey silt to silty clay (5)
- Sandy silt to clayey silt (6)
- Clay (3)
- Clayey silt to silty clay (5)
- Sandy silt to clayey silt (6)
- Sand to silty sand (8)
- Silty clay to clay (4)
- Sand to silty sand (8)
- Clayey silt to silty clay (5)
- Silty sand to sandy silt (7)



Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150


Location: Meramec Power Plant	Position: X: 937555.35 ft, Y: 865357.78 ft	Ground level: 417.49	Test no: P-1
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/2010	Scale: 1 : 42
Project: Ameren: Meramec Ash Pond Stability Analysis		Page: 2/2	Fig: 3-1
		File: Meramec P-1.cpd	

Classification by  
Robertson 1986



Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sleeve area [cm<sup>2</sup>]: 150



Location: Meramec Power Plant	Position: X: 936802.95 ft, Y: 864543.54 ft	Ground level: 414.57	Test no: P-2
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/2010	Scale: 1 : 42
Project: Ameren: Meramec Ash Pond Stability Analysis	Page: 1/2	Fig: 3-2	
		File: Meramec P-2.cpd	



Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Power Plant	Position: X: 936802.95 ft, Y: 864543.54 ft	Ground level: 414.57	Test no: P-2
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/2010	Scale: 1 : 42
Project: Ameren: Meramec Ash Pond Stability Analysis		Page: 2/2	Fig: 3-2
File: Meramec P-2.cpd			



Classification by  
Robertson 1986



Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Power Plant	Position: X: 864515.12 ft, Y: 936305.48 ft	Ground level: 413.25	Test no: P-3
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/2010	Scale: 1 : 28
Project: Ameren: Meramec Ash Pond Stability Analysis	Page: 1/3	Fig: 3-3	
		File: Meramec PZ-2.cpd	



Classification by Robertson 1986



Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Power Plant	Position: X: 864515.12 ft, Y: 936305.48 ft	Ground level: 413.25	Test no: P-3
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/2010	Scale: 1 : 28
Project: Ameren: Meramec Ash Pond Stability Analysis	Page: 2/3	Fig: 3-3	
File: Meramec PZ-2.cpd			



Classification by  
Robertson 1986



Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Power Plant	Position: X: 864515.12 ft, Y: 936305.48 ft	Ground level: 413.25	Test no: P-3
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/2010	Scale: 1 : 28
Project: Ameren: Meramec Ash Pond Stability Analysis		Page: 3/3	Fig: 3-3
File: Meramec PZ-2.cpd			

Classification by  
Robertson 1986




Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Power Plant	Position: X: 864848.16 ft, Y: 934529.04 ft	Ground level: 394.26	Test no: P-4
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/10	Scale: 1 : 42
Project: Ameren: Meramec Ash Pond Stability Analysis		Page: 1/2	Fig: 3-4
		File: Meramec P-4.cpd	

Classification by  
Robertson 1986

Silty clay to clay (4)  
Clayey silt to silty clay (5)  
Sandy silt to clayey silt (6)  
Silty clay to clay (4)  
Sandy silt to clayey silt (6)  
Sand (9)  
Sand to silty sand (8)



Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Power Plant	Position: X: 864848.16 ft, Y: 934529.04 ft	Ground level: 394.26	Test no: P-4
Project ID: 2010012488	Client: Ameren Missouri	Date: 10/7/10	Scale: 1 : 42
Project: Ameren: Meramec Ash Pond Stability Analysis	Page: 2/2	Fig: 3-4	
		File: Meramec P-4.cpd	

Classification by  
Robertson 1986




Clayey silt to silty clay (5)

Clay (3)

Sand to silty sand (8)



Sand (9)



Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Ash Ponds	Position: X: 864538.12 ft, Y: 936033.50 ft	Ground level: 398.00	Test no: P-5
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses	Page: 1/2	Fig: 3-5	
No data 33' to 35'		File: meramec p-5.cpd	



**Classification by Robertson 1986**



Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Ash Ponds	Position: X: 864538.12 ft, Y: 936033.50 ft	Ground level: 398.00	Test no: P-5
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses		Page: 2/2	Fig: 3-5
No data 33' to 35'		File: meramec p-5.cpd	



**Classification by Robertson 1986**



Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Ash Ponds	Position: X: 864498.59 ft, Y: 936885.56 ft	Ground level: 396.69	Test no: P-6
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses		Page: 1/2	Fig: 3-6
File: meramec p-6.cpd			

Classification by  
Robertson 1986




Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Ash Ponds	Position: X: 864498.59 ft, Y: 936885.56 ft	Ground level: 396.69	Test no: P-6
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses		Page: 2/2	Fig: 3-6
		File: meramec p-6.cpd	

**Classification by Robertson 1986**



- Clayey silt to silty clay (5)
- Clay (3)
- Silty clay to clay (4)
- Clay (3)
- Clayey silt to silty clay (5)
- Clay (3)
- Silty clay to clay (4)
- Clayey silt to silty clay (5)
- Silty clay to clay (4)
- Clayey silt to silty clay (5)
- Sandy silt to clayey silt (6)
- Silty clay to clay (4)
- Sand (9)



Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Ash Ponds	Position: X: 864861.25 ft, Y: 937323.69 ft	Ground level: 397.60	Test no: P-7
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses		Page: 1/2	Fig: 3-7
File: meramec b-1.cpd			



Classification by Robertson 1986



Cone No: 4274  
 Tip area [cm2]: 10  
 Sleeve area [cm2]: 150

Location: Meramec Ash Ponds	Position: X: 864861.25 ft, Y: 937323.69 ft	Ground level: 397.60	Test no: P-7
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses		Page: 2/2	Fig: 3-7
		File: meramec b-1.cpd	

Classification by Robertson 1986




Cone No: 4274  
 Tip area [cm<sup>2</sup>]: 10  
 Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Ash Ponds	Position: X: 864459.06 ft, Y: 936289.47 ft	Ground level: 398.00	Test no: P-8
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses	Page: 1/2	Fig: 3-8	File: meramec b-2.cpd


Classification by Robertson 1986

- Clay (3)
- Silty sand to sandy silt (7)
- Silty clay to clay (4)
- Clay (3)
- Silty clay to clay (4)
- Clayey silt to silty clay (5)
- Silty clay to clay (4)
- Clay (3)
- Silty clay to clay (4)
- Clayey silt to silty clay (5)
- Silty clay to clay (4)
- Clay (3)
- Silty clay to clay (4)
- Clay (3)
- Silty clay to clay (4)



Cone No: 4274  
Tip area [cm<sup>2</sup>]: 10  
Sleeve area [cm<sup>2</sup>]: 150

Location: Meramec Ash Ponds	Position: X: 864459.06 ft, Y: 936289.47 ft	Ground level: 398.00	Test no: P-8
Project ID: 2010012488	Client: Ameren Missouri	Date: 11/2/2010	Scale: 1 : 42
Project: Ameren: Ash Pond Stability Analyses		Page: 2/2	Fig: 3-8
File: meramec b-2.cpd			



**Appendix A**  
**Cross-sections**

Scale: 1:100  
 Date: 10/10/2010  
 Project: [Illegible]  
 Drawing No: [Illegible]



# Meramec Power Station








Figure A-1

# Meramec Power Station




# Meramec Power Station





**Appendix B**  
Elevation Profile  
Graphical Depictions of Slope Stability Models



Wetzel Power Station

# Meramec Power Station




Figure B-1

Material: Ash  
 Unit Weight: 110 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees



Material: Fill  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Friction Angle: 26 degrees

Material: Silty Clay  
 Unit Weight: 123 lb/ft<sup>3</sup>  
 Cohesion: 100 psf  
 Friction Angle: 27 degrees

Material: Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 26 degrees

Material: Clayey Silt, Silty Clay  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Meramec Power Station  
 Steady Seepage  
 Cross-section 1





- Material: Ash  
Unit Weight: 110 lb/ft3  
Friction Angle: 25 degrees
- Material: Clayey Silt\_Silty Clay  
Unit Weight: 125 lb/ft3  
Friction Angle: 26 degrees
- Material: Fill  
Unit Weight: 122 lb/ft3  
Friction Angle: 26 degrees
- Material: Silty Clay  
Unit Weight: 123 lb/ft3  
Cohesion: 100 psf  
Friction Angle: 27 degrees

Meramec Power Station  
Seismic  
Cross-section 1




Figure B-3

Material: Clay\_Silty Clay  
 Unit Weight: 123 lb/ft3  
 Cohesion: 100 psf  
 Friction Angle: 27.5 degrees

Material: Sand\_Gravel  
 Unit Weight: 130 lb/ft3  
 Friction Angle: 28 degrees


Material: Fill  
 Unit Weight: 122 lb/ft3  
 Cohesion: 200 psf  
 Friction Angle: 23 degrees

Material: Clay  
 Unit Weight: 125 lb/ft3  
 Friction Angle: 23 degrees

Material: Silty\_Sand  
 Unit Weight: 120 lb/ft3  
 Friction Angle: 30 degrees

Material: Ash  
 Unit Weight: 110 lb/ft3  
 Friction Angle: 25 degrees

Meramec Power Station  
 Steady Seepage  
 Cross-section 2



0.0575



- Material: Clay\_Silty Clay  
Unit Weight: 123 lb/ft3  
Cohesion: 100 psf  
Friction Angle: 27.5 degrees
- Material: Silty\_Sand  
Unit Weight: 120 lb/ft3  
Friction Angle: 30 degrees
- Material: Ash  
Unit Weight: 110 lb/ft3  
Friction Angle: 25 degrees

- Material: Sand\_Gravel  
Unit Weight: 130 lb/ft3  
Friction Angle: 28 degrees
- Material: Fill  
Unit Weight: 122 lb/ft3  
Cohesion: 200 psf  
Friction Angle: 23 degrees
- Material: Clay  
Unit Weight: 125 lb/ft3  
Friction Angle: 23 degrees

Meramec Power Station  
Seismic  
Cross-section 2




Figure B-5

Material: Fill  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Cohesion: 100 psf  
 Friction Angle: 26 degrees

Material: Clay and Silty Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 23 degrees

Material: Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 24 degrees


Material: Silty Silt and Clayey Silt  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 22.5 degrees

Material: Sandy Silt and Clayey Silt  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Material: Silty Clay and Clayey Silt  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 24 degrees

Material: Water  
 Strength Type: No strength  
 Unit Weight: 62.4 lb/ft<sup>3</sup>

Meramec Power Station  
 Steady Seepage  
 Cross-section 3





Material: Fill  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Cohesion: 100 psf  
 Friction Angle: 29 degrees

Material: Sandy Silt and Silty Sand  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Material: Silty Clay and Clayey Silt  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 24 degrees

Material: Water  
 Strength Type: No strength  
 Unit Weight: 62.4 lb/ft<sup>3</sup>

Material: Clay and Silty Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 23 degrees

Material: Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 24 degrees

Material: Sandy Silt and Clayey Silt  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 22.5 degrees

Meramec Power Station  
 Seismic  
 Cross-section 3





Figure B-7

Material: Fly Ash  
 Unit Weight: 110 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Material: Sand Gravel  
 Unit Weight: 130 lb/ft<sup>3</sup>  
 Friction Angle: 28 degrees


Material: Fill  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Cohesion: 200 psf  
 Friction Angle: 23 degrees

Material: Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 23 degrees

Material: Clay and Silty Clay  
 Unit Weight: 123 lb/ft<sup>3</sup>  
 Cohesion: 100 psf  
 Friction Angle: 27 degrees

Material: Silt and Sand  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 30 degrees

Meramec Power Station  
 Steady Seepage  
 Cross-section 4





Material: Fly Ash  
 Unit Weight: 110 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Material: Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 23 degrees

Material: Sand Gravel  
 Unit Weight: 130 lb/ft<sup>3</sup>  
 Friction Angle: 28 degrees

Material: Clay and Silty Clay  
 Unit Weight: 123 lb/ft<sup>3</sup>  
 Cohesion: 100 psf  
 Friction Angle: 27 degrees


Material: Fill  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Cohesion: 200 psf  
 Friction Angle: 23 degrees

Material: Silt and Sand  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 30 degrees

Meramec Power Station  
 Seismic  
 Cross-section 4



Sand and Gravel



Material: Silty Clay  
 Unit Weight: 123 lb/ft<sup>3</sup>  
 Cohesion: 100 psf  
 Friction Angle: 27 degrees

Material: Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 26 degrees


Material: Clayey Silt and Silty Clay  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Material: Ash  
 Unit Weight: 110 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Material: Sand and Gravel  
 Unit Weight: 130 lb/ft<sup>3</sup>  
 Friction Angle: 28 degrees

Material: Fill  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Friction Angle: 26 degrees

Meramec Power Station  
 Steady Seepage  
 Cross-section 5





Material: Ash  
 Unit Weight: 110 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Material: Sand and Gravel  
 Unit Weight: 130 lb/ft<sup>3</sup>  
 Friction Angle: 28 degrees

Material: Fill  
 Unit Weight: 122 lb/ft<sup>3</sup>  
 Friction Angle: 26 degrees

Material: Silty Clay  
 Unit Weight: 123 lb/ft<sup>3</sup>  
 Cohesion: 100 psf  
 Friction Angle: 27 degrees

Material: Clay  
 Unit Weight: 125 lb/ft<sup>3</sup>  
 Friction Angle: 26 degrees

Material: Clayey Silt and Silty Clay  
 Unit Weight: 120 lb/ft<sup>3</sup>  
 Friction Angle: 25 degrees

Meramec Power Station  
 Seismic  
 Cross-section 5




Figure B-11

APPENDIX A

DOC 1.11 PRELIMINARY SKETCHES

SEE DRAWING 8020-Y-122626 FOR CROSS SECTION 6





# Meramec Power Station

Elevation Profile Survey Limits  
Locations of Cross-sections and Borings



Figure 1



- NOTES:
- 1) DEPRESSED SECTIONS OF POND #489 LEVEES SHALL FIRST BE RESTORED TO THEIR ORIGINAL TOP-OF-LEVEE ELEVATION 416', AS SHOWN IN SECTION A-A.
  - 2) FLYASH SHALL BE RECLAIMED FROM POND #495 BY APPROPRIATE METHODS. FLYASH SHALL BE DRIED, PLACED AND COMPACTED IN POND #489, TO AN EL. OF 414'-6\".
  - 3) METHODS OF DRYING (IE. MOISTURE REDUCTION) SHALL BE RESTRICTED SUCH THAT ANY RESULTING RUNOFF BE KEPT WITHIN EXISTING ASH POND LIMITS AND BE ROUTED TO THE EXISTING PERMITTED DISCHARGE.
  - 4) RECLAIMED FLYASH SHALL BE PLACED IN LOOSE LIFTS NOT TO EXCEED 8-12 INCHES, AND IMMEDIATELY COMPACTED AT OPTIMUM MOISTURE CONTENT BY MEANS OF A VIBRATORY ROLLER. SEE SPECIFICATION FOR COMPACTION REQUIREMENT. (SEE ALSO NOTE #9)
  - 5) EARTHEN MATERIAL REQUIRED FOR EROSION PROTECTION AND CONTAINMENT SHALL CONFORM TO CL, CH, ML, OR MH SOIL CLASSIFICATIONS AS GIVEN BY ASTM DESIGNATION D 2487. THIS MATERIAL SHALL BE COMPACTED WITH A SHEEPS-FOOT TYPE COMPACTOR. SEE SPECIFICATION FOR COMPACTION REQUIREMENT. (SEE ALSO NOTE #9)
  - 6) SEE TOPOGRAPHIC MAP DRAWING 8020-W-22627 FOR EXISTING ELEVATIONS.
  - 7) REBUILD ACCESS ROADS TO RENOVATED LEVEE TO PROVIDE SMOOTH TRANSITIONS FOR SMALL VEHICLES.
  - 8) TWO NEW CULVERTS WILL BE INSTALLED AS SHOWN TO PROVIDE STORMWATER DRAINAGE FROM POND #489 INTO POND #495.
  - 9) COMPACTION SPECIFICATIONS SHOULD YIELD PERMEABILITIES WITHIN THE REPAIRED LEVEE AS FOLLOWS:  
 CLAY FILL - LESS THAN 10<sup>-7</sup> CM/SEC.  
 FLYASH - LESS THAN 10<sup>-6</sup> CM/SEC.
  - 10) SURVEY MONUMENT #2 SHALL BE RAISED TO ELEVATION 415'-0\"=2\". SEE DRAWING 8020-W-122627 FOR LOCATION.
  - 11) S.B. #5/7 - SOIL BORINGS (SEE U.E. SPEC. EC-2392, APPENDIX E)
  - 12) RENOVATED LEVEE SHOWN THUS
  - 13) ALL WORK SHALL BE DONE IN ACCORDANCE WITH U.E. SPECIFICATION EC-2392.

REFERENCE DRAWING :  
 TOPOGRAPHIC MAP ----- 8020-W-122627

 NOTICE OF LIMITED RESPONSIBILITY THE DESIGN PROFESSIONAL SHALL BE RESPONSIBLE FOR THE DESIGN AND CONSTRUCTION OF THE WORK SHOWN ON THIS DRAWING. THE CLIENT SHALL BE RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION PROVIDED TO THE DESIGN PROFESSIONAL AND FOR THE PROTECTION OF THE WORK SHOWN ON THIS DRAWING.	 THOMAS LEE HOLLETT LICENSE NO. 10247 PROFESSIONAL ENGINEER	DRAWN BY: 5/6/11 SCOTT HELD CHECKED BY: 5/11/11 DATE: 5/11/11	<b>PROPERTY PLAN</b> <b>ASH RETENTION PONDS</b>
		APP. BY: 5/7/11 C. KUNZE	LOCATION: MERAMEC PLANT ST. LOUIS, MO.

APPENDIX A

DOC 1.12 REITZ & JENS REVISED STABILITY REPORT, MARCH 29, 2011



**REITZ & JENS, INC.**  
CONSULTING ENGINEERS

1055 corporate square drive  
st. louis, mo 63132  
phone: 314.993.4132  
fax: 314.993.4177  
www.reitzjens.com

**MEMORANDUM**

To: Gene Campbell, E.I.T.

From: Jeff Bertel, P.E.

**Subject: Meramec Plant Stability Analysis**

Date: March 29, 2011

Attached are graphical depictions and summaries of slope stability analysis for four (4) cross-sections at the Meramec Plant. Ameren Missouri plans to place fill on the downstream slope in these locations with MoDOT Type 4 Rip Rap Ditch Liner so that the slope steepness is flattened to 3 horizontal (H) to 1 vertical (V). The attached cross-section 3 represent the slopes adjacent to Pond 489, cross-sections 1 and 5 represent the slopes adjacent to the Retention Pond and cross-section 6 represent the slopes adjacent to Pond 493.

The factors of safety for stability of the slopes as a result of the proposed modification are summarized in the following table. A factor of safety is presented for the short-term, long-term and seismic load cases.

Cross-section	Factor of Safety			
	Short-term	Long-term	Seismic*	Existing Long-term
3 (Pond 489)	1.61	1.56	1.30	1.3
1 (Retention Pond)	2.07	1.76	1.48	1.3
5 (Retention Pond)	2.06	2.10	1.72	1.2
6 (Pond 493)	1.31	1.46	1.22	1.1

\*Based on required design acceleration per MDNR 10 CSR 22-3

The factors of safety at the improved Cross-sections 3, 1 and 5 exceed those required by MDNR. For Cross-section 6 the factor of safety for the short-term condition is marginal. The soil profile for Cross-section 6 is a conservative estimate based on existing borings in the general proximity. Cross-sections 1 and 6 were analyzed with the new rock fill extending down to the flow line of the creek.

At locations where the creek meanders away from the toe of the existing embankment, the slope stability analysis show that a minimum of 10 feet should be maintained from the toe of the new rip rap fill and the top of the creek bank. This assumes that the creek has a depth of 8 feet from the top of the creek bank. We recommend for locations where the projection of the 3 (H) to 1 (V) final slope intersects the creek above the flowline (as shown on the attached sketch), the creek bank must be rip-rapped to avoid undermining the new slope.

The following bulleted list contains a few items you should consider when proceeding with this project:

- New rip rap fill should be keyed in at the toe, especially when placed as fill within the creek; generally the depth of the key is dependent on the hydraulic shear stress



**REITZ & JENS, INC.**  
CONSULTING ENGINEERS

1055 corporate square drive  
st. louis, mo 63132  
phone: 314.993.4132  
fax: 314.993.4177  
www.reitzjens.com

- MoDOT requires bedding material consisting of crushed stone or gravel beneath Type 4 Rock Ditch Liner, in our experience the rip rap is more susceptible to erosion when placed directly on geotextile
- A minimum thickness of 4 feet of rip rap should be specified. In some locations the existing slopes may become more shallow near the toe, and if rip rap is only placed at a 3 (H) to 1 (V) may lead to thin layer of rip rap. It may be necessary to increase the thickness of the rip rap based on the calculated hydraulic shear stresses
- Changes to the impounded water level can have a significant impact on the stability of the slopes and should be evaluated if changes are anticipated



**REITZ & JENS, INC.**  
CONSULTING ENGINEERS


PROJECT  
SUBJECT

MERAMEL PLANT ASH POND  
SLOPE STABILITY: NEW  
RIPRAP FILL

DATE 3-31-2011 BY JOB


Proj. Number \_\_\_\_\_

SHEET \_\_\_\_\_ OF \_\_\_\_\_



NOT TO SCALE

**Ameren Missouri  
Meramec Plant  
Cross-Section 3  
Undrained Loading**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 3 meramec rip rap.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

### **Material: Fill**

Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1500 psf  
Water Surface: Water Table  
Custom Hu value: 0

### **Material: Clay and Silty Clay**

Strength Type: Undrained  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 500 psf

Water Surface: Water Table  
Custom Hu value: 0

Material: Silty Clay

Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 750 psf  
Water Surface: Water Table  
Custom Hu value: 0

Material: Sandy Silt and Clayey Silt

Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 22.5 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay (2)

Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1000 psf  
Water Surface: Water Table  
Custom Hu value: 0

Material: Silty Sand

Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4

Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Water

Strength Type: No strength  
Unit Weight: 62.4 lb/ft<sup>3</sup>

Material: Silty Clay (3)

Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 750 psf  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

Material Boundary

57.560	416.000
110.060	398.500
125.000	398.500

Material Boundary

-67.450	394.300
-43.000	394.000
105.928	394.000
110.060	398.500

Material Boundary

-200.000	385.000
125.000	385.000

Material Boundary

-200.000	376.000
125.000	376.000

Material Boundary

-200.000	370.000
125.000	370.000

Material Boundary

-200.000	365.000
125.000	365.000

Material Boundary

-67.450	394.300
-42.800	397.000
-35.600	399.800
-26.500	404.760
-17.100	409.800
-9.700	413.550

Material Boundary

-200.000	372.000
125.000	372.000

External Boundary

-6.700	414.000
-9.700	413.550
-67.450	394.300
-91.700	393.200
-200.000	393.200
-200.000	385.000
-200.000	376.000
-200.000	372.000
-200.000	370.000
-200.000	365.000
-200.000	300.000
125.000	300.000
125.000	365.000
125.000	370.000
125.000	372.000
125.000	376.000
125.000	385.000

125.000	394.000
125.000	398.500
125.000	416.000
57.560	416.000
47.820	419.000
30.670	418.620
27.870	418.330
16.780	415.190
0.000	414.910


Water Table

-200.000	393.200
-91.700	393.200
-67.450	394.300
-42.800	397.000
110.060	398.500
125.000	398.500

Search Grid

-69.000	429.000
-13.000	429.000
-13.000	485.000
-69.000	485.000

**Ameren Missouri  
Meramec Plant  
Cross-Section 3  
Long-term Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 3 meramec rip rap longterm.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

### **Material: Fill**

Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

### **Material: Clay and Silty Clay**

Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

Material: Silty Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 22 degrees  
Water Surface: None

Material: Sandy Silt and Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 22.5 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 22.5 degrees  
Water Surface: None

Material: Silty Sand  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Water  
Strength Type: No strength  
Unit Weight: 62.4 lb/ft<sup>3</sup>

Material: Silty Clay (3)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 24 degrees  
Water Surface: None

### **List of All Coordinates**

Material Boundary  
57.560      416.000  
110.060     398.500  
125.000     398.500

Material Boundary

-67.450	394.300
-43.000	394.000
105.928	394.000
110.060	398.500

Material Boundary

-200.000	385.000
125.000	385.000

Material Boundary

-200.000	376.000
125.000	376.000

Material Boundary

-200.000	370.000
125.000	370.000

Material Boundary

-200.000	365.000
125.000	365.000

Material Boundary

-67.450	394.300
-42.800	397.000
-35.600	399.800
-26.500	404.760
-17.100	409.800
-9.700	413.550

Material Boundary

-200.000	372.000
125.000	372.000

External Boundary

-6.700	414.000
-9.700	413.550
-67.450	394.300
-91.700	393.200
-200.000	393.200
-200.000	385.000
-200.000	376.000
-200.000	372.000
-200.000	370.000
-200.000	365.000
-200.000	300.000
125.000	300.000
125.000	365.000
125.000	370.000
125.000	372.000
125.000	376.000
125.000	385.000
125.000	394.000
125.000	398.500
125.000	416.000
57.560	416.000
47.820	419.000

30.670	418.620
27.870	418.330
16.780	415.190
0.000	414.910

Water Table

-200.000	393.200
-91.700	393.200
-67.450	394.300
-42.800	397.000
110.060	398.500
125.000	398.500


Focus/Block Search Line

-43.000	365.000
-43.000	394.000

Search Grid

-80.000	429.000
-17.000	429.000
-17.000	489.000
-80.000	489.000

**Ameren Missouri  
 Meramec Plant  
 Cross-Section 3  
 Seismic Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 3 meramec rip rap longterm seis.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Loading**

Seismic Load Coefficient (Horizontal): 0.0575

## **Material Properties**

### **Material: Fill**

Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

### **Material: Clay and Silty Clay**

Strength Type: Mohr-Coulomb

Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

Material: Silty Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 22 degrees  
Water Surface: None

Material: Sandy Silt and Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 22.5 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 22.5 degrees  
Water Surface: None

Material: Silty Sand  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Water  
Strength Type: No strength  
Unit Weight: 62.4 lb/ft<sup>3</sup>

Material: Silty Clay (3)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 24 degrees  
Water Surface: None

## **List of All Coordinates**

Material Boundary

57.560	416.000
110.060	398.500
125.000	398.500

Material Boundary

-67.450	394.300
-43.000	394.000
105.928	394.000
110.060	398.500

Material Boundary

-200.000	385.000
125.000	385.000

Material Boundary

-200.000	376.000
125.000	376.000

Material Boundary

-200.000	370.000
125.000	370.000

Material Boundary

-200.000	365.000
125.000	365.000

Material Boundary

-67.450	394.300
-42.800	397.000
-35.600	399.800
-26.500	404.760
-17.100	409.800
-9.700	413.550

Material Boundary

-200.000	372.000
125.000	372.000

External Boundary

-6.700	414.000
-9.700	413.550
-67.450	394.300
-91.700	393.200
-200.000	393.200
-200.000	385.000
-200.000	376.000
-200.000	372.000
-200.000	370.000
-200.000	365.000
-200.000	300.000
125.000	300.000
125.000	365.000
125.000	370.000
125.000	372.000
125.000	376.000
125.000	385.000
125.000	394.000

125.000	398.500
125.000	416.000
57.560	416.000
47.820	419.000
30.670	418.620
27.870	418.330
16.780	415.190
0.000	414.910

Water Table

-200.000	393.200
-91.700	393.200
-67.450	394.300
-42.800	397.000
110.060	398.500
125.000	398.500


Focus/Block Search Line

-43.000	365.000
-43.000	394.000

Search Grid

-82.269	429.000
2.731	429.000
2.731	510.000
-82.269	510.000

**Ameren Missouri  
Meramec Plant  
Cross-section 1  
Undrained Loading**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 1 meramec rip rap.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

**Material: Ash**  
Strength Type: Mohr-Coulomb  
Unit Weight: 110 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**Material: Fill**  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees

Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay  
Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1500 psf  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay  
Strength Type: Undrained  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1000 psf  
Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay (2)  
Strength Type: Undrained  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 750 psf  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay (2)  
Strength Type: Undrained  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1250 psf  
Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay (3)  
Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1000 psf  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clayey Silt (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table

Custom Hu value: 1

Material: MoDOT Type 4  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

### List of All Coordinates

#### Material Boundary

16.700	413.700
22.094	411.003
26.109	408.996
34.092	405.004
45.089	399.505
50.100	397.000
54.100	395.000
100.000	395.000

#### Material Boundary

-49.308	397.000
50.100	397.000

#### Material Boundary

-200.000	385.000
100.000	385.000

#### Material Boundary

-200.000	380.000
100.000	380.000

#### Material Boundary

-48.000	397.560
-41.501	399.505
-32.300	402.260
-26.822	405.004
-20.300	408.270
-18.965	408.996
-15.272	411.003
-10.770	413.450

#### Material Boundary

-84.120	389.000
-68.000	389.000
-49.308	397.000
-48.000	397.560

#### Material Boundary

-15.272	411.003
22.094	411.003

#### Material Boundary

-18.965	408.996
---------	---------

26.109 408.996

Material Boundary

-26.822 405.004  
34.092 405.004

Material Boundary

-200.000 371.000  
100.000 371.000

External Boundary

-7.240 414.000  
-10.770 413.450  
-84.120 389.000  
-200.000 389.000  
-200.000 385.000  
-200.000 380.000  
-200.000 371.000  
-200.000 300.000  
100.000 300.000  
100.000 371.000  
100.000 380.000  
100.000 385.000  
100.000 395.000  
100.000 413.650  
68.380 413.650  
20.700 413.600  
16.700 413.700  
0.000 413.900


Water Table

-200.000 389.000  
-68.000 389.000  
-49.308 397.000  
-48.000 397.560  
16.700 400.000  
44.100 400.000  
100.000 400.000

Search Grid

-92.000 420.000  
-24.000 420.000  
-24.000 481.000  
-92.000 481.000

**Ameren Missouri  
 Meramec Plant  
 Cross-section 1  
 Long-term Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 1 meramec rip rap long term.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

**Material: Ash**  
Strength Type: Mohr-Coulomb  
Unit Weight: 110 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**Material: Fill**  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees

Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 100 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (3)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Clayey Silt (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>

Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

**Material Boundary**

16.700	413.700
22.094	411.003
26.109	408.996
34.092	405.004
45.089	399.505
50.100	397.000
54.100	395.000
100.000	395.000

**Material Boundary**

-49.308	397.000
50.100	397.000

**Material Boundary**

-200.000	385.000
100.000	385.000

**Material Boundary**

-200.000	380.000
100.000	380.000

**Material Boundary**

-48.000	397.560
-41.501	399.505
-32.300	402.260
-26.822	405.004
-20.300	408.270
-18.965	408.996
-15.272	411.003
-10.770	413.450

**Material Boundary**

-84.120	389.000
-68.000	389.000
-49.308	397.000
-48.000	397.560

**Material Boundary**

-15.272	411.003
22.094	411.003

**Material Boundary**

-18.965	408.996
26.109	408.996

**Material Boundary**

-26.822	405.004
34.092	405.004

Material Boundary

-200.000	371.000
100.000	371.000

External Boundary

-7.240	414.000
-10.770	413.450
-84.120	389.000
-200.000	389.000
-200.000	385.000
-200.000	380.000
-200.000	371.000
-200.000	300.000
100.000	300.000
100.000	371.000
100.000	380.000
100.000	385.000
100.000	395.000
100.000	413.650
68.380	413.650
20.700	413.600
16.700	413.700
0.000	413.900


Water Table

-200.000	389.000
-68.000	389.000
-49.308	397.000
-48.000	397.560
16.700	400.000
44.100	400.000
100.000	400.000

Search Grid

-74.833	446.000
-28.833	446.000
-28.833	494.000
-74.833	494.000

**Ameren Missouri  
Meramec Plant  
Cross-section 1 (with bench)  
Long-term Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 1 meramec rip rap long term bench.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

**Material: Ash**  
Strength Type: Mohr-Coulomb  
Unit Weight: 110 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**Material: Fill**  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees

Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 100 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (3)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Clayey Silt (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>

Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

**Material Boundary**

16.700	413.700
22.094	411.003
26.109	408.996
34.092	405.004
45.089	399.505
50.100	397.000
54.100	395.000
100.000	395.000

**Material Boundary**

-49.308	397.000
50.100	397.000

**Material Boundary**

-200.000	385.000
100.000	385.000

**Material Boundary**

-200.000	380.000
100.000	380.000

**Material Boundary**

-48.000	397.560
-41.501	399.505
-32.300	402.260
-26.822	405.004
-20.300	408.270
-18.965	408.996
-15.272	411.003
-10.770	413.450

**Material Boundary**

-60.120	397.000
-49.308	397.000
-48.000	397.560

**Material Boundary**

-15.272	411.003
22.094	411.003

**Material Boundary**

-18.965	408.996
26.109	408.996

**Material Boundary**

-26.822	405.004
34.092	405.004

Material Boundary

-200.000	371.000
100.000	371.000

External Boundary

-7.240	414.000
-10.770	413.450
-60.120	397.000
-70.000	397.000
-71.000	389.000
-84.120	389.000
-200.000	389.000
-200.000	385.000
-200.000	380.000
-200.000	371.000
-200.000	300.000
100.000	300.000
100.000	371.000
100.000	380.000
100.000	385.000
100.000	395.000
100.000	413.650
68.380	413.650
20.700	413.600
16.700	413.700
0.000	413.900

Water Table

-200.000	389.000
-71.000	389.000
-70.000	397.000
-60.120	397.000
-49.308	397.000
-48.000	397.560
16.700	400.000
44.100	400.000
100.000	400.000


Focus/Block Search Line

-62.533	373.983
-62.533	392.983

Search Grid

-98.000	407.000
-44.000	407.000
-44.000	455.000
-98.000	455.000

**Ameren Missouri  
Meramec Plant  
Cross-section 1  
Seismic Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 1 meramec rip rap long term seis.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft3  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Loading**

Seismic Load Coefficient (Horizontal): 0.0575

## **Material Properties**

Material: Ash  
Strength Type: Mohr-Coulomb  
Unit Weight: 110 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Fill

Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 100 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (3)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Clayey Silt (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

Material Boundary

16.700	413.700
22.094	411.003
26.109	408.996
34.092	405.004
45.089	399.505
50.100	397.000
54.100	395.000
100.000	395.000

Material Boundary

-49.308	397.000
50.100	397.000

Material Boundary

-200.000	385.000
100.000	385.000

Material Boundary

-200.000	380.000
100.000	380.000

Material Boundary

-48.000	397.560
-41.501	399.505
-32.300	402.260
-26.822	405.004
-20.300	408.270
-18.965	408.996
-15.272	411.003
-10.770	413.450

Material Boundary

-84.120	389.000
-68.000	389.000
-49.308	397.000
-48.000	397.560

Material Boundary

-15.272	411.003
22.094	411.003

Material Boundary

-18.965	408.996
26.109	408.996

Material Boundary

-26.822	405.004
34.092	405.004

Material Boundary

-200.000	371.000
100.000	371.000

External Boundary

-7.240	414.000
-10.770	413.450
-84.120	389.000
-200.000	389.000
-200.000	385.000
-200.000	380.000
-200.000	371.000
-200.000	300.000
100.000	300.000
100.000	371.000
100.000	380.000
100.000	385.000
100.000	395.000
100.000	413.650
68.380	413.650
20.700	413.600
16.700	413.700
0.000	413.900


Water Table

-200.000	389.000
-68.000	389.000
-49.308	397.000
-48.000	397.560
16.700	400.000
44.100	400.000
100.000	400.000

Search Grid

-84.000	444.000
-26.000	444.000
-26.000	500.000
-84.000	500.000

**Ameren Missouri  
Meramec Plant  
Cross-section 5  
Undrained Loading**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 5 meramec undrained.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

**Material: Ash**  
Strength Type: Mohr-Coulomb  
Unit Weight: 110 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**Material: Fill**  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees

Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay  
Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1750 psf  
Water Surface: None

Material: Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 100 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay  
Strength Type: Undrained  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1000 psf  
Water Surface: None

Material: Silty Clay (2)  
Strength Type: Undrained  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 750 psf  
Water Surface: None

Material: Clay (2)  
Strength Type: Undrained  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1250 psf  
Water Surface: None

Material: Silty Clay (3)  
Strength Type: Undrained  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 1000 psf  
Water Surface: None

Material: Clayey Silt (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4 Rip Rap  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>

Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

**Material Boundary**

11.851	418.383
18.460	415.000
26.441	411.009
30.405	409.028
38.424	405.018
49.561	399.449
54.460	397.000
58.460	395.000
100.000	395.000

**Material Boundary**

-200.000	385.000
100.000	385.000

**Material Boundary**

-200.000	380.000
100.000	380.000

**Material Boundary**

-72.920	398.980
-47.420	399.200
-37.250	405.018
-36.250	405.590
-30.463	409.028
-29.500	409.600
-27.111	411.009
-23.110	413.370
-20.447	415.000
-15.170	418.230

**Material Boundary**

-27.111	411.009
26.441	411.009

**Material Boundary**

-30.463	409.028
30.405	409.028

**Material Boundary**

-37.250	405.018
38.424	405.018

**Material Boundary**

-47.420	399.200
49.561	399.449

**Material Boundary**

-200.000	371.000
----------	---------

100.000 371.000

External Boundary

-12.840	418.630
-15.170	418.230
-72.920	398.980
-73.260	398.980
-200.000	398.980
-200.000	385.000
-200.000	380.000
-200.000	371.000
-200.000	350.000
100.000	350.000
100.000	371.000
100.000	380.000
100.000	385.000
100.000	395.000
100.000	418.230
14.300	418.230
12.000	418.380
11.851	418.383
0.000	418.590



Water Table

-200.000	398.980
-73.260	398.980
-72.920	398.980
11.851	400.000
100.000	400.000

Search Grid

-66.000	430.000
-14.000	430.000
-14.000	479.000
-66.000	479.000

**Ameren Missouri  
Meramec Plant  
Cross-section 5  
Long-term Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 5 meramec longterm.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

### **Material: Ash**

Strength Type: Mohr-Coulomb  
Unit Weight: 110 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

### **Material: Fill**

Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees

Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 100 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (3)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Clayey Silt (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4 Rip Rap  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>

Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

**Material Boundary**

11.851	418.383
18.460	415.000
26.441	411.009
30.405	409.028
38.424	405.018
49.561	399.449
54.460	397.000
58.460	395.000
100.000	395.000

**Material Boundary**

-200.000	385.000
100.000	385.000

**Material Boundary**

-200.000	380.000
100.000	380.000

**Material Boundary**

-72.920	398.980
-47.420	399.200
-37.250	405.018
-36.250	405.590
-30.463	409.028
-29.500	409.600
-27.111	411.009
-23.110	413.370
-20.447	415.000
-15.170	418.230

**Material Boundary**

-27.111	411.009
26.441	411.009

**Material Boundary**

-30.463	409.028
30.405	409.028

**Material Boundary**

-37.250	405.018
38.424	405.018

**Material Boundary**

-47.420	399.200
49.561	399.449

**Material Boundary**

-200.000	371.000
----------	---------

100.000 371.000

External Boundary

-12.840	418.630
-15.170	418.230
-72.920	398.980
-73.260	398.980
-200.000	398.980
-200.000	385.000
-200.000	380.000
-200.000	371.000
-200.000	350.000
100.000	350.000
100.000	371.000
100.000	380.000
100.000	385.000
100.000	395.000
100.000	418.230
14.300	418.230
12.000	418.380
11.851	418.383
0.000	418.590



Water Table

-200.000	398.980
-73.260	398.980
-72.920	398.980
11.851	400.000
100.000	400.000

Search Grid

-93.474	478.000
-21.000	478.000
-21.000	545.000
-93.474	545.000

**Ameren Missouri  
Meramec Plant  
Cross-section 5  
Seismic Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 5 meramec longterm seismic.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Loading**

Seismic Load Coefficient (Horizontal): 0.0575

## **Material Properties**

**Material: Ash**  
Strength Type: Mohr-Coulomb  
Unit Weight: 110 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**Material: Fill**

Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Silty Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Clayey Silt  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 100 psf  
Friction Angle: 27 degrees  
Water Surface: None

Material: Clay (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 123 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Silty Clay (3)  
Strength Type: Mohr-Coulomb  
Unit Weight: 122 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 26 degrees  
Water Surface: None

Material: Clayey Silt (2)  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4 Rip Rap  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

Material Boundary

11.851	418.383
18.460	415.000
26.441	411.009
30.405	409.028
38.424	405.018
49.561	399.449
54.460	397.000
58.460	395.000
100.000	395.000

Material Boundary

-200.000	385.000
100.000	385.000

Material Boundary

-200.000	380.000
100.000	380.000

Material Boundary

-72.920	398.980
-47.420	399.200
-37.250	405.018
-36.250	405.590
-30.463	409.028
-29.500	409.600
-27.111	411.009
-23.110	413.370
-20.447	415.000
-15.170	418.230

Material Boundary

-27.111	411.009
26.441	411.009

Material Boundary

-30.463	409.028
30.405	409.028

Material Boundary

-37.250	405.018
38.424	405.018

Material Boundary

-47.420	399.200
49.561	399.449

Material Boundary

-200.000	371.000
100.000	371.000

External Boundary

-12.840	418.630
-15.170	418.230
-72.920	398.980
-73.260	398.980
-200.000	398.980
-200.000	385.000
-200.000	380.000
-200.000	371.000
-200.000	350.000
100.000	350.000
100.000	371.000
100.000	380.000
100.000	385.000
100.000	395.000
100.000	418.230
14.300	418.230
12.000	418.380
11.851	418.383
0.000	418.590



Water Table

-200.000	398.980
-73.260	398.980
-72.920	398.980
11.851	400.000
100.000	400.000

Search Grid

-93.474	478.000
-21.000	478.000
-21.000	545.000
-93.474	545.000

**Ameren Missouri  
Meramec Plant  
Cross-section 6  
Long-term Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: no rip rap xsec 6 longterm.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

### **Material: Fill**

Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 25 degrees  
Water Surface: None

### **Material: Lean Clay**

Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

Material: Fat Clay

Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft3  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

Material: Sand & Gravel

Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 27 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

Material Boundary

-150.000 360.000  
150.000 360.000

Material Boundary

-150.000 325.000  
150.000 325.000

Material Boundary

-66.000 395.000  
-46.000 395.000  
-45.950 395.025

Material Boundary

-36.000 400.000  
36.000 400.000

External Boundary

-150.000 300.000  
150.000 300.000  
150.000 325.000  
150.000 360.000  
150.000 380.000  
76.000 380.000  
46.000 395.000  
36.000 400.000  
10.000 413.000  
6.000 415.000  
-6.000 415.000  
-10.000 413.000  
-36.000 400.000  
-45.950 395.025  
-66.000 395.000  
-150.000 395.000  
-150.000 360.000  
-150.000 325.000

Water Table

-150.000 395.000

-46.000	395.000
-32.817	401.591
12.000	412.000
150.000	412.000

Focus/Block Search Line

-30.000	358.000
-30.000	395.000


Search Grid

-64.000	417.000
-18.000	417.000
-18.000	459.000
-64.000	459.000

**Ameren Missouri  
Meramec Plant  
Cross-section 6  
Undrained Loading**



MoDOT Type 4 Rip Rap



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 6 undrained.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

### **Material: Fill**

Strength Type: Undrained  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 500 psf  
Water Surface: None

### **Material: Lean Clay**

Strength Type: Undrained  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion Type: Constant  
Cohesion: 500 psf  
Water Surface: None

Material: Fat Clay

Strength Type: Undrained  
Unit Weight: 120 lb/ft3  
Cohesion Type: Constant  
Cohesion: 750 psf  
Water Surface: None

Material: Sand & Gravel

Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 27 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4 Rip Rap

Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

Material Boundary

-150.000 360.000  
150.000 360.000

Material Boundary

-150.000 325.000  
150.000 325.000

Material Boundary

-66.000 395.000  
-46.000 395.000  
-36.000 400.000  
-10.000 413.000  
-6.000 415.000

Material Boundary

-36.000 400.000  
36.000 400.000

External Boundary

-150.000 300.000  
150.000 300.000  
150.000 325.000  
150.000 360.000  
150.000 380.000  
76.000 380.000  
46.000 395.000  
36.000 400.000  
10.000 413.000  
6.000 415.000  
-6.000 415.000

-66.000	395.000
-150.000	395.000
-150.000	360.000
-150.000	325.000



Water Table

-150.000	395.000
-46.000	395.000
-32.817	401.591
12.000	412.000
150.000	412.000

Search Grid

-56.000	419.000
-7.507	419.000
-7.507	464.000
-56.000	464.000

**Ameren Missouri  
Meramec Plant  
Cross-section 6  
Long-term Analysis**



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 6 longterm.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

Material: Fill  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 25 degrees  
Water Surface: None

Material: Lean Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

**Material: Fat Clay**

Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft3  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

**Material: Sand & Gravel**

Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 27 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**Material: MoDOT Type 4 Rip Rap**

Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft3  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

**List of All Coordinates**

**Material Boundary**

-150.000	360.000
150.000	360.000

**Material Boundary**

-150.000	325.000
150.000	325.000

**Material Boundary**

-66.000	395.000
-46.000	395.000
-36.000	400.000
-10.000	413.000
-6.000	415.000

**Material Boundary**

-36.000	400.000
36.000	400.000

**External Boundary**

-150.000	300.000
150.000	300.000
150.000	325.000
150.000	360.000
150.000	380.000
76.000	380.000
46.000	395.000
36.000	400.000
10.000	413.000
6.000	415.000
-6.000	415.000

-66.000	395.000
-150.000	395.000
-150.000	360.000
-150.000	325.000


Water Table

-150.000	395.000
-46.000	395.000
-32.817	401.591
12.000	412.000
150.000	412.000

Search Grid

-73.000	441.000
-28.000	441.000
-28.000	481.000
-73.000	481.000

Ameren Missouri  
Meramec Plant  
Cross-section 6  
Long-term Analysis (with bench)



MoDOT Type 4 Rip Rap

10 ft

W

W

W



Fill

Lean Clay

Fat Clay

# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 6 longterm bench.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Material Properties**

Material: Fill  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 25 degrees  
Water Surface: Water Table  
Custom Hu value: 0

Material: Lean Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees

Water Surface: Water Table  
Custom Hu value: 0

Material: Fat Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: Water Table  
Custom Hu value: 0

Material: Sand & Gravel  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 27 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4 Rip Rap  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

### List of All Coordinates

#### Material Boundary

-150.000	360.000
150.000	360.000

#### Material Boundary

-150.000	325.000
150.000	325.000

#### Material Boundary

-51.000	400.000
-36.000	400.000
-10.000	413.000
-6.000	415.000

#### Material Boundary

-36.000	400.000
36.000	400.000

#### External Boundary

-150.000	300.000
150.000	300.000
150.000	325.000
150.000	360.000
150.000	380.000
76.000	380.000
46.000	395.000
36.000	400.000
10.000	413.000

6.000	415.000
-6.000	415.000
-51.000	400.000
-61.000	400.000
-62.371	395.000
-150.000	395.000
-150.000	360.000
-150.000	325.000

Water Table

-150.000	395.000
-62.371	395.000
-61.000	400.000
-51.000	400.000
-36.000	400.000
-24.763	405.619
12.000	412.000
150.000	412.000

Focus/Block Search Line


-51.000	382.000
-51.000	396.000

Search Grid


-90.000	471.000
-36.000	471.000
-36.000	526.000
-90.000	526.000



**Ameren Missouri  
Meramec Plant  
Cross-section 6  
Seismic Analysis**



MoDOT Type 4 Rip Rap



# ***Slide Analysis Information***

## **Document Name**

File Name: xsec 6 longterm seismic.sli

## **Project Settings**

Project Title: SLIDE - An Interactive Slope Stability Program  
Failure Direction: Right to Left  
Units of Measurement: Imperial Units  
Pore Fluid Unit Weight: 62.4 lb/ft<sup>3</sup>  
Groundwater Method: Water Surfaces  
Data Output: Standard  
Calculate Excess Pore Pressure: Off  
Allow Ru with Water Surfaces or Grids: Off  
Random Numbers: Pseudo-random Seed  
Random Number Seed: 10116  
Random Number Generation Method: Park and Miller v.3

## **Analysis Methods**

Analysis Methods used:  
GLE/Morgenstern-Price with interslice force function: Half Sine  
Spencer

Number of slices: 25  
Tolerance: 0.005  
Maximum number of iterations: 50

## **Surface Options**

Surface Type: Circular  
Search Method: Grid Search  
Radius increment: 10  
Composite Surfaces: Disabled  
Reverse Curvature: Create Tension Crack  
Minimum Elevation: Not Defined  
Minimum Depth: Not Defined

## **Loading**

Seismic Load Coefficient (Horizontal): 0.0575

## **Material Properties**

### **Material: Fill**

Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 25 degrees  
Water Surface: None

### **Material: Lean Clay**

Strength Type: Mohr-Coulomb

Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

Material: Fat Clay  
Strength Type: Mohr-Coulomb  
Unit Weight: 120 lb/ft<sup>3</sup>  
Cohesion: 0 psf  
Friction Angle: 23 degrees  
Water Surface: None

Material: Sand & Gravel  
Strength Type: Mohr-Coulomb  
Unit Weight: 125 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 27 degrees  
Water Surface: Water Table  
Custom Hu value: 1

Material: MoDOT Type 4 Rip Rap  
Strength Type: Mohr-Coulomb  
Unit Weight: 135 lb/ft<sup>3</sup>  
Cohesion: 1 psf  
Friction Angle: 40 degrees  
Water Surface: Water Table  
Custom Hu value: 1

### List of All Coordinates

#### Material Boundary

-150.000 360.000  
150.000 360.000

#### Material Boundary

-150.000 325.000  
150.000 325.000

#### Material Boundary

-66.000 395.000  
-46.000 395.000  
-36.000 400.000  
-10.000 413.000  
-6.000 415.000

#### Material Boundary

-36.000 400.000  
36.000 400.000

#### External Boundary

-150.000 300.000  
150.000 300.000  
150.000 325.000  
150.000 360.000  
150.000 380.000  
76.000 380.000  
46.000 395.000

36.000	400.000
10.000	413.000
6.000	415.000
-6.000	415.000
-66.000	395.000
-150.000	395.000
-150.000	360.000
-150.000	325.000

Water Table

-150.000	395.000
-46.000	395.000
-32.817	401.591
12.000	412.000
150.000	412.000

Search Grid

-73.000	441.000
-28.000	441.000
-28.000	481.000
-73.000	481.000

APPENDIX B

UNIT 1 (POND 3) FIELD OBSERVATION CHECKLIST



<b>Site Name:</b>	<b>Meramec</b>	<b>Date:</b>	<b>September 29, 2010</b>
<b>Unit Name:</b>	<b>New Fly Ash Pond</b>	<b>Operator's Name:</b>	<b>AmerenUE</b>
<b>Unit I.D.:</b>	<b>498</b>	<b>Hazard Potential Classification:</b>	<b>High <input type="checkbox"/> Significant <input type="checkbox"/> Low <input checked="" type="checkbox"/></b>
<b>Inspector's Name:</b>		<b>Jeffrey Crabtree, PE and James Filson, PE</b>	

Check the appropriate box below. Provide comments when appropriate. If not applicable or not available, record "N/A". Any unusual conditions or construction practices that should be noted in the comments section. For large diked embankments, separate checklists may be used for different embankment areas. If separate forms are used, identify approximate area that the form applies to in comments.

US EPA ARCHIVE DOCUMENT

	Yes	No		Yes	No
1. Frequency of Company's Dam Inspections?	Annual		18. Sloughing or bulging on slopes?		X
2. Pool elevation (operator records)?	418		19. Major erosion or slope deterioration?		X
3. Decant inlet elevation (operator records)?	plans		20. Decant Pipes:		
4. Open channel spillway elevation (operator records)?		X	Is water entering inlet, but not exiting outlet?		X
5. Lowest dam crest elevation (operator records)?	423		Is water exiting outlet, but not entering inlet?		X
6. If instrumentation is present, are readings recorded (operator records)?	Plans		Is water exiting outlet flowing clear?	X	
7. Is the embankment currently under construction?		X	21. Seepage (specify location, if seepage carries fines, and approximate seepage rate below):		
8. Foundation preparation (remove vegetation, stumps, topsoil in area where embankment fill will be placed)?		N/A	From underdrain?		X
9. Trees growing on embankment? (If so, indicate largest diameter below)		N/A	At isolated points on embankment slopes?	X	
10. Cracks or scarps on crest?		X	At natural hillside in the embankment area?		X
11. Is there significant settlement along the crest?		X	Over widespread areas?		X
12. Are decant trashracks clear and in place?	X		From downstream foundation area?		X
13. Depressions or sinkholes in tailings surface or whirlpool in the pool area?		X	"Boils" beneath stream or ponded water?		X
14. Clogged spillways, groin or diversion ditches?		X	Around the outside of the decant pipe?		X
15. Are spillway or ditch linings deteriorated?		N/A	22. Surface movements in valley bottom or on hillside?		X
16. Are outlets of decant or underdrains blocked?		X	23. Water against downstream toe?	X	
17. Cracks or scarps on slopes?		X	24. Were Photos taken during the dam inspection?	X	

Major adverse changes in these items could cause instability and should be reported for further evaluation. Adverse conditions noted in these items should normally be described (extent, location, volume, etc.) in the space below and on the back of this sheet.

Issue #	Comments
#3	Information on plans and plans have been requested through AmerenUE Legal Group
#10	Noted as part of normal maintenance
#12	Clear of debris
#17	Cleared areas and scarps are from maintenance of eroded areas from runoff
#21	NW area between Bottom Ash and 498 Pond – Isolated area noted in Maintenance report and being monitored
#23	Floodwater - Mississippi River and backwater conditions on the Meramec River



## Coal Combustion Waste (CCW) Impoundment Inspection

**Impoundment NPDES Permit** MO-0000361                      **INSPECTOR**

**Date** 05/19/2000 to 05/18/2005  
**Impoundment Name** Meramec Power Plant

**Impoundment Company** AmerenUE  
**EPA Region** Region 7

**State Agency** State of Missouri  
**(Field Office) Address** Department of Natural Resources  
**Name of Impoundment** New Fly Ash Pond

*(Report each impoundment on a separate form under the same Impoundment NPDES Permit number)*

**New**                       **Update**

	<b>Yes</b>	<b>No</b>
<b>Is impoundment currently under construction?</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Is water or ccw currently being pumped into the impoundment?</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**IMPOUNDMENT FUNCTION:** Storage – Fly Ash

**Nearest Downstream Town Name:** Kimmswick

**Distance from the impoundment:** 2.8 miles

**Location:**

**Latitude**    38        Degrees        24        Minutes        25.16        Seconds        **N**

**Longitude**    90        Degrees        20        Minutes        26.97        Seconds        **W**

**State** Missouri                      **County** St. Louis

	<b>Yes</b>	<b>No</b>
<b>Does a state agency regulate this impoundment?</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

**If So Which State Agency?**

US EPA ARCHIVE DOCUMENT



**HAZARD POTENTIAL** *(In the event the impoundment should fail, the following would occur):*

- LESS THAN LOW HAZARD POTENTIAL:** Failure or misoperation of the dam results in no probable loss of human life or economic or environmental losses.
  
- x **LOW HAZARD POTENTIAL:** Dams assigned the low hazard potential classification are those where failure or misoperation results in no probable loss of human life and low economic and/or environmental losses. Losses are principally limited to the owner's property.
  
- SIGNIFICANT HAZARD POTENTIAL:** Dams assigned the significant hazard potential classification are those dams where failure or misoperation results in no probable loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns. Significant hazard potential classification dams are often located in predominantly rural or agricultural areas but could be located in areas with population and significant infrastructure.
  
- HIGH HAZARD POTENTIAL:** Dams assigned the high hazard potential classification are those where failure or misoperation will probably cause loss of human life.


**DESCRIBE REASONING FOR HAZARD RATING CHOSEN:**

Early assessment is determined to be low based on site assessment only. Visual assessment of unit was conducted and small isolated seep area noted and AmerenUE has been monitoring this location as noted in their annual inspection report. Units and site in good conditions. AmerenUE has a dam safety group which oversees the unit and conducts weekly inspections.

The new fly ash pond is located in the middle of the site and incised. The embankment is more than 100 yards away from this unit. The unit was built within the old fly ash area and is lined. The potential is low for failure at this unit.



**CONFIGURATION:**



- Cross-Valley
- Side-Hill
- Diked
- Incised (form completion optional)
- Combination Incised/Diked

**Embankment Height (ft)** 25      **Embankment Material** Ash with liner (in interior of dam)

**Pool Area (ac)** 13.5 ac      **Liner** Has Liner

**Current Freeboard (ft)**      **Liner Permeability**

US EPA ARCHIVE DOCUMENT



**TYPE OF OUTLET** (Mark all that apply)

N/A **Open Channel Spillway**


- Trapezoidal
- Triangular
- Rectangular
- Irregular

depth (ft)


average bottom width (ft)

top width (ft)


TRAPEZOIDAL




TRIANGULAR



RECTANGULAR



IRREGULAR




x **Outlet**

24" inside diameter

**Material**

- corrugated metal
- welded steel
- concrete
- x  plastic (hdpe, pvc, etc.)
- other (specify):



Yes

No

Is water flowing through the outlet?

x

No Outlet

Other Type of Outlet (specify):

US EPA ARCHIVE DOCUMENT



Yes      No

Has there ever been a failure at this site?            X

If So When?

If So Please Describe :

**US EPA ARCHIVE DOCUMENT**



	Yes	No
<b>Has there ever been significant seepages at this site?</b>	<input type="checkbox"/>	X

**If So When?**

**If So Please Describe :**

Minor seepage noted during the site assessment and AmerenUE is currently monitoring.

**US EPA ARCHIVE DOCUMENT**



	Yes	No
Has there ever been any measures undertaken to monitor/lower Phreatic water table levels based on past seepages or breaches at this site?	<input type="checkbox"/>	X

If so, which method (e.g., piezometers, gw pumping,...)?

If So Please Describe :

US EPA ARCHIVE DOCUMENT



**ADDITIONAL INSPECTION QUESTIONS**

*Concerning the embankment foundation, was the embankment construction built over wet ash, slag, or other unsuitable materials? If there is no information just note that.*

Interior Unit – 498 see detail map. Unknown ; Plans requested through AmerenUE

*Did the dam assessor meet with, or have documentation from, the design Engineer-of-Record concerning the foundation preparation?*

Plans will assist in determining the dam foundation and have been requested and waiting for clearance through AmerenUE Legal.

*From the site visit or from photographic documentation, was there evidence of prior releases, failures, or patchwork on the dikes?*

No – minor erosion noted during assessment.

APPENDIX B

UNIT 2 (POND 2) FIELD OBSERVATION CHECKLIST



<b>Site Name:</b>	<b>Meramec</b>	<b>Date:</b>	<b>September 29, 2010</b>
<b>Unit Name:</b>	<b>Old Fly Ash Pond</b>	<b>Operator's Name:</b>	<b>AmerenUE</b>
<b>Unit I.D.:</b>	<b>489</b>	<b>Hazard Potential Classification:</b>	<b>High <input type="checkbox"/> Significant <input type="checkbox"/> Low <input checked="" type="checkbox"/></b>
<b>Inspector's Name:</b>		<b>Jeffrey Crabtree, PE and James Filson, PE</b>	

Check the appropriate box below. Provide comments when appropriate. If not applicable or not available, record "N/A". Any unusual conditions or construction practices that should be noted in the comments section. For large diked embankments, separate checklists may be used for different embankment areas. If separate forms are used, identify approximate area that the form applies to in comments.

	Yes	No		Yes	No
1. Frequency of Company's Dam Inspections?	Annual		18. Sloughing or bulging on slopes?		X
2. Pool elevation (operator records)?	416.5		19. Major erosion or slope deterioration?		X
3. Decant inlet elevation (operator records)?	plans		20. Decant Pipes:		
4. Open channel spillway elevation (operator records)?		X	Is water entering inlet, but not exiting outlet?		X
5. Lowest dam crest elevation (operator records)?	420.2		Is water exiting outlet, but not entering inlet?		X
6. If instrumentation is present, are readings recorded (operator records)?	Plans		Is water exiting outlet flowing clear?	X	
7. Is the embankment currently under construction?		X	21. Seepage (specify location, if seepage carries fines, and approximate seepage rate below):		
8. Foundation preparation (remove vegetation, stumps, topsoil in area where embankment fill will be placed)?		N/A	From underdrain?		X
9. Trees growing on embankment? (If so, indicate largest diameter below)		N/A	At isolated points on embankment slopes?	X	
10. Cracks or scarps on crest?		X	At natural hillside in the embankment area?		X
11. Is there significant settlement along the crest?		X	Over widespread areas?		X
12. Are decant trashracks clear and in place?	X		From downstream foundation area?		X
13. Depressions or sinkholes in tailings surface or whirlpool in the pool area?		X	"Boils" beneath stream or ponded water?		X
14. Clogged spillways, groin or diversion ditches?		X	Around the outside of the decant pipe?		X
15. Are spillway or ditch linings deteriorated?		N/A	22. Surface movements in valley bottom or on hillside?		X
16. Are outlets of decant or underdrains blocked?		X	23. Water against downstream toe?	X	
17. Cracks or scarps on slopes?	X		24. Were Photos taken during the dam inspection?	X	

Major adverse changes in these items could cause instability and should be reported for further evaluation. Adverse conditions noted in these items should normally be described (extent, location, volume, etc.) in the space below and on the back of this sheet.

Issue #	Comments
#3	Information on plans and plans have been requested through AmerenUE Legal Group
#12	Clear of debris
#17	Cleared areas and scarps are from maintenance of eroded areas from runoff
#21	NW area between Bottom Ash and 498 Pond – Isolated area noted in Maintenance report and being monitored
#23	Floodwater - Mississippi River and backwater conditions on the Meramec River

US EPA ARCHIVE DOCUMENT



## Coal Combustion Waste (CCW) Impoundment Inspection

**Impoundment NPDES Permit** MO-0000361                      **INSPECTOR**

**Date** 05/19/2000 to 05/18/2005  
**Impoundment Name** Meramec Power Plant

**Impoundment Company** AmerenUE  
**EPA Region** Region 7

**State Agency** State of Missouri  
**(Field Office) Address** Department of Natural Resources  
**Name of Impoundment** Old Fly Ash Pond

*(Report each impoundment on a separate form under the same Impoundment NPDES Permit number)*

**New**                       **Update**

	<b>Yes</b>	<b>No</b>
<b>Is impoundment currently under construction?</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Is water or ccw currently being pumped into the impoundment?</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**IMPOUNDMENT FUNCTION:** Storage – Fly Ash

**Nearest Downstream Town Name:** Kimmswick

**Distance from the impoundment:** 2.8 miles

**Location:**

**Latitude**    38            Degrees            23            Minutes            59.43            Seconds            **N**

**Longitude**    90            Degrees            20            Minutes            31.67            Seconds            **W**

**State** Missouri                      **County** St. Louis

	<b>Yes</b>	<b>No</b>
<b>Does a state agency regulate this impoundment?</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

**If So Which State Agency?**

US EPA ARCHIVE DOCUMENT



**HAZARD POTENTIAL** *(In the event the impoundment should fail, the following would occur):*

- LESS THAN LOW HAZARD POTENTIAL:** Failure or misoperation of the dam results in no probable loss of human life or economic or environmental losses.
  
- x **LOW HAZARD POTENTIAL:** Dams assigned the low hazard potential classification are those where failure or misoperation results in no probable loss of human life and low economic and/or environmental losses. Losses are principally limited to the owner's property.
  
- SIGNIFICANT HAZARD POTENTIAL:** Dams assigned the significant hazard potential classification are those dams where failure or misoperation results in no probable loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns. Significant hazard potential classification dams are often located in predominantly rural or agricultural areas but could be located in areas with population and significant infrastructure.
  
- HIGH HAZARD POTENTIAL:** Dams assigned the high hazard potential classification are those where failure or misoperation will probably cause loss of human life.


**DESCRIBE REASONING FOR HAZARD RATING CHOSEN:**

Early assessment is determined to be low based on site assessment only. Visual assessment of unit was conducted and small isolated seep area noted and AmerenUE has been monitoring this location as noted in their annual inspection report. Units and site in good conditions. AmerenUE has a dam safety group which oversees the unit and conducts weekly inspections.

The old fly ash pond is located along the SE area of the embankments and has three sides incised. The one side which is adjacent to the embankment is approximately 75-100 yards away from this unit. The unit is lined.



**CONFIGURATION:**



- Cross-Valley
- Side-Hill
- Diked
- Incised (form completion optional)
- Combination Incised/Diked

**Embankment Height (ft)** 25' (24.7')

**Embankment Material** Ash with liner (in interior of dam)

**Liner** Has Liner

**Current Freeboard (ft)** 3.7'

**Liner Permeability**

US EPA ARCHIVE DOCUMENT



**TYPE OF OUTLET** (Mark all that apply)

N/A **Open Channel Spillway**


- Trapezoidal
- Triangular
- Rectangular
- Irregular

depth (ft)


average bottom width (ft)

top width (ft)


TRAPEZOIDAL




TRIANGULAR



RECTANGULAR



IRREGULAR




x **Outlet**

36" inside diameter

**Material**

- corrugated metal
- welded steel
- concrete
- x  plastic (hdpe, pvc, etc.)
- other (specify):



**Is water flowing through the outlet?**

Yes

No

x

**No Outlet**

**Other Type of Outlet**  
(specify):



Yes      No

Has there ever been a failure at this site?            X

If So When?

If So Please Describe :

US EPA ARCHIVE DOCUMENT



	Yes	No
Has there ever been significant seepages at this site?	<input type="checkbox"/>	X

If So When?

If So Please Describe :

Minor seepage noted during the site assessment and AmerenUE is currently monitoring.

US EPA ARCHIVE DOCUMENT



	Yes	No
Has there ever been any measures undertaken to monitor/lower Phreatic water table levels based on past seepages or breaches at this site?	<input type="checkbox"/>	X

If so, which method (e.g., piezometers, gw pumping,...)?

If So Please Describe :

US EPA ARCHIVE DOCUMENT



**ADDITIONAL INSPECTION QUESTIONS**

*Concerning the embankment foundation, was the embankment construction built over wet ash, slag, or other unsuitable materials? If there is no information just note that.*

Unknown; Plans requested through AmerenUE

*Did the dam assessor meet with, or have documentation from, the design Engineer-of-Record concerning the foundation preparation?*

Plans will assist in determining the dam foundation and have been requested and waiting for clearance through AmerenUE Legal.

*From the site visit or from photographic documentation, was there evidence of prior releases, failures, or patchwork on the dikes?*

No – minor erosion noted during assessment.

APPENDIX B

UNIT 3 (POND 4, 5 & 6) FIELD OBSERVATION CHECKLIST



<b>Site Name:</b>	<b>Meramec</b>	<b>Date:</b>	<b>September 29, 2010</b>
<b>Unit Name:</b>	<b>Bottom Ash Pond</b>	<b>Operator's Name:</b>	<b>AmerenUE</b>
<b>Unit I.D.:</b>	<b>Bottom Ash</b>	<b>Hazard Potential Classification:</b>	<b>High <input type="checkbox"/> Significant <input type="checkbox"/> Low <input checked="" type="checkbox"/></b>
<b>Inspector's Name:</b>		Jeffrey Crabtree, PE and James Filson, PE	

Check the appropriate box below. Provide comments when appropriate. If not applicable or not available, record "N/A". Any unusual conditions or construction practices that should be noted in the comments section. For large diked embankments, separate checklists may be used for different embankment areas. If separate forms are used, identify approximate area that the form applies to in comments.

US EPA ARCHIVE DOCUMENT

	Yes	No		Yes	No
1. Frequency of Company's Dam Inspections?	Annual		18. Sloughing or bulging on slopes?		X
2. Pool elevation (operator records)?	408		19. Major erosion or slope deterioration?		X
3. Decant inlet elevation (operator records)?	plans		20. Decant Pipes:		
4. Open channel spillway elevation (operator records)?		X	Is water entering inlet, but not exiting outlet?		X
5. Lowest dam crest elevation (operator records)?	417.4		Is water exiting outlet, but not entering inlet?		X
6. If instrumentation is present, are readings recorded (operator records)?	Plans		Is water exiting outlet flowing clear?	X	
7. Is the embankment currently under construction?		X	21. Seepage (specify location, if seepage carries fines, and approximate seepage rate below):		
8. Foundation preparation (remove vegetation, stumps, topsoil in area where embankment fill will be placed)?		N/A	From underdrain?		X
9. Trees growing on embankment? (If so, indicate largest diameter below)		N/A	At isolated points on embankment slopes?	X	
10. Cracks or scarps on crest?		X	At natural hillside in the embankment area?		X
11. Is there significant settlement along the crest?		X	Over widespread areas?		X
12. Are decant trashracks clear and in place?	X		From downstream foundation area?		X
13. Depressions or sinkholes in tailings surface or whirlpool in the pool area?		X	"Boils" beneath stream or ponded water?		X
14. Clogged spillways, groin or diversion ditches?		X	Around the outside of the decant pipe?		X
15. Are spillway or ditch linings deteriorated?		N/A	22. Surface movements in valley bottom or on hillside?		X
16. Are outlets of decant or underdrains blocked?		X	23. Water against downstream toe?	X	
17. Cracks or scarps on slopes?		X	24. Were Photos taken during the dam inspection?	X	

Major adverse changes in these items could cause instability and should be reported for further evaluation. Adverse conditions noted in these items should normally be described (extent, location, volume, etc.) in the space below and on the back of this sheet.

Issue #	Comments
#2 #3	Information on plans and plans have been requested through AmerenUE Legal Group
#12	Clear of debris
#21	SW quad of Bottom Ash Pond – Isolated area noted in Maintenance report and being monitored
#23	Floodwater - backwater conditions on the Meramec River



## Coal Combustion Waste (CCW) Impoundment Inspection

**Impoundment NPDES Permit** MO-0000361                      **INSPECTOR**

**Date** 05/19/2000 to 05/18/2005  
**Impoundment Name** Meramec Power Plant

**Impoundment Company** AmerenUE  
**EPA Region** Region 7

**State Agency** State of Missouri  
**(Field Office) Address** Department of Natural Resources  
**Name of Impoundment** Bottom Ash Pond

*(Report each impoundment on a separate form under the same Impoundment NPDES Permit number)*

**New**                       **Update**

	<b>Yes</b>	<b>No</b>
<b>Is impoundment currently under construction?</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Is water or ccw currently being pumped into the impoundment?</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**IMPOUNDMENT FUNCTION:** Storage – Bottom Ash

**Nearest Downstream Town Name:** Kimmswick

**Distance from the impoundment:** 2.8 miles

**Location:**

**Latitude**    38        Degrees        24        Minutes        30.56        Seconds        **N**

**Longitude**    90        Degrees        20        Minutes        20.56        Seconds        **W**

**State** Missouri                      **County** St. Louis

	<b>Yes</b>	<b>No</b>
<b>Does a state agency regulate this impoundment?</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

**If So Which State Agency?**

US EPA ARCHIVE DOCUMENT



**HAZARD POTENTIAL** *(In the event the impoundment should fail, the following would occur):*

- LESS THAN LOW HAZARD POTENTIAL:** Failure or misoperation of the dam results in no probable loss of human life or economic or environmental losses.
  
- x **LOW HAZARD POTENTIAL:** Dams assigned the low hazard potential classification are those where failure or misoperation results in no probable loss of human life and low economic and/or environmental losses. Losses are principally limited to the owner's property.
  
- SIGNIFICANT HAZARD POTENTIAL:** Dams assigned the significant hazard potential classification are those dams where failure or misoperation results in no probable loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns. Significant hazard potential classification dams are often located in predominantly rural or agricultural areas but could be located in areas with population and significant infrastructure.
  
- HIGH HAZARD POTENTIAL:** Dams assigned the high hazard potential classification are those where failure or misoperation will probably cause loss of human life.


**DESCRIBE REASONING FOR HAZARD RATING CHOSEN:**

Early assessment is determined to be low based on site assessment only. Visual assessment of unit was conducted and small isolated seep area noted and AmerenUE has been monitoring this location as noted in their annual inspection report. Units and site in good conditions. AmerenUE has a dam safety group which oversees the unit and conducts weekly inspections.

The bottom ash pond is located NW corner of the embankment and has three sides that are incised. The fourth side is part of the embankment. The seep location is in the SW corner of the unit and is a little wet, no running water. A stability analysis is being conducted and will be completed by the end of the year, we have requested a copy for this site assessment.



**CONFIGURATION:**



- Cross-Valley
- Side-Hill
- Diked
- Incised (form completion optional)
- Combination Incised/Diked

**Embankment Height (ft)** 25' (24.7')      **Embankment Material** Noted on Plans – Silty Clay / Clay

**Pool Area (ac)** 14 ac      **Liner**

**Current Freeboard (ft)** 9.4'      **Liner Permeability**

US EPA ARCHIVE DOCUMENT



**TYPE OF OUTLET** (Mark all that apply)

N/A **Open Channel Spillway**


- Trapezoidal
- Triangular
- Rectangular
- Irregular

depth (ft)


average bottom width (ft)

top width (ft)


TRAPEZOIDAL




TRIANGULAR



RECTANGULAR



IRREGULAR




x **Outlet**

18" inside diameter

**Material**

- corrugated metal
- welded steel
- concrete
- plastic (hdpe, pvc, etc.)
- x other (specify): Carbon Steel



Yes

No

Is water flowing through the outlet?

x

No Outlet

Other Type of Outlet (specify):

US EPA ARCHIVE DOCUMENT



Yes      No

Has there ever been a failure at this site?            X

If So When?

If So Please Describe :

US EPA ARCHIVE DOCUMENT



	Yes	No
Has there ever been significant seepages at this site?	<input type="checkbox"/>	X

If So When?

If So Please Describe :

Minor seepage noted during the site assessment and AmerenUE is currently monitoring.

US EPA ARCHIVE DOCUMENT



	Yes	No
Has there ever been any measures undertaken to monitor/lower Phreatic water table levels based on past seepages or breaches at this site?	<input type="checkbox"/>	X

If so, which method (e.g., piezometers, gw pumping,...)?

If So Please Describe :

US EPA ARCHIVE DOCUMENT



**ADDITIONAL INSPECTION QUESTIONS**

*Concerning the embankment foundation, was the embankment construction built over wet ash, slag, or other unsuitable materials? If there is no information just note that.*

Unknown; Plans requested through AmerenUE

*Did the dam assessor meet with, or have documentation from, the design Engineer-of-Record concerning the foundation preparation?*

Plans will assist in determining the dam foundation and have been requested and waiting for clearance through AmerenUE Legal.

*From the site visit or from photographic documentation, was there evidence of prior releases, failures, or patchwork on the dikes?*

No –

APPENDIX B

UNIT 4 (POND 1) FIELD OBSERVATION CHECKLIST



<b>Site Name:</b>	<b>Meramec</b>	<b>Date:</b>	<b>September 29, 2010</b>
<b>Unit Name:</b>	<b>Retention Pond</b>	<b>Operator's Name:</b>	<b>AmerenUE</b>
<b>Unit I.D.:</b>	<b>Retention</b>	<b>Hazard Potential Classification:</b>	<b>High <input type="checkbox"/> Significant <input type="checkbox"/> Low <input checked="" type="checkbox"/></b>
<b>Inspector's Name:</b>		Jeffrey Crabtree, PE and James Filson, PE	

Check the appropriate box below. Provide comments when appropriate. If not applicable or not available, record "N/A". Any unusual conditions or construction practices that should be noted in the comments section. For large diked embankments, separate checklists may be used for different embankment areas. If separate forms are used, identify approximate area that the form applies to in comments.

US EPA ARCHIVE DOCUMENT

	Yes	No		Yes	No
1. Frequency of Company's Dam Inspections?	Annual		18. Sloughing or bulging on slopes?		X
2. Pool elevation (operator records)?	405		19. Major erosion or slope deterioration?		X
3. Decant inlet elevation (operator records)?	plans		20. Decant Pipes:		
4. Open channel spillway elevation (operator records)?		X	Is water entering inlet, but not exiting outlet?		X
5. Lowest dam crest elevation (operator records)?	414		Is water exiting outlet, but not entering inlet?		X
6. If instrumentation is present, are readings recorded (operator records)?	Plans		Is water exiting outlet flowing clear?	X	
7. Is the embankment currently under construction?		X	21. Seepage (specify location, if seepage carries fines, and approximate seepage rate below):		
8. Foundation preparation (remove vegetation, stumps, topsoil in area where embankment fill will be placed)?		N/A	From underdrain?		X
9. Trees growing on embankment? (If so, indicate largest diameter below)		N/A	At isolated points on embankment slopes?	X	
10. Cracks or scarps on crest?		X	At natural hillside in the embankment area?		X
11. Is there significant settlement along the crest?		X	Over widespread areas?		X
12. Are decant trashracks clear and in place?	X		From downstream foundation area?		X
13. Depressions or sinkholes in tailings surface or whirlpool in the pool area?		X	"Boils" beneath stream or ponded water?		X
14. Clogged spillways, groin or diversion ditches?		X	Around the outside of the decant pipe?		X
15. Are spillway or ditch linings deteriorated?		N/A	22. Surface movements in valley bottom or on hillside?		X
16. Are outlets of decant or underdrains blocked?		X	23. Water against downstream toe?	X	
17. Cracks or scarps on slopes?		X	24. Were Photos taken during the dam inspection?	X	

Major adverse changes in these items could cause instability and should be reported for further evaluation. Adverse conditions noted in these items should normally be described (extent, location, volume, etc.) in the space below and on the back of this sheet.

Issue #	Comments
#2 #3	Information on plans and plans have been requested through AmerenUE Legal Group
#12	Clear of debris
#21	NW corner – Isolated area noted in Maintenance report and being monitored
#23	Floodwater - backwater conditions on the Meramec River



# Coal Combustion Waste (CCW) Impoundment Inspection

Impoundment NPDES Permit MO-0000361 INSPECTOR

Date 05/19/2000 to 05/18/2005  
Impoundment Name Meramec Power Plant

Impoundment Company AmerenUE  
EPA Region Region 7

State Agency State of Missouri  
(Field Office) Address Department of Natural Resources  
Name of Impoundment Retention Pond

(Report each impoundment on a separate form under the same Impoundment NPDES Permit number)

New  Update

	Yes	No
Is impoundment currently under construction?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Is water or ccw currently being pumped into the impoundment?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

IMPOUNDMENT FUNCTION: Storage – Bottom Ash

Nearest Downstream Town Name: Kimmswick

Distance from the impoundment: 2.8 miles

Location:

Latitude 38 Degrees 24 Minutes 27.68 Seconds N

Longitude 90 Degrees 20 Minutes 35.46 Seconds W

State Missouri County St. Louis

	Yes	No
Does a state agency regulate this impoundment?	<input type="checkbox"/>	<input checked="" type="checkbox"/>

If So Which State Agency?

US EPA ARCHIVE DOCUMENT



**HAZARD POTENTIAL** *(In the event the impoundment should fail, the following would occur):*

- LESS THAN LOW HAZARD POTENTIAL:** Failure or misoperation of the dam results in no probable loss of human life or economic or environmental losses.
  
- x **LOW HAZARD POTENTIAL:** Dams assigned the low hazard potential classification are those where failure or misoperation results in no probable loss of human life and low economic and/or environmental losses. Losses are principally limited to the owner's property.
  
- SIGNIFICANT HAZARD POTENTIAL:** Dams assigned the significant hazard potential classification are those dams where failure or misoperation results in no probable loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns. Significant hazard potential classification dams are often located in predominantly rural or agricultural areas but could be located in areas with population and significant infrastructure.
  
- HIGH HAZARD POTENTIAL:** Dams assigned the high hazard potential classification are those where failure or misoperation will probably cause loss of human life.

**DESCRIBE REASONING FOR HAZARD RATING CHOSEN:**


Early assessment is determined to be low based on site assessment only. Visual assessment of unit was conducted and small isolated seep area noted and AmerenUE has been monitoring this location as noted in their annual inspection report. Units and site in good conditions. AmerenUE has a dam safety group which oversees the unit and conducts weekly inspections.

The retention pond is located west of the embankment and has all sides incised. The edge of the retention pond, shortest distance to the embankment is approximately 75 yards. The side slopes are vertical timber board built within the fly ash pond area.

US EPA ARCHIVE DOCUMENT



**CONFIGURATION:**



- Cross-Valley
- Side-Hill
- Diked
- Incised (form completion optional)
- X Combination Incised/Diked

**Embankment Height (ft)** 25' (24.7')

**Embankment Material** Noted on Plans – Vertical wooden boards

**Pool Area (ac)** 0.7 ac

**Liner**

**Current Freeboard (ft)** 9'

**Liner Permeability**

US EPA ARCHIVE DOCUMENT



**TYPE OF OUTLET** (Mark all that apply)

N/A **Open Channel Spillway**


- Trapezoidal
- Triangular
- Rectangular
- Irregular

depth (ft)


average bottom width (ft)

top width (ft)


TRAPEZOIDAL




TRIANGULAR



RECTANGULAR



IRREGULAR




x **Outlet**

24" inside diameter

**Material**

- corrugated metal
- welded steel
- concrete
- plastic (hdpe, pvc, etc.)
- x other (specify): Carbon Steel



Yes

No

Is water flowing through the outlet?

x

No Outlet

Other Type of Outlet (specify):

US EPA ARCHIVE DOCUMENT



Yes      No

Has there ever been a failure at this site?            X

If So When?

If So Please Describe :

US EPA ARCHIVE DOCUMENT



	Yes	No
Has there ever been significant seepages at this site?	<input type="checkbox"/>	X

If So When?

If So Please Describe :

Minor seepage noted during the site assessment and AmerenUE is currently monitoring.

US EPA ARCHIVE DOCUMENT



	Yes	No
Has there ever been any measures undertaken to monitor/lower Phreatic water table levels based on past seepages or breaches at this site?	<input type="checkbox"/>	X

If so, which method (e.g., piezometers, gw pumping,...)?

If So Please Describe :

US EPA ARCHIVE DOCUMENT



**ADDITIONAL INSPECTION QUESTIONS**

*Concerning the embankment foundation, was the embankment construction built over wet ash, slag, or other unsuitable materials? If there is no information just note that.*

Unknown; Plans requested through AmerenUE

*Did the dam assessor meet with, or have documentation from, the design Engineer-of-Record concerning the foundation preparation?*

Plans will assist in determining the dam foundation and have been requested and waiting for clearance through AmerenUE Legal.

*From the site visit or from photographic documentation, was there evidence of prior releases, failures, or patchwork on the dikes?*

No –

APPENDIX C

REFERENCES

## REFERENCES

- Dent, J. and Heineman, J. 2010. Meramec Ash Impoundment: Weekly Inspection Checksheets. AmerenUE.
- Campbell, G. and Frerking, M. 2009. Meramec Ash Impoundment: 2008 Annual Inspection Checksheets. AmerenUE.
- Dent, J., Campbell, G., and Frerking, M. 2009. Meramec Ash Impoundment: 2009 Annual Inspection Checksheets. AmerenUE.
- Reitz & Jens, Inc. 2010. Ash Pond Dam Stability Analysis – Meramec Power Station. St. Louis, MO.
- Reitz & Jens, Inc. 2007. AmerenUE Dam Inventory and Inspection Program: Phase I Presentation of Field Observations, Analysis and Recommendations. St. Louis, MO.
- Ameren. 2009. AmerenUE Program DSP 003: Dam Safety Program for AmerenUE Non-Hydroelectric Facilities.
- Ameren Emergency Response Task Team. 1997. Meramec Power Plan Emergency Implementing Procedure, MP-EIP-DAMINT-16, Emergency Plant Dam Failure/Loss of Integrity Procedure. Revision 2.
- Environmental Protection Agency (EPA). 2010. Steam Electric Questionnaire: Part D – Pond/Impoundment Systems and Other Wastewater Treatment Operations. OMB Control Number 2040-0281.
- Haddock, M. and Lemon, M. 2008. AmerenUE Meramec Plan Ash Pond #494 Drilling and Piezometer Installation. Golder Associates Inc., St. Charles, MO.
- United States Army Corps of Engineers (USACE). 2004. “Upper Mississippi River System Flow Frequency Study.” January 2004.