

US EPA ARCHIVE DOCUMENT

## Apache Comments

**EPA HQ:** No comments, CD/JM

**EPA Region:**

See attached document date Nov. 17, 2009

**State:**

From: "Michael J. Johnson" <mjohnson@azwater.gov>  
To: James Kohler/DC/USEPA/US@EPA, John Schofield/R9/USEPA/US@EPA, 'Mel P.Bunkers' <Bunkers.Mel@azdeq.gov>  
Cc: Stephen Hoffman/DC/USEPA/US@EPA, Ravi Murthy <rmurthy@azwater.gov>, "Karen L. Smith" <klsmith@azwater.gov>  
Date: 11/09/2009 11:40 AM  
Subject: RE: Comment Request on EPA's Draft Coal Ash Impoundment Assessment Reports

Jim,

Thanks for the opportunity to review the reports. ADWR has no direct comments on the reports themselves. Please be advised that following our next inspection of the state-regulated dam at the Apache site (tentatively scheduled for December 2009), we will review the current earth fissure mitigation plan in light of more recent findings related to fissure monitoring and identification at other Arizona damsites.

Mike

Michael Johnson, Ph.D., P.E.  
Assistant Director, Surface Water Division  
Arizona Department of Water Resources  
(602) 771-8659  
mjohnson@azwater.gov

From: "Mel P. Bunkers" <Bunkers.Mel@azdeq.gov>  
To: James Kohler/DC/USEPA/US@EPA  
Date: 11/20/2009 11:43 AM  
Subject: RE: Comment Request on EPA's Draft Coal Ash Impoundment Assessment Reports

Jim,

I have no comments at this time.

Thanks,

Mel Bunkers, Manager  
Hazardous Waste Inspections and Compliance Unit  
Arizona Department of Environmental Quality  
1110 W Washington Street  
Phoenix, Arizona 85007  
Phone: (602) 771-4556  
Fax: (602) 771-4132

**Company:**

See attached letter dated November 24, 2009 and four (4) enclosures (comment document, 0.5 PMP Event Design Basis, ADWR License of Approval, Three-foot freeboard support calculations).



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IX

75 Hawthorne Street  
San Francisco, CA 94105

November 17, 2009

MEMORANDUM

SUBJECT: Comments to *Draft Final* Specific Site Assessment for Coal Combustion Waste Impoundments at Arizona Electric Power Cooperative (AEP) Apache Power Plant, Prepared by GEI Consultants, Inc., dated October 2009

FROM: John Schofield, RCRA Enforcement Office

TO: James Kohler, P.E., Office of Resource Conservation of Recovery

The following are EPA Region IX, RCRA Enforcement Office comments to the referenced report:

1. Page 26, 7.2 Inflow Design. The term "PMP" should be defined.
2. Page 26, 7.2.1. The term "PMF" is used in the title of this report and the term PMP is used in the subsection of the report. The discussion of this subsection should be expanded to include relationship between PMP and PMF, and any calculations GEI performed to verify the PMF.
3. Page 39, 12.5. The condition of the management units in this section of the report was determined by GEI Consultants, Inc. (GEI) as "Fair." It is not clear from the report what observations/findings were the basis of GEI's condition assessment determination. Recommend that GEI summarize which findings/observations lead to the company's condition determination.



# Arizona Electric Power Cooperative, Inc.

P.O. Box 670 • Benson, Arizona 85602-0670 • Phone 520-586-3631

VIA E-MAIL

November 24, 2009

Mr. Stephen Hoffman  
Office of Resource Conservation and Recovery (5304P)  
U. S. Environmental Protection Agency  
1200 Pennsylvania Avenue, NW  
Washington, D.C. 20460

**RE: AEPCO RESPONSE TO EPA SITE ASSESSMENT REPORT**

Dear Mr. Hoffman:

Arizona Electric Power Cooperative, Inc. appreciates the opportunity to review and comment on the "Draft Final – Specific Site Assessment for Coal Combustion Waste Impoundments at Arizona Electric Power Cooperative (AEPCO) Apache Power Plant" (the "Assessment") completed by GEI Consultants, Inc in October 2009.

AEPCO appreciated the opportunity to have the U.S. Environmental Protection Agency (EPA) on site for the inspection. AEPCO has always and will continue to maintain a high performing facility to ensure the safety of our employees and neighbors are first priority. Given our excellent compliance history and proven track record, as well as GEI's verbal assessment of our facility following the inspection, AEPCO respectfully requests that the Assessment be revised to rate our facility "Satisfactory," as further discussed in our attached comments. We look forward to working with EPA and its consultants during this review period.

If you have questions regarding the content of these comments, please contact me at 520-586-5122 or [mfreeark@ssw.coop](mailto:mfreeark@ssw.coop).

Sincerely,

Michelle R. Freeark  
Manager of Environmental Services

Attachments

cc: File: CERCLA/EPA Ash Pond Inspection/2009 w/ enc.

## **AEPCO Comments on GEI Draft Report**

Specific Site Assessment for Coal Combustion Waste Impoundments  
Arizona Electric Power Cooperative (AEPCO) Apache Power Plant  
Cochise, AZ

Dated October 2009

### **Page 1, Section 1.1**

General Comment – Please note that the impoundments are referred to by GEI as AP1, AP2, AP3, AP4, SSP1, and SSP2. All AEPCO documentation uses Ash 1, Ash 2, Ash 3, Ash 4, Scrub1, and Scrub 2. This may be confusing to anyone referencing both GEI and AEPCO documents in the future.

### **Page 6, Section 2.7 – Second paragraph**

Change the third sentence to read “An old ash and scrubber waste disposal facility that is no longer in service has been closed through Arizona DEQ and the ADWR Flood Warning and Dam Safety Section.”

### **Page 8, Section 3.0 – First paragraph**

Change the third sentence to read “An old ash and scrubber waste disposal facility that is no longer in service has been closed through Arizona DEQ and the ADWR Flood Warning and Dam Safety Section.”

### **Page 8, Section 3.0 – Fourth paragraph**

Need to clarify sixth sentence – the site had not been disturbed except for surface farming.

### **Page 13, Section 6.2 – Seventh sentence**

Correct the description of Ash Pond 1 to be consistent with Ash Pond 2 description in section 6.3, page 15. The bottom of the cell is lined with a 60-mil HDPE liner and the sides are lined with 80-mil HDPE.

### **Page 24, Section 6.9.4**

AEPCO suspects that minor damage has been caused by vandalism and wildlife. Additionally, the report mischaracterizes the condition of the SSP2 Liner. AEPCO indicated to GEI that there has been minor damage to the SSP2 Liner in the past which has been properly repaired by outside vendors. The report, however, states that there are similar instances of damage to the lining of the other ponds. This language should be revised to more accurately reflect the condition of the liners by replacing the sentence referring to “other ponds” with the following: “AEPCO indicated during the inspection that there had been minor damage to the SSP2 Liner only.”

### **Page 26, Section 7.2 – First paragraph**

Spell out PMP acronym for first time use.

### **Page 26, Section 7.2 – Second paragraph**

GEI states that the ponds were designed to hold the 11.2 inch NOAA Probable Maximum Precipitation (PMP) Event. This statement is incorrect. The correct design value was ½ PMP (see attached Burns & McDonnell sheet). Additional freeboard adequacy calculations, performed in 1997 at ADWR's request, are attached herein. The calculations illustrate that a three-foot-freeboard is adequate to contain a 9.6 inch rain event (more than a ½ PMP Event), including wind tide and wave heights generated from 55 mph winds without overtopping the dike crests. The facility is permitted to operate at a three-foot-freeboard (evaporation pond freeboard is 3.5 feet) by the Arizona Department of Water Resources (License number 02.03) and the Arizona Department of Environmental Quality (Aquifer Protection Permit number P-101494). A copy of the ADWR License of Approval, with freeboard levels specifically stated on the permit, is attached herein. Any language suggesting that the facility does not maintain adequate freeboard should be deleted. This comment applies to Sections 7.2.2 and 7.4 later in the report.

**Page 26, Section 7.2.3 – First Sentence**

Rewrite the first sentence to read “A simplified dam break analysis and inundation mapping was completed by Burns & McDonnell for the facility.”

**Page 28, Section 8.2 – Second bullet**

Correct first sentence to read “In 1974, Burns & McDonnell performed a subsurface investigation at the location of the proposed power plant for steam units 2 & 3.”

Second sentence appears to be missing reference to a specific report.

**Page 28, Section 8.2 – Third bullet**

Last sentence appears to be missing reference to a specific report.

**Page 30, Section 8.5 – Table 8.1**

Rapid Drawdown – Water Depth at 27 feet is reported to have a FOS of 0.74. These calculations were performed assuming the facility had no HDPE liner in place. This FOS is increased considerably by the HDPE liner being in-place on the upstream sideslope, as indicated by GEI's statement in the second paragraph of Section 8.8.1.

**Page 33, Section 9.3 – First sentence**

GEI states that the entire project is patrolled daily by APS personnel. AEPCO is confused by this reference to APS, and is concerned that GEI has confused AEPCO's facility with Arizona Public Service's ash pond facilities. Additionally, the AEPCO facility is patrolled every two hours by security personnel and on a daily basis by operations.

**Page 34, Section 10.0 – Fourth paragraph**

General Comment – Please note that the cooling tower blowdown is referred to by GEI as CTB. All AEPCO documentation uses CTBD. This may be confusing to anyone referencing both GEI and AECPO documents in the future.

**Page 36, Section 11.1.3 – First paragraph**

Refer to Section 7.2 comments above.



**Page 38, Section 12.3**

GEI states AEPCO needs to address inadequate freeboard. Refer to Section 7.2 comments. GEI states that automatic pump shutoff controls should be provided. AEPCO feels it would be of little benefit to install automatic pump shutoff controls compared to the cost of installation and maintenance. Normal operation of the ash ponds includes recirculation of pond water to the plant to sluice ash back to the ponds. This operation method ensures that outflow always equals or exceeds inflow to the ash ponds. Normal scrubber slurry waste disposal flows to the scrubber waste storage ponds are 100 gallons per minute (gpm). Although this water is not recycled, it would required 41 hours at normal disposal flow rates to the one active scrubber waste storage pond to raise the pond level one foot. However, AEPCO is investigating using the common Ash Pond Recirculation Water sump for passive freeboard level control. Excess water from Ash Ponds 1 & 2 would overflow to Ash Ponds 3&4 which are not currently in-service and have a large freeboard available. In the same manner, AEPCO is investigating using a standpipe attached to the HDPE piping between Scrubber Ponds 1 & 2 to send excess water to Scrubber Pond 2 which is not currently in-service and has a large freeboard available. Any language suggesting that the facility does not maintain adequate freeboard should be deleted.

**Page 38, Section 12.4**

Section titled “Any New or Additional Monitoring Instruments...” - paragraph 1 – These comments are not new or additional to what AEPCO is already performing. This paragraph should be deleted. Third paragraph – GEI has recommended installing observation wells or piezometer instrumentation. These items are not normally designed into or installed in ash ponds by consulting engineering firms. These items are usually installed after leaks, pooling or seepage is discovered. Each dike of the AEPCO facility is a dam, and as such, observation wells and piezometers would need to be installed along all exterior and interior dikes. AEPCO believes this to be a generic comment by GEI. If seepage, water pooling at dike toes, or significant HDPE liner leaks are discovered in the future, AEPCO would then consider installation of observation wells or piezometer instrumentation.

**Page 39, Section 12.5**

Section 11.2 of the GEI report states that “The seven impoundment dams were generally found to be in satisfactory condition”. In Section 12.5, GEI give the ponds a “FAIR” rating. Verbal comments from GEI personnel in the site meeting and inspections, including the debrief, indicated that the ponds were satisfactory. AEPCO is confused that GEI gave a satisfactory rating to the facility in the exit debrief, refers to the facility as satisfactory in Section 11.2, and then assesses the ponds as “FAIR” in Section 12.5. The ADWR Flood Warning and Dam Safety Section report dated December 19, 2008, states that there are no existing safety deficiencies with the AEPCO facility. AEPCO maintains that our facility should be assessed “SATISFACTORY”, based upon GEI’s verbal comments, report text, and AEPCO’s highly performing staff, operations, maintenance, testing program, and past record with permitting agencies. As such, the report should be revised to assess the facility as “Satisfactory” consistent with GEI’s verbal assessment and the facility’s performance.



**Appendix B**

Coal Combustion Waste (CCW) Impoundment Inspection Form for Ash Pond No. 1, 2, 3, 4 and Scrubber Waste Storage Ponds – page 3 – Liner Permeability for clay is incorrect. Correct permeability is  $1 \times 10^{-6}$  cm/s.

Coal Combustion Waste (CCW) Impoundment Inspection Form for Ash Pond No. 1, 2, 3, 4 and Scrubber Waste Storage Ponds – page 4 – Impoundment design date is incorrect. Correct date is 1994.

## 6.0 FREEBOARD CAPACITY FOR A 0.5 PMP STORM EVENT

The probable maximum precipitation (PMP) depth for this area in Arizona is approximately 11.2 inches based on information in the National Oceanic & Atmospheric Administration (NOAA) Hydrometeorological Report No. 49. The 0.5 PMP would be approximately 5.6 inches. All of the ponds are designed to exclude offsite runoff from entering and to maintain a minimum freeboard of 3 feet. Therefore, if the 0.5 PMP were to occur, there exists adequate freeboard to prevent discharge over the dike crest.

77 walking / 100m


XC: 92300/- Permits  
923001- Corp. Rec.

## ARIZONA DEPARTMENT OF WATER RESOURCES

### Dam Safety Section

500 North Third Street, Phoenix, Arizona 85004-3903  
Telephone (602) 417-2445  
Fax (602) 417-2423

August 26, 1997



Chuck: please let me know what you would like to do with the original gold seal license.

Thanks

Chuck Reece  
x 5120

Mr. Charles S. Reece IV, P.E.  
Arizona Electric Power Cooperative, Inc.  
Post Office Box 670  
Benson, Arizona 85602-0670

Subject: Apache Station Ash/Scrubber Waste Disposal Facility Dam (02.03)  
License of Approval

Dear Mr. Reece:

All statutory requirements in connection with the construction of the Apache Station Ash/Scrubber Waste Disposal Facility Dam have now been satisfied. Accordingly, enclosed is a License of Approval to operate the dam. The license outlines the terms and conditions, discussed with you by telephone, under which continued operation of the dam is permitted. This license supersedes any previous operating consent issued by the Department.

During the course of normal operation of your dam, Department engineers will inspect it periodically to confirm that it is being operated and maintained properly. We will contact you in advance of each regularly scheduled inspection to coordinate a mutually satisfactory inspection date. The next regular inspection is currently scheduled for November 1998. In the interim, please contact us immediately should you observe any unusual or alarming circumstances that may adversely affect the safety of the dam.

You may contact Mike Greenslade of our Flood Warning and Dam Safety Section at (602) 417-2400, Extension 7188, if you have any questions. Thank you for your cooperation.

Sincerely,

Dan Roger Lawrence, P.E.  
Manager  
Dam Safety Section

Enclosure

CC: Donald W. Kimball, AEPCO w/o encl

COPY



State of Arizona  
DEPARTMENT OF WATER RESOURCES

# *LICENSE OF APPROVAL*


*Pursuant to Title 45 - Waters, Chapter 6, Article 1, of the Arizona Revised Statutes, the DIRECTOR, Department of Water Resources issues this License of Approval to:*

ARIZONA ELECTRIC POWER COOPERATIVE, INC.

*Authorizing the use of:* APACHE STA. ASH/SCRUBBER WDF *Dam and Reservoir, File Number:* 02.03

*Located in Section 4, Twp. 16S, Rge. 24E, G. & S.R. B. & M., COCHISE County, State of Arizona, to impound water in accordance with and subject to the following conditions:*

1. The maximum operating water levels shall be: Ash Disposal Pond Cells at elevation 4213.0 ft.; Scrubber Sludge Pond Cells at elevation 4223.0 ft.; Evaporation Pond at elevation 4212.5 ft.
2. An instrumentation monitoring report shall be submitted to ADWR annually in February in accordance with the approved "Embankment Dikes Monitoring Plan", dated December 12, 1996.



*This License of Approval supersedes every previous consent for use issued by the State of Arizona relative to said dam and reservoir.*

*Witness my hand and seal of the Arizona Department of Water Resources*

this 25th day of AUGUST, 1997

*Darrell Jordan*  
Darrell Jordan  
Assistant Director  
Surface Water Management Division

COPY



# Arizona Electric Power Cooperative, Inc.

P.O. Box 670 • Benson, Arizona 85602-0670 • Phone 520-586-3631

May 27, 1997

Mr. William C. Jenkins, P.E.  
Arizona Department of Water Resources  
500 N. 3rd St.  
Phoenix, AZ 85004

RE: COMBUSTION WASTE DISPOSAL FACILITY W.O. 923001/933148  
PROJECT NO. 91-033-1-010  
CONTRACT 923001-2 - POND AND APPURTENANCES CONSTRUCTION  
INDIVIDUAL POND WAVE HEIGHT, SETUP, & RUNUP CALCULATIONS

Dear Mr. Jenkins:

In accordance with your Mr. Gerald Cox's request, enclosed are the subject matter. These are in support of AEPCO's request to allow a maximum reservoir height of three feet below the dike crest (4213' for ash disposal & 4223' for scrubber sludge disposal ponds) for all disposal ponds, with exception of the evaporation pond. Please review these calculations at your earliest convenience and let me know at (520)586-5120 should you have any questions or need additional information concerning the issuance of an Approval to Operate for the Facility.

Sincerely,

Charles S. Reece IV, P.E.  
Mechanical Engineer

enc

xc C. Davis, w/o enc  
L. Huff, w/o enc  
rt G. Grim, w/enc  
C. Walling, w/enc  
File 923001-ADWR, w/enc

S:\POWER\GENENGR\CHUCK\923001\ADWR\WAVEHGT.WPS



Significant wave height

$$Z_w = 0.034 V_w^{1.06} F^{0.47} \text{ (2)}$$

where  $Z_w$  = average height of highest  $\frac{1}{3}$  wave $V_w$  = wind velocity (miles/hr) = 55 mph (1) $F$  = fetch (miles)

$Z_w$ Table		Fetch		$Z_w$ (ft)
		(ft)	(miles)	
Ash Pond	1	1,560	0.295	1.34
	2	1,570	0.297	1.34
	3	1,700	0.322	1.40
	4	1,870	0.354	1.46
Scrubber Pond	1	1,880	0.356	1.46
	2	1,880	0.356	1.46

Add wind tide to wave height calculations  
for maximum wave height and runup  
See page 2 for wind tide calcs.

originals to  
file, copies  
to ADWR

Wind tide or set-up calculation

$$S = \frac{U^2 F}{1,400 D} \quad (3)$$

where  $S$  = wind tide (feet)  
 $U$  = avg. wind velocity (mph)  
 $F$  = fetch (miles)  
 $D$  = avg depth along fetch line (feet)

(see previous pages for wind vel. & fetch)

S Table	Avg Depth Along Fetch (ft)	Wind Tide (feet)
Ash Pond 1	27	0.02
2	27	0.02
3	27	0.03
4	27	0.03
Scrubber Pond 1	11	0.07
2	13	0.06

Add wind tide height to wave height calculation

Calculation of wave period & wave length

$$T_w = 0.46 V_w^{0.44} F^{0.28}$$

where  $T_w$  = wave period

$$\lambda = 5.12 T_w^2$$

where  $\lambda$  = wave length (feet)



Calc table

		$T_w$	$\lambda$	$Z_w/\lambda$
Ash Pond	1	1.91	18.7	0.07
	2	1.91	18.7	0.07
	3	1.95	19.5	0.07
	4	2.01	20.6	0.07
Scrubber Pond	1	2.01	20.6	0.07
	2	2.01	20.6	0.07

Embankment slope =  $1/3 = 0.333$

From Figure 7.13 ②

Relative Run up  $\frac{Z_r}{Z_w} = 1.48$

thus  $Z_r = \text{wave runup (vert)} (ft)$

$Z_r = 1.48 (Z_w + S)$  (see next page for S)

$Z_r$ table	$Z_w$ (ft)	$S$ (ft)	$Z_r$ (ft)	IDF (ft)	Pond Height Below Crest (IDF + $Z_r$ ) (ft)
Ash Pond 1	1.34	0.02	2.01	0.8	2.81
2	1.34	0.02	2.01	0.8	2.81
3	1.40	0.03	2.12	0.8	2.92
4	1.46	0.03	2.21	0.8	3.01
Scrubber Pond 1	1.46	0.07	2.26	0.8	3.06
2	1.46	0.06	2.25	0.8	3.05

Note: IDF is maximum inflow design flood which is  $1/2$  of predicted maximum precipitation or 0.8 ft

From the previous calculations, it may be concluded that a maximum pond level of three feet below the crest will not produce waves which overtop the dike. Maximum pond heights would be 4213' (4216-3) and 4223' (4226-3) for ash and scrubber sludge disposal ponds, respectively.

(see B&M Design Notes & Analysis for Comb. Waste Disposal Facility for Evaporation pond wave runup calculations)

#### References:

- ① B&M Design Notes & Analysis for ooo Ponds
- ② Water Resources Engineering
- ③ Hand book of Applied Hydraulics



7.2 WAVE RUNUP

WAVE RUNUP CALCS

ASSUMPTIONS: - 55 MPH DESIGN WIND SPEED  
- FETCH LENGTH  $\approx 2800$  L.F. = 0.53 MILES  
- PREVAILING WIND DIRECTION = SOUTHEAST TO NORTHWEST  
- DESIGN SOURCE "WATER-RESOURCES ENGINEERS"

SIGNIFICANT WAVE HEIGHT

$$Z_w = 0.034 V_w^{1.06} F^{0.47}$$

$V_w$  = WIND VELOCITY

$F$  = FETCH (IN MILES)

$$= 0.034 (55)^{1.06} (0.53)^{0.47}$$

$Z_w$  = MAX HEIGHT OF HIGHEST 1% OF WAVES

$$= 1.76 \text{ FT} = \text{SIGNIFICANT WAVE HEIGHT}$$

MINIMUM TIME DURATION OF WIND VELOCITY = 10 MIN

RELATIVE RUN-UP

$$\text{Wave Period} \rightarrow T_w = 0.46 V_w^{0.44} F^{0.28}$$

$$= 0.46 (55)^{0.44} (0.53)^{0.28}$$

$$= 2.25 \checkmark$$

$$\text{WAVE LENGTH} \rightarrow \lambda = 5.12 T_w^2$$

$$= 5.12 (2.25)^2$$

$$= 25.92 \checkmark$$

$$\text{VALUE OF } \frac{Z_w}{\lambda} = \frac{1.76}{25.92} = 0.068 \approx 0.07 \checkmark$$

$$\text{EMBANKMENT SLOPE} = \frac{1}{3} = 0.333 \checkmark$$

FROM FIGURE 7-13

$$\text{RELATIVE RUN-UP } \frac{Z_r}{Z_w} \approx 1.48$$

$$\text{VERTICAL HEIGHT OF RUNUP} = Z_r = 1.48 (1.76) = 2.6 \checkmark$$

$$\text{LENGTH OF RUNUP ALONG SLOPE} = 2.6 (3) = 7.8 \checkmark$$






FIG. 7-13. Wave run-up ratios versus wave steepness and embankment slopes. (From Saville, McClendon, and Cochran.)

rubble mounds. Height of run-up  $z$  is shown as a ratio  $z'/z_0$  and is dependent on the ratio of wave height to wavelength (wave steepness). Wavelength  $\lambda$  may be computed from

$$\lambda = 5.12t_w^2 \quad (7-4)$$

where the wave period  $t_w$  is given by

$$t_w = 0.46V_w^{0.44}F^{0.28} \quad (7-5)$$

TABLE 7-2. Per Cent of Waves Exceeding Various Wave Heights Greater than  $z_0$

(After Saville, McClendon, and Cochran)

$z'/z_0$ .....	1.67	1.40	1.27	1.12	1.07	1.02
Per cent of waves $> z'$ .....	0.4	2	4	8	10	12

## OTHER MCGRAW-HILL HANDBOOKS OF INTEREST

AMERICAN SOCIETY OF MECHANICAL ENGINEERS - ASME Handbook—Metals Properties  
 AMERICAN SOCIETY OF MECHANICAL ENGINEERS - ASME Handbook—Engineering Tables  
 BATHURST AND MARKS - Standard Handbook for Mechanical Engineers  
 BRADY - Materials Handbook  
 CALENDER - Time-Saver Standards  
 CARRIER AIR CONDITIONING COMPANY - Handbook of Air Conditioning System Design  
 COXOVER - Grounds Maintenance Handbook  
 CROCKER AND KING - Piping Handbook  
 CROFT AND GARR - American Electricians' Handbook  
 EMBERT - Handbook of Mechanical Specifications for Buildings and Plants  
 EMBERT - Heating Handbook  
 FACTORY MUTUAL ENGINEERING DIVISION - Handbook of Industrial Loss Prevention  
 FINK AND CARROLL - Standard Handbook for Electrical Engineers  
 FRIEDL - Petroleum Production Handbook  
 GAYLORD AND GAYLORD - Structural Engineering Handbook  
 GUTHRIE - Petroleum Products Handbook  
 HANNA - Handbook of Noise Control  
 HANNA AND CRUDE - Shock and Vibration Handbook  
 HETTEL - The Foreman's Handbook  
 HUSKEY AND KORN - Computer Handbook  
 KATZ - Handbook of Natural Gas Engineering  
 KING AND BEATER - Handbook of Hydraulics  
 KLEINER AND KUHN - Digital Computer User's Handbook  
 KORN AND KORN - Mathematical Handbook for Scientists and Engineers  
 LA LONDE AND JAMES - Concrete Engineering Handbook  
 MACHILL, HOLDEN, AND ACKLEY - Air Pollution Handbook  
 MARAS - National Plumbing Code Handbook  
 MANTUEL - Engineering Materials Handbook  
 MERRITT - Building Construction Handbook  
 MERRITT - Standard Handbook for Civil Engineers  
 MOOREY - Petroleum Exploration Handbook  
 MOUNOW - Maintenance Engineering Handbook  
 MULLIGAN - Handbook of Brick Masonry Construction  
 MYERS - Handbook of Ocean and Underwater Engineering  
 PERRY - Engineering Manual  
 ROSSIGNOL - Handbook of Rigging  
 STANTIAH - Plant Engineering Handbook  
 STETKA AND BRANDON - NFPA Handbook of the National Electrical Code  
 STREETER - Handbook of Fluid Dynamics  
 STUBBS - Handbook of Heavy Construction  
 TIMBER ENGINEERING CO. - Timber Design and Construction Handbook  
 URSQUANT - Civil Engineering Handbook  
 WOODS - Highway Engineering Handbook

# HANDBOOK OF APPLIED HYDRAULICS

**CALVIN VICTOR DAVIS** *Editor-in-Chief*  
*Chief Technical Advisor, Harza Engineering Company, Chicago*

**KENNETH E. SORENSEN** *Co-Editor*  
*Vice President, Harza Engineering Company, Chicago*

THIRD EDITION

MCGRAW-HILL BOOK COMPANY

New York    St. Louis    San Francisco    London    Sydney  
                  Toronto    Mexico    Panama



15. Application of Stochastic Approach. The use of the stochastic approach can be demonstrated by studies for a river in the Philippines. In that basin there were no runoff or precipitation data available for a large portion of the 1941-1949 period, with appreciable periods of record both before and after that time. Accordingly, the normal procedure for bridging the gap in data by correlating runoff with precipitation was not possible.

The storage reservoir proposed for this basin is of the holdover type, with several years of drawdown between reservoir fillings. Because of this, it was essential that the sequence of runoff for consecutive years be representative. The assumption that the record prior to 1941 would be continuous with the record starting in 1949 would be open to serious question. Accordingly, it was concluded that the best procedure would be to consider water supply on a stochastic basis.

In the stochastic analysis new sequences of historical flows were generated, utilizing the historical flow data as the basis. Normal distribution of the historical values about the mean was assumed in this analysis, except for certain controls that were placed on the sequence of monthly events. This control was developed by plotting successive monthly flows, one against the other, to develop serial correlations of successive monthly flows.

The generation of monthly streamflows, as well as operation studies necessary to estimate the dependable outflow, was by use of the digital computer. The drawdown was determined for four assumed controlled outflows by the digital computer, for several 100-year series of generated streamflow, and the resulting drawdowns were averaged. The results, expressed in terms of 0.1 percent, 1.0 percent, and 5.0 percent probabilities of occurrence, are shown in Fig. 8. Three curves furnished a basis for selection of the probability of a shortage in water supply that could be tolerated in design of the reservoir.

# RESERVOIR WAVE ACTION

16. Freeboard Allowances. The term "freeboard" is frequently used in different ways. As defined previously, freeboard must include consideration of the following:

1. Height of wind tide (referred to also as setup)
2. Height of waves in deep water generated by winds
3. Effect of wave run-up on sloping embankments on behalf of waves
4. Any additional margin of safety considered necessary

Final design decisions on freeboard allowances usually involve consideration of the type of dam, the situation governing the spillway design flood, and the effect of waves. This section is concerned only with wave action. An excellent article by Saville,




Fig. 8. Reservoir drawdown in critical period.

## RESERVOIR HYDRAULICS

of a variety of sequences of monthly and annual inflows (Lambert, et al.). Thus a variety of which gives an evaluation of the probabilities may be considered, the sum total of which gives an evaluation of the probabilities involved.

There is an inherent psychological advantage to the stochastic approach, since the results must be expressed in terms of probabilities. This discourages a false sense of security that the design drought period will not be exceeded in severity—a feeling which can easily be obtained when the basis of design is the most critical period of record.

The stochastic approach is under rapid development. Although the basic philosophy, theories, and some procedural matters have been worked out, much remains to be done in the development of specific procedures before the approach can be considered to be fully operational. The classic work in this field was performed by Thwaites, followed by highly significant work by Langbein<sup>1</sup> and Fiering.<sup>2</sup>

To utilize the stochastic approach, it is necessary to develop several statistical parameters. These include the values of mean flow, measures of the variability of individual occurrences from the mean, and correlations between flows during previous periods and the flow during following periods. Although techniques for these analyses are undergoing rapid change, reference by the reader to the writings of the pioneer investigators referred to will provide basic background on the details of procedures that may be used.

After the statistical parameters are developed, they may be used to select random values of streamflow. This is the equivalent of "pulling historically observed streamflows from a hat," with proper constraints being applied to assure that unrealistic results will not be obtained. These constraints include such factors as the limitation on minimum flow that will be randomly selected (obviously it cannot be less than zero and usually it will be more) and the effect of the runoff from a previous period on the otherwise randomly selected runoff of a following period.

In using the stochastic approach it is necessary to decide on the number of years of record that should be generated and analyzed. While the number of years required to produce a result which has a certain probability of accuracy is undoubtedly subject to mathematical analysis, procedures have not yet been developed for this determination. Some investigators have arbitrarily utilized a 100-year generated record, but in some instances comparison of two separately generated 100-year periods has resulted in substantially different storage requirements.

Whatever the period of record that may be generated, it can be done most expeditiously and economically by use of a digital computer. Programs are available for this purpose, and these usually can be combined expeditiously with programs for analysis of the performance of the reservoir in meeting a variety of storage and delivery requirements.

The use of stochastic procedures, through development of a stochastic model, should not be interpreted as ignoring of historical data. Historical data are used to develop means, parameters of variability of flow, and relationships between successive flow periods. The only element of historical occurrences which is given small importance is the sequence of flows. This, however, is highly desirable since the historical sequence represents only one of many possibilities of sequence. The stochastic approach attempts, therefore, to put the historical sequence into proper perspective as to its probability of recurrence.

<sup>1</sup> Hurst, H. R. Long Term Storage Capacity of Reservoirs, Trans. ASCE, 1951, pp. 770-808.  
<sup>2</sup> Linsley, W. H., Queuing Theory and Water Storage, Proc. ASCE, Paper 1811, October, 1958.  
<sup>3</sup> Langbein, W. H., and N. C. Matlack, Information Content of the Mean, J. Geophysical Res., August, 1962.  
<sup>4</sup> Fiering, M., and M. D. Yevjevich, Queuing Theory and Simulation in Reservoir Design, Trans. ASCE, 1959, vol. 1, pp. 1114-1144.



McClendon, and Corbitt<sup>1</sup> and a manual by the U.S. Corps of Engineers<sup>2</sup> form the basis of procedures given in this section for computing waves.

17. **Basic Assumptions.** A number of formulas have been developed for computation of heights of wind tide, waves, and run-up. Most of these involve use of wind velocity and fetch as basic parameters. While the different formulas will yield different results, the variation between formulas is frequently not so great as the variation possible in results that are due to assumptions as to wind velocity and fetch. Thus, the development of reasonable assumptions is of prime importance.

The magnitude of wind tide, wave height, and run-up will vary with the magnitude of wind velocity and the duration of that velocity. Thus, it is desirable to develop wind data on a duration basis, if possible. The proper combination of velocity and duration is not always subject to precise determination, although procedures are available in the computation of wave heights for determining the minimum required time to reach maximum wave heights. Frequently, maximum wave conditions will not result unless the duration is in the order of 1 hr. Therefore, in wind-tide calculations the maximum observed 60-min average wind is frequently taken as the first trial for design. This assumption then can be checked against the values of wind tides derived as described later.

Care should be taken to utilize only those wind conditions considered possible of occurrence at the same time or immediately following the meteorological conditions causing the pool level under consideration. For example, if the spillway design storm is not of the hurricane type, the winds used to compute frequency allowances should not be of the hurricane type.

**Fetch.** Fetch length is the horizontal distance of open water surface over which the wind blows. The use of the greatest straight-line distance over open water in wave computations will result in computed wave heights that are too high, since the amount of adjoining open water having shorter but significant fetches influences the winds. Observations on artificial reservoirs have indicated that use of an "effective fetch" is more reliable. The effective fetch is computed by dividing the 45° angle on either side of the maximum fetch line into about 15 equal segments, multiplying the fetch length for each segment by the cosine of the angle of deviation from the maximum fetch line, and dividing the sum of the products by the sum of the cosines.

Wind velocities over water are generally higher than over land under comparable meteorological conditions, because of lesser roughness. The following values represent averages observed on artificial reservoirs:

Fetch, miles.....	0.5	1.0	2.0	3.0	4.0	5.0 (or over)
Wind ratio over water over land	1.08	1.13	1.21	1.26	1.28	1.30

The maximum potential wind velocity may not always coincide in direction with the direction of maximum fetch. If observations of maximum winds of given directions are available, the use of the effective fetch length can be carried one step further, utilizing the appropriate design wind velocities with the fetches indicated.

18. **Wind Tide.** Wind tide, or "setup," is the piling up of water at the leeward end of an enclosed body of water, as a result of the horizontal stress on water exerted by the wind. The magnitude of wind tide can be expressed by the following modification:

<sup>1</sup> SAYLER, THOMAS J., ELSON W. McCLENDON, and ALBERT L. CORBITT, *Freeboard Allowances for Waves in Inland Reservoirs*, Trans. ASCE, 1933, pt. IV, pp. 140-220.  
<sup>2</sup> Waves in Inland Reservoirs, Tech. Mem. 132, Beach Erosion Board, U.S. Corps of Engineers, November, 1962.

cation of the Zelder Zee formula:

$$S = \frac{U^2 F}{1,400 D} \quad (3)$$

in which  $S$  is the wind tide (in feet) above still water,  $U$  is average wind velocity (in statute miles per hour) over the fetch distance  $F$  (in miles), and  $D$  is the average depth of water along the fetch line (in feet).

19. **Wave Height and Other Characteristics.** Wind-generated waves in a large body of water are not uniform in height. Successive waves will not be identical—each wave will be preceded and succeeded by a higher or lower wave. Data obtained from recordings of 45-storm periods at Fort Peck and Davison reservoirs have shown a very close comparison between the observed frequency distribution of wave heights on inland reservoirs with observed data on oceans. The following characteristics have been observed for the spectrum of waves observed at a given time and place:

% of total number of waves averaged to compute specific wave height $H$	Ratio of $H$ to average wave height $H_{ave}$	Ratio of $H$ to significant wave height $H_s$	% of waves exceeding $H$
1	2.88	1.67	0.4
5	2.34	1.40	2
10	2.03	1.27	5
33½	1.60	1.00	43
50	1.42	0.89	20
100	1.00	0.82	40

The significant wave height  $H_s$  is defined as the average height of the highest one-third of all waves in a spectrum. As will be seen from the above tabulation, 13 percent of all waves can be expected to exceed  $H_s$ . These values would be reached at the end of a buildup period and give measures of the variations that can be expected in wave-height distributions.  $H_s$  may be computed by the set of curves in Fig. 9. Knowing the effective fetch and the wind velocity, the curve can be entered with these values to give the minimum time duration and value of  $H_s$ .

Once the value of  $H_s$  is computed, the occurrence frequency of a wave of any height can be computed from the preceding tabulation. The design height for waves  $H$  can be selected on the basis of consideration of frequency of winds of a given magnitude, duration of winds, and frequency of waves of given size. The finally selected design height must be a judgment value, involving consideration of the type of dam involved, as well.

20. **Wave Run-up on Slopes.** A wind-generated wave will be influenced when it runs up the slope of an embankment. The effect may be either to increase or to decrease the height of the wave in relation to the still-water surface, depending on wave characteristics and the slope, roughness, and permeability of the embankment. Therefore, the effect of run-up is usually combined with the actual wave height in computing allowances for wave action, into a single item designated as wave run-up height  $R$ .

In this sense  $R$  is the vertical distance between the maximum elevation obtained by a wave running up an embankment and the water elevation at the toe of the slope. The water elevation at the toe of the slope is the still-water elevation plus wind tide. Because of the relationship between wave height and run-up, it usually is convenient to compute run-up as a function of wave height.



## RESERVOIR HYDRAULICS




FIG. 9. Generalized correlations of significant wave heights  $H_s$  with related factors (deep-water conditions). Solid lines represent significant wave heights, in feet; dashed lines represent maximum wave heights, in feet. Required for generation of wave heights indicated for corresponding wind velocities and fetch distances. (Seech *Exposition*, 1924, U.S. Corps of Engineers, Tech. Mem. 132.)




FIG. 10. Generalized relations between wave periods ( $T$ ) and related factors (deep-water conditions). (Seech *Exposition*, 1924, U.S. Corps of Engineers, Tech. Mem. 132.)

## RESERVOIR WAVE ACTION

The wave characteristics are represented by the wave steepness ratio  $H_s/L_0$ , where  $H_s$  = significant wave height and  $L_0$  = wave length, measured from crest to crest, in deep water.  $H_s$  may, for practical purposes in deep reservoirs, be taken as equal to  $H$ .  $L_0$  may be computed from the following formula:

$$L_0 = 5.12T^2 \quad (4)$$

where  $T$  is the wave period, which may be determined from Fig. 10. The wave period is approximately the same for waves ranging between the significant wave  $H_s$  and




FIG. 11. Wave run-up ratios vs. wave steepness and embankment slopes. (From ASCE, vol. 128, 217, 1963.)

the maximum wave  $H_{max}$ . Thus, in deep water the  $L_0$  determined for the wave steepness ratio can be used for any value of  $H$  between  $H_{max}$  and  $H_s$ . Deep-water conditions can be considered to be present when the depth at the toe of the slope is more than one-third of the calculated wave length.

Using the values of  $H_s$  and  $L_0$ , the effect of run-up on wave height may be computed from Fig. 11. Curves are shown for smooth slopes and for rubble mounds. Smooth slopes include surfaces such as well-graded earth embankments covered with sand and gravel or concrete facing. Run-up on hand-placed riprap slopes approaches that computed for smooth slopes. Run-up on dumped riprap slopes can be considered to be about 50 percent of computed run-up on smooth slopes.