

US EPA ARCHIVE DOCUMENT

Comments on Sikeston Power Station:

EPA Comments:

None.

State Comments:

From: "Clay, Bob" <bob.clay@dnr.mo.gov>
To: James Kohler/DC/USEPA/US@EPA
Date: 07/08/2010 02:26 PM
Subject: RE: Comment Request on EPA Draft Assessment Report for Sikestown Power Station

Jim,
Thank you for including us on this. I have read the report and see nothing that particularly concerns me. Since the consultant did not seem to think there was a sense of urgency in repairing the slide gate valve operating stems, I presume this structure is not critical to the safety of the dikes. The recommendation for seismic stability analysis seems prudent. The analysis should include evaluation of liquefaction potential of the foundation soils. I do not think it is necessary for me to make any formal comments.

WATER RESOURCES CENTER
Bob Clay, P.E.
Chief Engineer, Dam and Reservoir Safety Program

-----Original Message-----

From: Kohler.James@epamail.epa.gov [mailto:Kohler.James@epamail.epa.gov]
Sent: Wednesday, July 07, 2010 10:50 AM
To: Cruise.Nicole@epamail.epa.gov; Clay, Bob
Cc: Hoffman.Stephen@epamail.epa.gov
Subject: Comment Request on EPA Draft Assessment Report for Sikestown Power Station

Dear Bob and Nicole:

We would like to offer Missouri and EPA Region 7 an opportunity to comment on the Draft Assessment Report for the facility below. You can access the report by following the link below. Please let me know if intend to comment. Thank you!

Jim

Jim Kohler, P.E.

Environmental Engineer
LCDR, U.S. Public Health Service
U.S. Environmental Protection Agency
Office of Resource Conservation and Recovery
Phone: 703-347-8953
Fax: 703-308-0514

Company Comments:

From: "Chester Cardwell" <ccard@sbmu.net>
To: James Kohler/DC/USEPA/US@EPA
Date: 07/29/2010 04:47 PM
Subject: RE: Comment Request on EPA Draft Assessment Report for Sikeston Power Station

Mr. Jim Kohler, P.E,

After reviewing the report with plant staff there was only one comment.
Our fly ash was pneumatically conveyed to the fly ash pond where it was
discharged under water.

Thank you,
Chester Cardwell
Plant Manager

Office (573) 475-3112
Mobile (573) 380-3611
Plant (573) 471-5000
Fax (573) 471-5003
email ccard@sbmu.net
Website: <http://www.sikestonbmu.org/sikestonpowerstation.htm>

Sikeston Power Station
Board of Municipal Utilities
1551 W. Wakefield Ave.
PO. Box 370
Sikeston, Missouri 63801-0370