

US EPA ARCHIVE DOCUMENT

<b>COMPANY</b>	Columbus Southern Power Company
<b>PLANT</b>	Conesville
<b>ASH MANAGEMENT UNIT</b>	Ash Pond Complex
<b>QUESTION 1</b>	
Dam Hazard Rating	Significant
Who Established Rating	Ohio DNR -- Div. of Water
Basis for Rating	Health Hazard
No Rating Assigned	N/A
<b>QUESTION 2</b>	
Year Commissioned	1972
Year(s) Expanded	N/A
<b>QUESTION 3 - Mark all that apply</b>	
Fly Ash	X
Bottom Ash	X
Boiler Slag	
Flue Gas Emission Control Residuals	X
Other (Specify)	
<b>QUESTION 4</b>	
Designed by P.E.	Not Available
Constructed under P.E. Supervision	Not Available
Inspection/monitoring under P.E. Supervision	Yes
<b>QUESTION 5</b>	
Date of Last Company Safety Assessment	10/27/2008
Describe Evaluator's Credentials	OH P.E.
Describe Past Followup Corrective Actions	Routine maintenance
Describe Credentials of Corrective Action Implementers	Under plant supervision
Describe Planned Followup Actions	Dam break analysis and EAP, stability evaluation, routine maintenance.
Date of Next Safety Assessment	2010
<b>QUESTION 6</b>	
Date of Last Regulatory Safety Inspection	12/22/2008
Agency Name	ODNR -- Div. of Water
Date of Planned Regulatory Safety Inspection	2013-2014
Agency Name	ODNR -- Div. of Water
Copy of Most Recent Regulatory Inspection Included	Yes (from 5/10/2000, 2008 rpt. not available)
<b>QUESTION 7</b>	
Safety Issues from Regulatory Inspections w/in Past Year	N/A
Corrective Actions	N/A
Documentation Included	N/A
<b>QUESTION 8</b>	
Surface Area (acres)	49.4 acres - The ash pond complex is a multi-pond system where other wastewaters are separately treated in contiguous cells. These pond complexes typically also include secondary (and in some cases tertiary) settling ponds for final "polishing" of effluent quality. The information provided is based on the entire impoundment as regulated under dam safety rules.
Total Storage Capacity	865 acre-ft
Volume Currently Stored	Variable - ash is routinely removed for use or disposal in dry landfill
Date of Volume Measurement	N/A
Maximum Height (feet)	35
<b>QUESTION 9</b>	
Spills or Unpermitted Release History (10 Years)	No
<b>QUESTION 10</b>	
All legal owner(s) and operator(s)	Columbus Southern Power Company, Cincinnati Gas & Electric Company, Dayton Power & Light Company