

US EPA ARCHIVE DOCUMENT

COMPANY	Public Service Company of Oklahoma	Public Service Company of Oklahoma	Public Service Company of Oklahoma
PLANT	Oklauinion	Oklauinion	Oklauinion
ASH MANAGEMENT UNIT	Pond #6	Pond #23	Sludge Pond
QUESTION 1			
Dam Hazard Rating			
Who Established Rating			
Basis for Rating			
No Rating Assigned	X	X	X
QUESTION 2			
Year Commissioned	1986	1986	1986
Year(s) Expanded			
QUESTION 3 - Mark all that apply			
Fly Ash	X	X	
Bottom Ash	X	X	
Boiler Slag			
Flue Gas Emission Control Residuals	X		X
Other (Specify)	Air preheater baskets		
QUESTION 4			
Designed by P.E.	Yes	Yes	Yes
Constructed under P.E. Supervision	Yes	Yes	Yes
Inspection/monitoring under P.E. Supervision	Yes	Yes	Yes
QUESTION 5			
Date of Last Company Safety Assessment	Routine inspections only, no formal safety assessment performed	Routine inspections only, no formal safety assessment performed	Routine inspections only, no formal safety assessment performed
Describe Evaluator's Credentials	N/A	N/A	N/A
Describe Past Followup Corrective Actions	None	None	None
Describe Credentials of Corrective Action Implementers	N/A	N/A	N/A
Describe Planned Followup Actions	N/A	N/A	N/A
Date of Next Safety Assessment	4/2/2009 (AEP considers this facility to be Low Hazard)	4/2/2009 (AEP considers this facility to be Low Hazard)	4/2/2009 (AEP considers this facility to be Low Hazard)
QUESTION 6			
Date of Last Regulatory Safety Inspection	None	None	None
Agency Name			
Date of Planned Regulatory Safety Inspection			
Agency Name			
Copy of Most Recent Regulatory Inspection Included			
QUESTION 7			
Safety Issues from Regulatory Inspections w/in Past Year	N/A	N/A	N/A
Corrective Actions			
Documentation Included			
QUESTION 8			
Surface Area (acres)	58 acres	13.3 acres	22.6 acres
Total Storage Capacity	1044 acre-ft	332.5 acre-ft	565 acre-ft
Volume Currently Stored	Approx. 850 acre-ft	Approx. 150 acre-ft	approx. 400 acre-ft
Date of Volume Measurement	9/26/2008	9/26/2008	9/26/2008
Maximum Height (feet)	24	0 - excavated pond	0 - excavated pond
QUESTION 9			
Spills or Unpermitted Release History (10 Years)	None	None	None
QUESTION 10			
All legal owner(s) and operator(s)	Texas North Generation Company LLC, Public Service Company of Oklahoma, Oklahoma Municipal Power Authority, Public Utilities Board Brownsville	Texas North Generation Company LLC, Public Service Company of Oklahoma, Oklahoma Municipal Power Authority, Public Utilities Board Brownsville	Texas North Generation Company LLC, Public Service Company of Oklahoma, Oklahoma Municipal Power Authority, Public Utilities Board Brownsville