

### UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

Office of Research and Development

Washington, D.C. 20460







#### ENVIRONMENTAL TECHNOLOGY VERIFICATION PROGRAM VERIFICATION STATEMENT

TECHNOLOGY TYPE:	PAINT OVERSPRAY AR	RESTOR	
APPLICATION:	CONTROL OF PARTICLE EMISSIONS FROM AEROSPACE PAINT SPRAYING FACILITIES		
TECHNOLOGY NAME:	SL-90B 8 Pocket Bag		
COMPANY:	Columbus Industries Inc.		
ADDRESS:	2938 State Route 752 Ashville, OH 43103	PHONE: FAX:	(740) 983-2552 (740) 983-4622
WEB SITE: E-MAIL:	http:\\www.colind.com mike_haufe@colind.net		

## **PROGRAM DESCRIPTION**

The U.S. Environmental Protection Agency (EPA) has created the Environmental Technology Verification (ETV) Program to facilitate the deployment of innovative or improved environmental technologies through performance verification and dissemination of information. The goal of the ETV Program is to further environmental protection by substantially accelerating the acceptance and use of improved and cost-effective technologies. ETV seeks to achieve this goal by providing high quality, peer reviewed data on technology performance to those involved in the design, distribution, financing, permitting, purchase, and use of environmental technologies.

ETV works in partnership with recognized standards and testing organizations, stakeholder groups which consist of buyers, vendor organizations and permitters, and with the full participation of individual technology developers. The program evaluates the performance of innovative technologies by developing test plans that are responsive to the needs of stakeholders, conducting field or laboratory tests (as appropriate), collecting and analyzing data, and preparing peer reviewed reports. All evaluations are conducted in accordance with rigorous quality assurance protocols to ensure that data of known and adequate quality are generated and that the results are defensible.

The Air Pollution Control Technology (APCT) program, one of 12 technology areas under ETV, is operated by the Research Triangle Institute (RTI), in cooperation with EPA's National Risk Management Research Laboratory. APCT has recently evaluated the performance of paint overspray arrestors used primarily in the aerospace industry. This verification statement provides a summary of the test results for the Columbus Industries Inc. SL-90B 8 Pocket Bag.

### VERIFICATION TEST DESCRIPTION

All tests were performed in accordance with the APCT "Generic Verification Protocol for Paint Overspray Arrestors." The protocol incorporates all requirements of EPA Method 319: Determination of Filtration Efficiency for Paint Overspray Arrestors. [Method 319 is part of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Aerospace Manufacturing and Rework Facilities and was published in the *Federal Register* on March 27, 1998 (40 CFR Part 63).] The protocol also includes requirements for quality management, quality assurance, procedures for product selection, auditing of the test laboratories, and test reporting format.

Filtration efficiency is computed from aerosol concentrations measured upstream and downstream of an arrestor installed in a laboratory test rig. The aerosol concentrations upstream and downstream of the arrestor are measured with an aerosol analyzer that simultaneously counts and sizes the particles in the aerosol stream. The aerosol analyzer covers the particle diameter size range from 0.3 to 10  $\mu$ m in a series of contiguous sizing channels. Each sizing channel covers a narrow range of particle diameters. By taking the ratio of the downstream to upstream counts on a channel basis, the filtration efficiency is computed for each of the sizing channels.

The following series of tests were performed at a face velocity of 120 fpm (0.61 m/s):

- C Three arrestors were tested using a liquid-phase aerosol challenge,
- C Three arrestors were tested using a solid-phase aerosol challenge,
- C Six "no-filter" control tests (one performed prior to each arrestor test),
- C One high efficiency particulate air (HEPA) filter control test, and
- C One reference filter control test.

## **TECHNOLOGY DESCRIPTION**

The Columbus SL-90B 8 Pocket Bag arrestor is an eight-pocket bag filter with nominal dimensions of 24 x 24 x 21 in.  $(0.61 \times 0.61 \times 0.53 \text{ m})$ . The arrestor has a metal frame, and the filter media color is yellow. The label is white,  $\frac{1}{2} \times 3\frac{1}{2}$  in.  $(1.27 \times 8.89 \text{ cm})$  in size, and is affixed to the metal frame. The label includes the following information: Columbus Industries, SL-90B, Sept. 30, 1998. There is no label indication of the flow direction or filter orientation, so the industry standard orientation with the bags extended horizontally in the direction of the airflow and the individual bags side-by-side, as opposed to stacked vertically, was used in the tests.

#### **VERIFICATION OF PERFORMANCE**

Verification testing of the arrestor was performed from March 23 through 24, 1999, at the test facilities of RTI. For ready comparison, the filtration efficiency requirements of the NESHAP are tabulated with the test results in Tables 1 through 4. The test results indicate that the tested arrestor exceeded the requirements listed in Tables 1 and 2 for existing sources and those listed in Tables 3 and 4 for new sources. The pressure drop across the tested arrestors at 120 fpm (0.61 m/s) ranged from 0.10 to 0.12 in. H<sub>2</sub>O (25 to 30 Pa) for the six arrestors tested.

The APCT quality assurance officer has reviewed the test results and the quality control data and has concluded that the data quality objectives given in the generic verification protocol have been attained.

This verification statement addresses two aspects of paint overspray arrestor performance: filtration efficiency and pressure drop. Users of this technology may wish to consider other performance parameters such as service life and cost when selecting a paint overspray arrestor for their use.

In accordance with the generic verification protocol, this verification report is valid for 12 months after the publication date 8/11/99.

Aerodynamic particle diameter range, μm	Filtration efficiency requirement, %	Filtration efficiency achieved, %
> 5.7	> 90	>99
> 4.1	> 50	>99
> 2.2	> 10	99

### TABLE 1. EXISTING SOURCES\*: LIQUID-PHASE CHALLENGE AEROSOL PARTICLES

# TABLE 2. EXISTING SOURCES\*:SOLID-PHASE CHALLENGE AEROSOL PARTICLES

Aerodynamic particle diameter range, μm	Filtration efficiency requirement, %	Filtration efficiency achieved, %
> 8.1	> 90	>99
> 5.0	> 50	>99
> 2.6	> 10	99

#### TABLE 3. NEW SOURCES\*: LIQUID-PHASE CHALLENGE AEROSOL PARTICLES

Aerodynamic particle diameter range, µm	Filtration efficiency requirement, %	Filtration efficiency achieved, %
> 2.0	> 95	99
> 1.0	> 80	94
> 0.42	> 65	87

# TABLE 4. NEW SOURCES\*:SOLID-PHASE CHALLENGE AEROSOL PARTICLES

Aerodynamic particle diameter range, µm	Filtration efficiency requirement, %	Filtration efficiency achieved, %
> 2.5	> 95	99
> 1.1	> 85	97
> 0.70	> 75	95

\*A new source is any affected source that commenced construction after October 29, 1996. An existing source is any affected source that is not new. Original Signed By E. Timothy Oppelt 7/27/99

E. Timothy Oppelt Date Director National Risk Management Research Laboratory Office of Research and Development United States Environmental Protection Agency

Original Signed By Jack R. Farmer 7/29/99

Date

Jack R. Farmer Program Manager, Air Pollution Control Technology Program Research Triangle Institute

NOTICE: EPA verifications are based on an evaluation of technology performance under specific, predetermined criteria and the appropriate quality assurance procedures. EPA and RTI make no expressed or implied warranties as to the performance of the technology and do not certify that a technology will always operate as verified. The end user is solely responsible for complying with any and all applicable federal, state, and local requirements. Mention of commercial product names does not imply endorsement.

#### Availability of Verification Statement and Report

Copies of the public Verification Statement and Verification Report are available from the following:

1. **Research Triangle Institute** P.O. Box 12194 Research Triangle Park, NC 27709-2194

> Web site: <u>http://etv.rti.org/apct/index.html</u> or <u>http://www.epa.gov/etv</u> (click on partners)

2. USEPA / APPCD MD-4 Research Triangle Park, NC 27711

> Web site: <u>http://www.epa.gov/etv/library.htm</u> (*electronic copy*) <u>http://www.epa.gov/ncepihom/</u>