US EPA ARCHIVE DOCUMENT

SAMPLE

MONTHLY INVENTORY RECORD

N TANK IDENTIFICATION & TYPE OF FUEL: 4 MIDGRADE UNL

MONTH/YEAR: 9/93

FACILITY NAME: LAST CHANCE #2

DATE OF WATER CHECK: 9/1 LEVEL OF WATER (INCHES): 0 V

DATE	O START STICK INVENTORY (GALLONS)	P GALLONS DELIVERED	Q GALLONS PUMPED	R BOOK INVENTORY (GALLONS)	S END STICK INVENTORY (INCHES)	S END STICK INVENTORY (GALLONS)	T DAILY OVER (+) OR SHORT (−) ["End" − "Book"]	U INITIALS
1	4047 (+)	—	(−) 333	(=) 3714	38 1/4	3690	−24	JD
2	3690 (+)	—	(−) 44	(=) 3646	38	3658	+12	JD
3	3658 (+)	—	(−) 329	(=) 3329	35 3/8	3323	−6	JD
4	3323 (+)	—	(−) 60	(=) 3263	35	3275	+12	JD
5	3275 (+)	—	(−) 145	(=) 3130	33 3/4	3117	−13	JD
6	3117 (+)	—	(−) 238	(=) 2879	31 1/8	2790	−89	JD
7	2790 (+)	6134	(−) 117	(=) 8807	80	8844	+37	JD
8	8844 (+)	—	(−) 127	(=) 8717	78 7/8	8732	+15	JD
9	8732 (+)	—	(−) 182	(=) 8550	77 1/2	8591	+41	JD
10	8591 (+)	—	(−) 205	(=) 8386	75 1/2	8379	−7	JD
11	8379 (+)	—	(−) 204	(=) 8175	73 5/8	8173	−2	JD
12	8173 (+)	—	(−) 166	(=) 8007	72	7991	−16	JD
13	7991 (+)	—	(−) 320	(=) 7671	69 3/4	7730	+59	JD
14	7730 (+)	—	(−) 307	(=) 7423	67	7402	−21	JD
15	7402 (+)	—	(−) 76	(=) 7326	66 1/2	7342	+16	JD
16	7342 (+)	—	(−) 224	(=) 7118	64 1/8	7050	−68	JD
17	7050 (+)	—	(−) 390	(=) 6660	61	6657	−3	JD
18	6657 (+)	—	(−) 296	(=) 6361	58 5/8	6354	−7	JD
19	6354 (+)	—	(−) 78	(=) 6276	58 1/8	6290	+14	JD
20	6290 (+)	—	(−) 424	(=) 5866	54 5/8	5869	+3	JD
21	5869 (+)	—	(−) 205	(=) 5664	53 1/8	5639	−25	JD
22	5639 (+)	4177	(−) 403	(=) 9413	86 1/2	9423	+10	JD
23	9423 (+)	—	(−) 87	(=) 9336	85 1/2	9343	+7	JD
24	9343 (+)	—	(−) 311	(=) 9032	82	9036	+4	JD
25	9036 (+)	—	(−) 239	(=) 8797	79 1/8	8757	−40	JD
26	8757 (+)	—	(−) 256	(=) 8501	76 7/8	8526	+25	JD
27	8526 (+)	—	(−) 264	(=) 8262	74 1/2	8270	+8	JD
28	8270 (+)	—	(−) 263	(=) 8007	72	7991	−16	JD
29	7991 (+)	—	(−) 185	(=) 7806	69	7811	+5	JD
30	7811 (+)	—	(−) 116	(=) 7695	68	7690	−5	JD
31	(+)		(−)	(=)				

W TOTAL GALLONS PUMPED > 6594 TOTAL GALLONS OVER OR SHORT > −74 X

DROP THE LAST 2 DIGITS from the PUMPED number and enter on the TOTAL GALLONS line below

Compare these numbers

Y LEAK CHECK: 65 + 130 = 195 gallons

Is "TOTAL GALLONS OVER OR SHORT" LARGER than "LEAK CHECK" result? YES NO (circle one) Z

If answer is "YES" for 2 MONTHS IN A ROW, **notify regulatory agency** as soon as possible.

KEEP THIS PIECE OF PAPER ON FILE FOR AT LEAST 1 YEAR