BATTLEFIELD GOLF CLUB WATER PROJECT

Water Supply Feasibility Study

Prepared For

City of Chesapeake

April 10, 2009



TABLE OF CONTENTS

| 1.0 | EXE | CUTIVE | SUMMARY | 1 |
|-----|-----|---|--|---|
| 2.0 | BAC | KGROU | ND | 3 |
| | 2.1 | Project | Area Background | 3 |
| | 2.2 | Water S | Supply Feasibility Study Objectives | 4 |
| | 2.3 | wner Study Area Questionnaire Responses | | |
| | 2.4 | Drinkin | ng Water Regulations | 5 |
| | | 2.4.1 | Introduction | 5 |
| | | 2.4.2 | Current Water Quality Regulations | 6 |
| | | 2.4.3 | Contaminant Candidate List | 7 |
| 3.0 | GRC | OUNDWA | ATER CONDITIONS | |
| | 3.1 | Regiona | al Geology and Hydrogeology | |
| | 3.2 | Study A | Area Geology and Hydrogeology | |
| | 3.3 | Project | Area Groundwater Use | |
| | 3.4 | Existing | g Well Groundwater Quality | |
| | | 3.4.1 | Well Information | |
| | | 3.4.2 | Existing Well Water Quality Data | |
| | 3.5 | Backgro | ound Well Water Quality Data | |
| | 3.6 | Battlefi | eld Golf Course Groundwater Quality | |
| 4.0 | WAT | FER SUP | PLY ALTERNATIVES | |
| | 4.1 | Alterna | tive 1 - Extend City of Chesapeake Water Distribution System | |
| | | 4.1.1 | Water Main Extension | |
| | | 4.1.2 | Water Service Connections | |
| | | 4.1.3 | Distribution Supply/ Fire Protection | |
| | | 4.1.4 | Other Considerations | |
| | | 4.1.5 | Advantages/Disadvantages | |
| | 4.2 | Alterna | tive 2 - New Community Water Supply System | |
| | | 4.2.1 | Community Water Demand | |
| | | 4.2.2 | Raw Water Development: Proposed Aquifer Source | |
| | | 4.2.3 | Proposed Well Information | |
| | | 4.2.4 | Aquifer Water Quality and Treatment Requirements | |
| | | 4.2.5 | Reverse Osmosis Treatment | |
| | | 4.2.6 | Pre-Treatment Processes | |
| | | 4.2.7 | Permitting Requirements | |
| | | 4.2.8 | Post Treatment Water Conditioning | |
| | | 4.2.9 | Disinfection/Fluoridation Requirements | |
| | | 4.2.10 | Distribution System Requirements | |
| | | 4.2.11 | Water Storage Facilities – Fire Protection | |
| | | 4.2.12 | Land Acquisition | |

TABLE OF CONTENTS

| | | 4.2.13 | O&M Issues | 31 |
|-----|------|-----------|---|--------|
| | | 4.2.14 | Other Considerations | 31 |
| | | 4.2.15 | Advantages/Disadvantages | 32 |
| | 4.3 | Alternat | ive 3 – Individual Point of Entry (POE) Treatment System for Existing Wells | 33 |
| | | 4.3.1 | Housing Requirements | 33 |
| | | 4.3.2 | Brine Handling | 34 |
| | | 4.3.3 | O&M Issues | 34 |
| | | 4.3.4 | Other Considerations | 34 |
| | | 4.3.5 | Advantages/Disadvantages | 35 |
| | 4.4 | Alternat | ive 4 – Development and Installation of New Individual Home Owner Supply W | ells35 |
| | | 4.4.1 | Current Groundwater Conditions and Ongoing Investigations | 35 |
| | | 4.4.2 | New Well Installation | 36 |
| | | 4.4.3 | Permitting Requirements | 36 |
| | | 4.4.4 | Other Considerations | 37 |
| | | 4.4.5 | Advantages/Disadvantages | 37 |
| 5.0 | COST | EVALU | JATION AND RECOMMENDATIONS | 38 |
| | 5.1 | Present V | Worth Opinion of Cost evaluations | 38 |
| | 5.2 | Alternat | ive Evaluation Matrix | 39 |
| | 5.3 | Recomm | nended Alternative | 41 |
| 6.0 | REFE | RENCES | 5 | 43 |
| | | | | |

TABLE OF CONTENTS

TABLES

| | | Page |
|---------|---|------|
| Table 1 | DEQ Observation Wells Summary | 17 |
| Table 2 | Surficial Aquifer Water Quality | 18 |
| Table 3 | Yorktown-Eastover Aquifer Water Quality | 19 |

FIGURES

| | | Following Page |
|----------|--------------------------------|----------------|
| Figure 1 | Site Location | 4 |
| Figure 2 | Past Sample Locations | 9 |
| Figure 3 | General Hydrogeologic Section | 9 |
| Figure 4 | Residential Sampling Locations | 11 |

EXHIBITS

| Exhibit 1 | Extend City Water Distribution System | 22 |
|-----------|---------------------------------------|----|
| Exhibit 2 | Community Well System | 26 |

APPENDICES

| APPENDIX A | Resident Questionnaire |
|------------|--|
| APPENDIX B | Virginia Water Quality Standards |
| APPENDIX C | National Primary and Secondary Drinking Water Standards |
| APPENDIX D | The Second Contaminant Candidate List (EPA, 2005) |
| APPENDIX E | The Third Contaminant Candidate List (Draft, EPA, 2008) |
| APPENDIX F | Schnabel: Installed Monitoring Wells (MW-1 &MW-2) Report |
| APPENDIX G | Existing Well Groundwater Quality Data |
| APPENDIX H | Vicinity Groundwater Quality Data from VDEQ |
| APPENDIX I | Battlefield Golf Course Groundwater Quality Data |
| APPENDIX J | 2007 City of Chesapeake Water Quality Report |
| APPENDIX K | Water Storage Requirement for Alternative 2 |
| APPENDIX L | City of Chesapeake Public Utility Charges |
| APPENDIX M | Reverse Osmosis for Community Water System |
| APPENDIX N | Point of Entry Reverse Osmosis System |
| APPENDIX O | Present Worth Comparison of Alternative Evaluation |
| APPENDIX P | Alternative Evaluation Matrix |

1.0 EXECUTIVE SUMMARY

The potential introduction of contaminants from the Battlefield Golf Course fly ash into the Surficial groundwater has created a situation requiring immediate action. The City of Chesapeake has initiated a comprehensive water supply feasibility study to evaluate existing conditions and assess viable alternatives capable of delivering potable water to City residents located within the study area.

Existing local hydrogeologic data, water well information, and recent well water quality data were collected and evaluated to determine suitable water sources, well yield limits, and potential constituents requiring treatment to comply with drinking water standards. URS developed and assessed the following four alternatives:

Alternative 1: Extend the City of Chesapeake's central water distribution system via a water main extension.

Alternative 2: Install a "stand alone" community groundwater supply, treatment, storage and distribution system capable of providing potable water service to 100 equivalent residential connections (ERC).

Alternative 3: Install point-of-entry (POE) treatment systems on existing private wells currently used to provide water to these homes/businesses.

Alternative 4: Install and develop new individual residential and commercial water supply wells into aquifer(s) offering potentially less susceptibility to reduced water quality conditions and potential contaminants from the fly ash.

The four alternatives were evaluated using the following criterion: regulatory compliance, property owner impact, operational requirements, technical feasibility, permitting / administrative concerns, and present worth cost (capital and operations and maintenance (O&M) costs).

Alternatives 2 and 3 present significant regulatory issues. Even if these alternatives are able to overcome the regulatory obstacles, their ultimate costs from both capital and O&M perspectives are so substantial that a path forward make these alternatives unfavorable.

Alternative 4 costs are attractive and new wells can be implemented in a relatively expeditious manner, but this option suffers from the lack of certainty to completely protect the residents' future water quality without first obtaining more information from the concurrent City study focused on the fate and transport of any potential contaminants. Therefore, avoidance of future risk is not assured with this option. The complete present exercise of evaluating options and actions may only be temporarily delayed with this option.

URS recommends that the City proceed with the construction of Alternative 1 and extend the City distribution system to serve these areas. The provision of City water would allow for a safe, reliable, monitored water supply that would be most protective against any potential future impacts to the existing aquifer supply.

2.0 BACKGROUND

Due to concerns regarding potential impacts to groundwater quality from the use of fly ash as fill at the Battlefield Golf Club, the City of Chesapeake is undertaking efforts to supply water to homes on Murray Drive, from Centerville Turnpike to Whittamore Road; Whittamore Road, from Centerville Turnpike to Murray Drive; and, Centerville Turnpike, from Murray Drive to Whittamore Road. (With the installation of a City Water System Extension, other homes and businesses along Centerville Turnpike could also connect to the water system between the southern terminus of Albemarle Acres and Etheridge Manor Boulevard). This Water Supply Feasibility Study assesses four alternatives for providing potable water to these homes based on regulatory compliance, property owner impact, operational requirements, technical feasibility, administrative/permitting concerns, and present worth cost (capital and operations and maintenance (O & M) costs).

2.1 Project Area Background

The Murray-Whittamore-Centerville project area is located in the City of Chesapeake, VA. See Figure 1 for a Site Location Map. The area is represented on the Fentress, Virginia USGS topographic quadrangle at an approximate elevation of 10 to 15 feet (ft) above mean sea level (MSL), and it slopes eastwards.

The 216-acre Battlefield Golf Course is located on Centerville Turnpike between Murray Drive and Whittamore Road. It is understood based on information provided to URS that the site was constructed by using 1.5 million tons of fly ash originating from the Chesapeake Energy Facility operated by Dominion Power. Under Virginia's administrative code, fly ash, a coal combustion byproduct, can be used as a fill material as long as there are two feet of separation between the groundwater and an 18-inch cap of soil covering the fly ash at all times. Construction of the golf course took approximately 5 years and was completed in the summer of 2007.

In 2008, residents living in the immediate vicinity of the Golf Course voiced concerns to the City regarding the potential impacts to groundwater quality from the use of the fly ash. According to City documents, there are approximately 93 dwelling units adjacent to the golf course using wells as the primary source of drinking water.

In response to resident concerns, the City began to test drinking water wells of the surrounding residents for constituents of concern, including arsenic, barium, boron, chromium, cadmium, lead, selenium, silver, vanadium and mercury. On July 16, 2008, the City sent a letter to the U.S. Environmental Protection Agency (EPA) regional office requesting the Agency to respond to the detection of various analytes in the groundwater in support of the surrounding residents. The City then commissioned URS to investigate water supply alternatives described in Section 2.2 to bring reliable, potable water to the community.

2.2 Water Supply Feasibility Study Objectives

The purpose of this study is to provide stakeholders with information on existing conditions and to assess viable alternatives that assures potable water supply to city residents. Existing local hydrogeology data, water well information, and recent well water quality data have been collected and evaluated to determine suitable water sources, well yield limits, and potential constituents requiring treatment to comply with drinking water standards. Based on this information URS has generated the following four alternatives to provide potable water to 100 equivalent residential connections (ERC):

Alternative 1: Extend the City of Chesapeake's central water distribution system via a water main extension.

Alternative 2: Install a "stand alone" community groundwater supply, treatment, storage and distribution system capable of providing potable water service to 100 ERC.

Alternative 3: Install point-of-entry (POE) treatment systems on existing private wells currently used to provide water to these homes/businesses.

Alternative 4: Install and develop new individual residential and commercial water supply wells into aquifer(s) offering potentially less susceptibility to reduced water quality conditions and potential contaminants from the fly ash.

The alternatives have been compared to identify the relative suitability of each alternative, and to provide a recommended alternative based on the analysis performed.

2.3 Homeowner Study Area Questionnaire Responses

On December 8, 2008, the City of Chesapeake mailed 93 questionnaire forms to the residences and businesses within the Murray-Whittamore-Centerville study area. In the questionnaire, the City requested information about individual water wells and public opinion on connecting to the City water system. An example of the questionnaire is included in Appendix A.

Table 1 in Appendix A summarizes the responses from this investigation. At the time this feasibility report was prepared (February 3, 2009), there were 15 responses, including two businesses. The following illustration summarizes some important responses contained on the questionnaire. Among the respondents, 85% expressed an interest in connecting to City water if it became available.

According to the survey results, the water wells were installed between 1950 and 2000. Most of them are accessible. Only three households indicated problems with water pressure. The respondents provided little, if any, information about the configuration of their wells, such as depth of the well. Seventy (70) % of the respondents have experienced iron or manganese issues, and 50% of the respondents have experienced calcium scaling. About half have installed individual treatment devices.





Resident Questionnaire Summary

In the study area, three were tested for water quality by the City in July 2008; three had water quality tests performed in 2008, one in 2005, and another one in 1996.

2.4 Drinking Water Regulations

2.4.1 Introduction

The enactment by Congress in 1893 of the Interstate Quarantine Act provided federal authority to establish standards for drinking water systems. The first formal and comprehensive review and investigation of drinking water concerns was initiated in 1913. Federal regulation of drinking water began in 1914, when the U.S. Public Health Service set standards for the bacteriological quality of drinking water for contaminants capable of contagious disease. These standards were then revised and expanded in 1925, 1946, and 1962. The 1962 standards, regulating 28 substances, were the most comprehensive Federal drinking water standards in existence before the Safe Drinking Water Act (SDWA) of 1974.

In 1974 Congress passed the SDWA to ensure that public water supplies meet national standards that protect consumers from deleterious contaminants in the water. This law had



G: Projects/Battlefield_Golf_Club/GIS/Projects/Location_Map.mxd

significant amendments in 1986 and 1996 and is administered by the United States Environmental Protection Agency's Office of Groundwater and Drinking Water (EPA). These laws apply to all public water systems¹. Both publicly or privately-owned community water systems are included in this definition.

2.4.2 Current Water Quality Regulations

The SDWA gave the EPA the authority to delegate the primary responsibility for enforcing drinking water regulations to states provided that they meet specific requirements. States that comply are considered to have "primacy." Virginia has assumed primacy and the State's Department of Health, Office of Drinking Water (VDH) receives grants from the EPA to help pay for the oversight of water systems. As a primacy state, Virginia drinking water regulations are at least as stringent as federal regulations. Appendix B presents the Water Quality Standards for the Commonwealth of Virginia. The Virginia Department of Environmental Quality (DEQ) is the agency in charge of enforcing water withdrawal and wastewater disposal regulations.

A summary of the EPA's National Primary Drinking Water Regulations and Secondary Drinking Water Regulations is presented in Appendix C. Primary Contaminants are legally enforceable standards that apply to public water supply systems. Primary standards protect public health by limiting the amount of contaminants in drinking water through maximum contaminant levels (MCLs). Contaminants may be microorganisms, inorganic chemicals, organic chemicals, disinfectants, disinfection-by-products, and radionuclides.

Secondary contaminants are non-enforceable guidelines regulating contaminants that may cause cosmetic effects (e.g. tooth or skin discoloration) or aesthetic effects, such as taste, odors, or color in drinking water.

The following are also water quality regulations that apply to community or public water treatment plants and water distribution systems:

- EPA's Trihalomethane Regulation.
- EPA Requirement for Special Monitoring for Sodium and Corrosivity Characteristics.
- EPA's Phase I Regulations for 8 Volatile Organic Compounds (VOCs).
- EPA's Surface Water Treatment Rule (SWTR).
- EPA's revised Total Coliform Rule (TCR).
- EPA's Phase II Regulations for Synthetic Organic Compounds and Inorganic Compounds.
- EPA's Lead and Copper Rule.
- EPA's Phase V Drinking Water Regulations.
- EPA's Consumer Confidence Reports (CCRs).

¹ Public Water Systems provide water to at least 25 people or 15 service connections for at least 60 days per year. Today approximately 155,000 public water systems provide water to more than 292 million people.

- EPA's Stage 1 D/DBP Rule and the Interim Enhanced Surface Water Treatment Rule.
- EPA's Radionuclides Rule.
- EPA's Filter Backwashing Recycling Rule.
- EPA's Stage 2 D/DBP.
- EPA's Long-term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR).

Additionally, under the 1996 amendment to the SDWA the EPA publishes guidance to primacy states to carry out source water assessments within the state's boundary. This establishes a coordinated and comprehensive protection of groundwater resources within a state.

2.4.3 Contaminant Candidate List

The SDWA includes a process that the EPA must follow to identify new contaminants that may require future regulation. This list serves as the starting point for future regulations. The contaminants on this list are not subject to any current or proposed drinking water regulation. These contaminants are known or anticipated to occur in public water systems and may, in the future, require regulation. In February 2005, the EPA published the second Contaminant Candidate List (CCL) of 51 potential contaminants. Appendix D is a fact sheet of the Drinking Water Contaminant Candidate List published by the EPA along with a list of the chemical contaminant candidates. On February 21, 2008 the EPA published a draft of the third CCL in the Federal Registrar. This is presented in Appendix E.

3.0 GROUNDWATER CONDITIONS

3.1 Regional Geology and Hydrogeology

The project area is located within the Coastal Plain Physiographic Province of Virginia. The Virginia Coastal Plain is "underlain by a seaward-dipping strata of unconsolidated to partially consolidated sediments of Cretaceous, Tertiary, and Quaternary age that unconformably overlie a basement of consolidated bedrock" (MacFarland and Bruce, 2006). This "wedge" of sediments extends from the Fall Line located near Richmond, VA and thickens to the east, and is estimated to reach a thickness in excess of 3,000 feet in the Chesapeake area.

The most recent published literature describes seven discrete aquifers and eight confining units that separate the aquifers in the vicinity of the project area. Each of these units is briefly discussed, from the deepest to the shallowest, in this section based on the interpretations presented in MacFarland and Bruce (2006) of lithologic and geophysical logs obtained from the Fentress Core. Figure 2 illustrates the location of the Fentress test wells/core. As the study area is located approximately two miles to the west (up dip) of this core hole, the actual depths will be somewhat shallower (+/- 10 to 20 feet) and the units will typically be thinner (+/- 10 feet). Figure 3 presents a stratigraphic cross-section of these units based on the Fentress Core.



Figure 3 General Hydrogeologic Section

The Potomac aquifer is the deepest aquifer in the area and directly overlies the bedrock. Historically, this aquifer was divided into three separate aquifers, termed the Lower, Middle, and Upper Potomac aquifers (Meng and Harsh, 1988). However, recent studies have concluded that the confining units described in previous studies are probably not present, and for purposes of this study, the Potomac aquifer is defined as a single aquifer as described by MacFarland and Bruce (2006).

The top of the Potomac aquifer is encountered at a depth of approximately 1,065 feet below ground surface (bgs), and extends to depths in excess of 3,000 feet. Because of its large lateral extent and coarse grained sediments, this aquifer is one of the predominantly used aquifers in the Virginia Coastal Plain. Capable of providing large quantities of groundwater, its depth and the brackish nature of its water quality in the eastern portion of



G: Projects\Bat lefield_Golf_Club\GIS\Projects\Samples.mxd

the state limit its use to major water supply systems for industrial and municipal use, and the water must be treated to achieve potable water quality.

The Potomac Aquifer is overlain by the Potomac confining zone and the Upper Cenomanian confining unit that form a 200-foot thick sequence of fine grained sandy and silty clays. These confining beds are overlain by the Virginia Beach aquifer which is comprised of well-sorted sands. Extending from depths of approximately 800 feet to 855 feet bgs, this aquifer also has relatively poor water quality owing to its brackish nature, and water supplies obtained from this unit require treatment to achieve potable water quality.

The Virginia Beach confining zone overlies the Virginia Beach aquifer and is approximately 15 feet thick. The Peedee aquifer overlies the Virginia Beach confining zone and extends from depths of approximately 755 to 790 feet bgs. Owing to its depth, and limited areal extent in just the southern portions of Chesapeake and Virginia Beach, the Peedee aquifer it is considered to be unused as a source of groundwater in Virginia. It also is considered to contain brackish water; thus requiring treatment prior to use as a potable water source.

The Peedee confining zone overlies the Peedee aquifer, and is approximately 60 feet thick. The Aquia aquifer overlies the Peedee confining zone and extends from depths of approximately 665 to 690 feet bgs. The Aquia aquifer is a widespread aquifer in the Virginia Coastal Plain, and is comprised of medium- to coarse-grained sand. Due to its relative thinness, the Aquia aquifer is not a major water supply source, and wells installed into this aquifer typically do not produce quantities of water needed for large industrial, commercial, or municipal use in the area. This aquifer also contains brackish water, requiring the need for treatment prior to potable use.

The Nanjemony-Marlboro confining unit overlies the Aquia aquifer and is approximately 15 feet thick. The Piney Point aquifer overlies the Nanjemony-Marlboro confining unit, and extends from depths of approximately 630 to 650 feet bgs. A laterally extensive aquifer, it is a moderately used aquifer that provides water to small towns and can be used for low-density residential development. However, south of the James River, the Piney Point aquifer is not considered to be a productive groundwater source.

The Calvert confining unit overlies the Piney Point aquifer and is approximately 15 feet thick. This unit is overlain by the Saint Mary's confining unit that measures approximately 425 feet thick. Together these two units comprise an extensive confining unit that separates the underlying Piney Point aquifer from the Yorktown-Eastover aquifer. The Yorktown-Eastover aquifer extends from depths of approximately 85 to 185 feet bgs. A laterally extensive aquifer across the Virginia Coastal Plain, this aquifer is heavily used as a groundwater supply source. With interbedded fossiliferous sands, water-supply well yields range from 10 to 300 gallons per minute (gpm), and average nearly 90 gpm (Siudyla, et al., 1981) with larger production wells located along the eastern shore of Virginia producing up to 300 gpm.

Water quality of the Yorktown-Eastover aquifer is typically good, although salinity is reported to increase with depth, particularly if wells are drilled into the finer grained and less productive Calvert confining unit that underlies the aquifer. Iron may also be present in local areas, and poses taste and staining issues.

The Yorktown confining zone overlies the Yorktown-Eastover aquifer and is approximately 15 feet thick. Based on the amount of silt and clay present, this unit varies laterally and in certain locations where coarser sediments are present, it does not serve as a confining unit between the Yorktown-Eastover aquifer and the Surficial aquifer.

Formerly referred to as the Columbia aquifer, the Surficial aquifer lies above the Yorktown confining zone and is an unconfined, water table aquifer that exists within sands that are interbedded with laterally discontinuous silts and clays. Extending to a depth of approximately 70 feet bgs, the Surficial aquifer serves as a water supply source of shallow water, although sustained well yields are typically less than 25 gpm. As a result of its existence as a water table aquifer, it is continuously recharged as fresh water infiltrates from precipitation. In general, the water quality is good, although iron, manganese, and sulfate may pose taste and discoloration issues locally, and because the aquifer is not confined, it may be subject to degradation from pollution.

3.2 Study Area Geology and Hydrogeology

To supplement the published literature and gain a greater understanding of the study area, hydrogeological data gathered during previous investigations at the Battlefield Golf Club were reviewed, and residential well records were obtained from the City of Chesapeake Health Department. In addition, two monitoring wells (MW-1 and MW-2) were installed as part of this study as detailed in Appendix F to gain an understanding of the local stratigraphy and hydrogeologic relationship between the Surficial aquifer and the underlying Yorktown-Eastover aquifer. Figure 4 depicts the locations of the two wells.

Based on the lithologic logs from the wells installed at the end of Bonney Road (see Appendix F) as part of this study, the Surficial aquifer was found to extend to a depth of 52 feet bgs where lean clays indicative of the Yorktown confining zone were encountered. These clays extended for 10 feet, and then sands indicative of the Yorktown-Eastover aquifer were encountered.

As part of this study, two undisturbed tube samples were collected from the Yorktown confining zone and vertical permeability tests indicate hydraulic conductivities of 8.3×10^{-7} centimeters per second (cm/sec) from the 55-57 feet bgs sample and 1.7×10^{-6} cm/sec from the 60-62 feet bgs sample. Appendix F contains the testing results.

Water level measurements were obtained from wells MW-1 and MW-2 installed as part of this study from December 10, 2008 through January 15, 2009 (see Appendix F). Well MW-1 was installed into the Yorktown-Eastover aquifer and well MW-2 was installed into the Surficial aquifer. The portion of the Yorktown-Eastover aquifer screened in well MW-



G: Projects\Battlefield_Golf_Club\GIS\Projects\GolfClub.mxd

1 was comprised of lean clays, clayey sand, and silty sand, and was not a productive water bearing zone. Consequently, during well development, the well was pumped dry, and the water level recovery was very slow. This is evidenced by the water levels recorded in well MW-1 which slowly rose over the monitoring period.

Based on the water levels measured in these two wells, and the reduced rate of recovery of the water level in well MW-1, it appears that the potentiometric surface of groundwater in the Yorktown-Eastover aquifer is approximately 1.5 feet lower than the water level in the Surficial aquifer. Using the mid-point of the screened intervals (40 feet bgs at MW-2 and 85 feet bgs in MW-1), a downward vertical gradient of approximately 0.03 ft/ft is calculated. This gradient indicates that the Yorktown confining zone retards the vertical migration of groundwater from the Surficial aquifer downward into the Yorktown-Eastover aquifer at the location of these wells as would be expected given the low vertical permeability of the lean clays encountered between the Surficial and Yorktown-Eastover aquifers, mentioned above.

While at the location of wells MW-1 and MW-2, the Yorktown confining zone appears to act as a confining unit, this unit is typically not extensively mappable as a confining unit, and when present, is usually leaky (T. Scott Bruce, DEQ, personal communication, 2008). A review of lithologic logs obtained from residential wells in the area obtained did not identify the Yorktown confining zone as being present, although the quality of the logs, which are typically made from soil cuttings observed during drilling, may not be an accurate representation of the stratigraphy in the area.

Based on the data obtained, it is concluded that, where present, the Yorktown confining zone may serve to retard the migration of groundwater from the Surficial aquifer downward into the Yorktown-Eastover aquifer. However, leakage through the Yorktown Confining zone occurs, albeit slowly, and if this confining zone is not present or has a higher sand content, groundwater in the Surficial aquifer will migrate into the underlying Yorktown-Eastover aquifer.

3.3 **Project Area Groundwater Use**

The properties within the study area utilize private water supply wells for domestic and small business use. Groundwater is also used for feeding livestock. The upper two aquifers, the Surficial and the partially confined Yorktown-Eastover Aquifer, are the major sources for the local water supply wells. Water levels obtained from wells installed at the Battlefield Golf Club as reported by Kimley-Horn and Associates (2008) indicate that groundwater flow in the unconfined Surficial aquifer is toward the southeast, away from the homes and businesses located west of South Centerville Turnpike.

To avoid potential contamination that potentially may occur in the future in the Surficial aquifer, the Yorktown-Eastover aquifer will be considered the main groundwater source for any proposed well installation, private or community systems. For the purpose of this study it has been assumed that all individual supply wells are capable of producing 400 gallons per day to be consistent with the Virginia "Waterworks Regulations".

3.4 Existing Well Groundwater Quality

3.4.1 Well Information

Well records were located for 29 wells in the region at the City of Chesapeake Health Department. Among them, well yield information is available for 14 of the wells. Well information is summarized in Table 1 of Appendix G.

The average well yield is 19 gpm and the average well depth is 71 ft bgs. The screen interval data was reviewed to evaluate which wells withdraw water in the unconfined Surficial water table aquifer and which wells withdraw from the uppermost partially confined aquifer (Yorktown-Eastover aquifer). A small majority of the 29 wells with supporting data are believed to utilize water from the Surficial aquifer based on the recorded screen intervals. The remainder of the wells are advanced to deeper depths and resumed to be part of the Yorktown-Eastover aquifer.

3.4.2 Existing Well Water Quality Data

Past groundwater quality data for local water supply wells is summarized in Table 2 of Appendix G.

November and December 2001 Groundwater Tests

In November and December 2001, prior to the commencement of Battlefield Golf Course construction, 43 groundwater samples were taken from 40 homes in the region (Stokes Environmental Associates, Ltd., 2002). Sampling locations are indicated in Figure 4. Tests were conducted for the following elements:

- Primary contaminants: antimony (Sb), arsenic (As), barium (Ba), beryllium (Be), cadmium (Cd), chromium (Cr), copper (Cu), cyanide (CN), fluoride (F), mercury (Hg), lead (Pb), selenium (Se), thallium (Tl)
- Secondary contaminants: iron (Fe), manganese (Mn), silver (Ag), zinc (Zn)
- Other unregulated elements: nickel (Ni)

The test results indicate naturally elevated iron and manganese levels in the local groundwater, can be used as the baseline water quality data, and are summarized with respect to SDWA levels as indicated below:

| Constituent | Detected | Above Regulatory Limit | Comments |
|-------------------|----------|---|-----------------------------|
| Antimony (Sb) | No | | |
| Arsenic (As) | | No | Found at isolated locations |
| Barium (Ba) | No | | |
| Beryllium (Be) | | No | Found at isolated locations |
| Cadmium (Cd) | | No | Found at 20 locations |
| Chromium (Cr) | | No | Found at 5 locations |
| Copper (Cu) | | 2 Locations Above Primary Limit (1.30 mg/L) | Found at 9 locations |
| Cyanide (Cn) | No | | |
| Fluoride (F) | | No | Found at 29 locations |
| Iron (Fe) | | 16 Locations Above Secondary Limit (0.30 mg/L) | Found at 24 locations |
| Lead (Pb) | | No | Found at 17 locations |
| Manganese (Mn) | | 9 Locations Above Secondary Limit (0.05 mg/L) | Found at 11 locations |
| Mercury (Hg) | | No | Found at isolated |
| | | | locations |
| Nickel (Ni) | No | | |
| Selenium (Se) | No | | |
| Silver (Ag) | | No | Found at isolated locations |
| Thallium (Tl) | | 1 Location Above Primary Limit (0.002 mg/L) | Found at 11 locations |
| Zinc (ZN) | | No | Found at 7 locations |

April and May 2008 Groundwater Tests

In April and May 2008, 89 samples were drawn from 81 homes in the region and were tested for the presence of the following ten elements.

- Primary contaminants: arsenic (As), barium (Ba), cadmium (Cd), chromium (Cr), mercury (Hg), lead (Pb), selenium (Se)
- Secondary contaminants: silver (Ag)
- Other unregulated elements: boron (B), vanadium (V)

Test results reflect the following:

| Constituent | Detected | Above Regulatory Limit | Comments |
|---------------|----------|--|----------------------------------|
| Arsenic (As) | No | | |
| Barium (Ba) | | No | Found at 53 locations. |
| | | | Compared with the baseline |
| | | | data, the higher detectible rate |
| | | | was likely due to the lower |
| | | | detectible limit of the current |
| Doron (D) | | 2 Logations Above World Health | Eaund at nearly all the tested |
| DOIOII (D) | | Organization (WHO) recommended limit | homes |
| | | (0.50 mg/L) | nomes |
| Codmium (Cd) | | (0.30 llig/L) | Found at 12 locations |
| | | NO | Found at 12 locations |
| Chromium (Cr) | | No | Found at 1 location |
| Lead (Pb) | | 3 Locations Above "Action Level" (0.015 mg/L) | Found at 37 locations |
| Mercury (Hg) | No | - | |
| Selenium (Se) | No | | |
| Silver (Ag) | No | | |
| Vanadium (V) | No | | |
| Zinc (Zn) | | No | Found at 7 locations |

July 2008 Groundwater Tests

In July 2008, the City retested the 24 homes along Murray Drive and Whittamore Road. Besides the ten elements originally tested in April 2008, four new elements were added in this round of tests. They were cobalt (Co), nickel (Ni), zinc (Zn) and manganese (Mn). Of these, manganese (Mn) and zinc (Zn) are regulated as secondary contaminants. Nickel (Ni), zinc (Zn) and manganese (Mn) were the elements in the baseline test.

According to the City's documentation, test results reflect the following:

| Constituent | Detected | Above Regulatory Limit | Comments |
|---------------|----------|--|-------------------------|
| Arsenic (As) | No | | |
| Barium (Ba) | | No | Found at 9 locations |
| Boron (B) | | 2 Locations Above World Health | Found at all the tested |
| | | Organization (WHO) recommended limit | locations |
| | | (0.50 mg/L) | |
| Cadmium (Cd) | No | - | |
| Chromium (Cr) | No | | |
| Cobalt (Co) | No | | |
| Lead (Pb) | | 1 Location Above "Action Level" | Found at 5 locations |
| | | (0.015 mg/L) | |
| Manganese | | At least 7 Secondary Limit (0.05 mg/L) | Found at 15 locations |
| (Mn) | | | |
| Mercury (Hg) | No | | |
| Nickel (Ni) | No | | |
| Selenium (Se) | | No | Found at 3 locations |
| Silver (Ag) | No | | |
| Vanadium (V) | No | | |
| Zinc (Zn) | | No | Found at 10 locations |

Based on the analysis on the past water quality tests, the existing water supply wells in the region have naturally high levels of iron and manganese, both of which are regulated as "secondary" contaminants. Approximately 40% of the wells exceed the secondary limit for iron, and 30% exceed the secondary limit for manganese. The elevated iron and manganese level were also observed by the local residents on the homeowner questionnaire. Boron was detected in local groundwater supply during the 2008 tests. The most recent test shows approximately 10% of the 24 tested wells had a boron level above the WHO recommended limit.

December 2008 Well Water Quality Data

Following the contact of selected homeowners by URS, water samples were collected on December 23, 2008 from two residences on Murray Drive:

- Sample A (Yorktown-Eastover aquifer well 80 ft deep, screened from 67ft 80ft)
- Sample B (Surficial aquifer well 50 ft deep, screened from 40ft 50 ft)

The results of the analytical tests are included in Appendix F. In summary, the water quality meets the primary drinking water regulations at both locations. However, the shallower well on Murray Drive exceeded the secondary drinking water criteria for iron, manganese, and aluminum, while the deeper well on Murray Drive met all primary and secondary drinking water criteria.

3.5 Background Well Water Quality Data

The aquifer water quality data was obtained from DEQ and has been evaluated to determine the appropriate aquifer to be utilized as the community potable water supply.

This data comes from a set of observation wells (Fentress Test Wells) installed approximately 2.5 miles to the east/northeast of the project area as illustrated in Figure 2. The information for 12 observation wells is summarized in Table 1.

| Well Name | Screen Interval (Elev MSL) | Aquifer |
|---------------|----------------------------|--------------------|
| 91-A / 61B 2 | -77 to -82 | Yorktown Eastover |
| 91-B / 61B 5 | -1,025 to -1,045 | Potomac (top) |
| 91-C / 61B 6 | -745 to -765 | Peedee |
| 91-D / 61B 7 | - 2 to -7 | Surficial/Columbia |
| 91-E / 61B 12 | -1,806 to -1,816 | Potomac |
| 91-F / 61B 13 | -1,365 to -1,365 | Potomac |
| 91-G / 61B 14 | -1,078 to -1,088 | Potomac (top) |
| 91-H / 61B 15 | -744 to -754 | Peedee |
| 91-J / 61B 16 | -665 to -675 | Aquia |
| 91-K / 61B 17 | -73 to -83 | Yorktown Eastover |
| 91-L / 61B 18 | -42 to -52 | Surficial/Columbia |
| 91-M / 61B 19 | 5 to -5 | Surficial/Columbia |

Table 1 DEQ Observation Wells Summary

Based on the screen interval data, three wells (91-D, -L and -M) are believed to be supplied by the Surficial aquifer. The water quality data for these wells is summarized in Table 2 along with the regulatory limits of the contaminants. Water in this uppermost aquifer appeared to have high levels of iron (Fe) and manganese (Mn), which exceeded the secondary drinking water standard. Two wells had a pH value of 5.7, which is also outside the secondary criteria range.

| Demonster | T Ins \$4 m | Secondary | 01 D | 01 1 | 01 M |
|-------------------------------|------------------------------|------------|-------|-------|-------|
| Parameter | Units | MCL | 91-D | 91-L | 91-M |
| pH | std. units | 6.5-8.5 | 5.7 | 6.5 | 5.7 |
| HCO ₃ ⁻ | mg/L | | 90 | 90 | 90 |
| CO_{3}^{2} | mg/L | | 0.0 | 0.0 | 0.0 |
| Alkalinity | mg/L as CaCO ₃ | | 74 | 74 | 74 |
| ANC | mg/L | | 64 | 116 | 62 |
| Hardness | mg/L as CaCO ₃ | | 72 | 87 | 38 |
| Ca ²⁺ | mg/L | | 11.5 | 27.0 | 6.2 |
| Mg^{2+} | mg/L | | 10.4 | 4.8 | 5.4 |
| Na ⁺ | mg/L | | 17.9 | 21.0 | 17.0 |
| \mathbf{K}^{+} | mg/L | | 1.1 | 3.3 | 1.1 |
| Cl | mg/L | 250 | 24.0 | 18.0 | 17.0 |
| \mathbf{SO}_4^{2-} | mg/L | 250 | 12.0 | 11.0 | 15.0 |
| SiO ₂ | mg/L | | 20.0 | 44.0 | 19.0 |
| Fe _T | mg/L | 0.30 | 12.0 | 5.0 | 13.0 |
| Mn _T | mg/L | 0.05 | 0.24 | 0.14 | 0.24 |
| Al_T | mg/L | 0.05- 0.20 | 0.020 | 0.020 | 0.020 |
| TDS | mg/L | 500 | 159 | 191 | 134 |
| Specific Conductance | μS/cm | | 325 | 278 | 208 |
| B – Boron* | mg/L | | 0.04 | 0.05 | 0.02 |

Table 2 Surficial Aquifer Water Quality

* Boron -WHO recommended limit of 0.5 mg/L.

There are two wells, 91-A and -K, with screen interval between -73 feet (MSL) and -83 feet (MSL). These wells are believed to be supplied by the Yorktown-Eastover aquifer. The water quality data, shown in Table 3, indicate high levels of hardness, chloride (Cl), iron (Fe) and total dissolved solids (TDS), and slightly elevated levels of boron (B). Water with a hardness of 250 mg/L (as CaCO₃) is usually considered as very hard. The levels of chloride, iron and TDS were above the secondary limits.

| Parameter | Units | Secondary MCL | 91 . A | 91 - K |
|-------------------------------|------------------------------|------------------|--|--|
| T ut utilitetet | - | | <i>,</i> ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, | |
| pН | std. units | 6.5-8.5 | 7.4 | 7.3 |
| HCO ₃ ⁻ | mg/L | | 331 | |
| CO ₃ ²⁻ | mg/L | | 0 | |
| Alkalinity | mg/L as CaCO ₃ | | 271 | 282 |
| ANC | mg/L | | 291 | 91-K 7.3 282 276 240 54.0 26.0 240 21.0 340 20.0 36.0 1.00 0.012 0.01 905 1620 |
| Hardness | mg/L as CaCO ₃ | | 250 | 240 |
| Ca ²⁺ | mg/L | | 57.4 | 54.0 |
| Mg ²⁺ | mg/L | | 26.3 | 26.0 |
| Na ⁺ | mg/L | | 210 | 240 |
| \mathbf{K}^+ | mg/L | | 22.8 | 21.0 |
| Cl | mg/L | 250 | 358 | 340 |
| $\mathbf{SO_4}^{2-}$ | mg/L | 250 | | 20.0 |
| SiO ₂ | mg/L | | 42.4 | 36.0 |
| Fe _T | mg/L | 0.30 | 5.00 | 1.00 |
| Mn _T | mg/L | 0.05 | 0.05 | 0.012 |
| Al_T | mg/L | 0.05 - 0.20 | 0.02 | 0.01 |
| TDS | mg/L | 500 | 1,070 | 905 |
| Specific Conductance | μS/cm | | 1620 | 1620 |
| B – Boron* | mg/L | | 0.47 | 0.32 |

Table 3 Yorktown-Eastover Aquifer Water Quality

* Boron -WHO recommended limit of 0.50 mg/L.

The DEQ data set also include two wells which advance deeply into the Upper Potomac aquifer with a screen interval between -1,025 feet (MSL) and -1,088 feet (MSL). The water quality in this aquifer shows decreases in both hardness and iron. However, significantly higher levels of chlorides and TDS in the Upper Potomac make the Yorktown-Eastover aquifer more appealing as a community potable water supply.

All background DEQ water quality summary information can be found in Appendix H.

3.6 Battlefield Golf Course Groundwater Quality

Kimley-Horn and Associates, Inc installed three monitoring wells at the Battlefield Golf Course on May 15, 2008. Groundwater samples were taken and tested in May, July and August 2008. Meanwhile, groundwater samples were also taken from three monitoring wells located outside of the golf course in July. All the test results are summarized in Appendix I.

Table 2A in Appendix I demonstrates the metal analysis for three onsite monitoring wells. Below is a list of the constituents exceeding the drinking water standards:

- Aluminum (Al) average at approximately 56.0 mg/L (above the secondary limit of 0.20 mg/L)
- Arsenic (As) average at approximately 0.053 mg/L (above the secondary limit of 0.010 mg/L)
- Chromium (Cr) average at approximately 0.126 mg/L (slightly above the primary limit of 0.10 mg/L)
- Iron (Fe) average at approximately 101.80 mg/L (above the secondary limit of 0.30 mg/L)
- Lead (Pb) average at approximately 0.047 mg/L (above the "action level" of 0.015 mg/L)
- Manganese (Mn) average at approximately 0.784 mg/L (above the secondary limit of 0.050 mg/L)

Table 2B in Appendix I summarizes the metal analysis for the three offsite monitoring wells. Except for one offsite monitoring well having a high level of beryllium (Be), the results indicate lower levels of constituents in the offsite groundwater samples than those from the golf course groundwater samples. However, the levels of aluminum, iron and manganese at all offsite locations and the level of lead at two offsite locations still exceeded the drinking water standards.

Table 3A in Appendix I shows that the groundwater samples taken from the golf course met the secondary drinking water criteria for the classical chemical parameters, chloride (Cl), fluoride (F), sulfate (SO₄), and total dissolved solids (TDS).

4.0 WATER SUPPLY ALTERNATIVES

Based on the City's concern for the public health of the community from the potential contamination that may migrate from the Battlefield Golf Course to impact the private wells, URS investigated water supply alternatives to serve the adjacent properties. Common issues to all the alternatives include plumbing costs and water taste. All alternatives will require plumbing modifications for each homeowner or business. This will be necessary whether a house connection is made to a proposed distribution system or improvements are contained on-site, i.e. new well (Alternative 4) or Point of Entry Device (Alternative 3). A new water source, even if water is taken from the same aquifer, may taste different to different people. The New Community Water Supply Alternative (2) assumes chlorine as a disinfectant to maintain a residual in the distribution system. Consumers may observe a "chlorinous" taste due to the "free" chlorine residual. The City water system extension (Alternative 1) uses chloramines to maintain a residual in the distribution system. This type of residual typically imparts less of a chlorinous taste than free chlorine. No disinfectants are normally required with Alternatives 3 and 4.

4.1 Alternative 1 - Extend City of Chesapeake Water Distribution System

Presently the City of Chesapeake has two water treatment plants (WTPs) and contracts to purchase water from the cities of Norfolk and Portsmouth. Additional water is available from an auxiliary well source. These many sources give the City of Chesapeake the capacity to deliver the necessary quantity of water to all of the homes/businesses in the region of the Battlefield Golf Club. The City anticipates that the existing system has adequate water supply to handle future growth rates, at the current pace, until approximately 2040. A transmission main would be constructed from the City's existing water distribution system to extend the water services to the homes on Centerville Turnpike, Murray Drive, and Whittamore Road (See Exhibit 1). All of the water produced for the City of Chesapeake meets SDWA regulations. Chesapeake monitors over 100 contaminants, including herbicides, pesticides, radionuclides, heavy metals Cryptosporidia, Giardia, and coliform bacteria. Every year the City of Chesapeake publishes its consumer confidence report (CCR) detailing the water sources, purification processes, and the results of water quality testing² to ensure that all provision and standards set forth by the Safe Water Drinking Act (SDWA) are met. The 2008 CCR is presented in Appendix J. The water quality table details the highest level and range for the detected compounds found in the City of Chesapeake's drinking water. In summary, the water supply meets all regulations set forth by the Federal and State Agencies.

Under this alternative, the City of Chesapeake would construct, operate, and maintain the extended water supply system. The basic function of the City of Chesapeake would be to treat water from one of its sources to an acceptable quality, and deliver the desired quantity

² More than 195,000 analyses throughout the water treatment process are performed annually for regulatory compliance.

of water though the established distribution system and proposed extension to the study area.

4.1.1 Water Main Extension

The extension of the existing City water distribution system will require the installation of a 16-inch transmission main along Centerville Turnpike and a 10- and 8-inch distribution system along Murray Drive and Whittamore Road.

Centerville Turnpike is

predominately a 50-foot wide rightof-way, containing a two lane major collector street with roadside ditches for stormwater drainage. Additional widening for a center turn lane has been added to Centerville Turnpike at Whittamore Road along with additional right-of-way. The road widening for a center turn lane extends south with variable widening to Murray Drive.

Murray Drive is a 50-foot right-ofway section with curb and gutter



Centerville Turnpike

serving adjacent homes with connection to Whittamore Road. Whittamore Road is a narrow rural 30-foot right-of-way, containing a two lane pavement section, with roadside ditches. In places the ditches are deep and close to the edge of pavement.

The 16-inch line begins with a connection to the existing 16-inch just north of Etheridge Manor Blvd. and extends northward on the west side of Centerville Turnpike to a connection point with the proposed 16-inch line installed as part of the Albemarle Acres project for a distance of 7.730 feet. This line will be reinforced for flow and pressure with a 16-inch connection between Fentress Road and Centerville Turnpike along Blue Ridge Road. The new 16-inch line is needed to meet domestic and fire protection needs for the users along Centerville Turnpike, Murray Drive and Whittamore Road. Typically the 16-



inch line will be installed in the shoulder along Centerville. The existing roadside ditch



PROPOSED 10" / 8" WATER MAIN

> TIE TO EXISTING 16" WATER LINE

| DATE | 1/26/09 | SCALE |
|-----------|----------|-------------|
| PROL # | 11657474 | |
| DRAWN | MES | HORIZONTAL. |
| DESIGNED | SDE | |
| CHECKED | PSF | VERTICAL |
| PROT MICH | SOF | None |

will be relocated away from the edge of the road to create the corridor for the water line. Where needed, a "Drainage, Water and Sewer Easement" will be acquired for construction that extends beyond the right-of-way. The design of the 16-inch interconnecting main in Blue Ridge Road will be coordinated with the Department of Public Works road project for the relocation of Blue Ridge Road. Fire hydrants will be place at 500-foot intervals to provide fire protection along this route.

The Murray Drive-Whittamore Road loop will be a combination of 10 and 8-inch lines as needed to meet the fire protection requirements. The loop begins with a connection at the Murray Drive and Centerville Turnpike intersection. The new line will be placed 2-feet behind the south curb and gutter line along Murray Drive to the intersection with Whittamore Road for a distance of 7.300 feet. In several places, the line will transition to the pavement to avoid certain groups of trees and physical improvements at driveways. Most driveways will be



Whittamore Road

cut to allow a trench to be excavated for the installation of the water main. The driveway section will be replaced with "in-kind" materials, i.e., concrete, asphalt, gravel, etc. The distribution system loop along Whittamore Road from Murray Drive to Centerville will be 8,100 in length and placed under the existing pavement. Fire hydrants will be placed at 500-foot intervals along both roadways for fire protection. Easement will be acquired along Whittamore Road for the placement and access of the fire hydrants and water meters.

4.1.2 Water Service Connections

Each residence will have a separate service connection to the City of Chesapeake water supply. The City's Department of Public Utilities will furnish, install and maintain the service line from its water distribution main to the water meter, including the meter facilities. The plumbing connection from the meter to the house will be installed and maintained by the customer at their own expense and in accordance with the local plumbing code.

Each service would be separately metered. Charges for all water use would be on a metered rate basis as determined by the classification of the service and the applicable rate schedule. Cost of a new service connection shall be as provided in the City's rate schedule³.

³From the City of Chesapeake's web site the connection fee for a standard 5/8" residential water meter is \$3,697 plus a \$150 installation charge for a total of \$3,847, exclusive of other plumbing fees on private property.

4.1.3 Distribution Supply/ Fire Protection

The water supply would be sufficient to meet various water demand conditions and to meet normal demands during emergencies, such as power outages and disasters. The supply sources meet maximum day demands that occur for several consecutive days and are capable of meeting peak hour demands using water supplied from storage facilities. The system would be designed so that if any portion of the supply is placed out of service due to malfunction or maintenance the maximum day demand can still be met.

The City of Chesapeake will also provide fire flow protection to the new service area. The system will be capable of providing a minimum of 1,000 gpm at a pressure of at least 25 psi. A normal design criterion is to sustain fire flows for a minimum of 2 hours. Typical service pressure will be consistent with water supply throughout the citywide distribution system and be on the order of 40-60 psi.

4.1.4 Other Considerations

This alternative would include periodic sampling provisions from a series of monitoring wells to be installed by the City in the immediate vicinity of the Golf Course. Samples would be analyzed for constituents that may potentially leach from the Golf Course flyash, including:

- Primary contaminants: arsenic (As), barium (Ba),), beryllium (Be), cadmium (Cd), chromium (Cr), mercury (Hg), lead (Pb), selenium (Se), thallium (Tl)
- Secondary contaminants: silver (Ag)
- Other unregulated elements: boron (B), vanadium (V)

In this manner, homeowners could continue to use their existing well if they so desire. If the levels of any of the above contaminants begin to rise in the monitoring wells in the future to unsatisfactory levels, the homeowner could then decide if he/she wants to connect to the City system. Prevailing City connections fees would apply. Any homeowner who continues to use their existing well should grant the City a release of liability for failure to connect to City water when water system improvements have been offered by the City.

Recent reports from the City's Department of Public Works indicate that the existing Whittamore Road is built on a questionable subbase and complete roadway restoration should be included in the design.

4.1.5 Advantages/Disadvantages

The advantages and disadvantages of providing an extension of the City distribution system to serve all homes in the study area include:

| ADVANTAGES | DISADVANTAGES |
|--|--|
| • Access to the Highest Quality Water | • Water Bill |
| Technically Easy Solution | Price of Connection Fee |
| Implemented Quickly | Loss of Private Well * |
| Benefit that eliminates Homeowner Operation and Maintenance Responsibility Highest Level of Fire Protection Protects Public Welfare Minimizes Environmental Impact Redundancy – Reliable Water Possible Increase in Property Values | • Easements Necessary for Fire Hydrants, Water Meters & Drainage |

* Private wells may be used for irrigation purposes provided a physical disconnection from the home's plumbing system is made.

4.2 Alternative 2 - New Community Water Supply System

The second alternative would be to provide a new community water supply system for the service area. This alternative would be a stand alone groundwater supply, treatment, and distribution system (See Exhibit 2). This alternative has five major functional components: raw water development (wells), raw water treatment, residuals and concentrate disposal, finished water storage, and finished water distribution as well as associated subcomponents. The subcomponents include valves, pumps, power transmission, fire hydrants, back-up generator, and control operations among others. The schematic below indicates the components included in Alternative 2.



4.2.1 Community Water Demand

There will be an assumed 100 homes to be provided water. The per diem water use per dwelling unit is 400 gallons per day (gpd). The expected community average daily use will be 40,000 gpd. The maximum daily demand will be much higher. Typical peaking factors (or multiplication factors) for water systems of this size are approximately 3.0 (for maximum daily demand compared to the average daily demand). The smaller the system the higher the peaking factor and this community system is considered a very small water system. A factor of 3.0 has been assumed such that the maximum daily demand is expected to be 120,000 gpd.

4.2.2 Raw Water Development: Proposed Aquifer Source

Based on its relatively shallow depth, reasonable water quality and productivity, and based on information from the hydrogeologic review, the Yorktown-Eastover aquifer was the selected source of water. The raw water characteristics have been summarized previously. The aquifer may be semi-confined in the study area and provides a mitigating aquitard that may retard the migration of potential contaminations from the Surficial aquifer while also having the least total dissolved solids of the other potential raw water sources. The Yorktown-Eastover aquifer is also a more generally treatable water source when compared to the other groundwater supplies available within the project area. Iron, manganese, zinc, and total dissolved solids (TDS) concentrations are above the EPA's secondary standards, but will be removed with treatment.

4.2.3 Proposed Well Information

Assuming an average need of 40,000 gallons per day (gpd), a maximum water quantity requirement of 120,000 gpd, and that the water needs to be produced in a 12 hour cycle, a well field capable of delivering 170 gpm is required to meet the maximum demand.

Based on published literature, production wells installed in the Yorktown-Eastover aquifer produce an average of 87 gpm with a reported range of 12 - 304 gpm (Siudyla, et al., 1981). For planning purposes, an average production rate of 90 gpm per well is assumed. VDH regulations require a minimum well production 50 gpm for this sized community. A total of two supply wells with one additional backup well is required to obtain the necessary quantity of water and provide a suitable backup for the system⁴.

To avoid overlapping cones of depression that would reduce the yield of the well field; wells will need to be spaced a minimum of 1,500 feet apart, meaning that property for each well would need to be acquired and piping installed to transmit the water from each well to the treatment plant.

⁴*Recommended Standards for Water Works, Great Lakes – Upper Mississippi River Board of State Provincial Public Health and Environmental Standards* (Ten State Standards⁴) stipulates the total developed groundwater source capacity shall equal or exceed the maximum day demand with the largest production well out of service.



4.2.4 Aquifer Water Quality and Treatment Requirements

The source of supply for the community system would be the Yorktown-Eastover Aquifer. The water quality of this source has been discussed in Section 3.5. There are several secondary drinking water levels that are expected to be exceeded prior to treatment and are illustrated below.

| Contaminant | Expected Concentration Range (mg/L) | Secondary Standard (mg/L) |
|---------------------------------|---|------------------------------|
| Iron - Fe | 1.00 - 5.00 | 0.30 |
| Manganese - Mn | 0.012 - 0.050 | 0.05 |
| Zinc - Zn | 6.00 - 8.00 | 5.00 |
| Chloride - Cl | 340 - 350 | 250 |
| Total Dissolved Solids - TDS | 905 -1,070 | 500 |

Water with high levels of salts, measured as TDS, are less than palatable to consumers and impart a salty taste to the water. The EPA's secondary drinking water standard for aesthetic quality is 500 mg/L TDS; the World Health Organization guideline is 1,000 mg/L TDS maximum. Thus 905 – 1,070 mg/L is not within this range of 500 – 1,000 mg/L for the marginal acceptability of a water source as a drinking water supply. Removal of salts requires demineralization by ion exchange, electrodialysis, or reverse osmosis. While it is obvious that a new water treatment facility must meet the present drinking water regulations it is also prudent to consider future drinking water standards when planning a new treatment facility. Reverse Osmosis (RO), in addition to removing TDS, is capable of removing virtually all other contaminants present in a raw water source.

Other secondary contaminants in the water including iron, manganese, and zinc are also elevated. While the zinc and manganese concentrations are nearing their respectively taste thresholds, iron is significantly elevated. These contaminants are also problematic foulants to reverse osmosis membranes. Thus a pre-treatment system is required to remove these contaminants.

4.2.5 Reverse Osmosis Treatment

RO membrane filtration produces superior water that can meet even the most stringent drinking water regulations. The RO treatment acts as barrier to potential contaminants of the aquifer water source. RO is a physical process in which suitably pretreated water is delivered at moderate


pressures against a semi-permeable membrane. The principle theory of RO is applying a pressure greater than the osmotic pressure of water. This pressure causes water to pass through a semi-permeable membrane from the high TDS side of the membrane to the lower TDS side. The membrane is designed to reject the salts in the water. The membrane rejects most solutes, ions and molecules, while allowing water of very low mineral content to pass. The phenomena by which certain membranes reject different species of ions differently is very complex. Nevertheless, an RO process produces a concentrated waste stream in addition to a clear permeate product. Reverse Osmosis systems have been successfully applied to saline ground waters, brackish waters, and seawater as well as for inorganic contaminants and other contaminants such as pesticides, viruses, bacteria, and protozoa and are presently used by the City of Chesapeake at the Northwest River Water Treatment Facility. For this community system the RO units would have a 2-pass configuration to minimize the volume of concentrate production due to the location of the facility and to enhance water recovery. Appendix M presents a detailed depiction of an RO system and is associated components sized for the community water system.

A generalized summary of contaminant removal capabilities of RO is shown in the Table below. Such removal rates are dependent upon many factors.⁵

| Contaminant | Percent Removal |
|---|-----------------|
| Inorganics | 90 - 99 |
| Volatile Organic Compounds | 5 - 50 |
| Pesticides and Synthetic Organic Compounds | 90 - 99 |
| Microbiological | > 99 |
| Radiological | 90 - 99 |

4.2.6 **Pre-Treatment Processes**

Pretreatment would be necessary to remove the elevated iron in the water. The precipitation/filtration process is a well known technology for iron removal. The process initially oxidizes the raw water to change the iron, manganese and other reduced species to an oxidized form which form insoluble precipitates with hydroxide ions in the water. Additional chemicals may also be necessary to adjust pH to an optimal level and to assist in the agglomeration of particles for filtration. Filtration occurs in pressure filter vessels where the insoluble iron/manganese particles are trapped in the media. The filters are backwashed once the vessels reach a predefined pressure differential which results from ferric hydroxide precipitate building up within the filter. Backwash waters can be voluminous and need proper management and the resulting concentrated solids must be handled either by sludge removal or pumped via a force main to the sanitary sewer system.

⁵ These include membrane type, feed water pressures, number of passes, among others.

The pretreatment is also necessary to condition the raw water so that is does not damage the reverse osmosis equipment. All total suspended solids (TSS), oxidizable elements, scaling compounds must be significantly removed to reduce operational costs associated with RO water production.

4.2.7 Permitting Requirements

The project area is located within the Eastern Virginia Groundwater Management Area (9VAC 25-600-20), and the groundwater withdrawn for community well systems are permitted by DEQ. This alternative is projected to withdraw an average of more than 1 million gallons per month from the Yorktown-Eastover aquifer. In accordance with Virginia's Groundwater Management Act of 1992 (VA Code 62.1-254 et seq. and Virginia's Ground Water Withdrawal Regulations (VA Administrative Code 9 VAC 25-610-10 et seq.) a Ground Water Withdrawal Permit is required as more than 300,000 gallons of groundwater will be withdrawn per month under this alternative.

This process typically consists of preparing a Permit Application consisting of the installation of a test well, conduct of an aquifer test, and compilation of information in support of the permit application. This permit application is submitted to the DEQ and a public hearing is typically required. The test well is typically converted to one of the production wells to minimize capital costs.

As the Yorktown-Eastover aquifer is relatively heavily used in the region, additional withdrawals will be closely scrutinized by DEQ. In addition, one of the criteria that DEQ uses to evaluate these permit applications is the availability of alternative water sources (i.e., existing municipal water supplies). In light of the City's willingness to extend City water to this area, DEQ may not grant the permit because an alternate source is available.

The implementation of an RO facility requires that national, state, and local environmental regulations are met as well as local land use and zoning regulations. The water quality standards that the new facility must meet have been detailed extensively in Section 2.4. The waste disposal permitting associated with the concentrate disposal will require considerable effort. Regulations that pertain to concentrate discharge are complex and stringent. One initially discussed disposal alternative of delivering the brine to the Chesapeake Northwest River WTP and combining the waste stream with the brine produced at that plant has been rejected by the City because of such rigorous and inflexible permitting requirements that are presently in place at the facility. The present alternative to handle the liquid wastes generated by the proposed water treatment facility include the construction of a pump station and force main to convey the reject and backwash waters to the Hampton Roads Sanitation District's (HRSD) transport and treatment facilities. Approval from HRSD would be required for the disposal of brine waste originating from the RO facilities. (It should be noted that the study area of the City is not contained within the Sewer Service Franchise Area. This would require City Council approval to allow wastewater to be discharged into the City's sanitary sewer system.) Considering potential contaminants that may be introduced and that concentrated brine waste will be introduced (specifically chloride), it is unlikely that HRSD would accept the waste as it would interfere with treatment or reduce re-use options of their treated effluent. Present

communication with Erwin Bonatz of HRSD indicates that major policy changes would be required to allow for the acceptance of the brine wastewater. This alternative at the present time is highly improbable.

The development of a community public water supply system would require construction and operation permits from the Virginia State Health Department, Office of Drinking Water (12VAC5-590-200). The procedure for obtaining the Construction Permit includes the following steps: (i) the submission of an application, (ii) a preliminary engineering conference, (iii) the submission of an engineer's report (Optional at the discretion of the Field Director), and (iv) the submission of plans specifications, design criteria and other requested data. Following the issuance of the Construction Permit, the project may proceed to construction. After the facilities have been constructed in accordance with the approved plans and specifications, certified by a professional engineer, the VDH may issue an Operation permit. It is extremely doubtful that the VDH would issue a Construction Permit since City water is a viable alternative.

4.2.8 Post Treatment Water Conditioning

RO produces finished water that has low alkalinity and pH because the bicarbonate ions do not generally pass through the membranes. This creates water that has little buffering capacity, is corrosive, and is objectionably soft. Lime and caustic soda are chemicals that are typically utilized to increase the alkalinity and pH following treatment.

4.2.9 Disinfection/Fluoridation Requirements

All drinking water must be disinfected to insure that no biological contamination is present in the water or the water distribution system. A chlorination system would be necessary to impart a residual chlorine level in the finished water prior to entry into the distribution system.

Fluoridation is the adjustment of the fluoride concentration of the public water supply in accordance with scientific and medical guidelines. A sodium fluoride saturator will be utilized to feed fluoride to the finished water. A saturated fluoride solution is pumped into the water as it leaves the WTP to the distribution system.

4.2.10 Distribution System Requirements

The 8-inch water line to support the community water supply will follow the route along Centerville Turnpike, Murray Drive and Whittamore Road described in paragraph 4.1.1 and shown on Exhibit 2. The water line will be connected to the well, treatment and storage facilities and fire hydrants will be provided at 500-foot centers along the route.

4.2.11 Water Storage Facilities – Fire Protection

Sufficient water storage volume must be provided to allow for fire protection, and domestic demand consumption. Required storage tank volumes are calculated by computing domestic demands as prescribed by VDH and fire flow demands (See Appendix K). The VDH requires a minimum storage of 200 gallons per equivalent residential connection or 20,000 gallons for the study area. This VDH requirement does not include fire protection.

While there is no specific legal requirement governing fire protection needs, insurance companies establish fire insurance premiums for residential and commercial properties based on measured fire flow capacities within a Town or community. AWWA M31 – Manual of Water Supply Practices, Distribution System Requirements for Fire Protection, outlines various methods of determining required fire storage needs. These values shall be a minimum 1,000 gpm for 2 hours. Considering the necessary duration and flow rate, 120,000 gallons of storage is required for fire protection. However, using VDH calculations for communities of less than 1,000 ERC, the fire flow storage requirements of 120,000 gallons also satisfy the domestic demands. This option will met fire codes; however, it does not have the same capability for fighting fires for as long a time period as Alternative1.

4.2.12 Land Acquisition

In order to implement a new community water supply system, the City would need to purchase land for the treatment facility itself as well as the proposed three supply wells and water storage tank. Depending on the location of the wells and treatment facility additional easements are likely necessary to install a raw water transmission main that would bring the raw water from the wells to the treatment location.

4.2.13 O&M Issues

The community system alternative would bring significant operational burdens to the City of Chesapeake. A full time operations staff would be necessary to operate the intricate treatment system and to address all maintenance items associated with the unit processes, residuals and waste stream handling, and distribution system. There would also be new analytical, energy, and chemical costs to operate the system.

Typically water utility billing rates cover capital improvement loans as well as operating and maintenance costs. The City of Chesapeake's Public Utilities Charges effective July 1, 2008 for a 5/8" meter are \$17.50 for the first 300 cubic feet (2,244 gallons) of water and \$3.878 for usage over 300 cubic feet (Public Utility Charges are depicted in Appendix L). At this billing rate and at average water demands, only approximately 50% of the expected O& M costs for the community water system would be covered from the community system's customers.

4.2.14 Other Considerations

This alternative should include periodic sampling provisions from a series of monitoring wells to be installed in the immediate vicinity of the Golf Course. Samples should be analyzed for constituents that may potentially leach from the Golf Course flyash, including:

- Primary contaminants: arsenic (As), barium (Ba),), beryllium (Be), cadmium (Cd), chromium (Cr), mercury (Hg), lead (Pb), selenium (Se), thallium (Tl)
- Secondary contaminants: silver (Ag)
- Other unregulated elements: boron (B), vanadium (V)

In this manner, homeowners could continue to use their existing well if they so desire. If the levels of any of the above contaminants begin to rise in the future to unsatisfactory levels, the homeowner could then decide if he/she wants to connect to the City system. Prevailing City connections fees would apply. Any homeowner who continues to use their existing well should grant the City a release of liability for failure to connect to City water when water system improvements have been offered by the City.

4.2.15 Advantages/Disadvantages

The advantages and disadvantages of providing a new community supply, treatment, storage and distribution system to serve all homes in the study area include:

| ADVANTAGES | DISADVANTAGES |
|---|---|
| Access to High Quality Water | Exorbitant Water Production Costs |
| Limited Fire Protection | • Water Bill |
| • Eliminates Homeowner Operation and Maintenance Responsibility | • Price of Connection Fee |
| Protects Public Welfare | Loss of Private Well* |
| • Redundancy – Moderately Reliable Water | • Extensive Permitting Issues |
| | Brine Waste Disposal is extremely cost prohibitive Obtaining Groundwater Withdrawal Permit May Not Be Feasible VDH Construction Permit Unlikely to Be Approved Technically Challenging Solution |
| | Operationally Expensive Introduction of Potentially Hazardous Water Treatment Chemicals in Neighborhood Long Implementation Schedule Land Acquisition Necessary Easements Necessary for Fire Hydrants, Water Meters & Drainage Large Capital Expense Great Environmental Impact |

* Private wells may be used for irrigation purposes provided a physical disconnection from the home's plumbing system is made.

Alternative 3 – Individual Point of Entry (POE)⁶ Treatment System for 4.3 **Existing Wells**

This alternative uses similar treatment technologies previously discussed in Alternative 2. However, this alternative places the treatment system at each home or business to treat water from each existing well. The same pre-treatment methods are required. These systems are designed for an individual homeowner up to 400 gallons per day (gpd). Perhaps the biggest difference between the individual systems and the community system is the efficiency of water treatment. While the recovery of the community system can reach 92% recovery of the raw water the individual systems only reach approximately $40\%^7$. The consequence of this reduced recovery is that a home creates over twice the amount of rejected, unusable water as a waste brine needing disposal as the amount of potable water actually produced.

A pretreatment system will consist of a 40 gallon raw water tank that will store water pumped from the well. An RO system requires significant energy to pass the water through the membrane and the existing wells will not provide the required energy for this. A booster pump will then pump the water through the RO system and into a new 40 gal pressurized "bladder" tank that will supply water pressure to the home. The bladder tank eliminates the need for the well pump and RO system to turn on every time there is a user demand. Prefiltration is also necessary to preserve the membranes. Typical pretreatment will include a manganese dioxide mineral filter, ion exchange vessel, and carbon filtration. Appendix N gives a detailed depiction of a Point of Entry RO system and its associated components.

4.3.1 **Housing Requirements**

The individual RO units required are approximately 3' x 4' x 5.5' The RO units typically are on fiberglass mounting skid. With the required pretreatment system, the motor, electrical controls, conductivity monitor, pressure gauges, control valves, pressure switches, and high pressure piping will require a set-up location outside of the house. An 8' x 10'



⁶ It is an important to differentiate between Point of Use (POU) treatment and Point of Entry (POE) Treatment. POU systems treat water at a single "tap" and are typically installed "under the kitchen sink." POU system can process only a small percentage of the necessary total average residential design flow of 400 gpd/ERC. Whole house (POE) systems can process this requirement of 400 gpd/ERC.

⁷ High efficiency systems are available at much higher costs. These higher efficiency systems are more complicated as well because reject water is fed back to the feed tank to increase the efficiency. High efficiency systems typically operate at 125 -235 psi and have high quality components such as fiberglass membrane housings, as well as a feed tank with level controls to control recirculation rate of the reject water and to maintain flow across the membranes to optimize their performance.

storage shed with concrete floor will be needed to house the system.

4.3.2 Brine Handling

The reverse osmosis unit will reject TDS a concentrate that will have a brine concentration of approximately 1,300 mg/L. The concentrated brine will need to be properly disposed. According to VDH, the brine reject would not be permitted to enter a septic tank and leach field which is how the home's wastewater needs are presently served. Liquid hauling may be an expensive alternative if an approved discharge location could not be identified.

The present alternative to handle the liquid wastes generated by the proposed POE treatment systems include the construction of a pump station and force main to convey the reject water to the Hampton Roads Sanitation District's (HRSD) transport and treatment facilities. Approval from HRSD would be required for the disposal of brine waste originating from the RO facilities. (It should be noted that the study area of the City is not contained within the Sewer Service Franchise Area. This would require City Council approval to allow wastewater to be discharged into the City's sanitary sewer system.) Considering potential contaminants that may be introduced and that concentrated brine waste will be introduced (specifically chloride), it is unlikely that HRSD would accept the waste as it would interfere with treatment or reduce re-use options of their treated effluent. Present communication with Erwin Bonatz of HRSD indicates that major policy changes would be required to allow for the acceptance of the brine wastewater.

4.3.3 O&M Issues

There are problems with the POE systems that are hard to overlook. These include noise, poor aesthetics of equipment & tanks, complicated process to operate/repair, costly maintenance contracts, and the concern that the existing well may not produce sufficient water to create the needed clean water flow. Preliminary discussion with VDH indicates their desire to have the City maintain the individual systems because of their water treatment expertise and to maintain continuity following the transfer of properties when homes are sold. This task could be contracted by the City to a qualified private vendor. Vehicular access would be needed in the event that heavy equipment needed to be removed. The treatment housing units would need to be positioned in front yards which are typically not fenced, to provide uninhibited access now and in the future. There may be safety concerns by some residents who are uncomfortable with he additional "foot traffic" on their property. Each property owner would be required to enter into access and maintenance agreements with the City to allow these functions to be performed. This added expense would be billed to the residents by the City.

4.3.4 Other Considerations

Any homeowner who continues to use their existing well should grant the City a release of liability for failure to connect to City water when water system improvements have been offered by the City.

4.3.5 Advantages/Disadvantages

The advantages and disadvantages of providing new point of entry RO treatment systems for all homes include:

| ADVANTAGES | DISADVANTAGES | | | | | |
|--------------------------------|--|--|--|--|--|--|
| • Access to High Quality Water | • Extra Building On Property | | | | | |
| Protects Public Welfare | Access Agreement Needed For | | | | | |
| | City or Third Party Maintenance | | | | | |
| Continued Use of Private Well | High Electrical Expense to Owner | | | | | |
| | Water Bill For City Maintenance | | | | | |
| | Chemical Storage on Site | | | | | |
| | • Noise (can be attenuated in sound proof housing) | | | | | |
| | • Brine Waste Disposal would be the | | | | | |
| | Responsibility of the Homeowner | | | | | |
| | and would be Extremely Cost | | | | | |
| | Prohibitive | | | | | |
| | Increased Homeowner Burden | | | | | |
| | Permitting Issues May Be | | | | | |
| | Prohibitive | | | | | |
| | No Redundancy | | | | | |
| | No Fire Protection | | | | | |
| | Significant Environmental Impact | | | | | |

4.4 Alternative 4 – Development and Installation of New Individual Home Owner Supply Wells

This alternative consists of drilling and installing new individual residential water supply wells into an aquifer that is less susceptible to impacts from degradation of water quality should monitoring data indicate the release of contaminants from the Battlefield Golf Club into the Surficial aquifer and migration of these contaminants toward the residential wells.

4.4.1 Current Groundwater Conditions and Ongoing Investigations

As discussed in Section 3.4, analytical data obtained from home owner wells in the study area indicate that the current groundwater quality supplied from wells installed into both the Surficial and Yorktown-Eastover aquifers have naturally high levels of iron and manganese, which are both regulated as "secondary" contaminants, but the water is generally suitable for potable use. However, monitoring wells installed and sampled at the Battlefield Golf Club have detected inorganics in the groundwater at concentrations that may pose health threats (Kimley-Horn, 2008) in the Surficial aquifer.

As groundwater flow in the Surficial aquifer is generally toward the southeast based on available information, residential wells installed in this aquifer that are located in this

direction from the golf club may be impacted in the future. Currently, insufficient data exists to accurately predict if (or when) the detected analytes could migrate to the location of existing residential monitoring wells. However, ongoing investigations may provide adequate data to make this determination.

4.4.2 New Well Installation

Based on the results of ongoing studies, should it be determined that the Surficial aquifer is impacted, that the contaminants are migrating toward the residential wells, and that the underlying Yorktown confining zone serves to protect the underlying Yorktown-Eastover aquifer from these contaminants, installation of replacement wells into the Yorktown-Eastover aquifer could be successful. These wells would be designed and installed to seal off the Surficial aquifer and withdraw water from the Yorktown-Eastover aquifer.



The number of residential wells currently installed into the Surficial aquifer as opposed to the Yorktown-Eastover aquifer is unknown, as residential well records were not found for all of the wells located in the area, and home owners who responded to the questionnaires sent out as part of this study did not know the depth of their wells. Based on the records that were obtained from the City of Chesapeake Department of Health, it is assumed that half of the wells are installed into each aquifer. However, the well construction techniques used for wells installed into the Yorktown-Eastover aquifer may not sufficiently seal off the Surficial aquifer; thus providing a conduit for water to migrate from the Surficial aquifer downward into the Yorktown-Eastover aquifer.

Therefore, this alternative consists of proper abandonment of all existing homeowner wells, followed by the installation of new water supply wells into the Yorktown-Eastover aquifer that appropriately seal off the Surficial aquifer. Based on responses to questionnaires, some homeowners have installed water softeners to improve water quality, and this alternative includes the installation of such treatment along with filters, pressure tanks and other appurtenances typically associated with residential well systems.

4.4.3 Permitting Requirements

The City of Chesapeake Department of Health regulates the installation of private water supply wells (Class III wells) in accordance with the Virginia *Waterworks Regulations*. A

Virginia licensed well driller is required to install the wells and these companies are familiar with obtaining the required permits. Since each private well will withdraw a relatively small volume of water, the provisions of the Eastern Virginia Groundwater Management Area are not applicable. However, DEQ may question this approach since the combined withdrawal is equivalent to Alternative 2 using a series of community water supply wells.

4.4.4 Other Considerations

This option does not guarantee a reliable solution from potential contamination and homeowners' fears may continue.

4.4.5 Advantages/Disadvantages

The advantages and disadvantages of providing new, deeper homeowner wells include:

| ADVANTAGES | DISADVANTAGES | | | | |
|--|--|--|--|--|--|
| • Inexpensive | Potential for Future Water Quality Issues | | | | |
| Continued Use of Private Well (Surficial Aquifer only) for irrigation purposes | No Redundancy | | | | |
| | Does Not Minimize All Risk or Allay Homeowners Concerns No Fire Protection Continued Homeowner Maintenance | | | | |

5.0 COST EVALUATION AND RECOMMENDATIONS

5.1 Present Worth Opinion of Cost evaluations

The cost to install the four alternatives has been evaluated. Costs include all capital and operation and maintenance (O&M) costs. Using life cycle cost analyses helps correctly assess the most effective alternative. In a present worth comparison of alternatives, the costs associated with each alternative are all converted to a present sum of money, and the least of these values represents the best financial alternative. Annual costs over thirty years, future payments, and gradients must be brought to present value.

The present worth comparisons utilized in this report are *strictly for comparisons* and not actual cost estimations/determinations of the respective alternatives. Costs for site preparation, mobilization, demobilization, indirect costs, restoration, etc. were extrapolated from anticipated costs and scaled to match the anticipated requirements of each alternative. Important differences for each of the respective alternatives were also included to facilitate a comparison of the four alternatives present worth values. No brine disposal costs were included for Alternatives 2 and 3 since our investigations did not discover any solutions that were not extremely cost prohibitive. These alternatives are considered no longer viable. Estimated cost data for the four alternatives are shown below. See Appendix O for the detailed present worth alternative comparison.

| | Alternative 1 | Alternative 2 | Alternative 3 | Alternative 4 |
|---------------|---------------------|---------------------------|---------------------------|---------------|
| Capital Cost | \$7,221,756 | \$8,2411,704 ⁸ | \$2,770,149 ⁸ | \$803,000 |
| Useful Life | 30 Years | 30 Years | 30 Years | 30 Years |
| O & M costs | | | | |
| City | \$3,000/yr | \$187,227/yr ⁸ | \$460,879/yr ⁸ | \$0/yr |
| Homeowners | \$0/yr ⁹ | \$0/yr ⁹ | \$166,923/yr ⁸ | \$10,000/yr |
| Present Worth | \$7,267,873 | \$11,289,844 | \$9,854,989 | \$956,725 |

Alternative 1: Provide City of Chesapeake Water via a Water Main Extension.

Alternative 2: Install a Community Groundwater Supply, Treatment, Storage, and Distribution System.

Alternative 3: Install Point of Entry (POE) Treatment Systems on Existing Private Wells. *Alternative 4*: Development and Installation of New Private Wells into Yorktown-

⁸ Costs do not include brine disposal

⁹ Each residential connection shall have a separate service connection to the City of Chesapeake water supply. The city will maintain all service connections, including the meter facilities. *The house connection shall be installed and maintained by the customer at their own expense and in accordance with the standards established by the City Public Utilities Department*. The customer shall, at their own risk and expense, furnish, install and maintain in safe condition all equipment that may be required for receiving, controlling and utilizing water as the house connection.

Eastover aquifer.

The present worth value of each alternative is displayed above assuming:

- 1) Money is worth 5%, annual compounding,
- 2) Zero salvage value,
- 3) All other costs equal for all alternatives,

Present worth was determined as in the below example for Alternative 2:

Present Worth (Alternative 2) = P + A (P/A, 5%, 30)

$$= P + A \frac{\left[(1+i)^{N} - 1 \right]}{\left[i (1+i)^{N} \right]}$$

= 7,226,226+ 192,143 $\frac{\left[(1+0.05)^{30} - 1 \right]}{\left[0.05 (1+0.05)^{30} \right]}$
= 10,179,934

Alternative 4 is the least costly, while Alternatives 1 and 3 are comparable from a capital cost perspective, and Alternative 2 is the most expensive. Alternatives 1 and 4 benefit from a considerably reduced operations and maintenance (O&M) cost. The capital cost and O&M costs required for Alternative 2 make this choice not preferred from a present worth analysis. Likewise, Alternative 3 has such extensive O&M costs, that it is the least preferred from a present worth analysis perspective.

O&M costs have been divided between the City and Homeowners for each option. Alternatives 1 and 2 depict all the O&M costs being paid by the City. Alternative 3 shows a division of cost responsibility with the City absorbing the operations and sampling cost of the individual treatment units, while the homeowners pay for the electric and sanitary sewer disposal costs for the brine. All operational costs associated with Alternative 4 will be paid by the homeowner and would include electric and maintenance of the well system.

5.2 Alternative Evaluation Matrix

While a present worth analysis is invaluable in evaluating alternatives it should not be the only consideration. In this evaluation a decision matrix was developed which considered six categories of criteria to assess the alternatives. The six categories are as follows:

- 1. Regulatory Compliance Water Quality
- 2. Property Owner Impact
- 3. Operational Requirements
- 4. Technical Feasibility
- 5. Present Worth

6. Permitting / Administrative Burdens

Each category was further sub-divided into specific criteria and given a relative weight of importance on a scale of 0 - 10 (no importance rated 0, most important rated 10). The amount of "relative importance" is a comparison between the importances of the criteria. For example, as discussed below Regulatory Compliance is considered more important than Operational Requirements. A brief description of each follows below with a justification of its relative weight of importance.

Regulatory Compliance-Water Quality

The two specific criteria for this category are:

Meets VA Drinking Water Standards, and
 Long Term Compliance.

The criterion of providing safe drinking water that meets all applicable standards is the baseline for all future actions and was given a rank of 10. Equally important is insuring future water quality and maintaining long term compliance. This was also given a rank of 10. Overall Regulatory Compliance – Water Quality contributes 20% to the overall weighted score.

Property Owner Impact

An important component for the evaluation of alternatives is property owner impact. This category was subdivided into two criteria:

1) Affect Property Value, and

2) Homeowner responsibilities, increased burdens, safety

Obviously an inherent component to a home's marketability and value is the assumption that safe and potable drinking water is reliably available to perpetuity. The effect of the alternatives on the Home Property Value was given a rank of an 8. Equally important is the added burden to the homeowner to have this safe potable drinking water. The burdens include costs to obtain water (connections fees), cost for water use, increased energy consumption, access issues for City of Chesapeake run facilities, safety concerns with unknown personnel required to monitor systems among others. The Homeowner Responsibilities/Increased Burdens/Safety was given a rank of an 8. Overall Property Owner Impact contributes 16% to the overall weighted score.

Operational Requirements

The alternative selected should minimize waste generation, conserve resources, reduce energy expenditure and minimize greenhouse gases, and minimize impact on public resources (aquifers). These were collectively grouped into the criteria of Sustainability and given a rank of 8. Secondly, operational requirements should be fail safe. The selected alternative should have enough redundancy and reliability that future operational risks are minimized or eliminated. Also the selected alternative should have minimum complexity and ease of use so that safe water will always be available with a minimum of any interruption of service. Reliability was given a rank of 8. Overall Operational Requirements contribute to 16% of the overall weighted score.

Technical Feasibility

This category is governed by the time required for implementation, constructability, and the protection of the public welfare. Time is an important component in the alternative matrix because of the ramifications of a rapidly affected water source. In the event that water quality conditions in a water source were to decline, a rapidly implementable alternative for supplying potable water will be of utmost importance. The course of action should avoid complexity and reduce potential exposure to injury and/or release of contaminants. Constructability was given a rank of 6. Time for Implementation was given a rank of 8. This category contributes to 14% of the overall weighted score.

Present Worth

The present worth comparisons as described in the previous section were utilized in this category. The criteria of this category were capital and O&M costs. The necessary capital outlay to construct the project was given a rank of 10 while the O&M costs were given a rank of 10. This decision matrix weighted the Present Value of Costs as 20% of the overall importance.

Permitting / Administrative Burdens

This final category considers the necessary administration effort required to make the selected alternative a reality. Such burdens include permitting, zoning, pilot testing, public meetings and discussions, and administering construction contracts, among others. The permitting was given a rank of 8. The level of effort criterion was given a rank of 6. Overall the administrative burdens contribute 14% of the overall weighted score.

After the assignment of a relative weight between the various criteria each of the four alternatives was given a rating according to their anticipated performance with respect to the various criteria. The ratings follow a scale of 0 to 5 (exceptionally unfavorable rated 0 and exceptionally favorable rated 5). These rating were than multiplied by the relative weight to get a weighted rating. The sum of the weighted ratings for each of the alternatives resulted in total score with the highest score being the most favored. The details of the alternative decision matrix is presented in Appendix P.

The decision matrix shows Alternative 1 as the most desirable.

5.3 Recommended Alternative

It is understood that other, more comprehensive groundwater studies are currently being conducted in the area. Groundwater movement in this region is difficult to accurately predict in terms of leakage from one aquifer to another. The thickness and homogeneous characteristics of the confining zones could significantly vary in the study area, even from one street to the next. Therefore, the level of protection that may be provided by the confining zone between the Surfical and Yorktown-Eastover aquifer can not guarantee the

prevention of downward migration. Further, well construction techniques for most, if not all, of the existing wells withdrawing from the Yorktown-Eastover aquifer were most likely installed utilizing well construction methods that actually facilitate migration between the two aquifers. The migration or leakage (which has not been confirmed) could take place along the outside of the casing pipe since grouting between the exterior of the pipe and the confining zone typically is installed only 20 feet from the surface. The confining zone at the site is typically located some 50-60 feet below the surface.

The potential introduction of contaminants from the Golf Course fly ash into the Surficial aquifer through a leaching effect is a time consuming investigation and was beyond the scope of this study. However, the intent of this study was to identify implementable water source alternatives in an expeditious manner in the event that contamination was to occur. Based on the available information, it is not known if contaminants will leach from the fly ash and result in contamination of nearby wells. The data that was available to URS for this study does not show conclusive evidence that groundwater contamination from the Battlefield Golf Course property has migrated to residential water wells in the immediate vicinity. However, the threat of such an event is possible.

With the study area located within the Eastern Virginia Groundwater Management Area, it is considered unlikely that DEQ would approve a large groundwater withdrawal in this area with the availability of high quality City water in the vicinity. The City's drinking water meets all state and federal drinking water regulations and is closely monitored on a daily basis. The identification of regulatory-acceptable and cost effective means of brine waste disposal from an RO process – community system or individual systems, is doubtful.

Based on the investigations of the alternatives evaluated to supply potable water to the homes in the vicinity of the Battlefield Golf Course, it is recommend that the City proceed with the construction of Alternative 1 and extend the City distribution system to serve these areas. The provision of City water would allow for a safe, reliable, monitored water supply that would be most protective against any potential future impacts to the existing aquifer supply.

6.0 **REFERENCES**

- American Water Works Association (1990). *Water Quality and Treatment: A Handbook of Community Water Supplies* 4th Ed. McGraw Hill, Inc.
- American Water Works Association (2001). *Membranes: Practices for Water Treatment*. American Water Works Association. Denver, CO.
- American Water Works Association (2004). *Water Desalting: Planning Guide for Water Utilities*. John Wiley & Sons, Inc. Hoboken, NJ
- AWWA and ASCE (2005). Water Treatment Plant Design. McGraw-Hill. New York.
- AWWA Manual M4 (2004). *Water Fluoridation Principles and Practices* 5th Ed. American Water Works Association. Denver, CO.
- Boulos, P.F., K.E. Lansey, and B.W. Karney (2004). *Comprehensive Water Distribution Systems Analysis Handbook for Engineers and Planners*. MWH Soft, Inc. Pasadena, CA.
- Mays, Larry W (2000). Water Distribution Systems Handbook. McGraw Hill Companies, Inc.
- McFarland, E. Randolf and T. Scott Bruce, 2006. <u>The Virginal Coastal Plain.</u>
- <u>Hydrogeologic Framework.</u> U.S. Geological Survey, Professional Paper 1731.
- Meng, Andrew A., and John F. Harsh, 1988. <u>Hydrogeologic Framework of the Virginia</u> <u>Coastal Plain.</u> U.S. Geological Survey, Professional Paper 1404-C.
- MWH, Inc. (2005). *Water Treatment: Principles and Design* 2nd Ed. John Wiley & Sons, Inc. Hoboken, NJ.
- Siudyla, Eugene A., Anne E. May, and Dennis W. Hawthorne, 1981. <u>Ground Water</u> <u>Resources of the Four Cities Area, Virginia.</u> Commonwealth of Virginia, State Water Control Board, Bureau of Water Control Management, Planning Bulletin 331, November 1981.
- T. Scott Bruce, 2008. Personal communication between T. Scott Bruce, Virginia Department of Environmental Quality and Scott McClelland, URS Corporation, November 21, 2008.

APPENDIX A Resident Questionnaire

Table 1: Resident Questionnaire Summary Ware Suppher Besability Study Murray Drive – Whitamore Road Project City of Chesspeake, VA

| : | Residence(R)/ | Willing to Connect to City | Location of | Well | Year of Well | Well Pump | Well Pump | Adequate Water | Well Driller's | Well Depth | Water Treatment | Signs of | Signs of | Water Quality | | Consultant |
|--|---------------|--|-------------|---------------|--------------|-----------------------------|------------------|-------------------|----------------|------------|--|----------|----------|--------------------------|---------------------------------|--------------|
| Address | Business(B) | water ? | Well | Accessibility | Installation | Location | Information | Pressure? | Log | (11) | Device | Fe/Mn | Ca | lest | Non-domestic Use | Future VISIt |
| 826 Controvillo Tumoiro S | ٥ | | ano y | Voc | 1005 | Know | | Voc. | Ч | 70 | Yes For trop Demoval | SN SN | °N N | 2005 | CIN V | |
| 020 Ceruevile Lutipike o. | Ľ | 142 | NIOWI | 162 | 1300 | LIMOIN | 1 65 | 1 42 | 20 | 10 | | 00 | DN I | C007 | 00 | 165 |
| 1020 Centreville Turnpike S. (John Deere Landscapes) | В | | Known | Yes | 2000 | Warehouse | Yes | Yes | No | Unknown | No | Yes | Yes | N/A | Yes (Bussiness/Irrigation) | Yes |
| 1102 Centreville Turnpike S. | ж | Yes | Known | Yes | 1988 | Well House | No | Yes | No | Unknown | Yes (Self-serviced Softening Device) | No | No | No | ٥Ŋ | Yes |
| 1305 Centreville Tumpike S | ۵ | Уек | Known | Yes | Inknown | l Inknown | Yes | Yes | QN | l Inknown | Yes | Q | QN | Oct 2008 | Yes (I ivestock) | Удс |
| 1112 Murry Drive | . ~ | | Unknown | Yes | 1983 | Garage | 2 | Yes | e ov | Unknown | °N | Yes | °N | Sep. 2008 | Yes, very little (Livestock) | Yes |
| 1120 Murry Drive | ĸ | Yes | Known | Yes | 1977 | Garage | Flotec FP4112-08 | Yes | N | Unknown | No | Yes | Yes | Summer 2008 (By City) | Yes (Swimming Pool) | Yes |
| 1215 Murry Drive | × | Yes (At no charge to the resident) | Known | Yes | 1990 | Garage | Yes | Yes | No | Unknown | Yes | Yes | Yes | 2008 (Bv City) | oN | Yes |
| 1300 Murry Drive | ч | Yes | Known | Yes | 1990 | Garage | Yes | Yes | No | Unknown | Yes | Yes | Yes | No | Yes | Yes |
| 1441 Fentress Road 1431 Fentress Road 1401 Blueridge Road (Crossroads Properties) | ۵ | Yes | Known | Yes | Unknown | Unknown | Ŷ | Yes | Ŷ | Unknown | °Z | Yes | N/A | oz | Yes (Bussiness) | Yes |
| 1405 Whittamore Road | ъ | Yes | Known | Yes | 1994 | Shed | JET | No | No | Unknown | Yes | No | ٥N | 1996 | No | Yes |
| 1417 Whittamore Road | Я | Yes | Known | Yes | Unknown | Yard | No | No | No | Unknown | No | Yes | Yes | Yes | No | Yes |
| 1425 Whittamore Road | ĸ | Yes | Unknown | | 60 Years?? | Outside House | No | No | No | Unknown | No | Yes | No | No | No | Yes |
| 1457 Whittamore Road | Я | Yes | Known | | 1950 | Unknown | No | Yes | | 50 | Yes | No | | Jul-08 | No | |
| 1469 Whittamore Road | Я | No | Unknown | | | | No | No | No | | No | Yes | Yes | No | No | Yes |
| 1605 Whittamore Road | ٣ | Yes | Known | Yes | 2001-2002 | Laundry room of house | Yes | Yes | No | Unknown | Yes (for treating iron, hardness, impurities) | Yes | Yes | Spring 2008 | °N N | Yes |
| 1609 Whittamore Road | Ж | Yes | Known | No | Unknown | Shed | No | Yes | | 47 | Yes | Yes | Yes | 2008 (By City) | No | Yes |
| | | | | | | | | | | | | | | | | |

APPENDIX B Virginia Water Quality Standards

Commonwealth of Virginia Department of Environmental Quality

Water Quality Standards For toxic analytes

Adapted from

STATE WATER CONTROL BOARD 9 VAC 25-260 Virginia Water Quality Standards. Statutory Authority: § 62.1-44.15 3a of the Code of Virginia. WITH AMENDMENTS EFFECTIVE AUGUST 10, 2005

Refer to 9 VAC 25-260 for detailed comments on the standards summarized herein!

9 VAC 25-260-140. Criteria for surface water.

A. Instream water quality conditions shall not be acutely² or chronically³ toxic except as allowed in 9 VAC 25-260-20 B mixing zones. The following are definitions of acute and chronic toxicity conditions:

"Acute toxicity" means an adverse effect that usually occurs shortly after exposure to a pollutant. Lethality to an organism is the usual measure of acute toxicity. Where death is not easily detected, immobilization is considered equivalent to death.

"Chronic toxicity" means an adverse effect that is irreversible or progressive or occurs because the rate of injury is greater than the rate of repair during prolonged exposure to a pollutant. This includes low level, long-term effects such as reduction in growth or reproduction.

B. The following table is a list of numerical water quality criteria for specific parameters.

When information has become available from the Environmental Protection Agency to calculate additional aquatic life or human health criteria not contained in the table, the board may employ these values in establishing effluent limitations or other limitations pursuant to 9 VAC 25-260-20 A necessary to protect designated uses until the board has completed the regulatory standards adoption process.

Table of Parameters ⁶

| | USE DESIGNATION | | | | | | | |
|---|-----------------|----------------------|--------------------|----------------------|--|---|--|--|
| | | AQUATI | C LIFE | | HUMAN | HEALTH | | |
| PARAMETER | FRESH | WATER | SALT | WATER | | A11 | | |
| CAS Number | Acute | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | |
| Acenapthene(µg/l) 83329 | | | | | 1,200 | 2,700 | | |
| Acrolein (μg/l) 107028 | | | | | 320 | 780 | | |
| Acrylonitrile (μg/l) 107131 Known or suspected carcinogen; human health criteria at risk level 10 ⁵ . | | | | | 0.59 | 6.6 | | |
| Aldrin (µg/l) 309002 Known or suspected carcinogen; human health criteria at risk level 10 ⁵ . | 3.0 | | 1.3 | | 0.0013 | 0.0014 | | |
| Ammonia (μg/l) 766-41-7 Chronic criterion is a 30-day average concentration not to be exceeded more than once every three 3 years on the average. (see 9 VAC 25-260-155) | | | | | | | | |
| Anthracene (µg/l) 120127 | | | | | 9,600 | 110,000 | | |
| Antimony (μg/l) 7440360 | | | | | 14 | 4,300 | | |
| Arsenic (μg/l ⁵⁾ 7440382 | 340 | 150 | 69 | 36 | 10 | | | |
| Bacteria (see 9 VAC 25-260-160 and 170) | | | | | | | | |
| Barium (μg/l) 7440393 | | | | | 2,000 | | | |
| Benzene μg/l 71432 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 12 | 710 | | |
| Benzidine (µg/l) 92875 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.0012 | 0.0054 | | |
| Benzo (a) anthracene (μg/l) 56553 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.044 | 0.49 | | |

| | USE DESIGNATION | | | | | | | |
|---|--------------------|----------------------|--------------------|----------------------|--|---|--|--|
| | | AQUATI | C LIFE | | HUMAN | HEALTH | | |
| PARAMETER | FRESH | IWATER | SALT | WATER | | All | | |
| CAS Number | Acute ¹ | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | |
| Benzo (b) fluoranthene (μg/l) 205992 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.044 | 0.49 | | |
| Benzo (k) fluoranthene (μg/l) 207089 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.044 | 0.49 | | |
| Benzo (a) pyrene (μg/l) 50328 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.044 | 0.49 | | |
| Bis2-Chloroethyl Ether 111444 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.31 | 14 | | |
| Bis2-Chloroisopropyl Ether (µg/l) 39638329 | | | | | 1,400 | 170,000 | | |
| Bromoform (μg/l) 75252 Known or suspected carcinogen; human health criteria at risk level 10 ^{-5.} | | | | | 44 | 3,600 | | |
| Butyl benzyl phthalate (µg/l) 85687 | | | | | 3,000 | 5,200 | | |

| | | | USE DES | IGNATION | | |
|--|--|---|--------------------|----------------------|--|---|
| | | AQUAT | IC LIFE | | HUMAN I | HEALTH |
| PARAMETER | FRESH | WATER | SALT | WATER | | All |
| CAS Number | Acute ¹ | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ |
| Cadmium ($\mu g/l^{5}$) 7440439 Freshwater values are a function of total hardness as calcium carbonate CaCO ₃ mg/l and the WER. The minimum hardness allowed for use in the equation below shall be 25 and the maximum hardness shall be 400 even when the actual ambient hardness is less than 25 or greater than 400. Freshwater acute criterion ($\mu g/l$) WER [e {1.128[ln(hardness)] - 3.828}] Freshwater chronic criterion ($\mu g/l$) WER [e {0.7852[ln(hardness)] - 3.490}] WER = Water Effect Ratio =1 unless shown otherwise under 9 VAC 25-260-140.F and listed in 9 VAC 25- 260-310 e = natural antilogarithm ln = natural logarithm | 3.9 WER = 1 CaCO ₃ =10 0 | 1.1 WER = 1 CaCO ₃ = 100 | 40 WER=1 | 8.8 WER=1 | 5 | |
| Carbon tetrachloride (µg/l) 56235 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 2.5 | 44 |
| Chlordane (μg/l) 57749 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | 2.4 | 0.0043 | 0.09 | 0.0040 | 0.021 | 0.022 |
| Chloride (µg/l) 16887006 Human Health criterion to maintain acceptable taste and aesthetic quality and applies at the drinking water intake. | 860,000 | 230,000 | | | 250,000 | |
| Chlorine, Total Residual (µg/l) 7782505 In DGIF class i and ii trout waters (9 VAC 25-260 subsections 390-540) or waters with threatened or endangered species are subject to the halogen ban (subsection 110.) | 19 See 9 VAC 25-260-110 | 11 See 9 VAC 25-260-110 | | | | |
| Chlorine Produced Oxidant (μg/l) 7782505 | | | 13 | 7.5 | | |
| Chlorobenzene (µg/l) 108907 | | | | | 680 | 21,000 |
| Chlorodibromomethane (µg/l) 124481 Known or suspected carcinogen; human health criteria at risk level 10 ⁵ | | | | | 4.1 | 340 |

| | USE DESIGNATION | | | | | | |
|---|---|--|---------|----------------------|--|----------------------------|--|
| | | AQUAT | IC LIFE | | HUMAN | HEALTH | |
| PARAMETER | FRES | HWATER | SALT | WATER | | All | |
| CAS Number | Acute | Chronic ² | Acute | Chronic ² | Public Water Supply ³ | Other Surface Waters | |
| Chloroform (µg/l) 67663 Known or suspected carcinogen; however, non- carcinogen calculation used and is protective of carcinogenic effects. Use 30Q5 as default design flow (see footnote 6.) | | | | | 350 | 29,000 | |
| 2-Chloronaphthalene (μg/l) 91587 | | | | | 1,700 | 4,300 | |
| <mark>2-Chlorophenol (μg/l)</mark> 95578 | | | | | 120 | 400 | |
| Chlorpyrifos (µg/l) 2921882 | 0.083 | 0.041 | 0.011 | 0.0056 | | | |
| Chromium III ($\mu g/I^{50}$ 16065831 Freshwater values are a function of total hardness as calcium carbonate CaCO ₃ mg/l and the WER. The minimum hardness allowed for use in the equation below shall be 25 and the maximum hardness shall be 400 even when the actual ambient hardness is less than 25 or greater than 400. Freshwater acute criterion $\mu g/l$ WER [e ^{0.8190[ln(hardness)]+3.7256}] (CF _a) Freshwater chronic criterion $\mu g/l$ WER[e ^{0.8190[ln(hardness)]+0.6848}] (CF _c) WER = Water Effect Ratio = 1 unless shown otherwise under 9 VAC 25-260-140.F and listed in 9 VAC 25- 260-310 e = natural antilogarithm In=natural logarithm CF _a =0.316 CF _c =0.860 | 570 (WER=1; CaCO ₃ = 100) | 74 (WER=1; CaCO ₃ =100) | | | 100 (total Cr) | | |
| Chromium VI (µg/I⁵⁾ 18540299 | 16 | 11 | 1,100 | 50 | | | |
| Chrysene (µg/l) 218019 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.044 | 0.49 | |

| | | | USE DES | IGNATION | | |
|---|--------------------------|---------------------------|--------------|----------------------|--|---|
| | | AQUAT | IC LIFE | | HUMAN | HEALTH |
| PARAMETER | FRESH | WATER | SALT | WATER | | All |
| CAS Number | Acute ¹ | Chronic ² | Acute | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ |
| Copper ($\mu g/I^{5}$) 7440508 Freshwater values are a function of total hardness as calcium carbonate CaCO ₃ mg/l and the WER. The minimum hardness allowed for use in the equation below shall be 25 and the maximum hardness shall be 400 even when the actual ambient hardness is less than 25 or greater than 400. Freshwater acute criterion ($\mu g/I$) WER [e {0.9422[ln(hardness)]-1.700}] (CFa) Freshwater chronic criterion $\mu g/I$ WER [e {0.8545[ln(hardness)]-1.702}] (CFc) WER = Water Effect Ratio =1 unless shown otherwise under 9 VAC 25-260-140.F and listed in 9 VAC 25- 260-310. e = natural antilogarithm ln=natural logarithm CFa = 0.960 CFc = 0.960 Acute saltwater criterion is a 24-hour average not to be exceeded more than once every three years on the average. | 13 WER=I CaCO3=100 | 9.0 WER=1 CaCO3=100 | 9.3 WER=1 | 6.0 WER=1 | 1,300 | |
| Cyanide (µg/l) 57125 | 22 | 5.2 | , 1.0 | 1.0 | 700 | 220,000 |
| DDD (μg/l) 72548 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.0083 | 0.0084 |
| DDE (µg/l) 72559 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.0059 | 0.0059 |
| DDT (µg/l) 50293 Known or suspected carcinogen; human health criteria at risk level 10 ^{-5.} | 1.1 | 0.0010 | 0.13 | 0.0010 | 0.0059 | 0.0059 |
| Demeton (μg/l) 8065483 | | 0.1 | | 0.1 | | |

| | USE DESIGNATION | | | | | | | |
|--|--------------------|----------------------|--------------------|----------------------|--|---|--|--|
| | | AQUAT | IC LIFE | | HUMAN | HEALTH | | |
| PARAMETER | FRES | HWATER | SALT | WATER | | All | | |
| CAS Number | Acute ¹ | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | |
| Dibenz (a,h) anthracene (µg/l) 53703 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.044 | 0.49 | | |
| Dibutyl phthalate µg/l 84742 | | | | | 2,700 | 12,000 | | |
| Dichloromethane (μg/l) 75092 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ Synonym = Methylene Chloride | | | | | 47 | 16,000 | | |
| 1,2–Dichlorobenzene (μg/l0) 95501 | | | | | 2,700 | 17,000 | | |
| 1,3– Dichlorobenzene (μg/l) 541731 | | | | | 400 | 2,600 | | |
| 1,4 Dichlorobenzene (μg/l) 106467 | | | | | 400 | 2,600 | | |
| 3,3 Dichlorobenzidine 91941 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.4 | 0.77 | | |
| Dichlorobromomethane (µg/l) 75274 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 5.6 | 460 | | |
| 1,2 Dichloroethane (μg/l) 107062 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 3.8 | 990 | | |
| 1,1 Dichloroethylene (μg/l) 75354 | | | | | 310 | 17,000 | | |
| 1,2-trans-dichloroethylene (μg/l) 156605 | | | | | 700 | 140,000 | | |
| 2,4 Dichlorophenol (μg/l) 120832 | | | | | 93 | 790 | | |

| | USE DESIGNATION | | | | | |
|--|--------------------|----------------------|-------|----------------------|--|---|
| | | AQUATIC LIFE HUMAN H | | | | |
| PARAMETER | FRESH | IWATER | SALT | WATER | | All |
| CAS Number | Acute ¹ | Chronic ² | Acute | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ |
| 2,4 Dichlorophenoxy acetic acid (2,4-D) (µg/l) 94757 | | | | | 100 | |
| 1,2-Dichloropropane (μg/l) 78875 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 5.2 | 390 |
| 1,3-Dichloropropene (μg/l) 542756 | | | | | 10 | 1,700 |
| Dieldrin (µg/l) 60571 Known or suspected carcinogen; human health criteria at risk level 10 ^{-5.} | 0.24 | 0.056 | 0.71 | 0.0019 | 0.0014 | 0.0014 |
| Diethyl Phthalate (µg/l) 84662 | | | | | 23,000 | 120,000 |
| Di-2-Ethylhexyl Phthalate (μg/l) 117817 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . Synonym = Bis2-Ethylhexyl Phthalate. | | | | | 18 | 59 |
| 2,4 Dimethylphenol (μg/l) 105679 | | | | | 540 | 2,300 |
| Dimethyl Phthalate (µg/l) 131113 | | | | | 313,000 | 2,900,000 |
| Di-n-Butyl Phthalate (µg/l) 84742 | | | | | 2,700 | 12,000 |
| 2,4 Dinitrophenol (μg/l) 51285 | | | | | 70 | 14,000 |
| 2-Methyl-4,6-Dinitrophenol (μg/l) 534521 | | | | | 13.4 | 765 |
| 2,4 Dinitrotoluene (μg/l) 121142 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 1.1 | 91 |

| | | | USE DES | IGNATION | 1 | | | | | | | |
|---|-------|----------------------|--------------------|----------------------|--|---|--|--|--|--|--|--|
| | | AQUAT | IC LIFE | | HUMAN | HEALTH | | | | | | |
| PARAMETER | FRESH | IWATER | SALT | WATER | | All | | | | | | |
| CAS Number | Acute | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | | | | | |
| Dioxin 2, 3, 7, 8-tetrachlorodibenzo-p-dioxin (ppq) 1746016 Criteria are based on a risk level of 10 ⁻⁵ and potency of 1.75 x 10 ⁴ mg/kg–day ⁻¹ To calculate an average effluent permit limit, use mean annual stream flow. | | (a | | | 1.2 | 1.2 | | | | | | |
| 1,2-Diphenylhydrazine (μg/l) 122667 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.40 | 5.4 | | | | | | |
| Dissolved Oxygen (mg/l) (See 9 VAC 25-260-50 and 9 VAC 25-260-55) | | | | | | | | | | | | |
| Alpha-Endosulfan (µg/l) 959988 | 0.22 | 0.056 | 0.034 | 0.0087 | 110 | 240 | | | | | | |
| Beta-Endosulfan (µg/l) 33213659 | 0.22 | 0.056 | 0.034 | 0.0087 | 110 | 240 | | | | | | |
| Endosulfan Sulfate (µg/l) 1031078 | | | | | 110 | 240 | | | | | | |
| Endrin (μg/l) 72208 | 0.086 | 0.036 | 0.037 | 0.0023 | 0.76 | 0.81 | | | | | | |
| Endrin Aldehyde (μg/l) 7421934 | | | | | 0.76 | 0.81 | | | | | | |
| Ethylbenzene (μg/l) 100414 | | | | | 3,100 | 29,000 | | | | | | |
| Fecal Coliform (see 9 VAC 25-260-160 and 9 VAC 25-260-170) | | | | | | | | | | | | |
| Fluoranthenc (µg/l) 206440 | | | | | 300 | 370 | | | | | | |
| Fluorene (µg/l) 86737 | | | | | 1,300 | 14,000 | | | | | | |

| | | USE DESIGNATION | | | | | | | |
|--|--------------------|----------------------|--------------------|----------------------|--|---|--|--|--|
| | | AQUATI | C LIFE | | HUMAN | HEALTH | | | |
| PARAMETER | FRESI | IWATER | SALT | WATER | | All | | | |
| CAS Number | Acute ¹ | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | | |
| Foaming Agents (µg/l) Criterion measured as methylene blue active substances. Criterion to maintain acceptable taste, odor, or aesthetic quality of drinking water and applies at the drinking water intake. | | | | | 500 | | | | |
| Guthion (μg/l) 86500 | | 0.01 | | 0.01 | | | | | |
| Heptachlor (μg/l) 76448 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | 0.52 | 0.0038 | 0.053 | 0.0036 | 0.0021 | 0.0021 | | | |
| Heptachlor Epoxide (µg/l) 1024573 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | 0.52 | 0.0038 | 0.053 | 0.0036 | 0.0010 | 0.0011 | | | |
| Hexachlorobenzene (µg/l) 118741 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 0.0075 | 0.0077 | | | |
| Hexachlorobutadiene (µg/l) 87683 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 4.4 | 500 | | | |
| Hexachlorocyclohexane Alpha-BHC (μg/l) 319846 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 0.039 | 0.13 | | | |
| Hexachlorocyclohexane Beta-BHC (μg/l) 319857 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 0.14 | 0.46 | | | |
| Hexachlorocyclohexane (μg/l) (Lindane) Gamma-BHC 58899 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | 0.95 | | 0.16 | | 0.19 | 0.63 | | | |
| Hexachlorocyclopentadiene (µg/l) 77474 | | | | | 240 | 17,000 | | | |
| Hexachloroethane (µg/l) 67721 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 19 | 89 | | | |
| Hydrogen sulfide (μg/l) 7783064 | | 2.0 | | 2.0 | | | | | |

| | USE DESIGNATION | | | | | | | |
|--|--|---|--------------------|----------------------|--|---|--|--|
| | | AQUAT | IC LIFE | | HUMAN HEALTH | | | |
| PARAMETER | FRESH | IWATER | SALTWATER | | | All | | |
| CAS Number | Acute ¹ | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | |
| Indeno (1,2,3,-cd) pyrene (µg/l) 193395 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.044 | 0.49 | | |
| Iron (μg/l) 7439896 Criterion to maintain acceptable taste, odor or aesthetic quality of drinking water and applies at the drinking water intake. | | | | | 300 | | | |
| Isophorone (μg/I) 78591 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 360 | 26,000 | | |
| Керопе (µg/l) 143500 | | zero | | zero | | | | |
| Lead (µg/l) ⁵ 7439921 Freshwater values are a function of total hardness as calcium carbonate CaCO ₃ mg/l and the water effect ratio. The minimum hardness allowed for use in the equation below shall be 25 and the maximum hardness shall be 400 even when the actual ambient hardness is less than 25 or greater than 400. Freshwater acute criterion (µg/l) WER [e {1.273[ln(hardness)]-1.084}] Freshwater chronic criterion (µg/l) WER [e {1.273[ln(hardness)]-3.259}] WER = Water Effect Ratio =1 unless shown otherwise under 9 VAC 25-260-140.F and listed in 9 VAC 25- 260-310 e = natural antilogarithm ln = natural logarithm | 120 WER=1 CaCO ₃ =100 | 14 WER =1 CaCO ₃ = 100 | 240 WER=1 | 9.3 WER=1 | 15 | | | |
| Malathion (µg/l) 121755 | | 0.1 | | 0.1 | | | | |
| Manganese (µg/l) 7439965 Criterion to maintain acceptable taste, odor or aesthetic quality of drinking water and applies at the drinking water intake. | | | | | 50 | | | |
| Mercury µg/l⁵ 7439976 | 1.4 | 0.77 | 1.8 | 0.94 | 0.050 | 0.05 | | |

| | USE DESIGNATION | | | | | | | |
|---|---------------------------------|--|--------------------|----------------------|--|---|--|--|
| | | AQUAT | IC LIFE | | HUMAN | HEALTH | | |
| PARAMETER | FRES | HWATER | SALT | WATER | | All | | |
| CAS Number | Acute | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | |
| Methyl Bromide (µg/l) 74839 | | | | | 48 | 4,000 | | |
| Methoxychlor (µg/l) 72435 | | 0.03 | | 0.03 | 100 | | | |
| Mirex (µg/l) 2385855 | | zero | | zero | | | | |
| Monochlorobenzene (µg/l) 108907 | | | | | 680 | 21,000 | | |
| Nickel ($\mu g/L^{9}$ 744002 Freshwater values are a function of total hardness as calcium carbonate CaCO ₃ mg/l and the WER. The minimum hardness allowed for use in the equation below shall be 25 and the maximum hardness shall be 400 even when the actual ambient hardness is less than 25 or greater than 400. Freshwater acute criterion $\mu g/l$ WER[e {0.8460[ln(hardness)] + 1.312}] (CF _a) Freshwater chronic criterion ($\mu g/l$) WER [e {0.8460[ln(hardness)] - 0.8840}](CF _c) WER =Water Effect Ratio = unless shown otherwise under 9 VAC 25-260-140.F and listed in 9 VAC 25- 250-310 e = natural antilogarithm ln = natural logarithm (CF _a) = 0.998 (CF _c) = 0.997 | 180 WER =1 CaCO3 = 100 | 20 WER = 1 CaCO ₃ = 100 | 74 WER=I | 8.2 WER=1 | 610 | 4,600 | | |
| Nitrate as N (μg/l) 14797558 | | | | | 10,000 | | | |
| Nitrobenzene (µg/l) 98953 | | | | | 17 | 1,900 | | |
| N-Nitrosodimethylamine (μg/l) 62759 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ . | | | | | 0.0069 | 81 | | |

| | USE DESIGNATION | | | | | | | |
|--|--------------------|----------------------|--------------------|----------------------|--|--|--|--|
| | | AQUAT | IC LIFE | | HUMAN | HEALTH | | |
| PARAMETER | EDECL | IW/ATED | SALT | WATED | | A 11 | | |
| CAS Number | Acute ¹ | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | All Other Surface Waters ⁴ | | |
| N-Nitrosodiphenylamine (μg/l) 86306 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 50 | 160 | | |
| N-Nitrosodi-n-propylamine (μg/l) 621647 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.05 | 14 | | |
| Parathion (µg/l) 56382 | 0.065 | 0.013 | | | | | | |
| РСВ 1260 (µg/l) 11096825 | | 0.014 | | 0.030 | | | | |
| PCB 1254 (μg/l) 11097691 | | 0.014 | | 0.030 | | | | |
| РСВ 1248 (µg/l) 12672296 | | 0.014 | | 0.030 | | | | |
| РСВ 1242 (µg/l) 53469219 | | 0.014 | | 0.030 | | | | |
| РСВ 1232 (µg/l) 11141165 | | 0.014 | | 0.030 | | | | |
| РСВ 1221 (µg/l) 11104282 | | 0.014 | | 0.030 | | | | |
| РСВ 1016 (µg/l) 12674112 | | 0.014 | | 0.030 | | | | |
| PCB Total (µg/l) 1336363 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.0017 | 0.0017 | | |

| | | | USE DES | IGNATION | | | | | | | | |
|---|---|----------------------|--------------|----------------------|--|---|--|--|--|--|--|--|
| | | AQUAT | IC LIFE | | HUMAN HEALTH | | | | | | | |
| PARAMETER | FRESH | WATER | ATED SALT | | | All | | | | | | |
| CAS Number | Acute | Chronic ² | Acute | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | | | | | | |
| Pentachlorophenol (μg/l) 87865 Known or suspected carcinogen; human health criteria risk level at 10 ⁻⁵ Freshwater acute criterion (μg/l) e ^{(1.005(pH)-4.8 69)} Freshwater chronic criterion (μg/l) e ^{(1.005(pH)-5.134)} | 8.7 pH = 7.0 | 6.7 pH = 7.0 | 13 | 7.9 | 2.8 | 82 | | | | | | |
| pH See § 9VAC25-260-50 | | | | | | | | | | | | |
| Phenol (μg/l) 108952 | | | | | 21,000 | 4,600,000 | | | | | | |
| Phosphorus Elemental (µg/l) 7723140 | | | | 0.10 | | | | | | | | |
| Pyrene (μg/l) 129000 | | | | | 960 | 11,000 | | | | | | |
| Radionuclides Gross Alpha Particle Activity (pCi/L) Beta Particle & Photon Activity (mrem/yr) (formerly man-made radio nuclides) Strontium 90 (pCi/L) Tritium (pCi/L) | | | | | 15 4 8 20,000 | 15 4 8 20,000 | | | | | | |
| Selenium (μg/l ⁵⁰ 7782492 WER shall not be used for freshwater acute and chronic criteria. | 20 | 5.0 | 300 WER=1 | 71 WER=1 | 170 | 11,000 | | | | | | |
| Silver $(\mu g/l)^5$ 7440224 Freshwater values are a function of total hardness as calcium carbonate (CaCO ₃) mg/l and the WER. The minimum hardness allowed for use in the equation below shall be 25 and the maximum hardness shall be 400 even when the actual ambient hardness is less than 25 or greater than 400. | 3.4 WER=1; CaCO ₃ =100 | | 2.0 WER=I | | | | | | | | | |

| | USE DESIGNATION | | | | | | | |
|---|--------------------|----------------------|--------------------|----------------------|--|----------------------------|--|--|
| | | AQUAT | IC LIFE | | HUMAN HEALTH | | | |
| PARAMETER | FRESI | IWATER | SALT | WATER | | All | | |
| CAS Number | Acute ¹ | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters | | |
| Freshwater acute criterion (μ g/l) WER [e {1.72[ln(hardness)]-6.52}] (CF _a) WER = Water Effect Ratio =1 unless shown otherwise under 9 VAC 25-260-140.F and listed in 9 VAC 25-260-310 e = natural antilogarithm ln=natural logarithm (CF _a)= 0.85 | | | | | | | | |
| Sulfate (µg/l) Criterion to maintain acceptable taste, odor or aesthetic quality of drinking water and applies at the drinking water intake. | | | | | 250,000 | | | |
| Temperature See 9 VAC 25-260-50 | | | | | | | | |
| 1,1,2,2-Tetrachloroethane (μg/l) 79345 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 1.7 | 110 | | |
| Tetrachloroethylene (μg/l) 127184 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 8.0 | 89 | | |
| Thallium (μg/l) 7440280 | | | | | 1.7 | 6.3 | | |
| Toluene (μg/l) 108883 | | | | | 6,800 | 200,000 | | |
| Fotal Dissolved Solids (µg/l) Criterion to maintain acceptable taste, odor or aesthetic quality of drinking water and applies at the drinking water intake. | | | | | 500,000 | | | |
| Toxaphene (μg/l) 8001352 The chronic aquatic life criteria have been calculated to also protect wildlife from harmful effects through ingestion of contaminated tissue. Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | 0.73 | 0.0002 | 0.21 | 0.0002 | 0.0073 | 0.0075 | | |
| Tributyltin (μg/l) 60105 | 0.46 | 0.063 | 0.38 | 0.001 | | | | |
| | USE DESIGNATION | | | | | | |
|---|---|--|--------------------|----------------------|--|---|--|
| | | AQUATIC LIFE | | | | HUMAN HEALTH | |
| PARAMETER | FRESH | WATER | SALT | WATER | | All | |
| CAS Number | | Chronic ² | Acute ¹ | Chronic ² | Public Water Supply ³ | Other Surface Waters ⁴ | |
| 1, 2, 4 Trichlorobenzene (μg/l) 120821 | | | | ×) | 260 | 940 | |
| 1,1,2-Trichloroethane (μg/l) 79005 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 6.0 | 420 | |
| Trichloroethylene (μg/l) 79016 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 27 | 810 | |
| 2, 4, 6 – Trichlorophenol 88062 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 21 | 65 | |
| 2–(2, 4, 5 –Trichlorophenoxy propionic acid (Silvex) (µg/l) | | | | | 50 | | |
| Vinyl Chloride (µg/l) 75014 Known or suspected carcinogen; human health criteria at risk level 10 ⁻⁵ | | | | | 0.23 | 61 | |
| Zinc $(\mu g/l)^5$ Freshwater values are a function of total hardness as calcium carbonate (CaCO ₃) mg/l and the WER. The minimum hardness allowed for use in the equation below shall be 25 and the maximum, hardness shall be 400 even when the actual ambient hardness is less than 25 or greater than 400. Freshwater acute criterion $\mu g/l$ WER [e {0.8473[ln(hardness)]+0.884}] (CF _a) Freshwater chronic criterion $\mu g/l$ WER [e {0.8473[ln(hardness)]+0.884}] (CF _c) WER =Water Effect Ratio =1 unless shown otherwise under 9 VAC 25-260-140.F and listed in 9 VAC 25-260-310 e = base e exponential function. ln = log normal function CF _a = 0.978 CF _c = 0.986 | 120 WER=1 CaCO ₅ = 100 | 120 WER=1 CaCO ₃ =100 | 90 WER=1 | 81 WER=1 | 9,100 | 69,000 | |

¹ One hour average concentration not to be exceeded more than once every 3 years on the average, unless otherwise noted.

² Four-day average concentration not to be exceeded more than once every 3 years on the average, unless otherwise noted.

³ Criteria have been calculated to protect human health from toxic effects through drinking water and fish consumption, unless otherwise noted and apply in segments designated as PWS in 9 VAC 25-260-390-540.

⁴ Criteria have been calculated to protect human health from toxic effects through fish consumption, unless otherwise noted and apply in all other surface waters not designated as PWS in 9 VAC 25-260-390-540.

³ Acute and chronic saltwater and freshwater aquatic life criteria apply to the biologically available form of the metal and apply as a function of the pollutant's water effect ratio (WER) as defined in 9 VAC 25-260-140 F (WER X criterion.) Metals measured as dissolved shall be considered to be biologically available, or, because local receiving water characteristics may otherwise affect the biological availability of the metal, the biologically available equivalent measurement of the metal can be further defined by determining a Water Effect Ratio (WER) and multiplying the numerical value shown in 9 VAC 25-260-140 B by the WER. Refer to 9 VAC 25-260-140 F. Values displayed above in the table are examples and correspond to a (WER) of 1.0. Metals criteria have been adjusted to convert the total recoverable fraction to dissolved fraction using a conversion factor. Criteria that change with hardness have the conversion factor listed in the table above.

6 = The flows listed below are default design flows for calculating steady state waste load allocations unless statistically valid methods are employed which demonstrate compliance with the duration and return frequency of the water quality criteria.

Aquatic Life:

| Acute criteria | 1Q10 |
|--|---------------|
| Chronic criteria | 7Q10 |
| Chronic criteria (ammonia) | 30Q10 |
| Chronic criteria Chronic criteria (ammonia) | 7Q10 30Q10 |

Human Health:

| Non-carcinogens | 30Q5 | |
|-----------------|---|--|
| Carcinogens | Harmonic mean (An exception to this is for the carcinogen dioxin. mean annual stream flow.) | The applicable stream flow for dioxin is the |

The following are defined for this section:

"IQ10" means the lowest flow averaged over a period of one day which on a statistical basis can be expected to occur once every 10 climatic years.

"7Q10" means the lowest flow averaged over a period of seven consecutive days that can be statistically expected to occur once every 10 climatic years.

"30Q5" means the lowest flow averaged over a period of 30 consecutive days that can be statistically expected to occur once every five climatic years.

"30Q10" means the lowest flow averaged over a period of 30 consecutive days that can be statistically expected to occur once every 10 climactic years.

"Averaged" means an arithmetic mean.

"Climatic year" means a year beginning on April 1 and ending on March 31.

C. Application of freshwater and saltwater numerical criteria.

The numerical water quality criteria listed in subsection B of this section (excluding dissolved oxygen, pH, temperature) shall be applied according to the following classes of waters (see 9 VAC 25-260-50) and boundary designations:

| CLASS OF WATERS | NUMERICAL CRITERIA |
|--|---|
| I and II (Estuarine Waters) | Saltwater criteria apply |
| II (Transition Zone) | More stringent of either the freshwater or saltwater criteria apply |
| II (Tidal Freshwater,) III, IV, V. VI and VII | Freshwater criteria apply |

The following describes the boundary designations for Class II, (estuarine, transition zone and tidal freshwater waters) by river basin:

1. Rappahannock Basin.

Tidal freshwater is from the fall line of the Rappahannock River to Buoy 37 near Tappahannock, Virginia, including all tidal tributaries that enter the tidal freshwater Rappahannock River.

Transition zone is from Buoy 37 to Buoy 11 near Morattico, Virginia, including all tidal tributaries that enter the transition zone of the Rappahannock River.

Estuarine waters are from Buoy 11 to the mouth of the Rappahannock River (Buoy 6), including all tidal tributaries that enter the estuarine waters of the Rappahannock River.

2. York Basin.

Tidal freshwater is from the fall line of the Mattaponi River to Clifton, Virginia, and from the fall line of the Pamunkey River to Sweet Hall Landing, Virginia, including all tidal tributaries that enter the tidal freshwaters of the Mattaponi and Pamunkey Rivers.

Transition zone of the Mattaponi River is from Clifton, Virginia to the York River and the transition zone of the Pamunkey River is from Sweet Hall Landing, Virginia, to the York River. The transition zone for the York River is from West Point, Virginia, to Buoy 13 near Poropotank Bay. All tidal tributaries that enter the transition zones of the Mattaponi, Pamunkey, and York Rivers are themselves in the transition zone.

Estuarine waters are from Buoy 13 to the mouth of the York River (Tue Marsh Light) including all tidal tributaries that enter the estuarine waters of the York River.

3. James Basin.

Tidal Freshwater is from the fall line of the James River to the confluence of the Chickahominy River Buoy 70, including all tidal tributaries that enter the tidal freshwater James River.

Transition zone is from (Buoy 70) to Buoy 47 near Jamestown Island including all tidal tributaries that enter the transition zone of the James River.

Estuarine waters are from Buoy 47 to the mouth of the James River (Buoy 25) including all tidal tributaries that enter the estuarine waters of the James River.

4. Potomac Basin.

Tidal Freshwater includes all tidal tributaries that enter the Potomac River from its fall line to Buoy 43 near Quantico, Virginia.

Transition zone includes all tidal tributaries that enter the Potomac River from Buoy 43 to Buoy 33 near Dahlgren, Virginia.

Estuarine waters includes all tidal tributaries that enter the Potomac River from Buoy 33 to the mouth of the Potomac River (Buoy 44B.)

5. Chesapeake Bay, Atlantic Ocean, and small coastal basins.

Estuarine waters include the Atlantic Ocean tidal tributaries, and the Chesapeake Bay and its small coastal basins from the Virginia state line to the mouth of the bay (a line from Cape Henry drawn through Buoys 3 and 8 to Fishermans Island), and its tidal tributaries, excluding the Potomac tributaries and those tributaries listed above.

6. Chowan River Basin.

Tidal freshwater includes the Northwest River and its tidal tributaries from the Virginia-North Carolina state line to the free flowing portion, the Blackwater River and its tidal tributaries from the Virginia-North Carolina state line to the end of tidal waters at approximately state route 611 at river mile 20.90, the Nottoway River and its tidal tributaries from the Virginia-North Carolina state line to the end of tidal waters at approximately state line to the end of tidal waters at approximately Route 674, and the North Landing River and its tidal tributaries from the Virginia-North Carolina state line to the Carolina state line to the Great Bridge Lock.

Transition zone includes Back Bay and its tributaries in the City of Virginia Beach to the Virginia-North Carolina state line.

D. Site-specific modifications to numerical water quality criteria.

1. The board may consider site-specific modifications to numerical water quality criteria in subsection B of this section where the applicant or permittee demonstrates that the alternate numerical water quality criteria are sufficient to protect all designated uses (see 9 VAC 25-260-10) of that particular surface water segment or body.

2. Any demonstration for site-specific human health criteria shall be restricted to a reevaluation of the bioconcentration or bioaccumulation properties of the pollutant. The exceptions to this restriction are for site-specific criteria for taste, odor, and aesthetic compounds noted by double asterisks in subsection B of this section and nitrates.

3. Site-specific temperature requirements are found in 9 VAC 25-260-90.

4. Procedures for promulgation and review of site-specific modifications to numerical water quality criteria resulting from subdivisions 1 and 2 of this subsection.

a. Proposals describing the details of the site-specific study shall be submitted to the board's staff for approval prior to commencing the study.

b. Any site-specific modification shall be promulgated as a regulation in accordance with the Administrative Process Act. All site-specific modifications shall be listed in 9 VAC 25-260-310 (Special standards and requirements).

E. Variances to water quality standards.

1. A variance from numeric criteria may be granted to a discharger if it can be demonstrated that one or more of the conditions in 9 VAC 25-260-10 G limit the attainment of one or more specific designated uses.

a. Variances shall apply only to the discharger to whom they are granted and shall be reevaluated and either continued, modified or revoked at the time of permit issuance. At that time the permittee shall make a showing that the conditions for granting the variance still apply.

b. Variances shall be described in the public notice published for the permit. The decision to approve a variance shall be subject to the public participation requirements of the Virginia Pollutant Discharge Elimination System (VPDES) Permit Regulation, 9 VAC 25-31 (Permit Regulation).

c. Variances shall not prevent the maintenance and protection of existing uses or exempt the discharger or regulated activity from compliance with other appropriate technology or water quality-based limits or best management practices.

d. Variances granted under this section shall not apply to new discharges.

e. Variances shall be submitted by the department's Division of Scientific Research or its successors to the

Environmental Protection Agency for review and approval/disapproval.

f. A list of variances granted shall be maintained by the department's Division of Scientific Research or its successors.

2. None of the variances in subsection E of this section shall apply to the halogen ban section 9 VAC 25-260-110 or temperature criteria in 9 VAC 25-260-50 if superseded by § 316a of the Clean Water Act requirements. No variances in subsection E of this section shall apply to the criteria that are designed to protect human health from carcinogenic and noncarcinogenic toxic effects subsection B of this section with the exception of the metals, and the taste, odor, and aesthetic compounds noted by double asterisks and nitrates, listed in subsection B of this section.

F. Water effect ratio.

1. A water effects ratio (WER) shall be determined by measuring the effect of receiving water (as it is or will be affected by any discharges) on the bioavailability or toxicity of a metal by using standard test organisms and a metal to conduct toxicity tests simultaneously in receiving water and laboratory water. The ratio of toxicities of the metal(s) in the two waters is the WER (toxicity in receiving water divided by toxicity in laboratory water = WER. Once an acceptable WER for a metal is established, the numerical value for the metal in subsection B of this section is multiplied by the WER to produce an instream concentration that will protect designated uses. This instream concentration shall be utilized in permitting decisions.

2. The WER shall be assigned a value of 1.0 unless the applicant or permittee demonstrates to the department's satisfaction in a permit proceeding that another value is appropriate, or unless available data allow the department to compute a WER for the receiving waters. The applicant or permittee is responsible for proposing and conducting the study to develop a WER. The study may require multiple testing over several seasons. The applicant or permittee shall obtain the department's Division of Scientific Research or its successor approval of the study protocol and the final WER.

3. The Permit Regulation at 9 VAC 25-31-230 C requires that permit limits for metals be expressed as total recoverable measurements. To that end, the study used to establish the WER may be based on total recoverable measurements of the metals.

4. The Environmental Protection Agency views the WER in any particular case as a site-specific criterion. Therefore, the department's Division of Scientific Research or its successor shall submit the results of the study to the Environmental Protection Agency for review and approval/disapproval within 30 days of the receipt of certification from the state's Office of the Attorney General. Nonetheless, the WER is established in a permit proceeding, shall be described in the public notice associated with the permit proceeding, and applies only to the applicant or permittee in that proceeding. The department's action to approve or disapprove a WER is a case decision, not an amendment to the present regulation.

The decision to approve or disapprove a WER shall be subject to the public participation requirements of the Permit Regulation, 9 VAC 25-31-260 et seq. A list of final WERs will be maintained by the department's Division of Scientific Research or its successor.

5. A WER shall not be used for the freshwater and saltwater chronic mercury criteria or the freshwater acute and chronic selenium criteria.

9 VAC 25-260-150. (Repealed.)

APPENDIX C National Primary and Secondary Drinking Water Standards

SEPA National Primary Drinking Water Standards

| | Contaminant | MCL or TT1 (mg/L)2 | Potential health effects from exposure above the MCL | Common sources of contaminant in drinking water | Public Health Goal |
|-----|--------------------------------------|--|---|---|-----------------------|
| ос | Acrylamide | TT8 | Nervous system or blood problems; | Added to water during sewage/wastewater increased risk of cancer treatment | zero |
| ос | Alachlor | 0.002 | Eye, liver, kidney or spleen problems; anemia; increased risk of cancer | Runoff from herbicide used on row crops | zero |
| R | Alpha particles | 15 picocuries per Liter (pCi/L) | Increased risk of cancer | Erosion of natural deposits of certain minerals that are radioactive and may emit a form of radiation known as alpha radiation | zero |
| юс | Antimony | 0.006 | Increase in blood cholesterol; decrease in blood sugar | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder | 0.006 |
| IOC | Arsenic | 0.010 as of 1/23/06 | Skin damage or problems with circulatory systems, and may have increased risk of getting cancer | Erosion of natural deposits; runoff from orchards, runoff from glass & electronics production wastes | 0 |
| IOC | Asbestos (fibers >10 micrometers) | 7 million fibers per Liter (MFL) | Increased risk of developing benign intestinal polyps | Decay of asbestos cement in water mains; erosion of natural deposits | 7 MFL |
| OC | Atrazine | 0.003 | Cardiovascular system or reproductive problems | Runoff from herbicide used on row crops | 0.003 |
| IOC | Barium | 2 | Increase in blood pressure | Discharge of drilling wastes; discharge from metal refinerles; erosion of natural deposits | 2 |
| ос | Benzene | 0.005 | Anemia; decrease in blood platelets; increased risk of cancer | Discharge from factories; leaching from gas storage tanks and landfills | zero |
| ос | Benzo(a)pyrene (PAHs) | 0.0002 | Reproductive difficulties; increased risk of cancer | Leaching from linings of water storage tanks and distribution lines | zero |
| IOC | Beryllium | 0.004 | Intestinal lesions | Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries | 0.004 |
| R | Beta particles and photon emitters | 4 millirems per year | Increased risk of cancer | Decay of natural and man-made deposits of certain minerals that are radioactive and may emit forms of radiation known as photons and beta radiation | zero |
| DBP | Bromate | 0.010 | Increased risk of cancer | Byproduct of drinking water disinfection | zero |
| IOC | Cadmium | 0.005 | Kidney damage | Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints | 0.005 |
| OC | Carbofuran | 0.04 | Problems with blood, nervous system, or reproductive system | Leaching of soil fumigant used on rice and alfalfa | 0.04 |
| oc | Carbon tetrachloride | 0.005 | Liver problems; increased risk of cancer | Discharge from chemical plants and other industrial activities | zero |
| D | Chloramines (as Cl ₂) | MRDL=4.01 | Eye/nose irritation; stomach discomfort, anemia | Water additive used to control microbes | MRDLG=41 |

LEGEND

D DBP



Dinsinfectant



Inorganic Chemical



| | Contaminant | MCL or TT1 (mg/L)2 | Potential health effects from exposure above the MCL | Common sources of contaminant in drinking water | Public Health Goal |
|-----|---|---|--|--|-----------------------|
| ос | Chlordane | 0.002 | Liver or nervous system problems; increased risk of cancer | Residue of banned termiticide | zero |
| D | Chlorine (as Cl ₂) | MRDL=4.01 | Eye/nose irritation; stomach discomfort | Water additive used to control microbes | MRDLG=41 |
| D | Chlorine dioxide (as ClO ₂) | MRDL=0.81 | Anemia; infants & young children: nervous system effects | Water additive used to control microbes | MRDLG=0.81 |
| DBP | Chlorite | 1.0 | Anemia; infants & young children: nervous system effects | Byproduct of drinking water disinfection | 0.8 |
| OC | Chlorobenzene | 0.1 | Liver or kidney problems | Discharge from chemical and agricultural chemical factories | 0.1 |
| IOC | Chromium (total) | 0,1 | Allergic dermatitis | Discharge from steel and pulp mills; erosion of natural deposits | 0.1 |
| IOC | Copper | TT ⁷ ; Action Level = 1.3 | Short term exposure: Gastrointestinal distress. Long term exposure: Liver or kidney damage. People with Wilson's Disease should consult their personal doctor if the amount of copper in their water exceeds the action level | Corrosion of household plumbing systems; erosion of natural deposits | 1.3 |
| M | Cryptosporidium | тт3 | Gastrointestinal illness (e.g., diarrhea, vomiting, cramps) | Human and animal fecal waste | zero |
| IOC | Cyanide (as free cyanide) | 0.2 | Nerve damage or thyroid problems | Discharge from steel/metal factories; discharge from plastic and fertilizer factories | 0.2 |
| OC | 2,4-D | 0.07 | Kidney, liver, or adrenal gland problems | Runoff from herbicide used on row crops | 0.07 |
| ос | Dalapon | 0.2 | Minor kidney changes | Runoff from herbicide used on rights of way | 0.2 |
| ос | 1,2-Dibromo-3-chloropropa ne (DBCP) | 0.0002 | Reproductive difficulties; increased risk of cancer | Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards | zero |
| ос | o-Dichlorobenzene | 0.6 | Liver, kidney, or circulatory system problems | Discharge from industrial chemical factories | 0.6 |
| ос | p-Dichlorobenzene | 0.075 | Anemia; liver, kidney or spleen damage; changes in blood | Discharge from industrial chemical factories | 0.075 |
| oc | 1,2-Dichloroethane | 0.005 | Increased risk of cancer | Discharge from industrial chemical factories | zero |
| oc | 1,1-Dichloroethylene | 0.007 | Liver problems | Discharge from industrial chemical factories | 0.007 |
| 00 | cis-1,2-Dichloroethylene | 0.07 | Liver problems | Discharge from industrial chemical factories | 0.07 |
| oc | trans-1,2-Dichloroethylene | 0.1 | Liver problems | Discharge from industrial chemical factories | 0.1 |
| oc | Dichloromethane | 0.005 | Liver problems; increased risk of cancer | Discharge from drug and chemical factories | zero |
| oc | 1,2-Dichloropropane | 0.005 | Increased risk of cancer | Discharge from industrial chemical factories | zero |
| oc | Di(2-ethylhexyl) adipate | 0.4 | Weight loss, live problems, or possible reproductive difficulties | Discharge from chemical factories | 0.4 |
| oc | Di(2-ethylhexyl) phthalate | 0.006 | Reproductive difficulties; liver problems; increased risk of cancer | Discharge from rubber and chemical factories | zero |
| ос | Dinoseb | 0.007 | Reproductive difficulties | Runoff from herbicide used on soybeans and vegetables | 0.007 |
| oc | Dioxin (2,3,7,8-TCDD) | 0.0000003 | Reproductive difficulties; increased risk of cancer | Emissions from waste incineration and other combustion; discharge from chemical factories | zero |
| OC | Diquat | 0.02 | Cataracts | Runoff from herbicide use | 0.02 |
| 00 | Endothall | 0.1 | Stomach and intestinal problems | Runoff from herbicide use | 0.1 |

LEGEND

D

Dinsinfectant DBP Disinfection Byproduct





| A STATE | Contaminant | MCL or TT1 (mg/L)2 | Potential health effects from exposure above the MCL | Common sources of contaminant in drinking water | Public Health Goal |
|---------|-----------------------------------|------------------------------------|--|--|-----------------------|
| OC | Endrin | 0.002 | Liver problems | Residue of banned insecticide | 0.002 |
| ос | Epichlorohydrin | T18 | Increased cancer risk, and over a long period of time, stomach problems | Discharge from industrial chemical factories; an impurity of some water treatment chemicals | zero |
| oc | Ethylbenzene | 0.7 | Liver or kidneys problems | Discharge from petroleum refineries | 0.7 |
| OC | Ethylene dibromide | 0.00005 | Problems with liver, stomach, reproductive system, or kidneys; increased risk of cancer | Discharge from petroleum refineries | zero |
| IOC | Fluoride | 4.0 | Bone disease (pain and tenderness of the bones); Children may get mottled teeth | Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories | 4.0 |
| M | Giardia lamblia | Π3 | Gastrointestinal illness (e.g., diarrhea, vomiting, cramps) | Human and animal fecal waste | zero |
| OC | Glyphosate | 0.7 | Kidney problems; reproductive difficulties | Runoff from herbicide use | 0.7 |
| DBP | Haloacetic acids (HAA5) | 0.060 | Increased risk of cancer | Byproduct of drinking water disinfection | n/a6 |
| OC | Heptachlor | 0.0004 | Liver damage; increased risk of cancer | Residue of banned termiticide | zero |
| 00 | Heptachlor epoxide | 0.0002 | Liver damage; increased risk of cancer | Breakdown of heptachlor | zero |
| M | Heterotrophic plate count (HPC) | Π3 | HPC has no health effects; it is an analytic method used to measure the variety of bacteria that are common in water. The lower the concentration of bacteria in drinking water, the better maintained the water system is. | HPC measures a range of bacteria that are naturally present in the environment | n/a |
| ос | Hexachlorobenzene | 0.001 | Liver or kidney problems; reproductive difficulties; increased risk of cancer | Discharge from metal refineries and agricultural chemical factories | zero |
| ос | Hexachlorocyclopentadien e | 0.05 | Kidney or stomach problems | Discharge from chemical factories | 0.05 |
| юс | Lead | TT7; Action Level = 0.015 | Infants and children: Delays in physical or mental development; children could show slight deficits in attention span and learning abilities; Adults: Kidney problems; high blood pressure | Corrosion of household plumbing systems; erosion of natural deposits | zero |
| M | Legionella | TT3 | Legionnaire's Disease, a type of pneumonia | Found naturally in water; multiplies in heating systems | zero |
| ос | Lindane | 0.0002 | Liver or kidney problems | Runoff/leaching from insecticide used on cattle, lumber, gardens | 0.0002 |
| IOC | Mercury (inorganic) | 0.002 | Kidney damage | Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and croplands | 0.002 |
| ос | Methoxychlor | 0.04 | Reproductive difficulties | Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock | 0.04 |
| юс | Nitrate (measured as Nitrogen) | 10 | Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome. | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits | 10 |
| IOC | Nitrite (measured as Nitrogen) | 1 | Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome. | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits | 1 |

LEGEND

D DBP

DBP Disinfection Byproduct

Dinsinfectant





| | Contaminant | MCL or TT1 (mg/L)2 | Potential health effects from exposure above the MCL | Common sources of contaminant in drinking water | Public Health Goal |
|-----|--|------------------------------------|--|--|-----------------------|
| ос | Oxamyl (Vydate) | 0.2 | Slight nervous system effects | Runoff/leaching from insecticide used on apples, potatoes, and tomatoes | 0.2 |
| oc | Pentachlorophenol | 0.001 | Liver or kidney problems; increased cancer risk | Discharge from wood preserving factories | zero |
| OC | Picloram | 0.5 | Liver problems | Herbicide runoff | 0.5 |
| oc | Polychlorinated biphenyls (PCBs) | 0.0005 | Skin changes; thymus gland problems; immune deficiencies; reproductive or nervous system difficulties; increased risk of cancer | Runoff from landfills; discharge of waste chemicals | zero |
| R | Radium 226 and Radium 228 (combined) | 5 pCi/L | Increased risk of cancer | Erosion of natural deposits | zero |
| IOC | Selenium | 0.05 | Hair or fingernail loss; numbness in fingers or toes; circulatory problems | Discharge from petroleum refineries; erosion of natural deposits; discharge from mines | 0.05 |
| OC | Simazine | 0.004 | Problems with blood | Herbicide runoff | 0.004 |
| OC | Styrene | 0.1 | Liver, kidney, or circulatory system problems | Discharge from rubber and plastic factories; leaching from landfills | 0.1 |
| OC | Tetrachloroethylene | 0.005 | Liver problems; increased risk of cancer | Discharge from factories and dry cleaners | zero |
| юс | Thallium | 0.002 | Hair loss; changes in blood; kidney, intestine, or liver problems | Leaching from ore-processing sites; discharge from electronics, glass, and drug factories | 0.0005 |
| oc | Toluene | 1 | Nervous system, kidney, or liver problems | Discharge from petroleum factories | 1 |
| M | Total Coliforms (including fecal coliform and <i>E. coli</i>) | 5.0%4 | Not a health threat in itself; it is used to indicate whether other potentially harmful bacteria may be present ⁵ | Coliforms are naturally present in the environment as well as feces; fecal coliforms and <i>E. coli</i> only come from human and animal fecal waste. | zero |
| DBP | Total Trihalomethanes (TTHMs) | 0.10 0.080 after 12/31/03 | Liver, kidney or central nervous system problems; increased risk of cancer | Byproduct of drinking water disinfection | n/a6 |
| OC | Toxaphene | 0.003 | Kidney, liver, or thyroid problems; increased risk of cancer | Runoff/leaching from insecticide used on cotton and cattle | zero |
| OC | 2,4,5-TP (Silvex) | 0.05 | Liver problems | Residue of banned herbicide | 0.05 |
| OC | 1,2,4-Trichlorobenzene | 0.07 | Changes in adrenal glands | Discharge from textile finishing factories | 0.07 |
| OC | 1,1,1-Trichloroethane | 0.2 | Liver, nervous system, or circulatory problems | Discharge from metal degreasing sites and other factories | 0.20 |
| OC | 1,1,2-Trichloroethane | 0.005 | Liver, kidney, or immune system problems | Discharge from industrial chemical factories | 0.003 |
| OC | Trichloroethylene | 0.005 | Liver problems; increased risk of cancer | Discharge from metal degreasing sites and other factories | zero |
| M | Turbidity | Π3 | Turbidity is a measure of the cloudiness of water. It is used to indicate water quality and filtration effectiveness (e.g., whether disease-causing organisms are present). Higher turbidity levels are often associated with higher levels of disease-causing micro-organisms such as viruses, parasites and some bacteria. These organisms can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. | Soil runoff | n/a |
| R | Uranium | 30 ug/L as of 12/08/03 | increased risk of cancer, kidney toxicity | Erosion of natural deposits | zero |

LEGEND

......

D Dinsinfectant





Inorganic Chemical



| A CONTRACTOR | Contaminant | MCL or TT1 (mg/L)2 | Potential health effects from exposure above the MCL | Common sources of contaminant in drinking water | Public Health Goal |
|--------------|-------------------|-----------------------|--|---|-----------------------|
| OC | Vinyl chloride | 0.002 | Increased risk of cancer | Leaching from PVC pipes; discharge from plastic factories | zero |
| M | Viruses (enteric) | TT3 | Gastrointestinal illness (e.g., diarrhea, vomiting, cramps) | Human and animal fecal waste | zero |
| ос | Xylenes (total) | 10 | Nervous system damage | Discharge from petroleum factories; discharge from chemical factories | 10 |

NOTES

- 1 Definitions
 - Maximum Contaminant Level Goal (MCLG)—The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety and are non-enforceable public health goals,
- Maximum Contaminant Level (MCL)—The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology and taking cost into
 consideration. MCLs are enforceable standards.
- Maximum Residual Disinfectant Level Goal (MRDLG)—The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control
 microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL)—The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Treatment Technique (TT)—A required process intended to reduce the level of a contaminant in drinking water.
- 2 Units are in milligrams per liter (mg/L) unless otherwise noted. Milligrams per liter are equivalent to parts per million (ppm).
- 3 EPA's surface water treatment rules require systems using surface water or ground water under the direct influence of surface water to (1) disinfect their water, and (2) filter their water or meet criteria for avoiding filtration so that the following contaminants are controlled at the following levels:
 - Cryptosporidium (as of 1/1/02 for systems serving >10,000 and 1/14/05 for systems serving <10,000) 99% removal.
 - Giardia lamblia: 99,9% removal/inactivation
 - Viruses: 99,99% removal/inactivation
 - · Legionella: No limit, but EPA believes that if Giardia and viruses are removed/inactivated, Legionella will also be controlled.
 - Turbidity: At no time can turbidity (cloudiness of water) go above 5 nephelolometric turbidity units (NTU); systems that filter must ensure that the turbidity go no higher than 1 NTU (0.5 NTU for conventional or direct filtration) in at least 95% of the daily samples in any month. As of January 1, 2002, for systems servicing >10,000, and January 14, 2005, for systems servicing <10,000, turbidity may never exceed 1 NTU, and must not exceed 0.3 NTU in 95% of daily samples in any month.
 - · HPC: No more than 500 bacterial colonies per milliliter
- Long Term 1 Enhanced Surface Water Treatment (Effective Date: January 14, 2005); Surface water systems or (GWUDI) systems serving fewer than 10,000 people must comply with the applicable Long Term 1 Enhanced Surface Water Treatment Rule provisions (e.g. turbidity standards, individual filter monitoring, Cryptosporidium removal requirements, updated watershed control requirements for unfiltered systems).
- Filter Backwash Recycling: The Filter Backwash Recycling Rule requires systems that recycle to return specific recycle flows through all processes of the system's existing conventional or direct filtration system or at an alternate location approved by the state.
- 4 No more than 5.0% samples total coliform-positive in a month. (For water systems that collect fewer than 40 routine samples per month, no more than one sample can be total coliform-positive per month.) Every sample that has total coliform must be analyzed for either facal coliforms or *E*, coli if two consecutive TC-positive samples, and one is also positive for *E*. coli facal coliforms, system has an acute MCL violation.
- 5 Fecal coliform and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Disease-causing microbes (pathogens) in these wastes can cause diarrhea, cramps, nausea, headaches, or other symptoms. These pathogens may pose a special health risk for infants, young children, and people with severely compromised immune systems.
- 6 Although there is no collective MCLG for this contaminant group, there are individual MCLGs for some of the individual contaminants:
 - · Haloacetic acids: dichloroacetic acid (zero); trichtoroacetic acid (0.3 mg/L)
 - Trihalomethanes: bromodichloromethane (zero); bromoform (zero); dibromochloromethane (0.06 mg/L)
- 7 Lead and copper are regulated by a Treatment Technique that requires systems to control the corrosiveness of their water. If more than 10% of tap water samples exceed the action level, water systems must take additional steps. For copper, the action level is 1.3 mg/L, and for lead is 0.015 mg/L.
- 8 Each water system must certify, in writing, to the state (using third-party or manufacturers certification) that when it uses acrylamide and/or epichlorohydrin to treat water, the combination (or product) of dose and monomer level does not exceed the levels specified, as follows: Acrylamide = 0.05% dosed at 1 mg/L (or equivalent); Epichlorohydrin = 0.01% dosed at 20 mg/L (or equivalent).



National Secondary Drinking Water Standards

National Secondary Drinking Water Standards are non-enforceable guidelines regulating contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water. EPA recommends secondary standards to water systems but does not require systems to comply. However, states may choose to adopt them as enforceable standards.

| Contaminant | Secondary Standard |
|------------------------|-------------------------|
| Aluminum | 0.05 to 0.2 mg/L |
| Chloride | 250 mg/L |
| Color | 15 (color units) |
| Copper | 1.0 mg/L |
| Corrosivity | noncorrosive |
| Fluoride | 2.0 mg/L |
| Foaming Agents | 0.5 mg/L |
| Iron | 0.3 mg/L |
| Manganese | 0.05 mg/L |
| Odor | 3 threshold odor number |
| pН | 6.5-8.5 |
| Silver | 0.10 mg/L |
| Sulfate | 250 mg/L |
| Total Dissolved Solids | 500 mg/L |
| Zinc | 5 mg/L |

Office of Water (4606M) EPA 816-F-03-016 www.epa.gov/safewater June 2003

APPENDIX D The Second Contaminant Candidate List (EPA, 2005)



Fact Sheet: The Drinking Water Contaminant Candidate List -- The Source of Priority Contaminants for the Drinking Water Program

EPA has drinking water regulations for more than 90 contaminants. The Safe Drinking Water Act (SDWA) includes a process that we must follow to identify new contaminants which may require regulation in the future. EPA must periodically release a Contaminant Candidate List (CCL). EPA uses this list of unregulated contaminants to prioritize research and data collection efforts to help us to determine whether we should regulate a specific contaminant.

In February 2005, we published the second CCL of 51 contaminants. We also provided an update on our work to improve the CCL process for the future that is based, in part, on recommendations from the National Research Council and the National Drinking Water Advisory Council. In addition to making the process used for selecting contaminants easier to understand, our goals for the future are to:

- •• evaluate a wider range of information
- · screen contaminants more systematically, and
- •• develop a more comprehensive CCL by expanding the number of contaminants being reviewed for inclusion on the next CCL.

You can find more information on the CCL on EPA's website at www.epa.gov/safewater/ccl/

Questions and Answers

What is the drinking water CCL?

The drinking water CCL is the primary source of priority contaminants on which we conduct research and make decisions about whether regulations are needed. The contaminants on the list are known or anticipated to occur in public water systems. However, they are currently unregulated by existing national primary drinking water regulations.

How often is the CCL published?

The Safe Drinking Water Act directs that we periodically publish a CCL. We published the first CCL of 60 contaminants in March 1998 and the second CCL in February 2005 after deciding to continue research on the list of contaminants on the first CCL.

What contaminants are included in CCL 2?

The CCL (published in 2005) carries forward 51 (of the original 60) unregulated contaminants from the first CCL, including nine microbiological contaminants and 42 chemical contaminants or contaminant groups (see table). In July 2003, EPA announced its final determination for a subset of nine contaminants from the first CCL, which concluded that sufficient data and

information was available to make the determination not to regulate Acanthamoeba, aldrin, dieldrin, hexachlorobutadiene, manganese, metribuzin, naphthalene, sodium, and sulfate. These nine contaminants were not carried forward to the 2005 CCL.

Does the CCL impose any requirements on public water systems?

No. The CCL alone does not impose any requirements on public water systems. However, we may regulate contaminants on the list in the future. Public water systems would have to follow specific requirements to comply with a regulation.

What happens to contaminants on the CCL?

We carry out studies to develop analytical methods for detecting the contaminants, determine whether they occur in drinking water, and evaluate treatment technologies to remove them from drinking water. We also investigate potential health effects from the contaminants. These efforts help us to determine if actions such as drinking water guidance, health advisories or regulations need to be developed for contaminants on the CCL, or if no action is necessary at this time.

What is a regulatory determination?

A regulatory determination is a formal decision on whether we should issue a national primary drinking water regulation for a specific contaminant. The law requires that we make regulatory determinations for five or more contaminants from the most recent CCL.

In 2003, we made regulatory determinations for nine contaminants from the first CCL. We plan to propose the second cycle of preliminary regulatory determinations from the second CCL in the summer of 2005 and make final regulatory determinations in August of 2006.

It is important to note that we are not limited to making regulatory determinations for only those contaminants on the CCL. We can also decide to regulate other unregulated contaminants if information becomes available showing that a specific contaminant presents a public health risk.

What criteria do EPA consider to make regulatory determinations?

When making a "determination" to regulate, the law requires that we consider three areas:

- •• projected adverse health effects from the contaminant,
- •• the extent of occurrence of the contaminant in drinking water, and
- •• whether regulation of the contaminant would present a "meaningful opportunity" for reducing risks to health.

What is EPA doing to improve future CCLs?

During development of the first CCL, we received comments that indicated a need for a broader, more comprehensive approach for selecting contaminants. In response, we sought the advice of the National Research Council (NRC) on how we could improve the process for selecting contaminants. The NRC's 2001 report provided us with a framework for how we could evaluate a larger number of contaminants and make decisions about those contaminants by applying innovative technologies and expert advice.

We then asked the National Drinking Water Advisory Council (NDWAC) to advise us on how to address the NRC's recommended classification process. The NDWAC's May 2004 report provided us with a number of recommendations on how the process should be managed and principles that we should use in developing future CCLs. We are reviewing the NDWAC recommendations and are on schedule to meet the February 2008 deadline for the third CCL. You can review the NDWAC report on EPA's web site at www.epa.gov/safewater/ndwac/pdfs/report ccl ndwac 07-06-04.pdf.

Where can I find more information about this notice and the CCL?

For information on the CCL and the contaminant selection process, please visit www.epa.gov/safewater/ccl/. For general information on drinking water, please visit the EPA Safewater website at www.epa.gov/safewater or contact the Safe Drinking Water Hotline at 1-800-426-4791. The Safe Drinking Water Hotline is open Monday through Friday, excluding legal holidays, from 9:00 a.m. to 5:00 p.m. Eastern time.

Drinking Water Contaminant Candidate List 2

Microbial Contaminant Candidates

Adenoviruses

Aeromonas hydrophila

Caliciviruses

Coxsackieviruses

Cyanobacteria (blue-green algae), other freshwater algae, and their toxins

Echoviruses

Helicobacter pylori

Microsporidia (Enterocytozoon & Septata)

Mycobacterium avium intracellulare (MAC)

| Chemical Contaminant Candidates | CASRN |
|---------------------------------|------------|
| 1,1,2,2-tetrachloroethane | 79-34-5 |
| 1,2,4-trimethylbenzene | 95-63-6 |
| 1,1-dichloroethane | 75-34-3 |
| 1,1-dichloropropene | 563-58-6 |
| 1,2-diphenylhydrazine | 122-66-7 |
| 1,3-dichloropropane | 142-28-9 |
| 1,3-dichloropropene | 542-75-6 |
| 2,4,6-trichlorophenol | 88-06-2 |
| 2,2-dichloropropane | 594-20-7 |
| 2,4-dichlorophenol | 120-83-2 |
| 2,4-dinitrophenol | 51-28-5 |
| 2,4-dinitrotoluene | 121-14-2 |
| 2,6-dinitrotoluene | 606-20-2 |
| 2-methyl-Phenol (o-cresol) | 95-48-7 |
| Acetochlor | 34256-82-1 |

| Chemical Contaminant Candidates | CASRN |
|---|------------|
| Alachlor ESA & other acetanilide pesticide degradation products | N/A |
| Aluminum | 7429-90-5 |
| Boron | 7440-42-8 |
| Bromobenzene | 108-86-1 |
| DCPA mono-acid degradate | 887-54-7 |
| DCPA di-acid degradate | 2136-79-0 |
| DDE | 72-55-9 |
| Diazinon | 333-41-5 |
| Disulfoton | 298-04-4 |
| Diuron | 330-54-1 |
| EPTC (s-ethyl-dipropylthiocarbamate) | 759-94-4 |
| Fonofos | 944-22-9 |
| p-Isopropyltoluene (p-cymene) | 99-87-6 |
| Linuron | 330-55-2 |
| Methyl bromide | 74-83-9 |
| Methyl-t-butyl ether (MTBE) | 1634-04-4 |
| Metolachlor | 51218-45-2 |
| Molinate | 2212-67-1 |
| Nitrobenzene | 98-95-3 |
| Organotins | N/A |
| Perchlorate | 14797-73-0 |
| Prometon | 1610-18-0 |
| RDX | 121-82-4 |
| Terbacil | 5902-51-2 |
| Terbufos | 13071-79-9 |

| Chemical Contaminant Candidates | CASRN |
|---|--|
| Triazines & degradation products of triazines | including, but not limited to Cyanazine 21725-46-2 and atrazine-desethyl 6190-65-4 |
| Vanadium | 7440-62-2 |

APPENDIX E The Third Contaminant Candidate List (Draft, EPA, 2008)



0

Thursday, February 21, 2008

Part II

Environmental Protection Agency

Drinking Water Contaminant Candidate List 3—Draft; Notice

ENVIRONMENTAL PROTECTION AGENCY

[EPA-HQ-OW-2007-1189 FRL-8529-7]

RIN 2040-AD99

Drinking Water Contaminant Candidate List 3—Draft

AGENCY: Environmental Protection Agency (EPA). ACTION: Notice.

SUMMARY: EPA is publishing for public review and comment a draft list of contaminants that are currently not subject to any proposed or promulgated national primary drinking water regulations, that are known or anticipated to occur in public water systems, and which may require regulations under the Safe Drinking Water Act (SDWA). This is the third Contaminant Candidate List (CCL 3) published by the Agency since the SDWA amendments of 1996.

This draft CCL 3 includes 93 chemicals or chemical groups and 11 microbiological contaminants. The EPA seeks comment on the draft CCL 3, the approach used to develop the list, and other specific contaminants. DATES: Comments must be received on

or before May 21, 2008.

ADDRESSES: Submit your comments, identified by Docket ID No. EPA-HQ-OW-2007-1189, by one of the following methods:

 http://www.regulations.gov: Follow the on-line instructions for submitting comments.

• *Mail:* Water Docket, Environmental Protection Agency, Mailcode: 2822T, 1200 Pennsylvania Ave., NW., Washington, DC 20460.

• Hand Delivery: Water Docket, EPA Docket Center (EPA/DC) EPA West, Room 3334, 1301 Constitution Ave., NW., Washington, DC. Such deliveries are only accepted during the Docket's normal hours of operation, and special arrangements should be made for deliveries of boxed information.

Instructions: Direct your comments to Docket ID No. EPA-HQ-OW-2007-1189. EPA's policy is that all comments received will be included in the public docket without change and may be made available online at http:// www.regulations.gov, including any personal information provided, unless the comment includes information claimed to be Confidential Business Information (CBI) or other information whose disclosure is restricted by statute. Do not submit information that you consider to be CBI or otherwise protected through http:// www.regulations.gov or e-mail. The

http://www.regulations.gov Web site is an "anonymous access" system, which means EPA will not know your identity or contact information unless you provide it in the body of your comment. If you send an e-mail comment directly to EPA without going through http:// www.regulations.gov your e-mail address will be automatically captured and included as part of the comment that is placed in the public docket and made available on the Internet. If you submit an electronic comment, EPA recommends that you include your name and other contact information in the body of your comment and with any disk or CD-ROM you submit. If EPA cannot read your comment due to technical difficulties and cannot contact you for clarification, EPA may not be able to consider your comment. Electronic files should avoid the use of special characters, any form of encryption, and be free of any defects or viruses. For additional instructions on submitting comments, go to Unit I.B of the SUPPLEMENTARY INFORMATION section of this document.

Docket: All documents in the docket are listed in the http:// www.regulations.gov index. Although listed in the index, some information is not publicly available, e.g., CBI or other information whose disclosure is restricted by statute. Certain other material, such as copyrighted material, will be publicly available only in hard copy. Publicly available docket materials are available either electronically in http:// www.regulations.gov or in hard copy at the Water Docket, EPA/DC, EPA West, Room 3334, 1301 Constitution Ave., NW., Washington, DC. The Public Reading Room is open from 8:30 a.m. to 4:30 p.m., Monday through Friday, excluding legal holidays. The telephone number for the Public Reading Room is (202) 566-1744, and the telephone number for the EPA Docket Center is (202) 566-2426.

FOR FURTHER INFORMATION CONTACT: For information on chemical contaminants contact Thomas Carpenter, Office of Ground Water and Drinking Water, Standards and Risk Management Division, at (202) 564–4885 or e-mail *carpenter.thomas@epa.gov*. For information on microbial contaminants contact Tracy Bone, Office of Ground Water and Drinking Water, at 202–564– 5257 or e-mail *bone.tracy@epa.gov*. For general information contact the EPA Safe Drinking Water Hotline at (800) 426–4791 or e-mail: *hotline-sdwa@epa.gov*. Abbreviations and Acronyms

- <—less than
- ≤—less than or equal to
- >-greater than
- ≥—greater than or equal to
- µ--microgram, one-millionth of a gram
- µg/L—micrograms per liter
- ATSDR—Agency for Toxic Substances and Disease Registry
- AWWA—American Water Works Association
- CASRN—Chemical Abstract Services Registry Number
- CDC—Centers for Disease Control and Prevention
- CCL-Contaminant Candidate List
- CCL 1—EPA's First Contaminant Candidate List
- CCL 2—EPA's Second Contaminant Candidate List
- CCL 3--EPA's Third Contaminant Candidate List
- CFR--Code of Federal Regulations
- CUS/IUR—Chemical Update System/ Inventory Update Rule
- DBP-disinfection byproduct
- DWEL-drinking water equivalent level
- EPA—United States Environmental
- Protection Agency
- ESA-ethanesulfonic acid
- FDA—United States Food and Drug Administration
- FR—Federal Register
- g-gram
- HAAs—haloacetic acids
- IOCs-inorganic contaminants
- IRIS—Integrated Risk Information System
- kg-kilogram
- L—liter
- LD₅₀—lethal dose 50; an estimate of a single dose that is expected to cause the death of 50 percent of the exposed animals; it is derived from experimental data.
- lbs-pounds
- LOAEL—lowest-observed-adverse-effect level
- MCL-maximum contaminant level
- MCLG—maximum contaminant level goal
- MRDD—maximum recommended daily dose
- mg/kg—milligrams per kilogram body weight
- mg/kg/day—milligrams per kilogram body weight per day
- mg/L—milligrams per liter
- MMWR—Morbidity and Mortality Weekly Report
- NAS—National Academy of Sciences
- NCI—National Cancer Institute
- NCOD-National Contaminant
- Occurrence Database
- NDWAC—National Drinking Water Advisory Council
- NOAEL—no-observed-adverse-effect level

- NRC—National Academy of Sciences' National Research Council
- NPDWR----national primary drinking water regulation
- NTP-National Toxicology Program
- OPP-Office of Pesticide Programs
- PFOA—perfluorooctanoic acid
- PFOS—perfluorooctane sulfonic acid
- PWS—public water system
- RfD--reference dose
- SAB—Science Advisory Board
- SDWA—Safe Drinking Water Act
- TCR—Total Coliform Rule
- TD₅₀—tumorigenic dose 50; The doserate which if administered chronically for the standard life-span of the species will have a 50% probability of causing tumors at some point during that period.
- TR1-Toxics Release Inventory
- TDS-training data set
- UCM—Unregulated Contaminant Monitoring
- UCMR 1—First Unregulated
- Containinant Monitoring Regulation UCMR 2—Second Unregulated
- Contaminant Monitoring Regulation US—United States of America
- USDA—United States Department of Agriculture
- USGS—United States Geological Survey
- WBDO-waterborne disease outbreak
- WHO—World Health Organization
- vr—vear

SUPPLEMENTARY INFORMATION:

- I. General Information
 - A. Does this Action Impose Any Requirements on My Public Water System?
 - B. What Should I Consider as I Prepare My Comments for EPA?
- Purpose, Background, and Summary of This Action
 - A. What is the Purpose of This Action?
 - B. Background on the CCL, Regulatory Determinations, and Unregulated Contaminant Monitoring
 - 1. Statutory Requirements for CCL and Regulatory Determinations
 - 2. The First Contaminant Candidate List
 - 3. The Regulatory Determinations for CCL 1
- 4. The Second Contaminant Candidate List 5. The Regulatory Determinations for CCL
- 2
- 6. The Unregulated Contaminant Monitoring Rule
- 7. The Third Contaminant Candidate List
- C. Summary of the Approach Used to Identify and Evaluate Candidates for CCL
- D. What is on EPA's Draft CCL 3?
- III. What Analyses Did EPA Use To Develop the Draft CCL 3?
 - A. Classification Approach for Chemicals
 - 1. Identifying the Universe
 - 2. Screening from the Universe to a PCCL
- 3. Using Classification Models to Develop the CCL 3
- 4. Selection of the Draft CCL 3—Chemicals B. Classification Approach for Microbial
- Contaminants

- 1. Developing the Universe
- 2. The Universe to PCCL
- 3. The PCCL to Draft CCL Process
- 4. Selection of the Draft CCL 3 Microbes from the PCCL
 C. Public Input
- 1. Nominations & Surveillance
- 2. External Expert Review and Input
- Boothan B
- IV. Request for Comment
- A. Pharmaceuticals
- B. Perfluorooctanoic acid and
- Perfluorooctane sulfonic acid
- C. Helicobacter pylori
- V. EPA's Next Steps

VI. References

I. General Information

A. Does This Action Impose Any Requirements on My Public Water System?

The draft Contaminant Candidate List 3 (CCL 3) or the final CCL 3, when published, will not impose any requirements on anyone. Instead, this action notifies interested parties of the availability of EPA's draft CCL 3 and seeks comment on the contaminants listed.

B. What Should I Consider as I Prepare My Comments for EPA?

You may find the following suggestions helpful for preparing your comments:

• Explain your views as clearly as possible.

Describe any assumptions that you used.

 Provide any technical information and/or data you used that support your views.

Provide specific examples to

illustrate your concerns.

Offer alternatives.

Make sure to submit your comments by the comment period deadline. To ensure proper receipt by EPA, identify the appropriate docket identification number in the subject line on the first page of your response. It would also be helpful if you provided the name, date, and **Federal Register** citation related to your comments.

II. Purpose, Background, and Summary of This Action

This section briefly summarizes the purpose of this action, the statutory requirements, previous activities related to the Contaminant Candidate List (CCL), and the approach used to develop the CCL 3.

A. What Is the Purpose of This Action?

The Safe Drinking Water Act (SDWA), as amended in 1996, requires EPA to publish a list of currently unregulated contaminants that may pose risks for drinking water (referred to as the Contaminant Candidate List, or CCL) and to make determinations on whether to regulate at least five contaminants from the CCL with a national primary drinking water regulation (NPDWR) (section 1412(b)(1)). The 1996 SDWA requires the Agency to publish both the CCL and the regulatory determinations every five years. The purpose of this action is to present EPA's draft list of contaminants on the CCL 3, a description of the selection process, and the rationale used to make the list.

This action also includes a request for comment on the Agency's draft CCL 3, the approach used to develop the list, and other specific contaminants.

B. Background on the CCL, Regulatory Determinations, and Unregulated Contaminant Monitoring

1. Statutory Requirements for CCL and Regulatory Determinations

Section 1412(b) (1) of SDWA, as amended in 1996, requires EPA to publish the Contaminant Candidate List every five years. SDWA specifies that the list must include contaminants that are not subject to any proposed or promulgated NPDWRs, are known or anticipated to occur in public water systems (PWSs), and may require regulation under SDWA.

The 1996 SDWA Amendments also specify three criteria to determine whether a contaminant may require regulation:

 The contaminant may have an adverse effect on the health of persons;

• The contaminant is known to occur or there is a substantial likelihood that the contaminant will occur in public water systems with a frequency and at levels of public health concern; and

• In the sole judgment of the Administrator, regulation of such contaminant presents a meaningful opportunity for health risk reduction for persons served by public water systems.

In developing the draft CCL 3, the Agency considered the best available data and information for unregulated contaminants. As required under the Safe Drinking Water Act, EPA evaluated substances identified in section 101(14) of the Comprehensive Environmental Response, Compensation, and Liability Act of 1980 and substances registered as pesticides under the Federal Insecticide, Fungicide, and Rodenticide Act. In addition to these required data sources, the Agency also developed the National Contaminant Occurrence Database (NCOD) established under section 1445(g) of SDWA. Substances from NCOD were included in the initial set

of contaminants considered for the draft CCL 3.

SDWA also directs the Agency to consider the health effects and occurrence information for unregulated contaminants to identify those contaminants that present the greatest public health concern related to exposure from drinking water. In selecting contaminants for the draft CCL 3, adverse health effects that may pose a greater risk to subgroups which represent a meaningful portion of the population were considered. Adverse health effects associated with infants, children, pregnant women, the elderly, and individuals with a history of serious illness were evaluated for both chemicals and microbes. The specific analyses and evaluations used by the Agency are discussed and cited in the relevant sections of this notice.

2. The First Contaminant Candidate List

Following the 1996 SDWA Amendments, EPA sought input from the National Drinking Water Advisory Council (NDWAC) on the process that should be used to identify contaminants for inclusion on the first CCL (CCL 1). For chemical contaminants, the Agency developed screening and evaluation criteria based on the recommendations provided by NDWAC. For microbiological contaminants, NDWAC recommended that the Agency seek external expertise to identify and select potential waterborne pathogens. As a result, an external group of microbiologists and public health experts developed the criteria for screening, conducted an evaluation of microbial agents, and selected the initial list of microbiological contaminants for the CCL 1.

The draft CCL 1 was published on October 6, 1997 (62 *FR* 52193 (USEPA, 1997)). After consideration of all comments, EPA published the final CCL 1, which included 50 chemical and 10 microbiological contaminants, on March 2, 1998 (63 *FR* 10273 (USEPA, 1998 b)). A more detailed discussion of how EPA developed CCL 1 can be found in the 1997 and the 1998 **Federal Register** notices (62 *FR* 52193 (USEPA, 1997) and 63 *FR* 10273 (USEPA, 1998 b)).

3. The Regulatory Determinations for CCL 1

EPA published its preliminary regulatory determinations for a subset of contaminants listed on CCL 1 on June 3, 2002 (67 FR 38222 (USEPA, 2002 b)). The Agency published its final regulatory determinations on July 18, 2003 (68 FR 42898 (USEPA, 2003 a)). EPA identified 9 contaminants from the 60 contaminants listed on CCL 1 that had sufficient data and information available to make regulatory determinations. The 9 contaminants were *Acanthamoeba*, aldrin, dieldrin, hexachlorobutadiene, manganese, metribuzin, naphthalene, sodium, and sulfate. The Agency determined that a national primary drinking water regulation was not necessary for any of these 9 contaminants. The Agency issued guidance on *Acanthamoeba* and health advisories for magnesium, sodium, and sulfate.

4. The Second Contaminant Candidate List

The Agency published its draft second CCL (CCL 2) **Federal Register** notice on April 2, 2004 (69 *FR* 17406 (USEPA, 2004)) and the final CCL 2 **Federal Register** notice on February 24, 2005 (70 *FR* 9071 (USEPA, 2005 b)). The CCL 2 carried forward the 51 remaining chemical and microbial contaminants that were listed on CCL 1.

5. The Regulatory Determinations for CCL 2

EPA published its preliminary regulatory determinations for a subset of contaminants listed on CCL 2 on May 1, 2007 (72 FR 24015 (USEPA, 2007 d)). EPA identified 11 contaminants from the 51 contaminants listed on CCL 2 that had sufficient data and information available to make preliminary regulatory determinations. The 11 contaminants are boron, the dacthal mono- and diacid degradates, 1,1-dichloro-2,2-bis (pchlorophenyl) ethylene (DDE), 1,3dichloropropene, 2,4-dinitrotoluene, 2,6-dinitrotoluene, s-ethyl propylthiocarbamate (EPTC), fonofos, terbacil, and 1,1,2,2-tetrachloroethane. The Agency has made a preliminary determination that a national primary drinking water regulation is not necessary for any of these 11 contaminants. The Agency is scheduled to publish its final regulatory determinations in 2008. In the May 1, 2007 FR notice, the Agency indicated that additional information was needed to make the regulatory determinations for perchlorate and methyl tertiary butyl ether (MTBE) and provided a summary of the current health effects, occurrence, and exposure information.

6. The Unregulated Contaminant Monitoring Rule

SDWA provides EPA with the authority to require all large and a subset of small systems to monitor for unregulated contaminants. EPA may require monitoring for up to 30 contaminants under the Unregulated Contaminant Monitoring Rule (UCMR). Since the 1996 SDWA amendments, the Agency has issued two UCMRs (UCMR 1 and UCMR 2). UCMR 1 was promulgated on September 17, 1999 (64 *FR* 50556 (USEPA, 1999)) and UCMR 2 on January 4, 2007 (72 *FR* 367 (USEPA, 2007 a)), followed by two revisions published later in January 2007 (72 *FR* 3916 (USEPA, 2007 b) and 72 *FR* 4328 (USEPA, 2007 c)). Monitoring under UCMR 2 will take place during the 2008–2010 time period.

UCMR 2 requires monitoring for several pesticides and pesticide degradates, five polybrominated diphenyl ether (PBDE) flame retardants, a group of nitrosamines and two munitions (TNT and RDX). All of the chemicals on UCMR 2 were included among the contaminants evaluated for CCL 3. Data collected under the UCMR are an important source of occurrence information for the CCL process.

7. The Third Contaminant Candidate List

In 1998, the Agency sought advice from the National Academy of Sciences' National Research Council (NRC) on how to improve the CCL process. The NRC published its recommendations on the CCL process in 2001 (NRC, 2001). The NRC proposed a broader, more reproducible process to identify the CCL than the process used by EPA in the first CCL. The NRC recommended that EPA develop and use a multi-step process for creating CCL 3 and future CCLs, whereby a broadly defined "universe" of potential drinking water contaminants is identified, assessed, and reduced to a preliminary CCL (PCCL) using simple screening criteria. All of the contaminants on the PCCL would then be assessed in more detail using a classification tool to evaluate the likelihood that specific contaminants could occur in drinking water at levels and at frequencies that pose a public health concern.

In 2002, the Agency sought input from the National Drinking Water Advisory Council (NDWAC) on how to implement the NRC's recommendations to improve the CCL process. NDWAC agreed that EPA should proceed with the NRC's recommendations and provided some additional considerations, including the overarching principles the Agency should follow. The NDWAC workgroup met 10 times between September 2002 and May 2004. The NDWAC issued its recommendations in "The National Drinking Water Advisory Council Report on the CCL Classification Process to the U.S. Environmental Protection Agency" (NDWAC, 2004).

NDWAC recommended two guiding principles for construction of the CCL universe, which are:

• The universe should include those contaminants that have demonstrated or have potential occurrence in drinking water, and

 The universe should include those contaminants that have demonstrated or have potential adverse health effects.

These inclusionary principles apply to the selection of contaminants for initial CCL consideration.

The NDWAC also recommended that the universe of contaminants should be screened based on widely available data elements that indicate important health effects and occurrence information. This screening step should be as simple as possible and capable of identifying contaminants of the greatest significance for further consideration. Consideration of a classification approach was also recommended to increase the transparency and reproducibility of the CCL decision process. NDWAC recommended that EPA pursue classification models that build on the screening criteria to further characterize the adverse health effects and occurrence of chemical contaminants. NDWAC noted that the classification models are tools to help prioritize contaminants for the CCL. The model results, available information used by the model, and expert reviews should be used to determine which contaminants are listed for the next CCL. The process to develop the models should be viewed as iterative, and EPA should involve experts and allow opportunities for meaningful public comment on the evaluation of contaminants.

NDWAC recommended several overarching principles that EPA should use to develop the CCL. In addition to the need for transparency and public participation, these overarching recommendations include:

• Integrate expert judgment throughout the CCL process. Expert judgment is inherent throughout the development of the CCL process and in implementing that process once it is developed. Critical reviews, involving various types of expert consultation and collaboration, will be useful at key points in the new, evolving CCL process.

 Conduct an active surveillance and nomination/evaluation processes to ensure timely identification of information relevant to new and emerging agents. • Apply an adaptive management approach (i.e., an approach that can be refined in future iterations as more knowledge is acquired) to implement the CCL process. The development of any model should be an adaptive process, and should be reviewed by experts with consideration given to updating the process with each successive CCL cycle.

NDWAC also recognized that there were significant differences in the methods and information used to characterize chemical and microbiological contaminants. Chemical contaminants tend to be characterized by toxicological and occurrence data that can be modeled or estimated if measurement is not possible. These discrete characteristics are often captured in data sources. For microbes, the adverse health effects from exposure are characterized by clinical or epidemiological data and there are few methods to estimate or model their occurrence. Limited sources of tabular data for microbes may require evaluation of primary literature, technical reports, monographs, and reference books to identify a universe of microbes for consideration. NDWAC recommended the Agency use human pathogens as the starting point for identifying microorganisms considered for inclusion in the CCL and apply a two-step evaluation of those pathogens.

C. Summary of the Approach Used To Identify and Evaluate Candidates for CCL 3

The Agency revised the CCL process used in previous efforts based on the knowledge and experience it has gained from evaluating unregulated contaminants and the recommendations and advice from NRC and NDWAC. Based on these recommendations the Agency developed and implemented a classification approach that identifies priority drinking water contaminants in a transparent and reproducible manner that is amenable to an adaptive management approach.

The Agency's approach to classifying contaminants is based on available data to characterize the occurrence and adverse health risks a contaminant may pose to consumers of public water systems. EPA developed and implemented the following multi-step CCL process to identify contaminants for inclusion on the Draft CCL 3. • Identify a broad universe of potential drinking water contaminants (called the CCL 3 Universe). EPA evaluated 284 data sources that may identify potential chemical and microbial contaminants and selected a set of approximately 7,500 chemical and microbial contaminants from these data sources for initial consideration.

• Apply screening criteria to the CCL 3 Universe to identify those contaminants that should be further evaluated. Contaminants not passing the screening criteria remained in the universe. The screening criteria EPA developed are based on a contaminant's potential to occur in public water systems and the potential for public health concern. Applying these criteria narrows the universe of contaminants to a Preliminary-CCL (or PCCL).

· Identify contaminants from the PCCL to include on the CCL based on a more detailed evaluation of occurrence and health effects. For chemicals, EPA used structured classification models as tools to evaluate and identify drinking water priority contaminants. Decisions to include chemicals were made using the model results and the best available data to identify contaminants that may occur in PWSs and may cause adverse health effects. EPA used a decision tree approach for microbial contaminants to identify those contaminants that have the potential to occur in PWSs and transmit waterborne disease. These two approaches resulted in a draft list of chemicals and microbes for inclusion on the Draft CCL 3.

• Incorporate public input and expert review in the CCL process. EPA sought public input by asking for nominations of contaminants to consider for the CCL (71 *FR* 60704 (USEPA, 2006 b)) and incorporated these nominations in the three key steps already discussed. EPA also convened several expert panels for both chemicals and microbes to review, and provide input and comment, on the CCL 3 process and on a review of a preliminary draft CCL 3.

Exhibit 1 illustrates the CCL multistep approach that resulted from the Agency's efforts, input, and collaboration with NRC and NDWAC. This generalized process is applied to both chemical and microbial contaminants, though the specific execution of particular steps differs in detail.



Exhibit 1. Schematic of CCL classification process

EPA provides a more detailed discussion of the analyses and decisions it made to develop the Draft CCL 3 in the EPA Water Docket. EPA prepared several support documents that are available for review at *http:// www.regulations.gov*. These documents include:

• Three comprehensive support documents for the chemicals entitled, "Contaminant Candidate List 3 Chemicals: Identifying the Universe" (USEPA, 2008 a), "Contaminant Candidate List 3 Chemicals: Screening to a PCCL" (USEPA, 2008 b), and "Contaminant Candidate List 3 Chemicals: Classification of the PCCL to the CCL" (USEPA, 2008 c). These documents describe in detail how the classification process was developed and used to select the chemicals for the Draft CCL.

• Three comprehensive support documents for the microbes entitled, "Contaminant Candidate List 3 Microbes: Identifying the Universe" (USEPA, 2008 d), "Contaminant Candidate List 3 Microbes: Screening to the PCCL" (USEPA, 2008 e), and "Contaminant Candidate List 3 Microbes: PCCL to CCL Process" (USEPA, 2008 f). These documents describe the microbial listing process in detail.

• The Agency also prepared summaries of stakeholder involvement and reviews conducted on the CCL process and draft list. These documents are also available in the EPA Water Docket and at http:// www.regulations.gov.

 National Drinking Water Advisory Council Report on the CCL Classification Process to the U.S. Environmental Protection Agency, May 19, 2004. • A nominations and surveillance report, entitled "Summary of the Nominations for the Third Contaminant Candidate List" (USEPA, 2008 g), which describes the nominations process and the contaminants that were nominated as part of EPA's process.

• Two documents summarizing the expert review of the chemical and microbial processes, entitled "Chemical Expert Input and Review for the Third Contaminant Candidate List" (USEPA, 2008 h) and "Microbial Expert Input and Review for the Third Contaminant Candidate List" (USEPA, 2008 i).

D. What Is on EPA's Draft CCL 3?

EXHIBIT 2.—DRAFT CONTAMINANT CANDIDATE LIST 3: MICROBIAL CON-TAMINANTS

| Pathogens | | |
|--|--|--|
| Caliciviruses Campylobacter jejuni Entamoeba histolytica Escherichia coli (0157) Helicobacter pylori Hepatitis A virus Legionella pneumophila Naegleria fowleri Salmonella enterica Shigella sonnei | | |
| | | |

CHEMICAL CONTAMINANTS

| Common name—registry name | CASRN |
|---------------------------|----------|
| alpha- | |
| Hexachlorocyclohexane | 319-84-6 |
| 1,1,1,2-Tetrachloroethane | 630-20-6 |
| 1,1-Dichloroethane | 75-34-3 |
| 1,2,3-Trichloropropane | 96-18-4 |
| 1.3-Butadiene | 106-99-0 |
| 1.3-Dinitrobenzene | 99-65-0 |
| 1.4-Dioxane | 123-91-1 |
| 1-Butanol | 71-36-3 |

CHEMICAL CONTAMINANTS—Continued

| Common name-registry | CASEN |
|-------------------------------|-------------|
| name | Gridenit |
| 2-Methoxyethanol | 109-86-4 |
| 2-Propen-1-ol | 107-18-6 |
| 3-Hydroxycarbofuran | 16655-82-6 |
| 4,4'-Methylenedianiline | 101-77-9 |
| Acephate | 30560-19-1 |
| Acetaldehyde | 75-07-0 |
| Acetamide | 60-35-5 |
| Acetochlor | 34256-82-1 |
| Acetochlor ethanesulfonic | |
| acid (ESA) | 187022113 |
| Acetochlor oxanilic acid (OA) | 184992-44-4 |
| Acrolein | 107-02-8 |
| Alachlor ethanesulfonic acid | |
| (ESA) | 142363-53-9 |
| Alachlor oxanilic acid (OA) | 171262-17-2 |
| Aniline | 62-53-3 |
| Bensulide | 741-58-2 |
| Benzyl chloride | 100-44-7 |
| Butylated hydroxyanisole | 25013-16-5 |
| Captan | 133-06-2 |
| Chloromethane (Methyl chlo- | |
| ride) | 74-87-3 |
| Clethodim | 110429-62-4 |
| Cobalt | 7440-48-4 |
| Cumene hydroperoxide | 80-15-9 |
| Cyanotoxins (3). | |
| Dicrotophos | 141-66-2 |
| Dimethipin | 55290-64-7 |
| Dimethoate | 60-51-5 |
| Disulfoton | 298-04-4 |
| Diuron | 330-54-1 |
| Ethion | 563-12-2 |
| Ethoprop | 13194-48-4 |
| Ethylene glycol | 107-21-1 |
| Ethylene oxide | 75-21-8 |
| Ethylene thiourea | 96-45-7 |
| Fenamiphos | 22224-92-6 |
| Formaldehyde | 50-00-0 |
| Germanium | 7440-56-4 |
| HCFC-22 | 75-45-6 |
| Hexane | 110-54-3 |
| Hydrazine | 302-01-2 |
| Methamidophos | 10265-92-6 |
| Methanol | 67-56-1 |
| Methyl bromide | |
| (Bromomethane) | 74-83-9 |
| Methyl tert-bulyl ether | 1634-04-4 |

CHEMICAL CONTAMINANTS—Continued CHEMICAL CONTAMINANTS—Continued

| Common name—registry name | CASRN |
|------------------------------|--------------------|
| Metolachlor | 51218-45-2 |
| Metolachlor ethanesulfonic | |
| acid (ESA) | 171118-09-5 |
| Metolachlor oxanilic acid | 12010000 8080098 |
| (OA) | 152019-73-3 |
| Molinate | 2212-67-1 |
| Molybdenum | 7439-98-7 |
| Nitrobenzene | 98-95-3 |
| Nitrofen | 1836-75-5 |
| Nitroalvcerin | 55-63-0 |
| N-Methyl-2-pyrrolidone | 872-50-4 |
| N-nitrosodiethylamine | |
| (NDFA) | 55-18-5 |
| N-nitrosodimethylamine | |
| (NDMA) | 62-75-9 |
| N-nitroso-di-n-propylamine | 02 10 0 |
| (NDPA) | 621-64-7 |
| N-Nitrosodinhenvlamine | 86-30-6 |
| N-nitrosonyrroliding (NPVP) | 020-55-2 |
| a Propulbopzopo | 102 66 1 |
| o Toluidino | 05 53 4 |
| Ovirano methul | 95-55-4 75 56 0 |
| Oxidemeter method | /0-00-9 |
| Oxydemeton-methyl | 301-12-2 |
| Oxynuorren | 42874-03-3 |
| Perchiorate | 14/9/-/3-0 |
| Permethrin | 52645-53-1 |
| acid) | 335-67-1 |
| Profenotos | 41198-08-7 |
| Ouipoline | 91-22-5 |
| BDX (Heyabydro_135- | 01-22-0 |
| tripitro 1.3.5 tripzipo) | 101.80.4 |
| Con Rutubanzono | 126 00 0 |
| Stroatium | 7440 24-6 |
| Tehuesessels | 107504 00 0 |
| Tebuconazole | 10/534-90-3 |
| Teourenozide | 112410-23-8 |
| Tellurium | 13494-80-9 |
| Terbulos | 130/1-/9-9 |
| reputos sultone | 56070-16-7 |
| Thiodicarb | 59669-26-0 |
| Thiophanate-methyl | 23564-05-8 |
| Toluene diisocyanate | 26471-62-5 |
| Tribufos | 78-48-8 |

| Common name—registry name | CASRN |
|------------------------------|------------|
| Triethylamine | 121-44-8 |
| Triphenyltin hydroxide | |
| (TPTH) | 76-87-9 |
| Urethane | 51-79-6 |
| Vanadium | 7440-62-2 |
| Vinclozolin | 50471-44-8 |
| Ziram | 137-30-4 |
| | |

III. What Analyses Did EPA Use To **Develop the Draft CCL 3?**

A. Classification Approach for Chemicals

1. Identifying the Universe

In the first step in the approach, EPA compiled potential data sources, including sources identified at a stakeholder workshop sponsored by the American Water Works Association (AWWA), to develop a broad universe of potential drinking water contaminants, as shown in Exhibit 1. This compilation identified the 284 data sources that were assessed for the CCL Universe.

EPA developed a decision tree for data source selection that was based on four assessment factors, which were applied to all of the potential data sources:

 Relevance. Ensures that the data source provided information on demonstrated or potential health effects, occurrence, or potential occurrence using surrogate information (e.g., environmental release, environmental fate, and transport properties);

· Completeness. Ensures that the data source had minimum record requirements-contact name,

description of the data elements, and how the data were obtained:

 Redundancy. Ensures that the data source does not contain information identical to other more comprehensive data sources; and

· Retrievability. Ensures that the data in the source are formatted for automated retrieval. Each source was accessed on-line (or as provided by the source) and reviewed.

Basic information about the source, its purpose, and the data elements it contained, was compiled and documented. Every source was evaluated using all assessment factors sequentially. Those sources that met all four factors became the prime sources that formed the "Universe of Data Sources." Sources that passed the first three factors, but were not retrievable, were designated as supplemental data sources, to be consulted as necessary (e.g., to fill in data gaps) in the development of the CCL. Some of the sources that were not easily retrievable were identified as "unique" or "exceptional" because of the importance of their data (i.e., the Hazardous Substance Database). EPA included chemicals from these sources in the Universe.

After application of the four assessment factors, 39 sources (Exhibit 3) met all four factors or were considered as exceptional. These sources were the primary sources used to develop the CCL Chemical Universe. The details of the how EPA compiled the list of data sources is discussed in the document entitled, "CCL 3 Chemicals: Identifying the Universe" (USEPA, 2008 a).

EXHIBIT 3.—SOURCES THAT COMPRISE THE CHEMICAL UNIVERSE OF DATA SOURCES FOR THE CCL PROCESS

Name of data source

1. ATSDR CERCLA Priority List.

2. ATSDR Minimal Risk Levels (MRLs).

3. Chemical Toxicity Database-Ministry of Health and Welfare, Japan.

- 4. Chemical Update System/Inventory Update Rule (CUS/IUR)-EPA.
- 5. Cumulative Estimated Daily Intake/Acceptable Daily Intake (CEDI/ADI) Database--FDA.
- 6. Database of Sources of Environmental Releases of Dioxin-Like Compounds in the United States-EPA.
- 7. Distributed Structure Searchable Toxicity Public Database Network (DSSTox)-EPA.
- 8. Everything Added to Food in the United States (EAFUS) Database-FDA.
- 9. Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA) List-EPA.
- 10. Generally Regarded As Safe (GRAS) Substance List-FDA.

- 12. Hazardous Substances Data Bank (HSDB)---NLM.
- 13. Health Advisories (HA) Summary Tables-EPA.
- 14. High Production Volume (HPV) Chemical List-EPA.
- 15. Indirect Additives Database-FDA.
- 16. Integrated Risk Information System (IRIS)-EPA.
- 17. International Agency for Research on Cancer (IARC) Monographs.
- 18. International Toxicity Estimates for Risk (ITER) Database-TERA.
- 19. Joint Meeting On Pesticide Residues (JMPR)—2001 Inventory of Pesticide Evaluations—WHO, FAO. 20. National Drinking Water Contaminant Occurrence Database (NCOD)—Round 1&2—EPA.
- 21. National Drinking Water Contaminant Occurrence Database (NCOD)-Unregulated Contaminant Monitoring Rule (UCMR)-EPA.
- 22. National Inorganics and Radionuclides Survey (NIRS)-EPA.
- 23. National Pesticide Use Database-NCFAP.

^{11.} Guidelines for Canadian Drinking Water Quality (CADW): Summary of Guidelines-Health Canada.

EXHIBIT 3.—SOURCES THAT COMPRISE THE CHEMICAL UNIVERSE OF DATA SOURCES FOR THE CCL PROCESS— Continued

| Name of data source | | | | |
|--|--|--|--|--|
| 24. National Reconnaissance of Emerging Contaminants (NREC)—USGS Toxic Substances Hydrology Program. | | | | |
| 26. National Water Quality Assessment (NAWQA)—USGS. | | | | |
| 27. OSHA 1988 Permissible Exposure Limits (PELs)—NIOSH. | | | | |
| 28. Pesticide Data Program—USDA. | | | | |
| 29. Pesticides Pilot Monitoring Program—USGS/EPA. | | | | |
| 30. Nisk Assessment Information System (NAIS)—Department of Energy—Chemical Factors. | | | | |
| 32. State of California Chemicals Known to the State to Cause Cancer or Reproductive Toxicity. | | | | |
| 33. Substances Registry System (SRS)—EPA. | | | | |
| 34. Syracuse Research Corporation (SRC)—BIODEG. | | | | |
| 35. The Toxics Release Inventory (TRI)—EPA. | | | | |

36. Toxic Substances Control Act (TSCA) List-EPA.

37. Toxicity Criteria Database-California Office of Environmental Health Hazard Assessment (OEHHA).

38. University of Maryland-Partial List of Acute Toxins/Partial List of Teratogens.

39. WHO Guidelines for Drinking Water Quality: Summary Tables.

There were approximately 26,000 unique substances identified from the 39 data sources. Because of the large number of unique substances identified, EPA developed an initial universe selection process. In the first phase of the data evaluation process, EPA identified the chemicals that were present in both health effects and occurrence data sources. The Agency queried the data sources and found that approximately 7,300 chemicals, or about one-third of the chemicals, were present in both health effects and occurrence data sources. Occurrence was defined broadly to include production data and environmental occurrence data. EPA placed these chemicals in the chemical universe to be further evaluated for screening to the PCCL. EPA then examined the rest of the approximately 18,600 chemicals left in the initial universe more closely to determine whether they were found only in health effects data sources or only in occurrence data sources. EPA found that approximately 5,100 chemicals were in health effects data sources only. Many of these chemicals were biochemical compounds (e.g., amino acids, sugars, steroids); mixtures and natural products (e.g., coal tar, petroleum related substances, rocks, stone, wool); and other entries that were identified as unique "substances" in the data sources but were not chemicals (e.g., turbidity, boot and shoe manufacture, surgical implants). EPA evaluated these to identify which ones are chemicals of greatest toxicological concern. Many of the chemicals fell into the category of greatest toxicological concern due to their classification as carcinogens. This is described in the report entitled, "CCL 3 Chemicals: Screening to a PCCL' (USEPA, 2008 b). Through this process, a total of 122 chemicals with only

toxicity data were added to the 7,300 chemicals already in the CCL Chemical Universe.

The chemicals found only in occurrence sources were also categorized. The approximately 13,500 chemicals with only occurrence data were a diverse group, comprised of many different types of chemicals. Data sources that provide the amount of an individual chemical that is manufactured and produced account for 70 percent (or 9,344) of the total. The remaining 30 percent of chemicals are from various other data sources (i.e., finished water, ambient water, environmental release, environmental fate and transport properties, and food additives). EPA grouped these chemicals by the type of occurrence data for further evaluation. These included the following groupings:

 Chemicals with Finished or Ambient Water Data

Chemicals with Release Data

Chemicals with High Production
Volumes

EPA added 42 chemicals with finished or ambient water data to the Universe despite the lack of health effects information in the data sources because of their demonstrated occurrence in ambient or potable water. In addition, disinfection byproducts and water treatment additives were added to the Chemical Universe. While there may not have been measured occurrence data for these chemicals in the universe of data sources, they are considered to have "default" occurrence data because they are formed in, or intentionally added to, drinking water supplies.

EPA also added 36 chemicals with an environmental release data source (e.g., those on the Toxics Release Inventory or with pesticide application data) to the Chemical Universe even though they lacked health effects data.

The largest group of chemicals found only in occurrence data sources had only production information. These contaminants include: organometallics, elements, salts of the inorganic elements, salts of organic acids, natural product organics (including oils, fatty acids, sugars, intermediary metabolites), and mixtures (e.g., petroleum related compounds, hydrocarbons, and others). Over half of the production chemicals are compounds and/or complexes of elemental constituents; for example, there were about 750 sodium or potassium salt compounds alone. In these cases, health effects data are not available for the exact compound, but are generally available for other related compounds or the key ion or elemental constituent (e.g., sodium). Nearly all elements found in inorganic or organic salts are represented in the Universe by other compounds with both health effects and occurrence data. EPA found only 10 elements (excluding carbon, hydrogen, and oxygen, and the inert gasses krypton, neon, and xenon) that did not otherwise have representative compounds with health effects data in the Universe. EPA added these compounds (i.e., europium, gadolinium, gold, lanthanum, praseodymium, platinum, polonium, samarium, terbium, and yttrium) to the Universe. After evaluation of the characteristics of the chemicals with production data and the amounts produced on a yearly basis, and because the primary constituents (i.e., elements) of the chemicals were already in the Chemical Universe, EPA decided to move only those produced at greater than 1 billion pounds per year to the CCL Chemical Universe when they lacked health effects information.

EPA added a total of 269 chemicals with only occurrence data to the CCL 3 Chemical Universe. The rest of the substances included in the original data sources were not included in the Universe.

The initial selection process brought into the CCL Chemical Universe all substances from the data sources that met the defined selection criteria, described above. Upon further review, EPA found the Chemical Universe also contained regulated as well as unregulated compounds, mixtures, and some substances that were not really chemicals. To further refine the initial list, EPA removed chemicals with a national primary drinking water regulation. These contaminants are already regulated; thus, their inclusion in the CCL process is unnecessary and does not meet the statutory requirement for selection of the CCL. EPA removed 1,006 chemicals, which is more than the number of primary drinking water standards. This is because regulated contaminants can be found in many forms and because many contaminants are regulated as part of a class or group(s). For example, EPA removed approximately 780 radionuclides from the initial list, because they are regulated as alpha and beta emitters. Also removed were various salts of regulated elements, and entries for individual trihalomethanes, haloacetic acids, polychlorinated biphenyls and polyaromatic hydrocarbons that are regulated as a group. The Agency has determined that it is inappropriate to include aldicarbs (aldicarb, aldicarb sulfoxide, and aldicarb sulfone) and nickel on the CCL. These contaminants are subject to regulation under SDWA section 1412(b)(2) and thus are not part of the contaminant selection process specified under SDWA section 1412(b)(1). In response to an administrative petition from the manufacturer Rhone-Poulenc, the Agency issued an administrative stay of the effective date of the maximum contaminant levels (MCLs) for aldicarbs, and they never became effective. NPDWRs for nickel were promulgated on July 17, 1992 (57 FR 31776 (USEPA, 1992)), but the MCL was later vacated and remanded by the D.C. Court of Appeals in response to a joint motion by EPA and industry parties challenging the nickel MCL and MCLG. Because these contaminants are subject to separate regulatory consideration, EPA has not included them in the CCL process.

EPA also removed substances that are considered a mixture of chemicals. EPA defines a mixture in this case as a combination of two or more chemicals/ items that are not defined as a unique substance. Examples of substances in this category include "chlorinated compounds, aliphatic alcohols with more than 14 carbon atoms (c>14), coaltar-containing shampoo, petroleumrelated substances, resin acids, and rosin acids." Undefined mixtures, such as "diesel engine exhaust" were also included in this group.

EPA also removed ⁴'non-chemically defined'' entries from further consideration for the initial list. Examples include: "solar radiation, wood dust, surgical implants, and welding fumes." Some of these substances are present in the data sources because they have been evaluated for their potential to cause cancer.

The final step removed biological agents from the initial list. Contaminants in this category are biological organisms that are being evaluated as part of the CCL 3 Microbiological Universe. Entries for biological entities were uploaded from the universe of data sources from various health effects data sources and pesticide data sources. Many biological entities were also removed as nonchemically defined.

During this phase of the data evaluation, 1,717 chemicals or substances were removed from the initial Chemical Universe, leaving approximately 6,000 chemicals that were designated as the CCL 3 Universe. A list of the CCL Chemical Universe is provided in the docket. EPA further evaluated these 6,000 chemicals in the next key step of the process.

2. Screening from the Universe to a PCCL

The next step in the CCL selection approach involved narrowing the Universe of chemicals to a PCCL, as shown in Exhibit 1. EPA considered and built upon NDWAC recommendations that the screening process be based on a contaminant's potential to occur in public water systems and the potential for public health concern, to select those contaminants that should move to the PCCL for further evaluation. The screening approach:

 Identifies chemicals that have relatively high toxicity with high potential to occur in PWSs;

• Identifies chemicals that have relatively high toxicity with minimal

actual or potential occurrence in drinking water;

 Identifies chemicals that have high potential to occur in PWSs with relatively moderate toxicity; and

• Considers and uses as many of the available types of health effects and occurrence data identified in the data source evaluations as practical.

EPA compared the chemicals' health effects relative to their occurrence and developed analyses that specifically incorporate many types of available data into the screening criteria. The health effects information included quantitative, descriptive, or categorical information. Within each of these broad types of health effects information, there are multiple types of reported health related values from multiple sources. The health effects analyses conducted by EPA identified approaches to compare each of these data types and identified similarities among chemicals that could be used to define toxicity categories. The occurrence information also included many types of available data representative of a chemical's potential to occur in water. Occurrence data ranged from quantified detection in PWSs, to environmental release, to production data.

The basic framework EPA used in screening is shown in Exhibit 4. EPA categorized the CCL Chemical Universe contaminants by their toxicity along the vertical axis and by their occurrence on the horizontal axis. This allows for separation of chemicals into those that move to the PCCL based on their toxicity and occurrence properties (e.g., upper right in Exhibit 4) and those that are not further evaluated and remain in the CCL Chemical Universe (e.g., lower left in Exhibit 4).

EPA used a set of test chemicals to develop the screening criteria. This set of chemicals included regulated and unregulated chemicals that provided comprehensive information on health effects and occurrence in finished and/ or ambient water as well as environmental release and production volume. EPA then used these criteria to select chemicals for the PCCL for further consideration. The following sections summarize how EPA developed the screening criteria by evaluating the available data for chemicals in the Universe, using the framework (Exhibit 4) and the test chemicals. A more detailed discussion is provided in the support document entitled, "CCL 3 Chemicals: Screening to a PCCL" (USEPA, 2008 b).

Exhibit 4: Partition for Screening the Universe



a. Health Effects Data Elements

EPA evaluated the toxicity information and health effects data compiled from the data sources in the Universe and these data varied greatly. Some of these data are quantitative (e.g., RfD, LOAEL, NOAEL, LD₅₀) and some are descriptive (e.g., cancer classifications or predictions). EPA designed the screening process to accommodate both types of health effects data.

The quantitative toxicity elements and values available in the Universe included the following:

· RfDs and equivalent (RfD-eq): RfDs, Minimum Risk Levels (MRLs) from ATSDR, Tolerable Daily Intakes (TDIs) from the World Health Organization (WHO), and Public Health Goals (PHGs) from California EPA. A reference dose is an estimate (with uncertainty spanning perhaps an order of magnitude) of a daily oral exposure to the human population (including sensitive subgroups) that is likely to be without an appreciable risk of deleterious effects during a lifetime. There are slight differences among Agencies in the methodologies used for some of the RfD equivalents.

• NOAELs—No Observed Adverse Effect Levels. The NOAEL is the highest dose evaluated in a study or group of studies that does not have a biologically significant adverse effect on the species evaluated as compared to controls.

• LOAELS—Lowest Observed Adverse Effect Levels. The LOAEL is the lowest dose evaluated in a study or group of studies that has a biologically significant adverse effect on the species evaluated as compared to the controls.

• TD₅₀S—Tumorigenic dose 50. The dose-rate which if administered chronically for the standard life-span of the species will have a 50 percent probability of causing tumors at some point during that period.

• MRDD—Maximum Recommended Daily Dose. Recommendations for the maximum adult daily therapeutic doses for pharmaceuticals.

• LD_{50} s—Lethal dose 50; an estimate of a single dose that is expected to cause the death of 50 percent of the exposed animals; it is derived from experimental data.

EPA used descriptive cancer data to group data elements into toxicity categories that provide gradation based upon the strength of the data. Sources for the descriptive cancer data included:

U.S. EPA Cancer Groupings.

IARC Cancer Groupings.

• NTP weight-of-evidence findings from cancer bioassays.

• National Cancer Institute (NCI) weight-of-evidence findings from cancer bioassays.

EPA Water Disinfection By-

Products with Carcinogenicity Estimates PCCL'' (USEPA, 2008 b).

(DBP-CAN) groupings based on carcinogenic potential derived from Quantitative Structure Activity Relationship (QSAR) projections.

EPA divided the chemicals in the Universe into five toxicity categories for screening based upon the distribution of the toxicity value for each type of quantitative data element and/or the qualitative information on cancer weight-of evidence. The five toxicity categories are designated 1 through 5, with Toxicity Category 1 containing chemicals in the most toxic grouping and Toxicity Category 5 the least toxic grouping.

Based upon the distribution of the chemicals for each quantitative data element, EPA selected ranges of toxicity values for each toxicity category that differed based upon the type of data element. For example, the range of toxicity values that place a LOAEL in Toxicity Category 1 differs from the values used for a LD₅₀. Exhibit 5 displays the ranges for each data element and their respective Toxicity Categories.

Additional information which describes how EPA performed the analyses to select the toxicity categories is described in the document entitled, "CCL 3 Chemicals: Screening to a PCCL" (USEPA, 2008 b).

EXHIBIT 5.—POTENCY MEASURES FOR UNIVERSE DATA ELEMENTS PARTITIONED BASED ON TOXICITY

[mg/kg/day or mg/kg]

| | RfD | NOAEL | LOAEL | MRDD | LD_{50} |
|---------------------|---------------|----------|----------|----------|-----------|
| Toxicity Category 1 | <0.0001 | <0.01 | <0.01 | <0.01 | <1 |
| Toxicity Category 2 | 0.0001-<0.001 | 0.01-<1 | 0.01-<1 | 0.01-<1 | 1-<50 |
| Toxicity Category 3 | 0.001-<0.05 | 1-<10 | 1<10 | 1-<10 | 50-<500 |
| Toxicity Category 4 | 0.05-<0.1 | 10-<1000 | 10-<1000 | 10-<1000 | 500-5000 |
| Toxicity Category 5 | >0.1 | >1000 | >1000 | >1000 | >5000 |

EPA partitioned the cancer-related data elements in the Universe into the Toxicity Categories as shown in Exhibit 6. The cancer data placed chemicals in only the three highest Toxicity Categories. EPA did not use quantitative measures of dose-response for carcinogenicity in the screening criteria because more chemicals have categorical data and can be analyzed using this descriptive data than by cancer slope factors. In addition, EPA did not use descriptors indicating lack of carcinogenic potential or insufficient data to determine carcinogenic potential

in categorizing chemicals because those descriptors apply only to the cancer endpoint and do not consider noncancer

effects associated with exposure to the chemical.

EXHIBIT 6.—PARTITIONING OF CANCER DATA BASED ON TD 50 VALUES AND WEIGHT-OF-EVIDENCE DESCRIPTORS

| | TD 50 | EPA | IARC/HC | NTP | NCI | DSS-Tox |
|---------------------------|---------|--|----------|---|--|-----------|
| Toxicity Category 1**. | <0.1 | Group A; Human Carcinogen. | Group 1 | CE 2 species/2 sexes; or 2 spe- cies; or 2 sexes. | P 2 species/2 sexes; or 2 spe- cies; or 2 sexes. | н. |
| Toxicity Category 2 | 0.1-100 | Groups B1 and B2; likely carcino- gens. | Group 2A | Combinations of CE, SE, EE, and NE. | Combinations of P, E and N. | HM. |
| Toxicity Category 3 | >100 | Group C; Sugges- tive evidence of carcinogenicity. | Group 2B | Combinations of SE, EE, and NE. | Combinations of E and N. | M and LM. |

** Cancer data placed chemicals in only the three highest Toxicity Categories.

CE = clear evidence, SE = some evidence, EE = equivocal evidence, NE = no evidence.

P = positive, N = Negative, E = equivocal.

H = high probability, HM = high to medium probability, M = medium probability, LM = medium to low probability.

EPA chose a conservative approach in the screening process to categorize each chemical's toxicity and evaluated all the available health effects dose-response and categorical data elements for a given chemical. Chemicals were assigned to the highest toxicity category indicated after an evaluation of all the available data. Accordingly, if a chemical had just one data element that places it in Toxicity Category 1, it was categorized as such even if some of the other data elements for that same chemical may place it in a lower toxicity category. For example, if a chemical is classified as a 2A carcinogen by IARC, it was placed in Toxicity Category 2 using the descriptive cancer data even if a quantified LOAEL from a different study places it in Toxicity Category 3.

b. Occurrence Data Elements

EPA evaluated the occurrence data elements for each chemical and placed them on the horizontal axis of the screening table. In assessing the data, EPA found that the data elements that represent a chemical's potential to occur in drinking water vary greatly. EPA's goal was to determine which data elements best represented the potential to occur in drinking water. EPA considered and evaluated data elements in the following categories:

 Finished Water—measures of concentration and frequency of detections.

 Ambient Water—measures of concentration and frequency of detections.

Total Releases in the

Environment—pounds per year and number of States.

 Pesticide Application Rates pounds per year and number of States.

• Production volume—pounds per vear.

In addition to evaluating quantitative data elements listed above, EPA also considered chemicals with descriptive data based upon their likelihood of occurring in drinking water. Examples of descriptive occurrence data elements include characterization as a disinfection byproduct or a drinking water treatment chemical.

EPA used the following hierarchal approach to select the occurrence data element used to screen a chemical: Finished Water or Ambient Water > Environmental Release Data > Production Data.

The highest data elements in the hierarchy are the finished and ambient water data; the lowest, the production data. Environmental release data from the Toxics Release Inventory (TRI) and pesticide application amounts occupy the middle position in the hierarchy.

EPA also decided that when multiple data values exist for the chemicals within a given component of the hierarchy, the most conservative data value is used. For example, in the case of a chemical that has finished water data and ambient water data, EPA selected the highest reported concentration as the occurrence value used in screening.

EPA obtained the finished water data elements from the National Contaminant Occurrence Database (NCOD), the Unregulated Contaminant Monitoring (UCM) Rounds 1 and 2, the National Inorganic Radionuclides Survey (NIRS), the Unregulated Contaminant Monitoring Regulation (UCMR) monitoring, the Information Collection Rule database for disinfection byproducts, the U.S. Department of Agriculture (USDA) Pesticide Data Program (PDP), and the U.S. Geological Survey (USGS) Pesticides Pilot Monitoring Program (PPMP). These sources included data elements such as percent samples with detections, percent drinking water systems with detections, mean and/or median detected concentrations, and highest observed concentrations.

EPA obtained ambient water values from the USGS National Water Quality Assessment Program (NAWQA), the USGS Toxics Substances Hydrology program's National Reconnaissance of Emerging Contaminants (NREC) and related studies, and the PPMP. These sources included data elements such as percent samples with detections, percent sites with detections, mean and/ or median detected concentrations, and highest observed concentrations.

The environmental release data are those reported for 2004 from the TRI and the National Pesticide Use Database, developed by the National Center for Food and Agricultural Policy (NCFAP). The available environmental release data elements include: total releases to the environment (lbs/yr), number of States with releases, pesticide total mass active ingredient applied nationally (lbs/yr), and number of States with pesticide application. EPA chose to use the pounds released per year into the environment for screening because the mass applied to the environment was more directly related to a potential concentration in water than the number of States where a chemical is released or applied.

EPA used the Toxic Substances Control Act (TSCA) chemical production volume ranges reported under the Chemical Update System/ Inventory Update Rule (CUS/IUR) to assess production volume. EPA selected the most recent year of data available for each particular chemical. CUS/IUR reports chemical production volume ranges rather than as exact values of release, and provides production data for all chemicals produced in volumes exceeding 10,000 lbs/yr. The production data are reported in 5 categories that range from less than 10,000 lbs/yr to greater than 1 billion lbs/yr. Therefore, EPA chose to use those ranges as the occurrence subdivisions for the production data.

The occurrence data were grouped by powers of 10 and arrayed from low to high across the horizontal axis of the screening table (Exhibit 4). The document entitled "CCL 3 Chemicals: Screening to a PCCL" (USEPA, 2008b) describes the analyses in greater detail.

In some cases, disinfection byproducts and water treatment chemicals lacked quantitative data elements in the Universe. However, both groups have a strong potential to be present in drinking water. EPA moved chemicals in these two categories forward to the PCCL for further evaluation even when limited health effects and/or occurrence information were available.

c. Selection of the PCCL

The last step in the screening process used the intersections between health effects and occurrence data elements in the screening table (Exhibit 4) to establish the PCCL selection line. As noted above, the health data elements were grouped by the 5 toxicity

categories with the element showing the highest potency determining placement in the screening table. EPA selected the highest available data element in the occurrence hierarchy to determine placement of a chemical on the horizontal axis in the screening table. Because the chemicals were evaluated using a hierarchical approach for their occurrence elements, EPA developed separate criteria for each of the occurrence elements, and used the placement of a group of test chemicals that had all or nearly all of the occurrence data elements, to establish the position of the PCCL selection line. The test chemicals were selected from regulated and past CCL chemicals. Each had data to illustrate whether it was or was not of concern as a drinking water contaminant.

As a secondary analysis, EPA evaluated existing Drinking Water Equivalent Levels (DWELs) to confirm whether they would make the PCCL. The DWELS were derived from the lower RfD potency for each of the RfD Toxicity Categories. The DWEL (mg/L) is calculated from the RfD in mg/kg/day by multiplying the RfD by an adult body weight of 70 kg and dividing by a drinking water intake of 2 L/day (rounded to one significant figure).When comparing the position of the set of DWELs to the PCCL selection line, all four toxicity categories would be put on the PCCL. This analysis supports the position of the PCCL selection line for chemicals with finished or ambient water concentration data.

EPA also used the test chemicals to determine the PCCL selection line for the other occurrence data elements total releases to the environment (i.e., TRI, pesticide application data) and production data. For example, the test chemicals were placed in Exhibit 4 based on their release data to guide the placement of the line that separated the "pass to the PCCL" chemicals from the "do not pass to the PCCL" chemicals. In general, the PCCL selection line was positioned so that regulated and most prior CCL chemicals would be selected for the PCCL.

EPA also analyzed the test chemicals with respect to occurrence, releases, and production data. The test data fit well for the former two categories. For the latter, the fit was not as good so EPA chose to set the PCCL selection line at the point where all chemicals produced at greater than 100 million pounds per year pass to the PCCL even if they fall in the lowest toxicity category.

The criteria for moving a chemical with finished or ambient water, environmental release, and production data to the PCCL are displayed in Exhibit 7.

EXHIBIT 7.-CRITERIA FOR A CHEMICAL TO PASS SCREENING TO THE PCCL

| Health offects | Occurrence (by data type) | | | | |
|---------------------|------------------------------|-----------------|-------------------|--|--|
| Health enects | Finished/ambient | Release amount | Production volume | | |
| | water concentrations | (per year) | (per year) | | |
| Toxicity Category 1 | All Concentrations | Ali Amounts | All Amounts. | | |
| Toxicity Category 2 | | ≥10,000 lbs/yr | ≥500,000 lbs/yr. | | |
| Toxicity Category 3 | | ≥100,000 lbs/yr | ≥10 M lbs/yr. | | |
| Toxicity Category 4 | | ≥1 M lbs/yr | ≥50 M lbs/yr. | | |
| Toxicity Category 5 | | ≥10 M lbs/yr | ≥100 M lbs/yr. | | |

EPA added DBPs and drinking water additives that lacked quantitative occurrence data but fell in the Toxicity Category 1 or Toxicity Category 2 groupings to the PCCL because of their high probability for being present in disinfected and treated drinking water.

The screening process provides a data-driven, objective, and transparent process for selecting the PCCL from the Universe. All Toxicity Category 1 chemicals (i.e., most toxic) were captured regardless of their occurrence category. The occurrence threshold required for the PCCL selection became less inclusive as the contaminant toxicity decreased. The screening of the CCL 3 Universe resulted in the selection of 532 chemical contaminants for the PCCL from the approximately 6,000 chemicals that were screened. The categorical summary of chemicals that passed the screening is illustrated in Exhibit 8. A complete chemical PCCL list can be found in Appendix B of the document entitled, "CCL 3 Chemicals: Screening to a PCCL" (USEPA, 2008b). The 532 PCCL chemicals were further scrutinized as part of the next key step in the process. Some of the contaminants on the PCCL had limited data available for the scoring protocols and could not be run through the models. The 32 contaminants that had limited data identified in the appendixes to the "Classification of the PCCL to the CCL" support document (EPA 2008c) and will remain on the PCCL until new data are identified for further evaluation.

| Toxicity categories | Finished or ambient water con- centration | Pesticide app | Total re- leases | Production volume | Totals |
|---------------------|--|------------------|---------------------|----------------------|--------|
| Toxicity Category 1 | 29 | 4 | 56 | 38 | 127 |
| Toxicity Category 2 | 33 | 26 | 32 | 61 | 152 |
| Toxicity Category 3 | 36 | 31 | 21 | 66 | 154 |
| Toxicity Category 4 | 5 | 4 | 10 | 63 | 82 |
| Toxicity Category 5 | 0 | 0 | 0 | 17 | 17 |

EXHIBIT 8.—SUMMARY OF TOTAL CHEMICALS THAT PASSED SCREENING FOR PCCL BY SCREENING CATEGORIES

3. Using Classification Models To Develop the CCL 3

The 532 PCCL chemicals were further scrutinized as part of this key step in the process by using classification models as tools to aid in the selection of the draft CCL 3. As experience is gained, the EPA expects to modify and improve the development of the classification process for future CCLs.

From the inception of the development of the CCL classification process, EPA intended to use classification models as a decision support tool. EPA envisioned that, after testing and evaluation, models would be used to process complex data in a consistent, objective, and reproducible manner and provide a prioritized listing of candidate contaminants for the last stage of the CCL process-an expert review and evaluation. Model application also would help EPA focus resources for the expert review and evaluation of the highest priority potential contaminants.

An overview of the classification model approach used to further evaluate chemicals on the PCCL is described in the following sections. A detailed discussion of the process is provided in a document entitled, "Contaminant Candidate List 3 Chemicals: Classification of the PCCL to the CCL" (USEPA, 2008c). The development of this classification process involves the following steps:

• Development of the Attribute Scoring Protocols.

 Development of the Training Data Set.

• Application of the Classification Models.

• Evaluation of Classification Model Output and Selection of the CCL.

To use models to evaluate and classify the PCCL contaminants for listing on the CCL, EPA needed to develop methods to interrelate the important measures (i.e., attributes) that represent a contaminant's health effects and potential for occurrence in drinking water. Four attributes were selected: Potency, severity, prevalence, and magnitude. Protocols were developed for scoring each attribute.

EPA also tested and evaluated the results of several classification models to determine which ones might provide the best decision support tools. To make this evaluation, EPA developed a chemical data set and used the data set to "train" the classification models. The selected models were utilized to process the data for the PCCL chemicals and provide a prioritized listing of candidate contaminants for the expert review and evaluation.

a. Development of the Attribute Scoring Protocols

EPA used attributes to characterize different chemicals on the basis of similar qualities or traits. These qualities or traits represent the likelihood of occurrence or potential for adverse health effects of each contaminant. Throughout the process of evaluating the attributes EPA recognized that a wide range of data elements would have to be used for each attribute to characterize chemicals on the PCCL. To evaluate PCCL chemicals with differing types of occurrence and health effects data as potential CCL contaminants, one must be able to establish consistent relationships among the different types of data that represent measures of the attributes. If the same data were available for all contaminants, the comparison and prioritization of candidates would be less complex. To consistently apply the best available data for PCCL chemicals, EPA normalized the different types of data into scales and scoring protocols that accept a variety of input data, apply a consistent framework, and compare different types of data. The following sections describe how EPA developed the scales and scoring protocols for the health effects and occurrence attributes.

i. Health Effects Attributes

Potency and severity are the attributes used to describe health effects. EPA defines potency as the lowest dose of a chemical that causes an adverse health effect and severity is based on the adverse health effect associated with the dose used to define the measure of potency. In other words, potency was scored on the dose that produced the adverse effect and severity was scored based on the health-related significance of the adverse effect (*e.g.*, from dermatitis to organ effects to cancer). These two attributes are interrelated, in that the severity is linked to the measure of potency.

The following toxicological parameters were used to evaluate potency:

Reference Dose (RfD) or equivalent.
Cancer potency (concentration in

water for 10⁻⁴ cancer risk).
No-Observed-Adverse-Effect Level

(NOAEL).

• Lowest-Observed-Adverse-Effect Level (LOAEL).

• Rat oral median Lethal Dose (LD₅₀). EPA developed a "learning set" of about two hundred chemicals to calibrate the potency scoring protocols. Once the data for the learning set of chemicals was collected, EPA arrayed and graphically displayed the data to analyze their range and distribution. EPA selected a distribution based on logarithms (base 10) of the toxicity parameters rounded to the nearest integer because it provided a spread of the chemical toxicity parameters across the range and the curve was roughly lognormal.

EPA used a log-based distribution to establish a potency scoring equation for each toxicity parameter. This was accomplished by assigning the most frequent (modal) value in each distribution a score of 5 on a 10 point scale. When the toxicity parameter was one log more toxic than the modal value, a score of 6 was assigned. Similarly, when the parameter was one log less toxic than the modal value a score of 4 was given, and so on. EPA developed an equation for each toxicity parameter that equated the modal value to a score of 5 and calculated the potency score. Because the modal rounded log differed for the different measures of toxicity, it was necessary to use a different equation for each to normalize the mode to a score of 5. The

resultant equations are summarized in Exhibit 9.

EXHIBIT 9.—SCORING EQUATIONS FOR POTENCY

 $\begin{array}{l} \text{RID Score} = 10 \ - \ (\text{Log}_{10} \ \text{of } \text{RfD} + 7), \\ \text{NOAEL Score} = 10 \ - \ (\text{Log}_{10} \ \text{of } \text{NOAEL} + 4), \\ \text{LOAEL Score} = 10 \ - \ (\text{Log}_{10} \ \text{of } \text{LOAEL} + 4), \\ \text{LD}_{50} \ \text{Score} = 10 \ - \ (\text{Log}_{10} \ \text{of } \text{LD}_{50} + 2), \\ 10^{-4} \ \text{cancer} \ \text{risk} \ \text{Score} = 10 \ - \ (\text{Log}_{10} \ \text{of } \text{the} 10^{-4} \ \text{cancer} \ \text{risk} + 6), \\ \end{array}$

For distributions that spanned more than 5 orders of magnitude above or below the mode, scores for the tails of the distribution were truncated at 1 and 10. Conversely, for distributions that did not span 5 full orders of magnitude above and below the mode, not all scores between 1 and 10 were used. For example, the distribution of the 10values for cancer risk was skewed, with values up to 5 orders of magnitude above the modal value (more potent carcinogens) but only 2 orders of magnitude below the mode (less potent carcinogens). This meant that the lowest potency score for this toxicity parameter was a ''3.''

EPA tested the scoring process by using a subset of contaminants with values from multiple data elements considered in the process. In the testing of the potency scoring process, EPA scored all of the chemicals in the learning set for each toxicity parameter to examine the consistency across scores for the non-cancer measures of potency. EPA evaluated the agreement of noncancer scores across the RfD, NOAEL, LOAEL and LD₅₀ inputs and found the scores for any given compound to be generally consistent across parameters. Because of the general consistency among scores, EPA determined that a hierarchy of RfD> NOAEL> LOAEL> LD₅₀ would be used in the scoring of potency. This hierarchy gives preference to the potency value with the richest supporting data set (the RfD-or equivalent values) and gives the lowest ranking to the LD₅₀ because it is a measure of acute rather than chronic toxicity. If data are available for both the cancer and noncancer endpoints, the higher of the cancer or noncancer potency is selected and the critical effect of the higher measure of potency is used to score the severity.

Severity refers to the relative impact of an adverse health affect. Just as toxicity increases with dose, the severity of the observed effect also increases. A low dose effect could be a simple increase in liver weight while the same chemical at a higher dose could cause cirrhosis of the liver. For consistency, the measure of severity that was used for scoring the PCCL chemicals was the effect or effects seen at the LOAEL. Restricting severity scores to the effects at the LOAEL ties them to the data used to derive the potency score.

The severity measures used to score the PCCL chemicals differ from those used for potency, prevalence, and magnitude because they are descriptive rather than quantitative. Accordingly, they are less amenable to automation and often require more scientific judgment in their application. To guide scoring for severity, EPA developed the nine-point scale displayed in Exhibit 10, and a compendium of nearly 250 descriptions of critical effects grouped by their severity scores (e.g., "Chronic irritation without histopathology changes" equals a score of 3).

EXHIBIT 10.—FINAL NINE-POINT SCORING PROTOCOL FOR SEVERITY

| Score | Critical effect | Interpretation |
|-------|---|--|
| 1 | No adverse effect. | |
| 2 | Cosmetic effects | Considers those effects that alter the appearance of the body without affecting structure or functions. |
| 3 | Reversible effects; differences in organ weights, body weights or changes in biochemical parameters with minimal clinical significance. | Transient, adaptive effects. |
| 4 | Cellular/physiological changes that could lead to disorders (risk factors or precursor effects). | Considers cellular/physiological changes in the body that are used as indicators of disease susceptibility. |
| 5 | Significant functional changes that are reversible or permanent changes of minimal toxicological significance. | Considers those disorders in which the removal of chemical ex- posure will restore health back to prior condition. |
| 6 | Significant, irreversible, non-lethal conditions or disorders | Considers those disorders that persist for over a long period of time but do not lead to death. |
| 7 | Developmental or reproductive effects | Considers those chemicals that cause developmental effects or that impact the ability of a population to reproduce. |
| 8 | Tumors or disorders likely leading to death | Considers chemical exposures that result in a fatal disorder and all types of tumors. |
| 9 | Death. | 54 |

Severity scores 1 through 6 represent a progression in the severity of the observed effect. Severity score 7 is used for all studies where the effect observed is a reproductive and/or developmental effect allowing the Agency to track the chemicals that pose developmental or reproductive concerns consistent with the 1996 SDWA. A severity score of 8 was used to track all cases where cancer is the basis for the potency score.

ii. Occurrence Attributes

EPA used prevalence and magnitude to describe the potential to occur in drinking water. Prevalence measures

how widespread the occurrence of the contaminant is in the environment or how widely the contaminant may be distributed. The prevalence measure indicates the percent of public water systems or monitoring sites across the nation with detections, number of States with releases, or the total pounds produced nationally. Magnitude relates to the quantity of a contaminant that may be found in the environment. The magnitude measures include the median concentration of detections in water or the total pounds of the chemical released into the environment. In most cases the same data element (e.g.,

detections in drinking water or amount released into the environment) could be used to determine the prevalence, based on the spatial distribution and magnitude based on the amounts. However, where production data were used to determine prevalence, there was no corresponding direct measure of magnitude, so persistence and mobility data were used as surrogate indicators of potential magnitude.

Production/persistence and mobility data are assigned the lowest level in the hierarchy of data available for prevalence and magnitude. Persistencemobility is determined by chemical properties that measure or estimate environmental fate characteristics of a contaminant and affect their likelihood to occur and persist in the water environment. Data sources that could provide occurrence data ranged from direct measure of concentrations in water to annual measures of environmental release or production. EPA compiled a second subset or learning set of 207 chemicals, with available data for all of the occurrence attribute data elements that measured prevalence and each of the data elements that measured magnitude, to calibrate protocols for prevalence and magnitude.

The data available for the prevalence attribute consisted of measurements of a contaminant's occurrence across the United States. The prevalence measures have finite ranges such as zero to 100 percent of samples/sites or 1 to 50 States depending on the reporting requirements of the available data source. Accordingly, the scaling of scores for prevalence focused on establishing appropriate groupings of the number of sites or States impacted across the 1 to 10 scoring scale.

The relationship between production or even environmental release data and the actual occurrence in drinking water is complex. Where actual water measurements are available, they are the preferred data element to score prevalence because they are the most direct measures of occurrence in drinking water. EPA selected the following hierarchy for scoring prevalence:

• Percent of PWSs with detections (national scale data).

• Percent of ambient water sites or samples with detections (national scale data).

 Number of States reporting application of the contaminant as a pesticide.

• Number of States reporting releases (total) of the chemical.

• Production volume in lbs/yr. The production data provide the pounds produced annually of a chemical product in the United States. To some extent, this production rate represents the commercial importance of the chemical, so EPA interpreted the high production tonnage as a likely indication of wide use of a commodity chemical and used this information to score prevalence. For example, a chemical produced at a billion lbs/yr is more likely to be used and released more widely than a compound produced at only 10,000 lbs/yr.

Magnitude represents the quantity of a contaminant that may be in the

environment. The data sources that provided the first four levels of the prevalence hierarchy provided direct measurements of water and environmental release that could be used to score magnitude. However, the production categories did not supply an appropriate measure for magnitude. EPA used the persistence and mobility for chemicals with only production data as the basis of the magnitude attribute.

To keep the process straightforward, EPA used one scale for all water concentration data. EPA distributed scores across the range of values so that organic contaminants could receive high scores as well as the inorganic contaminants (IOCs). Comparisons and adjustments were made until there was a reasonable distribution of the scores for organic and inorganic contaminants by using a semi-logarithmic scale. EPA selected the single scale approach and this is discussed in more detail in the report entitled "CCL 3 Chemicals: Classification of the PCCL to the CCL" (USEPA, 2008 c).

When developing the calibration scales for the release data, the ranges of data were similarly arrayed using a scale based on half-log units with a distribution of scores that reflected the distribution of the data in the learning set.

EPA based the persistence and mobility scores on chemical and physical properties combined with environmental fate parameters. Persistence and mobility act as measures of potential magnitude because both fate (i.e., persistence) and transport (i.e., mobility) affect the amount of a contaminant to be found in water. The length of time a chemical remains in the environment before it is degraded (persistence) affects its concentration in water. Similarly, the mobility of a chemical, or its ability to be transported to and in water, affects its potential to reach and dissolve in the source waters, and thus, the ultimate concentration of the chemical in the water.

EPA considered a number of data elements to measure the mobility of a chemical in the environment. The physical/chemical parameters that were chosen for the CCL process are:

• Organic Carbon Partition Coefficient (K_{oc})

• Octanol/Water Partition Coefficient (K_{ow})

 Soil/Water Distribution Coefficient (K_d)

Henry's Law Coefficient (K_H)
 Solubility

The first 4 measures of mobility represent the equilibrium ratio for the

partitioning of the contaminant from one medium to another: K_{oe} (soil/ sediment organic carbon: water), K_{ow} (octanol: water), K_d (soil/sediment: water) and Henry's Law Coefficient (air: water). K_{oc} . K_{ow} and K_d are sometimes expressed as logs of the original measurements. The measures of persistence reflect the time the chemical will remain unchanged in the environment. Persistence is reflected in the following measures of environmental fate:

Half-Life

- Measured Degradation Rate
- Modeled Degradation Rate

Each of the mobility and persistence data elements listed above are presented in hierarchical order, with the most desirable at the top (i.e., the first data to be used if available).

As was the case with prevalence, EPA used a hierarchy in scoring magnitude. The hierarchy uses finished water occurrence data if available, and if not, the highest available element in the hierarchy of finished water data > ambient water data > environmental release data > persistence and mobility data. The data elements used in scoring magnitude follow:

• Median value of detections from finished water systems (PWSs) (national scale data)

 Median value of detections from ambient water sites or samples (national scale data)

 Amount of pesticide applied (annual, in pounds)

• Amount of total releases (annual, in pounds)

 Persistence and mobility data EPA developed attribute scoring protocols through a step-wise process of data selection, data analysis, calibration of scales, and evaluation of the functionality of the scores in PCCL to CCL decision-making. This is discussed in more detail in the report entitled "Contaminant Candidate List 3 Chemicals: Classification of the PCCL to the CCL" (USEPA, 2008 c). EPA used the attribute protocols to normalize the data for the PCCL chemicals and develop a set of scores for the four attributes that are the input into the models. By normalizing the data elements, EPA developed a process that can use different kinds of data and information (e.g., quantitative and descriptive) to develop input to the models and provide a relative score for potential contaminants using the attribute scores.

b. Training Data Set for the Classification Models

The training data set (TDS) for chemicals is the set of data used to train (or teach) the classification models to mimic EPA expert list-not list decisions for PCCL chemicals. EPA compiled this data set in addition to the two learning sets to represent the types of chemicals likely to move forward to the PCCL. This data set also represents the range of possible attribute scores and listing decisions needed to train and calibrate the classification models. The TDS used to train the models for GCL 3 was comprised of 202 discrete sets of attribute scores for chemicals and consensus list-not list decisions made by a team of EPA subject matter experts.

Classification models use statistical approaches for pattern recognition and derive mathematical relationships among input variables (e.g., measurements or descriptive data) and output from a TDS. EPA used classification models to develop a relationship between the contaminant attribute scores (input variables) and the classification of these contaminants into list-not list categories (output). EPA subject matter experts familiar with the technical aspects of the attribute data and the selection of drinking water contaminants for listing and regulation made the list-not list decisions for the TDS. EPA then applied the models to the PCCL to predict likely list-not list decisions.

EPA considered the following key factors in developing the training data set:

 Selection of contaminants representing a range of outcomes and decisions likely to be encountered in developing a CCL;

• A variety of input data ensuring adequate coverage of attribute scores and combinations of scores;

• Chemicals that, when present in drinking water, would present a meaningful opportunity for public health improvement if regulated; and

• Contaminants that would likely be selected for the PCCL.

The TDS used for training the classification models consisted of 202 combinations of attribute scores and the decisions made by EPA experts. The TDS included some of the contaminants from the learning sets used in developing the scoring protocols for toxicity and occurrence. It also included additional contaminants to meet the key factor requirements described above. The set of known chemicals chosen for the TDS was supplemented with a set of attribute scores and decisions that were selected to balance the range of scored attributes the classification model would need to evaluate as described further below.

Initially, EPA selected "data rich" contaminants from among regulated

contaminants and previous CCLs because they had a range of readily available occurrence and health effects information. EPA drinking water subject matter experts and stakeholders reviewed the initial list of contaminants and identified additional candidates for the TDS. This initial selection process identified 51 chemical contaminants. Subsequently, EPA randomly chose 50 contaminants from chemicals in the CCL 3 Universe with high health effects potency values and accompanying occurrence data because they represented contaminants likely to make it to the PCCL. The addition of these 50 contaminants resulted in 101 contaminants with data to score attributes

The performance of the classification models using the initial TDS gave an indication of gaps in the possible attribute space that the set of 101 TDS contaminants did not adequately cover. This led EPA to add the sets of possible attribute scores to the TDS based on Latin hypercube sampling (NIST, 2006; http://www.itl.nist.gov/div898/ handbook/glossary.htm#LHC). Using this approach, EPA added 101 specific combinations of attribute scores to fill in gaps in the space defined by total possible attribute scores and improve the performance of the models. This set of 202 scores and decisions ensured good coverage of both "list" and "not list" outcomes and became the TDS. Models trained with the TDS with 202 decisions had greater agreement with EPA subject matter experts than those trained with the TDS of 101 contaminants.

List-not list decisions were a key component of the TDS. EPA subject matter experts made list-not list decisions as individuals and as a group, based on attribute scores and based on data that had not been converted to attribute scores (actual or raw data). The development of the list-not list decisions was an iterative process that incorporated revisions to the attribute scoring protocols as experience was gained by the EPA experts. EPA resolved differences between the decisions based on the scored attributes and the raw data by revising the scoring protocols based on the EPA experts' experience to improve the correlation of decisions based on scores to those based on raw data.

EPA subject matter experts reviewed and evaluated the health effects and occurrence data for each contaminant. Each individual reviewer made decisions about how to classify the contaminant and then met as a group to discuss their decisions. Early in the process the reviewers recognized that

clear list or not-list decisions could easily be made for some contaminants. but not for other contaminants. For the chemicals where the decision whether to list contaminants was not clear, two categories were added to the analyses. The categories of List? (L?) or Not List? (NL?) allowed the group to identify chemicals that were close to the boundary for a List-Not List decision. That is L? signifies that the decision is leaning towards listing but with some uncertainty, and NL? signifies that the decision is leaning towards not listing but with some uncertainty. These additional two categories were incorporated into the evaluation and model training process.

The EPA subject matter experts also reached a consensus decision for each contaminant. This consensus decision was used to train the models. This is discussed in more detail in the report entitled "Contaminant Candidate List 3 Chemicals: Classification of the PCCL to the CCL" (USEPA, 2008c).

c. Evaluation of Classification Models

EPA identified several different models for possible use in selecting contaminants from the PCCL for the CCL: Artificial neural networks, classification decision trees, linear models, and multivariant adaptive regression splines. EPA evaluated the classification models in a two-step process. The first step was the evaluation and selection of models from within each of the model classes that best predicted the consensus decisions of the subject matter experts. The second step was the evaluation of the performance of the best models selected from each class (USEPA, 2008c).

EPA evaluated models based on the 4 attributes that the model was able to consider, the types of relationships or mathematical functions that the model utilized, and the model's ability to predict classifications of the TDS. The iterative training process minimized the model's predictive error, thereby reducing incorrect model predictions. EPA also evaluated the impact of the attributes used by the models and the effects of missing data on the performance of the models during the various stages of development.

EPA evaluated the performance of five models. Three models, Artificial Neural Network (ANN), Quick, Unbiased and Efficient Statistical Tree (QUEST), and Linear Regression demonstrated consistent performance when trained and evaluated with the TDS. The classification models were assessed and compared with respect to:
• The number of correct and incorrect classifications for the 202 TDS contaminants.

The number of "large"

misclassifications (off by more than one category).

• The weighted sum of TDS classification errors.

• Ability to identify intermediate classifications.

• Consistent behavior (e.g., no decreasing classification as attribute scores increase).

This is discussed in more detail in the report entitled "Contaminant Candidate List 3 Chemicals: Classification of the PCCL to the CCL" (USEPA, 2008c).

d. Application and Use of Model Results

From the inception of the development of the CCL classification process, EPA intended to use classification models as decision support tools. It was envisioned that the models would be used to process complex data in a consistent, objective, and reproducible manner and provide a prioritized listing of contaminants, allowing EPA to focus resources on the expert review and evaluation of the highest priority potential contaminants. The ANN, Linear, and QUEST models are three different classes of models, with three different mathematical approaches, yet they all provided similar results and logical determinations. EPA explored simple ways to combine the results of all three models, to capture both agreement among models and unique results. Both a straightforward, additive approach, and a collective, rank-order approach were utilized to provide a prioritized listing of contaminants to be considered further and evaluated for possible inclusion on the draft CCL 3.

e. Model Outcome and Expert Evaluation

In the last step of the process, the chemicals on the PCCL were scored for

their attributes and evaluated by the three models. Some of the contaminants on the PCCL had limited data available for the scoring protocols and could not be run through the models. The 32 contaminants that had limited data are identified in the appendixes to the "Classification of the PCCL to the CCL" support document (EPA 2008c) and will remain on the PCCL until new data are identified for further evaluation. As part of the evaluation of model output, EPA formulated several post-model refinements that were added to the CCL selection process. Exhibit 11 illustrates the results of the model output for the PCCL contaminants. The PCCL consisted of chemicals with variable health effects data, ranging from reference doses (RfD) to Lethal Dose 50s (LD₅₀), and occurrence data ranging from measured water concentration data from Public Water Systems (PWS) to production volume data.

EXHIBIT 11.-MODEL RESULTS FOR THE PCCL CHEMICALS

| 3-Models decision | % of PCCL | Total # PCCL | Finished or ambient water | Release | Production |
|-------------------|-----------|-----------------|---------------------------------|---------|------------|
| L | 9 | 44 | 3 | 24 | 17 |
| L-L? | 12 | 58 | 9 | 29 | 20 |
| L? | 33 | 163 | 26 | 64 | 73 |
| NL?-L? | 6 | 30 | 6 | 11 | 13 |
| NL? | 28 | 139 | 29 | 28 | 82 |
| NL?-NL | 4 | 20 | 7 | 9 | 4 |
| NL | 9 | 46 | 21 | 7 | 18 |
| N (all) | 100 | 500 | 101 | 172 | 227 |

Four of the seven decision categories, L, L?, NL?, NL, in the first column of Exhibit 11 signify that all of the models were in unanimous agreement with the listing decision. The other categories (e.g., NL?-L?) represent varied agreement where one or two of the models chose one category and the other model(s) resulted in a different category. Note that none of the models placed a contaminant in a category more than one category higher or lower than the other models. That is, no contaminants were categorized as "L" by one model and as "NL?" by one of the other models, or visa versa. The models categorized approximately one-half of the chemicals on the PCCL as L? or above. When analyzed by data type, the majority of chemicals in the List category used LD₅₀ data for health effects. This was a concern and became an important issue for consideration. The role LD₅₀ played in the health effects scoring was discussed extensively during the post-model evaluation process.

As part of the last stage in the CCL classification process, the model output was reviewed by a group of internal EPA experts representing several offices. This step involved a detailed review of the data used for the models and the available supplemental data for the chemicals. The EPA experts also deliberated on the method of using the model data to produce a draft proposal for CCL 3. The function of this review was to critically compare the results from the model to the data for the chemicals for a cross section of the modeled contaminants.

Based upon issues identified by the evaluators, several post model refinements were added to the CCL process. Three major issues and refinements are described below.

The relationship between potency and concentration was important when deciding whether to list a chemical. However this ratio could only be developed when water concentration data were available. Accordingly, calculation of the ratio between the health-based value and the 90th percentile concentration in finished or ambient water was added as a postmodel process. The potency/ concentration ratio serves as a benchmark that suggests a greater concern for a contaminant if the ratio is low and a lesser concern when it is high.

The addition of modeled occurrence data for pesticides and estimated concentration in surface and ground water was obtained from the EPA Office of Pesticide Programs (OPP). The modeled estimates of concentration in water for pesticides are part of the EPA's pesticide registration and re-registration evaluations. Once the availability of the OPP data for some of the pesticides was confirmed, the data were extracted from OPP documents and used to generate a potency/concentration ratio similar to that used with the water concentration data.

Data certainty was factored into the decision process by characterizing health effect and occurrence data elements and their relative certainty based upon the type of data that was used to score the attribute for the model classification. This characterization tagged data elements with high certainty and low certainty. The combined certainty measure for a single contaminant (i.e., health effects and occurrence tags) was used to place contaminants in bins of high, medium and low certainty.

The high certainty bin consisted of chemicals with direct occurrence measured in water and well-studied data for health effects. Such contaminants are expected to be good candidates for regulatory determination because they provide information that can be considered in that process and have minimal research needs. Examples of the data used to characterize chemicals in the high certainty bin include chemicals with RfDs, LOAELs, and NOAELs, and water concentration data. The medium bin consists of chemicals that will need further occurrence and/or health effects research. For example, chemicals with well studied health effects that only have environmental release data are included in the medium bin. Chemicals that are released to the environment and need further health effects research are also included in the medium bin. The low certainty bin consists of chemicals that have limited data, yet these data suggest that further evaluation should be pursued. These chemicals may need extensive health effects and occurrence research that may require significant resources before regulatory determinations can be made. Examples include chemicals with only LD₅₀ and/ or production volume data. The CCL should consist both of chemicals that provide sufficient data to support regulatory determinations as well as chemicals that are of concern and need to be targeted for additional drinking water research. Contaminants from each bin were scrutinized separately in selecting which ones should be listed on the CCL 3.

4. Selection of the Draft CCL 3— Chemicals

The chemicals for the draft CCL 3 were selected from within the three certainty bins with the emphasis placed on the source of the occurrence data (e.g., measured concentrations, release, and production). Four groups of chemicals were placed on the CCL based on their modeled scores, the potency-concentration ratios, where available, and the estimate of data certainty. They included:

 36 chemicals in the high certainty bin with finished or ambient water data and a potency/90th percentile concentration ratio ≤10.

• 24 pesticide chemicals in the medium certainty bin with modeled surface and/or ground water data that yielded a potency/concentration ratio ≤10.

• 27 chemicals in the medium certainty bin with release data that gave modeled L or L-L? rankings.

• 8 chemicals in the low certainty bin that were added to the CCL as recommended by the public in response to EPA's Federal Register notice (71 FR 60704, USEPA, 2006b). The notice requested that the public submit chemical and microbial contaminant nominations that should be considered for CCL 3. This process is discussed in section III.C.1.

The potency and concentration were compared to develop a ratio that was used to select contaminants for the draft CCL 3 from the high certainty bin. A ratio between the health-based value and the 90th percentile was taken for chemicals with measurements in finished and ambient water. Contaminants for this bin were selected for the draft CCL 3 when the ratio was ≤10, representing occurrence in water at a level of concern related to its health effects data.

The pesticides in the medium bin, where modeled data was obtained from OPP, were selected for the draft CCL 3 based on their potency/concentration ratios. Similar to the chemicals in the high certainty bin, pesticides were selected for the draft CCL 3 when the potency/concentration ratio was <10, representing potential occurrence in water at a level of concern related to its health effects data. The other chemicals in the medium bin were selected for the draft CCL 3 based on a review of their data and their prioritization from the classification models.

Chemicals in the low certainty bin were selected for the draft CCL 3 based on a review of their supplemental data and the data submitted through the nominations process. Some of the chemicals identified through the nominations process were already on the draft CCL 3 based on the data EPA collected for the universe. The supplemental data provided with the nominations were used to screen the nominated chemicals and score the attributes for those that passed the screen. The scored attributes were then processed through the models and the post-model evaluations. Those that were listed demonstrated adverse health effects and a potential to occur in PWSs. Chemicals not selected for the draft CCL 3 will remain on the PCCL until additional occurrence or health effects

data become available to support their reevaluation.

B. Classification Approach for Microbial Contaminants

As discussed in CCL 2 (USEPA, 2005b), the Agency evaluated the NDWAC, NRC and other recommendations, and used the information to develop a pragmatic approach for classifying the microorganisms on the draft CCL 3. The CCL 3 approach for microbes, like the approach used for chemicals, uses the attributes of occurrence and health effects to select the microbial contaminants. EPA's objective is to target microorganisms with the highest potential for human exposure and the most serious adverse health effects. Parallel to the chemical selection process, the Agency considers a broad universe of microbial contaminants and systematically narrows that universe down to develop the draft CCL 3 in a transparent and scientifically sound CCL process. The first step of the CCL 3 approach for microbes identifies a universe of potential drinking water contaminants. The second step screens that universe of microbiological contaminants to a Preliminary Contaminant Candidate List (PCCL). Lastly, EPA selects the draft CCL 3 microbial list by ranking the PCCL contaminants based on occurrence in drinking water (including waterborne disease outbreaks) and human health effects.

1. Developing the Universe

EPA defined the microbial Universe for the draft CCL 3 as all known human pathogens. The Universe process began with the list of 1,415 recognized human pathogens compiled by Taylor *et al.* (2001). The Agency added organisms to the Universe and updated nomenclature in Taylor *et al.* (2001) to account for emerging pathogens and new taxonomy research.

As EPA reviewed Taylor *et al.* (2001), additional pathogens were also identified. EPA surveyed fungi in drinking water and identified six fungi reported to occur in drinking water distribution systems that did not appear on the Taylor list. The added fungi are shown in Exhibit 12. EPA also added reovirus to the Universe based on additional health effects information (Tyler, *et al.*, 2004).

In October 2006, EPA published a notice (71 FR 60704 (USEPA, 2006b)) requesting chemical and microbial contaminant nominations as part of the process to identify emerging contaminants that should be considered for the CCL. As a result of the

nominations process, 24 microbial contaminants were nominated by the public. Twenty-two of the microbes were previously identified by Taylor et al. (2001) and are already in the Universe. The two additional pathogens nominated were Methylobacterium (with two species) and Mimivirus. These two bacterial species, two viral groups and six fungal species were added to the Microbial Universe which brings the Microbial Universe list to 1,425 pathogens. The full Universe list is available in the document, "Contaminant Candidate List 3 Microbes: Identifying the Universe" (USEPA, 2008d).

| EXHIBIT | 12 | -FUN | GI A | DDED | TO | THE |
|---------|-------|------|------|-------|----|-----|
| N | AICRO | BIAL | UN | VERSE | | |

Pathogen

| Arthrographis kelrae | |
|-----------------------------|--|
| Chryosporium zontatum | |
| Geotrichum candidum | |
| Sporotrichum pruinosum | |
| Stachybotrys chartarum | |
| Stemphylium macrosporoideum | |

2. The Universe to PCCL

EPA developed screening criteria to reduce the Universe of all human pathogens to just those pathogens that could be transmitted through drinking water. For example, pathogens transmitted solely by animals, such as the virus that causes rabies, were screened out of the Universe and are not included on the PCCL. Screening is based on a pathogen's epidemiology, geographical distribution, and biological properties in their host and in the environment. EPA moved pathogens forward to the PCCL if there was any evidence linking a pathogen to a drinking water-related disease. The screening criteria restrict the microbial PCCL to human pathogens that may cause drinking water-related diseases resulting from ingestion of, inhalation of, or dermal contact with drinking water. EPA used 12 screening criteria (Exhibit 13) to reduce the pathogens in the microbial CCL universe to the PCCL.

EXHIBIT 13.-CCL SCREENING CRITERIA FOR PATHOGENS

1. All anaerobes.

4. Transmitted by vectors.

6. Transmitted solely by respiratory secretions.

7. Life cycle incompatible with drinking water transmission.

8. Drinking water-related transmission is not implicated.

10. Not endemic to North America.

12. Current taxonomy changed from taxonomy used in Universe.

Pathogens meeting any single criterion of the 12 criteria were removed from further consideration and not moved forward to the PCCL. Based upon this screening exercise, 1,396 of the 1,425 pathogens were excluded and 29 pathogens moved on to the PCCL. The results of the screening process are summarized in Exhibit 14. The screening criteria and results of the screening process are discussed in greater detail in the supporting document titled "Contaminant Candidate List 3 Microbes: Screening to the PCCL" (USEPA, 2008 e).

EXHIBIT 14.—APPLICATION OF TWELVE SCREENING CRITERIA TO PATHOGENS IN THE MICROBIAL CCL UNIVERSE

| 2.4 | Screening Criteria | | | | | | | | Pathogens | 0.000 | | | | | |
|----------------------|--------------------|-----|----|----|-----|-----|----|-----|-----------|-------|-----|----|-----|---------|-----|
| Pathogen class Total | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | oul | ON PCCL | |
| Bacleria | 540 | 125 | 14 | 10 | 37 | 117 | 7 | 0 | 29 | 154 | 2 | 28 | 5 | 528 | 12 |
| Viruses | 219 | 0 | 0 | 26 | 104 | 0 | 19 | 1 | 18 | 0 | 36 | 8 | 0 | 212 | 7 |
| Protozoa | 66 | 0 | 0 | 1 | 29 | 3 | 0 | 4 | 7 | 7 | 0 | 6 | 0 | 57 | 7. |
| Helminths | 287 | 0 | 0 | 0 | 25 | 0 | 0 | 106 | 0 | 0 | 156 | 0 | 0 | 287 | 0 |
| Fungi | 313 | 0 | 0 | 0 | 0 | 12 | 1 | 0 | 0 | 297 | 0 | 0 | 0 | 310 | 3 |
| Total | 1,425 | 125 | 14 | 37 | 195 | 132 | 27 | 111 | 54 | 458 | 194 | 42 | 5 | 1,394 | 29* |

*Two additional protozoa, Cryptosporidium and Giardia were not considered for CCL 3 and they are discussed in more detail later.

3. The PCCL to Draft CCL Process

Pathogens on the PCCL were scored for placement on the draft CCL. EPA devised a scoring system to assign a numerical value to each pathogen on the PCCL.

Each of the pathogens on the PCCL was scored using three scoring protocols, one protocol each for waterborne disease outbreaks (WBDO), occurrence in drinking water, and health effects. The higher of the WBDO score or the occurrence score is added to the normalized health effects score to produce a composite pathogen score. Pathogens receiving high scores were considered for placement on the CCL.

EPA normalized the health effects score so that occurrence and health effects have equal value in determining the ranking of the CCL. The equal weighting of occurrence and health effects information closely mirrors the risk estimate methods used by EPA during drinking water regulation development. This scoring system prioritizes and restricts the number of pathogens on the CCL to only those that have been strongly associated with drinking water-related disease. Pathogens that scored low will remain on the PCCL until additional occurrence data, epidemiological surveillance data, or health effects data become available to support their reevaluation. It is important to note that pathogens for which there are no data documenting a waterborne disease outbreak in drinking water earn a low score under the protocols. EPA believes that pathogens that have caused a WBDO and have health effects data should rank higher than pathogens that have only data on health effects but no evidence of a WBDO. The following sections describe

^{2.} Obligate intracellular fastidious pathogens.

^{3.} Transmitted by contact with blood or body fluids.

^{5.} Indigenous to the gastrointestinal tract, skin and mucous membranes.

^{9.} Natural habitat is in the environment without epidemiological evidence of drinking water-related disease.

^{11.} Represented by a pathogen for the entire genus or species (that are closely related).

the three protocols used to score the pathogens on the PCCL and the process by which the scores are combined.

a. Waterborne Disease Outbreak Protocol

The Centers for Disease Control and Prevention (CDC), EPA and the Council of State and Territorial Epidemiologists (CSTE) have maintained a collaborative surveillance system for collecting and periodically reporting data related to occurrences and causes of WBDOs since 1971. EPA used the CDC surveillance system as the primary source of data for the waterborne disease outbreaks protocol. Reports from the CDC system are published periodically in *Morbidity* and Mortality Weekly Report (MMWR).

For this protocol (Exhibit 15), a pathogen is scored as having a WBDO(s) in the U.S. if that pathogen is listed in a CDC waterborne disease drinking water surveillance summary (i.e., in the MMWR). A pathogen with multiple WBDOs listed by CDC is given the highest score under this protocol. EPA also scored non-CDC reported WBDOs and WBDOs outside the U.S. as well; however these were given lower scores. WBDOs outside the U.S. were scored when information was available from World Health Organization publications or other peer-reviewed publications.

In addition, CDC and EPA acknowledge that the WBDOs reported in the surveillance system represent only a portion of the burden of illness associated with drinking water exposure (CDC, 2004). The surveillance information does not include endemic waterborne disease risks, nor are reliable estimates available of the number of unrecognized WBDOs and associated cases of illness. Therefore, EPA also considered data as indicating a WBDO (even though CDC does not list a WBDO in their MMWR) if the non-CDC data showed a link between human illness defined by a common water source, a common time period of exposure and/or similar symptoms. EPA also considered the use of molecular typing methods to link patients and environmental isolates.

Only two pathogens were given a WBDO score on this basis, *Mycobacterium avium* and *Arcobacter butzlerei*. They are discussed in greater detail in the "Contaminant Candidate List 3 Microbes: PCCL to CCL Process" (USEPA, 2008 f).

| EXHIBIT 15.—WATERBORNE DISEASE |
|--------------------------------|
| OUTBREAK SCORING PROTOCOL |

| Category | Score |
|--|-------|
| Has caused multiple (2 or more) documented WBDOs in the U.S. since CDC sur- veillance initiated in 1973 | |
| Has caused at least one docu- mented WBDO in the U.S. since CDC surveillance initi- ated in 1973 | |
| Has caused documented WBDOs at any time in the U.S. | |
| Has caused documented WBDOs in countries other than the U.S. | |
| Has never caused WBDOs in any country, but has been epidemiologically associated with water-related disease | |

b. Occurrence Protocol

The second attribute of the scoring process evaluates the occurrence of a pathogen in drinking water. Because water-related illness may also occur in the absence of recognized outbreaks, EPA scored the occurrence (direct detection) of microbes using cultural, immunochemical, or molecular detection of pathogens in drinking water under the Occurrence Protocol (Exhibit 16). Occurrence characterizes pathogen introduction, survival, and distribution in the environment. Occurrence implies that pathogens are present in water and that they may be capable of surviving and moving through water to produce illness in persons exposed to drinking water by ingestion, inhalation, or dermal contact.

Pathogen occurrence is considered broadly to include treated drinking water, and all waters using a drinking water source for recreational purposes. This attribute does not characterize the extent to which a pathogen's occurrence poses a public health threat from drinking water exposure. Because viability and infectivity cannot be determined by non-cultural methods, the public health significance of noncultural detections is unknown.

EXHIBIT 16.—OCCURRENCE SCORING PROTOCOL FOR PATHOGENS

| Category | Score |
|--|-------|
| Detected in drinking water in the U.S. | |
| Detected in source water in the U.S. | |
| Not detected in the U.S. | |

1

c. Health Effects Protocol

EPA's health effects protocol evaluates the extent or severity of human illness produced by a pathogen across a range of potential endpoints. The seven-level hierarchy developed for this protocol (Exhibit 17) begins with mild, self-limiting illness and progresses

to death. The final outcome of a host-pathogen

- relationship resulting from drinking
 water exposure is a function of viability, infectivity, and pathogenicity of the microbe to which the host is exposed
- 3 and the host's susceptibility and immune response. SDWA directs EPA to
- consider subgroups of the population at greater risk of adverse health effects (i.e., sensitive populations) in the

1

selection of unregulated contaminants for the CCL. Sensitive populations may have increased susceptibility and may experience increased severity of symptoms, compared to the general population. SDWA refers to several categories of sensitive populations including the following: children and infants, elderly, pregnant women, and persons with a history of serious illness.

Health effects for individuals with marked immunosuppression (e.g., primary or acquired severe immunodeficiency, transplant recipients, individuals undergoing potent cytoreductive treatments) are not included in this health effects scoring. While such populations are considered sensitive subpopulations, immunosuppressed individuals often have a higher standard of ongoing health care and protection required than the other sensitive populations under medical care. More importantly, nearly all pathogens have very high health effect scores for the markedly immunosuppressed individuals; therefore there is little differentiation between pathogens based on health effects for the immunosuppressed subpopulation.

This protocol scores the representative or common clinical presentation for the specific pathogen for the population category under consideration. EPA used recently published clinical microbiology manuals as the primary data source for the common clinical presentation. These manuals take a broad epidemiological view of health effects rather than focusing on narrow research investigations. The one exception to this approach was EPA's scoring of health effects for Helicobacter pylori. H. pylori is discussed in greater detail in section IV.C as well as in the support document, "CCL 3 Microbes: PCCL to CCL Process" (USEPA, 2008 f).

To obtain a representative characterization of health effects in all populations, EPA evaluated separately the general population and these four sensitive populations as to the common clinical presentation of illness for that population. EPA added the general population score to the highest score among the four sensitive subpopulations for an overall health effects score. The resulting score acknowledges that sensitive populations have increased risk for waterborne diseases.

| EXHIBIT 17.—HEALTH | H EFFECTS | SCORING | PROTOCOL | FOR P | ATHOGENS |
|--------------------|-----------|---------|----------|-------|----------|
|--------------------|-----------|---------|----------|-------|----------|

| | | Manifestation in population class | | | | | |
|---|-------|-----------------------------------|----------------------|---------|-------------------|--------------------|--|
| Outcome category | Score | General population | Children/ infants | Elderly | Pregnant women | Chronic disease | |
| Does the organism cause significant mortality (> 1/1,000 cases)?. | 7 | | | | | | |
| Does the organism cause pneumonia, meningitis, hepatitis, encephalitis, endocarditis, cancer, or other severe mani- festations of illness necessitating long term hospitalization (> week)?. | 6 | | | | | | |
| Does the illness result in long term or permanent dysfunction or disability (e.g., sequelae)?. | 5 | | | | | | |
| Does the illness require short term hospitalization? (< week)? | 4 | | | | | | |
| Does the illness require physician intervention? | 3 | | | | | | |
| Is the illness self-limiting within 72 hours (without requiring medical intervention)?. | 2 | | | | | | |
| Does the illness result in mild symptoms with minimal or no impact on daily activities?. | 1 | | | | | | |

d. Combining Protocol Scores to Rank Pathogens

EPA scored and ranked the PCCL using the three attribute scoring protocols, occurrence, waterborne disease outbreaks, and health effects. These protocols are designed in a hierarchical manner so that each pathogen is evaluated using the same criteria and the criteria range for each protocol varies from high significance to low significance. The three attribute scores are then combined into a total score.

EPA scored pathogens first using the WBDO and occurrence protocols, and then selected the highest score. Selection of the higher score from the WBDO or occurrence protocol elevates pathogens that have been detected in drinking water or source water in the U.S. (occurrence score of 2 or 3) above pathogens that have caused WBDOs in other countries but not in the U.S. (WBDO score of 2).

The CCL selection process considered pathogens causing recent waterborne outbreaks more important than pathogens detected in drinking water without documented disease from that exposure. Direct detection of pathogens indicates the potential for waterborne transmission of disease. Documented

waterborne disease outbreaks provide an additional weight of evidence that illness was transmitted and that there was a waterborne route of exposure. EPA developed protocols to define a hierarchy of the relevance that each of these types of data provide in evaluating microbes for the CCL. Combining these two sources of occurrence information enabled EPA to consider both emerging pathogens, which are detected in water and should be considered, yet are not tracked by public health surveillance programs, and those pathogens with WBDO data. This hierarchy also acknowledges that organisms identified as agents in WBDO are a higher priority for the CCL.

Next, pathogens were scored using the Health Effects Protocol. All five population categories were scored for each pathogen using the most common clinical presentation for the specific pathogen for the population category under consideration. Because it is recognized that pathogens may produce a range of illness from asymptomatic infection to fulminate illness progressing rapidly to death, scoring decisions are based upon the more common clinical presentation and clinical course for the population under consideration, rather than the extremes. The pathogen's score for the general population is added to the highest score among the four sensitive populations to produce a sum score between 2 and 14.

Finally, EPA normalizes the Health Effects and WBDO/Occurrence score because the Agency believes they are of equal importance. The highest possible score for WBDO/Occurrence is 5 and the highest possible Health Effect score is 14. To equalize this imbalance, the Agency multiplies the health effects score by 5/14. Combining health effects data with the WBDO/occurrence data by adding the scores from these protocols provides a system that evaluates both the severity of potential disease and the potential magnitude of exposure through drinking water.

Exhibit 18 presents the scores for all the PCCL pathogens with the exception of *Giardia* and *Cryptosporidium*. These two protozoan pathogens made it through the screening protocol, however, EPA chose not to score or include them on the PCCL because EPA has recently published a national primary drinking water regulation that specifically addresses these pathogens (January 4, 2006, 71 FR 388 (USEPA, 2006 a) and is discussed in more detail later.

EXHIBIT 18.—PATHOGENS ON THE PCCL

| Pathogen | WBDO | Occurrence | Normalized health score | Total ¹ score |
|-------------------------|------|------------|----------------------------|--------------------------|
| Naegleria fowleri | 4 | 3 | 5.0 | 9.0 |
| Legionella pneumophila | 5 | 3 | 3.6 | 8.6 |
| Escherichia coli (0157) | 5 | 3 | 3.2 | 8.2 |

| Pathogen | WBDO | Occurrence | Normalized health score | Total ¹ score |
|-----------------------------|------|------------|----------------------------|--------------------------|
| Hepatitis A virus | 5 | 2 | 3.2 | 8.2 |
| Shigella sonnei | 5 | 3 | 3.2 | 8.2 |
| Helicobacter pylori | 1 | 3 | 5.0 | 8.0 |
| Campylobacter jejuni | 5 | 3 | 2.5 | 7.5 |
| Salmonella enterica | 5 | 3 | 2.5 | 7.5 |
| Caliciviruses | 5 | 3 | 2.1 | 7.1 |
| Entamoeba histolytica | 5 | 3 | 2.1 | 7.1 |
| Vibrio cholerae | 5. | 3 | 2.1 | 7.1 |
| Adenovirus | 2 | 3 | 3.6 | 6.6 |
| Enterovirus | 2 | 3 | 3.6 | 6.6 |
| Cyclospora cayetanensis | 4 | 1 | 2.5 | 6.5 |
| Mycobacterium avium | 4 | 3 | 2.5 | 6.5 |
| Rotavirus | 4 | 2 | 2.5 | 6.5 |
| Yersinia enterocolitica | 5 | 3 | 1.4 | 6.4 |
| Arcobacter butzleri | 4 | 3 | 2.1 | 6.1 |
| Fusarium solani | 1 | 3 | 2.9 | 5.9 |
| Plesiomonas shigelloides | 4 | 3 | 1.8 | 5.8 |
| Hepatitis E virus | 2 | 1 | 3.6 | 5.6 |
| Toxoplasma gondii | 2 | 1 | 3.2 | 5.2 |
| Aspergillus fumigatus group | 1 | 3 | 2.1 | 5.1 |
| Exophiala jeanselmei | 1 | 3 | 2.1 | 5.1 |
| Aeromonas hydrophila | 1 | 3 | 1.8 | 4.8 |
| Astrovirus | 2 | 2 | 1.4 | 3.4 |
| Microsporidia | 1 | 2 | 1.4 | 3.4 |
| Isospora belli | 2 | 0 | 1.1 | 3.1 |
| Blastocystis hominis | 1 | 0 | 0.7 | 1.7 |

EXHIBIT 18 .--- PATHOGENS ON THE PCCL-Continued

1. Total Score = Normalized Health Score + the higher of WBDO or Occurrence scores.

e. Other Criteria Considered for Listing and Scoring Microbes on the Draft CCL 3

i. Organisms Covered by Existing Regulations

EPA considered an additional screening criterion based upon contaminants that might be controlled through drinking water monitoring requirements under the Total Coliform Rule (TCR) (54 FR 27544, June 29, 1989 (USEPA, 1989b)). Many of the bacteria in the CCL Universe, including the Enterobacteriaceae and members of the genera Campylobacter and Vibrio, are associated with fecal contamination and as such their presence could be signaled by the total coliform monitoring requirements under current drinking water regulations. In the TCR, EPA chose to require monitoring for Escherichia coli or fecal coliform (and total coliforms) in finished drinking water because it provides a broad indication of the potential presence of fecal pathogens in drinking water, though more so for bacteria than for viruses and protozoa.

EPA chose not to exclude common enteric bacterial pathogens from the PCCL even though they may be indicated by the TCR. Numerous waterborne disease outbreaks have occurred in systems that were in compliance with drinking water monitoring requirements under the TCR. EPA recognizes the frequency of total coliform monitoring under the TCR may be limited, especially for smaller systems, thus transitory fecal contamination could go undetected. The recognition of these bacterial pathogens on the CCL list will provide additional understanding of the risks posed by distribution systems.

The Agency is currently revising the TCR and considering distribution water quality issues (because of the pathways of potential fecal contamination). Including these pathogens on the CCL emphasizes their importance in protecting public health. EPA believes that enteric pathogens should be included for further specific regulatory consideration in the CCL.

ii. Organisms Covered by Treatment Technique Regulations

According to SDWA (section 1412(b)(1), as amended in 1996), EPA must select CCL contaminants that "at the time of publication, are not subject to any proposed or promulgated national primary drinking water regulation * * *." In promulgating regulations for contaminants in drinking water, EPA can set either a legal limit (MCL) and require monitoring for the contaminant in drinking water or, for those contaminants that are difficult to measure, EPA can establish a treatment technique requirement. The Surface Water Treatment Rule (SWTR) (54 FR 27486, June 29, 1989 (USEPA, 1989a)) included MCLGs for Legionella, Giardia, and viruses at zero because any amount of exposure to these contaminants represents some public health risk. Since measuring disease-causing microbes in drinking water is not considered to be feasible, EPA established treatment technique requirements for these contaminants. The purpose of subsequent treatment technique requirements (Interim Enhanced Surface Water Treatment Rule (63 FR 69478; USEPA 1998a), Long Term Surface Water Treatment Rule 1 (67 FR 1813; USEPA, 2002a) and the Long Term Surface Water Treatment Rule 2 (71 FR 654; USEPA, 2006a)) which included an MCLG of zero for Cryptosporidium, is to reduce disease incidence associated with Cryptosporidium and other pathogenic microorganisms in drinking water. These rules apply to all public water systems that use surface water or ground water under the direct influence of surface water.

The Ground Water Rule (71 FR 65573, (USEPA, 2006c)) set treatment technique requirements to control for viruses (and pathogenic bacteria) because it was not feasible to monitor for viruses (or pathogenic bacteria) in drinking water. Under the GWR, if systems detect total coliforms in the distribution system, they are required to monitor for a fecal indicator (*E. coli*, coliphage, or enterococci) in the source water. If fecal contamination is found in the source water, the system must take remedial action to address contamination.

While *Cryptosporidium* and *Giardia* have been implicated in WBDOs, there is a substantial amount of research regarding health effects and sensitivity to various treatment control measures. More importantly, as noted above, EPA has recently published a National Primary Drinking Water Regulation, The Long Term 2 Surface Water Treatment Rule that specifically addresses these pathogens (71 FR 654 (USEPA, 2006a)). Therefore, they are excluded from the CCL.

EPA did not exclude specific viruses and Legionella from consideration for the CCL even though they have broad category MCLGs and treatment technique requirements. Viruses include a wide range of taxa. The treatment and health effects information for different viral taxa was very limited when setting the treatment technique requirements for surface water and ground water systems. Also, different viral taxa have been implicated in various waterborne disease outbreaks for which EPA did not have dose response or treatment data when promulgating its treatment technique requirements. Legionella has recently been identified in numerous WBDOs (e.g., CDC MMWR reports, 2006). Additionally EPA received additional information on the occurrence of Legionella in distribution systems as part of the nominations process (USEPA 2008g). Therefore EPA included viruses and Legionella on the draft CCL 3.

iii. Applying Genomic and Proteomic Data to Microbes

The Agency and NDWAC workgroup evaluated the possibility of using genomics and proteomics as data to identify emerging waterborne pathogens, opportunistic microorganisms, and other newly identified microorganisms. While the application of these data in identifying genetic properties that may be pathogenic is a powerful tool for the elucidation of pathogenic mechanisms, the technology is yet largely unproven and the Agency has decided at this time not to use these techniques for CCL application. However, the Agency is monitoring the progress of these technologies and as the data improve and genomics progresses the Agency may consider them for future CCL development.

4. Selection of the Draft CCL 3 Microbes From the PCCL

The 29 PCCL pathogens in Exhibit 18 are ranked according to an equal weighting of their summed scores for normalized health effects and the higher of the individual scores for WBDO and occurrence in drinking water. EPA believes this ranking indicates the most important pathogens to consider for the draft CCL 3. To determine which of the 29 PCCL pathogens should be the highest priority for EPA's drinking water program and included on the draft CCL 3, the Agency considered both scientific and policy factors. The factors included the PCCL scores for WBDO, occurrence, and health effects; comments and recommendations from the various expert panels; the specific intent of SDWA; and the need to focus Agency resources on pathogens to provide the most effective opportunities to advance public health protection. After consideration of these factors, EPA has determined that the draft CCL 3 will include the 11 highest ranked pathogens shown in Exhibit 18.

Additionally, the Agency notes that, and as can be observed in Exhibit 18, there are a few "natural" break points in the ranked scores for the 29 pathogens, with the top 11 forming the highest ranked group of pathogens. EPA does believe that the overall rankings strongly reflect the best available scientific data and high quality expert input employed in the CCL selection process, and therefore should be important factors in helping to identify the top priority pathogens for the draft CCL 3.

C. Public Input

1. Nominations and Surveillance

On October 16, 2006, EPA published a Federal Register notice (71 FR 60704 (USEPA, 2006 b)) requesting the public to submit chemical and microbial contaminant nominations that should be considered for CCL 3. EPA evaluated nominated contaminants to identify the data supporting their nomination. This section describes EPA's request for contaminants and summarizes the nominations received by EPA. A more detailed discussion of the contaminants. including a list of the specific contaminants nominated, can be found in the CCL 3 Nominations Summary in EPA's Water Docket (USEPA, 2008 g).

The Agency sought CCL nominations for contaminants by framing the SDWA requirements in a series of questions to document the anticipated or known occurrence in PWS(s) and adverse health effects of potential contaminants. The Agency requested that the public respond to these questions and provide the documentation and rationale for including a contaminant for consideration in the CCL process. The questions posed to the public were:

—What are the contaminant's name, CAS number, and/or common synonym (if applicable)?

--What factors make this contaminant a priority for the CCL 3 process (e.g., widespread occurrence; anticipated toxicity to humans; potentially harmful effects to susceptible populations (e.g., children, elderly and immunocompromised); potentially contaminated source water (surface or ground water), and/or finished water; releases to air, land, and/or water; contaminants manufactured in large quantities with a potential to occur in source waters)?

—What are the significant health effects and occurrence data available, which you believe supports the CCL requirement(s) that a contaminant may have an adverse effect on the health of persons and is known or anticipated to occur in public water systems?

The Agency compiled the information from the nominations process to identify the contaminants nominated and the rationale for the nomination and to compare the supporting data to information already gathered by EPA.

The nominations process identified 150 chemical and 24 microbial contaminants from 11 organizations and individuals. The organizations that nominated contaminants are:

—American Society of Microbiology (ASM),

—American Water Works Association (AWWA),

--Association of Metropolitan Water Agencies (AMWA),

-Association of State Drinking Water Administrators (ASDWA),

—Mothers Against Acanthamoeba Disease,

---Natural Resources Defense Council, (NRDC),

-Riverkeepers,

—State of New Jersey Department of Environmental Protection,

-State of New York Department of Health, and

---State of Texas Commission on Environmental Quality.

Exhibit 19 summarizes the types of nominated contaminants and who nominated them. The complete list of chemical and microbial contaminants nominated can be found in EPA's Water Docket. Some of the nominations identified categories of contaminants that the Agency should consider for the CCL. There were 23 chemical groups identified from the 150 chemical contaminants that were nominated. For example, several organizations identified pesticides that are not

currently regulated under the SDWA as candidates for consideration. Other

groups identified by the public are listed in Exhibit 19.

EXHIBIT 19.—SUMMARY OF CCL 3 NOMINATIONS

| Nominator | Number of in- dividual con- taminants or specific exam- ples from nominated groups | Types and groups of contaminants |
|--------------------------------------|--|---|
| ASM | 2 | Mimivirus, Naegleria fowleri. |
| AMWA | 3 | Nitrosoamines and other DBPs. |
| ASDWA | 14 | Disinfection byproducts (DBPs), unregulated pesticides, solvents, total petroleum hydrocarbons, cyanotoxins, 3 perfluorinated contaminants (PFCs), viruses, phthalates, nitrite, nitrate; endocrine disruptors. |
| AWWA | 38 | DBPs, pesticides, 16 specific microbes, cyanotoxins, radium, 1,4-dioxane. |
| Mothers Against Acanthamoeba Disease | 1 | Acanthamoeba. |
| New Jersev DEP | 4 | PFOS, PFOA, trichloropropane, tertiary butyl alcohol, |
| New York DOH | 24 | Pharmaceuticals, personal care products, DBPs, fuel oxygenates, 1,4-dioxane, her- bicides, bio-monitoring data. |
| NRDC | 26 | Alkylphenolpolyethoxylates (APEs that may be endocrine disrupter compounds (EDC)), all unregulated pesticides, perchlorate, Mycobacterium avium complex (MAC), phthalates, managanese, bisphenol A. |
| Riverkeeper | 52 | Pharmaceuticals, sodium, chloride. |
| Texas DEQ | 3 | Viruses, nitrite, nitrate. |

The Agency evaluated the nominations to identify contaminants not previously considered for the CCL and new pertinent information provided by the public. Nominated contaminants were evaluated to identify and compare supporting information provided to that used in the CCL process. Of the 174 chemical and microbial contaminants nominated, 152 contaminants were already being considered by the Agency. Seven of the nominated contaminants are currently regulated in PWSs and will not be included in the CCL 3 process. Most of the data sources cited in the nominations process were already identified for the CCL 3 process. The nominations process did identify recently published specialized studies from scientific literature that were subsequently incorporated in the CCL 3 evaluation process.

Where new supplemental data was provided for contaminants that had not been identified for the draft CCL 3, EPA used the supplemental data to screen the nominated chemicals and score the attributes for those that passed the screen. EPA then processed the nominated contaminants through the models and the post-model evaluations. Twenty of the contaminants identified in the nominations process are on the draft CCL 3.

2. External Expert Review and Input

EPA actively sought external advice and expert input for the draft CCL 3. In addition to their own recommendations, the NRC and NDWAC recommended that the Agency seek opportunities to incorporate additional expert input in the development of the draft CCL 3. EPA convened several external expert panels at integral stages during the development of the draft CCL 3. EPA incorporated expert judgment and input from the scientific community into the CCL process for both chemicals and microbes. The Agency has requested a consultation with the Science Advisory Board that will take place in 2008.

For each expert panel, EPA sought panel members that provided a variety of disciplines and expertise. Panel members were encouraged to provide comments as individuals based upon their expertise and background, not as representatives of their respective organizational affiliations. Expert panel members were also encouraged to present individual comments if consensus comments were not developed. Separate panels were convened to review the draft chemical and microbial CCL 3 lists and the processes used to develop them. A more detailed discussion of the chemical and microbial expert review and input is provided in the support documents in the EPA Water Docket. A brief overview of the chemical and microbial expert review and stakeholder involvement follows.

a. Chemical Expert Input Panels

In September of 2006, EPA formed two external expert panels to provide specific input into the chemical CCL 3 process. In the first panel, experts reviewed the data sources and the process used to identify the chemical

universe. EPA convened the second panel for a 3-day workshop to review the data and information used to develop screening criteria, the data and methodology for the classification approach, and to provide overall input into the CCL process. In summary, the panels recommended that EPA consider additional data sources in the process. They also commented on ways to improve and clarify the presentation of EPA efforts, thereby ensuring that the CCL 3 process for chemicals is more transparent. The expert panel reviewing the classification approach identified additional analyses and approaches to train and validate the models. The panel specifically commented on the varied nature of data elements and sources considered in the classification process. The panel recommended that to account for these varied data sources, contaminants be flagged based upon data certainty, and that uncertainty be considered in making a listing decision. The Agency applied their recommendations in the development of the draft CCL 3. In addition, the expert panels acknowledged the Agency's efforts to transparently present a complex process and noted that many of the questions posed by the panels were previously considered by EPA. They recommended that additional discussion and information in the support documents would add to the clarity of the process.

In March 2007, EPA convened a panel to review the preliminary draft CCL 3 list for the chemical contaminants in a two-day workshop. Panelists provided

comments on a preliminary draft list of contaminants after receiving supporting materials and presentations from EPA staff. The panel's review focused mainly on the chemicals on the draft CCL 3. They provided comments on contaminants considered for the draft CCL 3 and commented on the supporting data and methods EPA used to identify the contaminants selected. They also provided general comments on the classification model output and the processes used to select chemical contaminants for CCL 3. In addition, they recommended EPA consider a strong outreach process to highlight the significant modeling and decision making processes used in its development.

The panel recognized the level of effort and detail that went into the development of the modeling process used to create the draft list and complimented EPA on these efforts. Comments from all the panels were considered by EPA and appropriate changes were incorporated into the process/protocols to formulate the draft CCL 3. (Specific recommendations and comments are further described in USEPA, 2008h.)

b. Microbial Expert Input Panels

EPA convened three workshops to review, discuss, and comment on the microbes considered and selected for the draft CCL 3. In December 2005, a group of expert microbiologists reviewed and commented on the universe of human pathogens and the screening criteria used to develop the PCCL. This panel agreed that focusing on human pathogens is a reasonable and pragmatic way to identify potential drinking water contaminants. While the panel suggested that animal pathogens may develop the ability to infect humans, they noted that these emerging contaminants should not be listed on the CCL based on the theoretical potential to become zoonotic pathogens. They also identified additional criteria and methods to apply those criteria to the Microbial Universe, which EPA incorporated into the CCL process.

In June 2006, a panel of experts met for three days to review EPA's implementation of recommendations by NRC and NDWAC to select microbes for the CCL. EPA implemented the NDWAC recommendation to develop a process that paralleled the chemical process yet still accounted for the different types of data and information that are uniquely available for microbial contaminants. Panel members agreed that health effects and occurrence of microbes should be evaluated to identify pathogens of the greatest health importance. The panel recommended that EPA use a decision tree approach for microbes rather than the classification approach suggested by NRC and NDWAC.

The panel further recommended that the Agency consider a different selection process than the one used for chemical contaminants, related to the different information available for microbes. Based on this recommendation, the Agency evaluated options to consolidate the potency and severity attributes for microbes into a single health effect attribute, developed a waterborne disease outbreak protocol, and considered occurrence as a single attribute. The Agency considered these and other recommendations as it developed the current three attribute selection process discussed in Section III.B. The panel also recommended that the Agency consider drinking water treatment and removing microbes from further consideration if conventional drinking water treatment protects public health. The Agency's considerations of these and other recommendations are discussed in the Microbial Expert Review support document (USEPA, 2008i).

In March 2007, EPA convened a third workshop to review the preliminary draft CCL 3 list of microbial contaminants. EPA provided the panel with background materials and staff presentations. The panel's review focused mainly on the draft CCL 3 for microbes. The panel also provided comments on the processes used to select the microbial contaminants. Panel members commented on specific microbes considered for the draft CCL 3 and commented on the data and processes EPA used to identify the contaminants selected. The panel noted that the Agency considered a comprehensive list of microbes and thought the draft CCL 3 was reasonable. The panel also recommended that the Agency consider adding a frequency of disease parameter to the health effects scoring protocol for future CCLs. For example, while the panel agreed with EPA that the health effects for Naegleria fowleri are severe, the health effects scoring protocol should consider the limited occurrence of disease. The panel also noted that this would help balance the consideration of less severe adverse health effects such as gastrointestinal illness that are more prevalent with consideration of more severe responses that are less prevalent, such as N. fowleri. The panel recommended that EPA provide further discussion of the rationale to evaluate waterborne disease and health effects equally in the protocol. The discussion of the Agency's rationale is included in Section III.B and addresses the importance of documented waterborne disease outbreaks to identify potential microbial contaminants for the CCL. (A more detailed summary of the expert comments is provided in USEPA, 2008 i.)

3. How are the CCL and UCMR Interrelated for Specific Chemicals and Groups?

EPA promulgated UCMR 2 on January 4, 2007 (72 FR 367 (USEPA, 2007 a; see also USEPA, 2007 b and c)). The UCMR program was developed in coordination with the CCL. Both programs consider the adverse health effects a contaminant may pose through drinking water exposures. Sixteen contaminants on the UCMR 2 monitoring list are also on the draft CCL 3. The draft CCL 3 includes acetochlor and its degradates, alachlor degradates, dimethoate, 1,3dinitrobenzene, metolachlor and its degradates, RDX, terbufos sulfone, and four of the nitrosamines. In addition to the health effects data and potential occurrence, the UCMR 2 also considers analytical methods, availability of analytical standards, and laboratory capacity to conduct a nationwide monitoring program in selecting contaminants. The UCMR 2 includes nine contaminants that are not on draft CCL 3. The five polybrominated flame retardants can be measured by the same analytical method used for terbufos sulfone. The polybrominated flame retardants lacked sufficient occurrence information to be listed on draft CCL 3 (USEPA 2008 b). The polybrominated flame retardants are listed on UCMR2 because of recent concern that these have become more widespread environmental contaminants (e.g., Darnerud et al., 2001) and this monitoring data will provide information for future CCLs. Similarly, 2,4,6-trinitrotoluene (TNT) and two of the nitrosamines also use an analytical method in the UCMR 2. The Agency will also use the results from UCMR 2 as a source of occurrence information during the selection of CCL 4, as well as for CCL 3 regulatory determinations. Alachor was listed on UCMR 2, but was removed from consideration for CCL 3 because there is an existing MCL.

IV. Request for Comment

The purpose of this notice is to present the draft CCL 3 and seek comment on various aspects of its development. The Agency requests comment on the approach used to develop the draft CCL 3 and also requests comments on the contaminants selected, including any supporting data

that can be utilized in developing the final CCL 3. A number of contaminants considered for the draft CCL 3 may be of particular current interest. The following sections provide information for a few of the contaminants that are of most interest. Data obtained and evaluated for developing the draft CCL 3 and referred to in the following sections may be found in the docket for this notice. Specifically, the Agency is also asking for public comments on pharmaceuticals and perfluorinated compounds to identify any additional data and information on their concentrations in finished or ambient water and requests comment on how they have been considered in the CCL 3 process. The Agency is also seeking additional data and information on the occurrence and health effects of H. pylori and how this pathogen was considered in the CCL 3 process. Information and comments submitted will be considered in determining the final CCL 3, as well as in the development of future CCLs and in the Agency's efforts to set drinking water priorities in the future.

A. Pharmaceuticals

The Agency evaluated data sources to identify pharmaceuticals and personal care products that have the potential to occur in PWSs. The primary source of health effects information on pharmaceuticals in the universe was the Food and Drug Administration Database on Maximum Recommended Daily Doses (MRDD). This database includes the recommended adult doses for over 1,200 pharmaceutical agents. Occurrence information from USGS Toxics Substances Hydrology program's National Reconnaissance of Emerging Contaminants, and related efforts, provided ambient water concentration data for 123 contaminants, which include pharmaceuticals. Other data sources included TRI and high production volume chemical data. From this analysis, EPA included 287 pharmaceuticals in the Chemical Universe. These pharmaceuticals had maximum recommended daily dose information that EPA used to evaluate adverse health effects. EPA considered those pharmaceuticals for which MRDD values and occurrence information were available and pharmaceuticals that were in Toxicity Category 1, using the same criteria discussed in Section III.A.2.a. EPA found that less than two percent of the pharmaceuticals included in the MRDD database fell into this category.

EPA applied the LOAEL screening protocols to contaminants with MRDD values. The LOAEL protocol was used because pharmaceutical agents, although used for their beneficial effects, have associated side-effects that may be adverse. Chemicals evaluated with these data had similar modal values and distributions to the toxicity values from IRIS. The range of toxicity values in this database covered 9 orders of magnitude when evaluated based on their rounded logs. They had the same modal value as the LOAELs from IRIS and a very similar distribution. Thirtyfive percent of the IRIS LOAELS and 38 percent of the MRDDs had the modal rounded log. Thirty-three percent of the LOAELs and 19 percent MRDDs had rounded logs that were lower than the mode, while 31 percent of the LOAELs and 44% of the MRDDs had rounded logs that were above the modal log value.

The screening process moved approximately 10 percent of the pharmaceuticals in the Universe to the PCCL. All toxicity data on those chemicals were included in the screening with the most serious qualitative or quantitative measure of toxicity determining placement in a toxicity category. Only one of the PCCL chemicals (diazinon, a veterinary product as well as a pesticide) had water concentration data. Two other pharmaceuticals: phenytoin (an anticonvulsant) and nitroglycerin (treatment of angina), had release data. The remainder were scored for occurrence based on production information, which meant that they fell into the low certainty bin for their occurrence parameters. Nitroglycerin is the only pharmaceutical that is included on the draft CCL 3. EPA is aware of concerns regarding the potential presence of pharmaceuticals in water supplies. The Agency is seeking additional data and information on the concentrations of pharmaceuticals in finished or ambient water and requests comment on how pharmaceuticals have been considered in the CCL 3 process.

B. Perfluorooctanoic Acid and Perfluorooctane Sulfonic Acid

EPA evaluated perfluorinated compounds in the CCL 3 process and requests comment on its decisions to include perfluorooctanoic acid (PFOA) and not to include perfluorooctane sulfonic acid (PFOS) on the draft CCL 3. EPA identified potential health effects and occurrence information for these compounds from the data sources discussed in Section III. The data used for these compounds are discussed in the support documents in more detail. Available analytic methods for these chemicals limited the occurrence data for these compounds. The Agency identified data on the annual

production from CUS/IUR indicating limited production and possible release to the environment. Several organizations nominated PFOS and PFOA for consideration in the CCL process. The nominations noted that these chemicals are persistent in the environment and have been detected at varying levels in drinking water and ambient water in smaller specialized studies. EPA collected the information cited in the nominations and evaluated each of these chemicals. The Agency included PFOA on the draft CCL 3 because it met the criteria for inclusion on draft CCL 3 based on drinking water occurrence studies in Ohio and West Virginia (Emmett, et al., 2006) and on health effects data indicated through animal studies (USEPA, 2005 a).

The Agency did not include PFOS on the draft CCL 3. Occurrence data for PFOS characterized detections in several States (Boulanger, et al., 2004, Hansen, et al., 2002, Goeden and Kelly, 2006). These data showed that levels of detection for PFOS in ambient water ranged from 20 to approximately 100 parts per trillion. Data identified in the nominations process detected PFOS at higher concentrations in areas surrounding landfills known to be contaminated with industrial waste containing PFOS. The CCL process did not consider occurrence data from targeted studies of contaminated waste sites, however. Such studies are usually developed to identify and characterize hazardous waste cleanup efforts and may not be representative of occurrence in drinking water not in close proximity to the study site. PFOS was phased out of production in the U.S. between 2000 and 2002, and regulation limits its importation to a very small number of controlled, very low release uses, (67 FR 72854; December 9, 2002 (USEPA, 2002 c)). Based on the general absence of occurrence data, combined with the phase out, effectively eliminating most future releases, PFOS did not meet the criteria for CCL 3.

The Agency is evaluating data related to PFOA in a formal risk assessment process under the Toxic Substance Control Act. EPA's Science Advisory Board (SAB) completed a review of a draft risk assessment in 2006 and SAB made recommendations for the further development of the risk assessment. A final risk assessment may not be completed for several years, as a number of important studies are underway. The Agency is also participating in additional research regarding the toxicity and persistence of related perfluorochemicals, as well as research to help identify where these chemicals

are coming from and how people may be exposed to them.

C. Helicobacter pylori

Helicobacter pylori is a pathogen that causes gastric cancer in addition to acute gastric ulcers. EPA placed this pathogen on the draft CCL. However, the analysis for H. pylori differs from the other pathogens due to the long term and/or chronic nature of its health effects rather than the more common acute effects of most waterborne pathogens. This organism is an emerging pathogen whose impact has only recently begun to be understood. Given the slow development of adverse health effects due to infection by H. pylori, it is more difficult to link contamination of drinking water and show a waterborne disease outbreak. Therefore, given the long timeframe of cancer and ulcer development (as opposed to the commonly acute gastrointestinal illness of nearly all the other pathogens on the PCCL) as well as the ongoing nature of the research, EPA used peer-reviewed scientific papers to score the health effects of Helicobacter pylori. EPA request comment on the process of selection of microbial contaminants that cause chronic rather than acute health effects.

V. EPA's Next Steps

Between now and the publication of the final CCL, the Agency will evaluate comments received during the comment period for this notice, consult with the SAB, and re-evaluate the criteria used to develop the draft CCL and revise the CCL, as appropriate.

VI. References

- Boulanger, B., J. Vargo, J.L. Schnoor and K.C. Hornbuckle. 2004. Detection of Perfluorooctane Surfactants in Great Lakes Water. *Environmental Science and Technology*, Vol. 38, No. 15, pp 4064– 4070.
- CDC. 2004. Surveillance for Waterborne-Disease Outbreaks Associated with Drinking Water—United States, 2001– 2002. MMWR Surveillance Summaries, 53(SS08); 23–45.
- CDC, 2006. Surveillance for Waterborne-Disease Outbreaks Associated with Drinking Water—United States, 2003– 2004. MMWR Surveillance Summaries, 55(SS12); 31–58.
- Darnerud, P.O., G.S. Erickson, T. Johannesson, P.B. Larson, and M. Viluksela. 2001. Polybrominated Diphenyl Ethers: Occurrence, Dietary Exposure, and Toxicology. Environmental Health Perspectives Supplements. Vol. 109, No. S1. Available on the Internet at: http:// ehp.niehs.nih.gov/members/2001/suppl-1/49-68darnerud/darnerud-fall.html.
- Eminett, E.A., F.S. Shofer, H. Zhang, D. Freeman, C. Desai, L.M. Shaw. 2006.

Community Exposure to Perfluorooctanoate: Relationships Between Serum Concentrations and Exposure Sources, Journal of Occupational and Environmental Medicine, Vol. 48, No. 8, pp. 759–770.

- Goeden, H. and J. Kelly. 2006. Perfluorochemicals in Minnesota, Minnesota Department of Health, Senate Environment and Natural Resources Committee, February 27. Available on the Internet at: http:// www.health.state.mn.us/divs/eh/
- hazardous/sites/washington/pfcsmn.pdf, Hansen, K.J., H.O. Johnson, J.S. Eldridge, J.L.
- Blutenholf and L.A. Dick. 2002. Quantitative Characterization of Trace Levels of PFOS and PFOA in the Tennessee River. *Environmental Science* and Technology, Vol. 36, No. 8, pp. 1681–1685.
- National Drinking Water Advisory Council (NDWAC). 2004. National Drinking Water Advisory Council Report on the CCL Classification Process to the U.S. Environmental Protection Agency, May 19, 2004.
- National Research Council (NRC). 2001. Classifying Drinking Water Contaminants for Regulatory Consideration. National Academy Press, Washington, DC.
- NIST. 2006. NIST/SEMATECH e-Handbook of Statistical Methods. Available on the internet at: http://www.itl.nist.gov/ div898/handbook/, (used on May 3, 2007).
- Taylor, L.H., S.M. Latham, and M.E. Woolhouse. 2001. Risk factors for human disease emergence (Appendix A). Phil. Trans. R. Soc. Lond. B. Vol. 256, pp. 983–989.
- Tyler, K.T., E.S. Barton, M.L. Ibach, C. Robinson, J.A. Campbell, S.M. O'Donnell, T. Valyi-Nagy, P. Clarke, J.D. Wetzel, T.S. Dermody. 2004. Isolation and Molecular Characterization of a Novel Type 3 Reovirus from a Child with Meningitis. Jour. Infect. Dis. Vol. 189, No. 9, pp. 1664–75.
- USEPA. 1989a. National Primary Drinking Water Regulations; Filtration, Disinfection; Turbidity, Giardia Lamblia, Viruses, Legionella, and Heterotrophic Bacteria; Final Rule. Part 2. Federal Register. Vol. 54, No. 124, p. 27486, June 29, 1989.
- USEPA. 1989b. Drinking Water; National Primary Drinking Water Regulations; Total Coliforms (Including Fecal Coliforms and E. Coli). Federal Register. Vol. 54, No. 124, p. 27544, June 29, 1989.
- USEPA. 1992. Drinking Water, National Primary Drinking Water Regulations—)-Synthetic Organic Chemicals and Inorganic Chemicals; National Primary Drinking Water Regulations Implementation; Final Rule. Federal Register, Vol. 57, No. 138, p. 31776, July 17, 1992.
- USEPA. 1997. Announcement of the Draft Drinking Water Contaminant Candidate List; Notice. Federal Register. Vol. 62, No. 193, p. 52193, October 6, 1997.
- USEPA. 1998a. Interim Enhanced Surface Water Treatment; Final Rule. Federal

Register. Vol. 63, No 241, p. 69478, December 16, 1998.

- USEPA. 1998b. Announcement of the Draft Drinking Water Contaminant Candidate List; Notice. Federal Register. Vol. 63, No. 40, p. 10273, March 2, 1998.
- USEPA. 1999. Revisions to the Unregulated Contaminant Monitoring Regulation for Public Water Systems. Federal Register. Vol. 64, No. 180, p. 50556, September 17, 1999.
- USEPA. 2002a. Long Term 1 Enhanced Surface Water Treatment Rule; Final Rule. Federal Register. Vol. 67, No. 9, p. 1813. January 14, 2002.
- USEPA. 2002b. Announcement of Preliminary Regulatory Determinations for Priority Contaminants on the Drinking Water Contaminant Candidate List. Federal Register. Vol. 67, No. 106, p. 38222, June 3, 2002.
- USEPA. 2002c. Perfluoroalkyl Sulfonates; Significant New Use Rule. Federal Register. Vol 67, No. 236, p. 72854, December 9, 2002.
- USEPA. 2003a. Announcement of Regulatory Determinations for Priority Contaminants on the Drinking Water Contaminant Candidate List. Federal Register. Vol. 68, No. 138, p. 42898, July 18, 2003.
- USEPA. 2004. Drinking Water Contaminant Candidate List 2; Notice. Federal Register. Vol. 69, No. 64, p. 17406, April 2, 2004.
- USEPA. 2005a. Draft Risk Assessment of the Potential Human Health Effects Associated with Exposure to Perfluorooctanoic Acid and its Salts. OPPTS, SAB Draft. January 4, 2005.
- USEPA, 2005b. Notice—Drinking Water Contaminant Candidate List 2; Final Notice. Federal Register. Vol. 70, No. 36, p. 9071, February 24, 2005.
- USEPA. 2006a. Long Term 2 Enhanced Surface Water Treatment Rule; Final Rule. Federal Register. Vol. 71, No. 3, p. 654, January 5, 2006.
- USEPA. 2006b. Request for Nominations of Drinking Water Contaminants for the Contaminant Candidate List; Notice. Federal Register. Vol. 71, No. 199, p. 60704, October 16, 2006.
- USEPA. 2006c. National Primary Drinking Water Regulations: Ground Water Rule; Final Rule. Federal Register. Vol. 71, No. 216, p. 65573, November 8, 2006.
- USEPA. 2007 a. Unregulated Contaminant Monitoring Regulation (UCMR) for Public Water Systems Revisions; Final Rule. Federal Register. Vol. 72, No. 2, p. 367, January 4, 2007.
- USEPA, 2007 b. Unregulated Contaminant Monitoring Regulation (UCMR) for Public Water Systems Revisions; Correction. Federal Register. Vol. 72, No. 17, p. 3916, January 26, 2007.
- USEPA. 2007 c. Unregulated Contaminant Monitoring Regulation (UCMR) for Public Water Systems Revisions; Correction. Federal Register. Vol. 72, No. 19, p. 4328, January 30, 2007. USEPA. 2007 d. Drinking Water; Regulatory
- USEPA. 2007 d. Drinking Water: Regulatory Determinations Regarding Contaminants on the Second Drinking Water Contaminant Candidate List—

Preliminary Determinations; Proposed Rule. Federal Register. Vol. 72, No. 83, p. 24016, May 1, 2007.

- p. 24016, May 1, 2007. USEPA. 2008 a. Contaminant Candidate List 3 Chemicals: Identifying the Universe. EPA 815–R–08–002. Draft. February, 2008.
- USEPA. 2008 b. Contaminant Candidate List 3 Chemicals: Screening to a PCCL. EPA 815–R–08–003. Draft. February, 2008.
- USEPA. 2008 c. Contaminant Candidate List 3 Chemicals: Classification of the PCCL to the CCL, EPA 815–R–08–004. Draft. February, 2008.
- USEPA. 2008 d. Contaminant Candidate List 3 Microbes: Identifying the Universe, EPA 815–R–08–005. Draft. February, 2008.
- USEPA. 2008 e. Contaminant Candidate List 3 Microbes: Screening to the PCCL, EPA 815–R–08–006. Draft. February, 2008.
- USEPA. 2008 f. Contaminant Candidate List 3 Microbes: PCCL to CCL Process, EPA 815-R-08-007. Draft. February, 2008.
- USEPA. 2008 g. Summary of Nominations for the Third Contaminants Candidate List. EPA 815–R–08–008. Draft. February, 2008.
- USEPA. 2008 h. Chemical Expert Input and Review for the Third Contaminant Candidate List, EPA 815–R–08–009, Draft. February, 2008.
- USEPA. 2008 i. Microbial Expert Input and Review, EPA 815–R–08–010. Draft. February, 2008.

Dated: February 6, 2008.

Benjamin H. Grumbles,

Assistant Administrator, Office of Water. [FR Doc. E8–3114 Filed 2–20–08; 8:45 am] BILLING CODE 6560–50–P APPENDIX F Schnabel: Installed Monitoring Wells (MW-1 &MW-2) Report Monitoring Well Installation & Residential Well Sampling Battlefield Golf Club Water Project Centerville Turnpike South Murray Drive & Whittamore Road Chesapeake, Virginia

Project 08330106 February 3, 2009





300 Ed Wright Lane, Suite I Newport News, VA 23606

Phone (757) 947-1220 Fax (757) 947-1225 www.schnabel-eng.com

February 3, 2009

Mr. Robert Sciacchitano, P.E. URS Corporation 277 Bendix Road, Suite 500 Virginia Beach, Virginia 23452

Subject: 08330106, Monitoring Well Installation and Residential Well Sampling, Battlefield Golf Club Water Project, Centerville Turnpike South, Murray Drive and Whittamore Road, Chesapeake, Virginia

Dear Robert:

Schnabel Engineering, LLC is pleased to submit this report concerning monitoring well installation and residential well sampling at the Battlefield Golf Club Water Project.

PROJECT DESCRIPTION

Two test wells were installed and water samples were obtained from two residential wells as part of this study.

FIELD ACTIVITIES

Fishburne Drilling, Inc., Chesapeake, Virginia installed two monitoring wells (MW-1 and MW-2) on November 24, 25 and 26, 2008. The two-inch diameter monitoring wells were installed to depths of 45 and 90 feet below ground surface. Monitoring Well MW-1 was installed to 90 feet and MW-2 was installed to 45 feet. MW-1 was constructed as a Type III monitoring well. The monitoring wells were installed within an easement along the east side of Bonney Road in a grassy area near the northern terminus of Bonney Road. A permit was granted by the City of Chesapeake prior to drilling activities. The drilling and well construction activities were performed under the observation of Schnabel personnel. The test boring locations are shown on

Figure 1 in Appendix A. Monitoring well construction details and protocol for installing monitoring wells in test borings are also included in Appendix A.

Test borings were advanced with a 2.9375-inch O.D. tri-cone roller bit, 4.25-inch and 8.25-inch I.D. hollow stem augers. Soil samples were collected in MW-1 at a minimum of every five feet from 18 to 90 feet in the test boring. We collected two undisturbed samples from the MW-1 test boring. The undisturbed samples were collected from depths of 55 to 57 feet and 60 to 62 feet below ground surface. Boring logs are included in Appendix A.

The wells were developed using a submersible pump. Several groundwater measurements were obtained in MW-1 and MW-2. Measurements were referenced to the ground surface (the rim of protective manhole cover) at each well location. The groundwater measurements obtained from MW-1 and MW-2 are indicated in the table below.

| Well | Dete | | 7839 |
|-------------|----------|------------------|---------|
| Number | Date | water Level (ft) | Time |
| MW-1 | 12-10-08 | 21.53 | 7:24 AM |
| MW-1 | 12-17-08 | 15.33 | 6:55 AM |
| MW-1 | 12-19-08 | 11.82 | 6:45 AM |
| MW-1 | 12-22-08 | 9.52 | 5:35 PM |
| MW-1 | 12-23-08 | 8.03 | 7:16 AM |
| MW-1 | 12-24-08 | 7.01 | 6:25 AM |
| MW-1 | 1-5-09 | 6.28 | 7:44 AM |
| MW-1 | 1-15-09 | 5.61 | 2:51 PM |
| MW-2 | 12-10-08 | 4.08 | 7:09 AM |
| MW-2 | 12-17-08 | 3.07 | 6:58 AM |
| MW-2 | 12-19-08 | 3.35 | 6:43 AM |
| MW-2 | 12-22-08 | 3.06 | 5:39 PM |
| MW-2 | 12-23-08 | 3.17 | 7:20 AM |
| MW-2 | 12-24-08 | 3.17 | 6:28 AM |
| MW-2 | 1-5-09 | 4.03 | 7:46 AM |
| MW-2 | 1-15-09 | 3.87 | 2:53 PM |

Field sampling of two residential wells was conducted on December 22, 2008. The residential well samples were collected from 1204 and 1208 Murray Drive. The well samples were collected from exterior spigots at the rear of each residence. A field blank sample was also

-2-

collected on December 22, 2008. The samples were submitted to REIC Consultants, Inc., Beaver, West Virginia for laboratory analysis. The water samples were analyzed according to the Well Specification – Water Analysis Parameters from URS dated September 17, 2008. Modifications to the Water Analysis Parameters provided by URS included the exemption of E. Coli, Color and Asbestos and the addition of Total Organic Carbon (TOC). Certificates of Analysis and Chains of Custody are included in Appendix B.

SOIL LABORATORY TESTING

Permeability tests were performed on the undisturbed samples in our geotechnical laboratory. The summary of soil laboratory test results and laboratory test curves are included in Appendix C.

This letter report summarizes our activities to date for the Battlefield Golf Club Water Project. We have endeavored to complete the services identified herein in a manner consistent with that level of care and skill ordinarily exercised by members of the profession currently practicing in the same locality and under similar conditions as this project. No other representation, express or implied, is included or intended, and no warranty or guarantee is included or intended in this report, or any other instrument of service.

We appreciate the opportunity to be of service and look forward to a continued cordial working relationship on this project. If you have any questions, please do not hesitate to contact us.

Very truly yours, SCHNABEL ENGINEERING, LLC

Russell Rounts.

Russell W. Rountree Senior Staff Scientist

Gilbert T. Seese, P.E. Principal



RWR:GTS:dah

Appendices:

Appendix A – Subsurface Exploration Data

Appendix B – Laboratory Analytical Chemical Data

Appendix C – Soil Laboratory Test Data

APPENDIX A

Subsurface Exploration Data

Protocol for Installing Monitoring Wells within Test Borings (2 Sheets) Location Plan (Figure 1) General Notes for Subsurface Exploration Logs Identification of Soils Test Boring Logs (MW-1 and MW-2) Monitoring Well Construction Details (2 Sheets)

PROTOCOL FOR INSTALLING MONITORING WELLS IN TEST BORINGS

I. DRILLING METHODS AND PROCEDURE

Drilling and sampling was performed using a 2-15/16 inch, tri-cone roller bit, a 5-7/8 inch, tri-cone roller bit, 8-1/4 inch I.D., hollow-stem auger and 4-1/4 inch I.D., hollow-stem auger drill and split-barrel (spoon) soil sampling device.

- A. Monitoring well locations were staked by Schnabel Engineering. A permit was obtained from the City of Chesapeake prior to drilling at the monitoring well locations.
- B. The Unified Soil Classification System, ASTM D 2487-83, with additional descriptive terms was used for visual sample classifications.
- C. Elevations at the top of the wells was provided by URS Corporation.

II. MONITORING WELL MW-1

- A. The following procedure was followed to develop and finish the borehole as a monitoring well.
 - 1. Upon encountering the clay layer at a depth of approximately 52 feet, a six-inch diameter PVC casing was installed to depth of 53 feet. The six-inch casing was then grouted with a slurry mixture of bentonite cement and allowed to cure for a minimum of 24 hours.
 - Upon curing of the grout, drilling and sampling were resumed through the six-inch casing to a depth of 90 feet. Upon completion of drilling, 2-inch diameter Schedule 40 PVC pipe was installed at the desired depth of the borehole. The monitoring well was furnished with 10 feet of No. 10 slot, 2-inch diameter Schedule 40 PVC, screen flush jointed to permanent casing. No organic solvents were used during well construction.
 - 3. The monitoring well screen was surrounded with a filter pack compatible with surrounding medium consisting of graded washed filter sand placed above the top of the screen. A minimum two-foot thick bentonite clay seal

was placed above the filter pack. A slurry mixture of bentonite and cement was used to grout the annulus above the bentonite seal in the well.

- 4. The permanent monitoring well casing was finished flush with the ground surface. The well head was finished with a cap, and an outer (surface) protective steel casing with a locking cap. The protective casing was set into a thick concrete collar at grade.
- 5. Well development consisted of purging the well using a 12-volt submersible pump. Development was complete when a significant drop in the turbidity of the water was observed.

III. MONITORING WELL MW-2

- 1. Upon completion of drilling, 2-inch diameter Schedule 40 PVC pipe was installed at the desired depth of the borehole. The monitoring well was furnished with 10 feet of No. 10 slot, 2-inch diameter Schedule 40 PVC, screen flush jointed to permanent casing. No organic solvents were used during well construction.
- 2. The monitoring well screen was surrounded with a filter pack compatible with surrounding medium consisting of graded washed filter sand placed above the top of the screen. A minimum two-foot thick bentonite clay seal was placed above the filter pack. A slurry mixture of bentonite and cement was used to grout the annulus above the bentonite seal in the wells.
- 3. The permanent monitoring well casing was finished flush with the ground surface. The well head was finished with a cap, and an outer (surface) protective steel casing with a locking cap. The protective casing was set into a thick concrete collar at grade.
- 4. Well development consisted of purging the well using a 12-volt submersible pump. Development was complete when a significant drop in the turbidity of the water was observed.



SCHNABEL ENGINEERING GENERAL NOTES FOR SUBSURFACE EXPLORATION LOGS

- Numbers in sampling data column next to Standard Penetration Test (SPT) symbols indicate blows required to drive a 2 inch O.D., 1-3/8 inch I.D. sampling spoon 6 inches using a 140 pound hammer falling 30 inches. The Standard Penetration Test (SPT) N value is the number of blows required to drive the sampler 12 inches, after a 6 inch seating interval. The Standard Penetration Test is performed in general accordance with ASTM-1586.
- 2. Visual classification of soil is in accordance with terminology set forth in "Identification of Soil." The ASTM D-2487 group symbols (e.g. CL) shown in the classification column are based on visual observations.
- 3. Estimated ground water levels indicated on the logs are only estimates from available data and may vary with precipitation, porosity of the soil, site topography, and other factors.
- 4. Refusal at the surface of rock, boulder, or other obstruction is defined as an SPT resistance of 100 blows for 2 inches or less of penetration.
- 5. The logs and related information depict subsurface conditions only at the specific locations and at the particular time when drilled or excavated. Soil conditions at other locations may differ from conditions occurring at these locations. Also, the passage of time may result in a change in the subsurface soil and ground water conditions at the subsurface exploration location.
- 6. The stratification lines represent the approximate boundary between soil and rock types as obtained from the subsurface exploration. Some variation may also be expected vertically between samples taken. The soil profile, water level observations and penetration resistances presented on these logs have been made with reasonable care and accuracy and must be considered only an approximate representation of subsurface conditions to be encountered at the particular location.
- 7. Key to symbols and abbreviations:

| S-1, SPT 5+10+1 | - Sample No., Standard Penetration Test - Number of blows in each 6-in increment |
|---|---|
| UD-1, UNDIST REC=24", 100% | Sample No., 2" or 3" Undisturbed Tube Sample Recovery in inches, Percent Recovery |
| C-1, CORE Run = 5.0 ft REC = 60" 100% RQD = 60" 100% | Core No., Rock Core Run Length in feet Recovery in inches, Percent Recovery RQD in inches, Percent RQD |
| MC | - Moisture Content |
| PP | - Pocket Penetrometer Reading (tsf) |
| FID | - Flame Ionization Detector Reading (ppm) |
| PID | - Photoionization Detector Reading (ppm) |
| GP | - Geostick Penetration Reading (inches) |
| LL | - Liquid Limit |
| PL | - Plastic Limit |
| ТРН | - Total Petroleum Hydrocarbons |
| | S-1, SPT 5+10+1 UD-1, UNDIST REC=24", 100% C-1, CORE Run = 5.0 ft REC = 60" 100% RQD = 60" 100% MC PP FID PID GP LL PL TPH |

SCHNABEL ENGINEERING IDENTIFICATION OF SOILS

1. DEFINITION OF SOIL GROUP NAMES (ASTM D-2487)

SYMBOL GROUP NAME

| Coarse-Grained Soils More than 50% retained on No. 200 sieve | Gravels – More than 50% of coarse fraction retained on No. 4 sieve Coarse, ¾" to 3" | Clean Gravels Less than 5% fines | GW GP | WELL GRADED GRAVEL POORLY GRADED GRAVEL |
|--|--|-------------------------------------|----------|--|
| 1 | Fine, No. 4 to ³ | Gravels with fines | GM | SILTY GRAVEL |
| | | More than 12% fines | GC | CLAYEY GRAVEL |
| | Sands - 50% or more of coarse | Clean Sands | SW | WELL GRADED SAND |
| ļ | Fraction passes No. 4 sieve Coarse, No. 10 to No. 4 | Less than 5% fines | SP | POORLY GRADED SAND |
| | Medium, No. 40 to No. 10 Fine No. 200 to No. 40 | Sands with fines | SM | SILTY SAND |
| | 1 110, 110, 200 10 110, 10 | More than 12% fines | SC | CLAYEY SAND |
| Fine-Grained Soils | Silts and Clays ~ | Inorganic | CL | LEAN CLAY |
| 50% or more passes | Liquid Limit less than 50 | | ML | SILT |
| the No. 200 sieve | Low to medium plasticity | Organic | OL | ORGANIC CLAY |
| | | | | ORGANIC SILT |
| | Silts and Clays - | Inorganic | CH | FAT CLAY |
| | Liquid Limit 50 or more | | MH | ELASTIC SILT |
| | Medium to high plasticity | Organic | OH | ORGANIC CLAY |
| | | | | ORGANIC SILT |
| Highly Organic Soils | Primarily organic matter, dark in col | or and organic odor | PT | PEAT |

II. DEFINITION OF SOIL COMPONENT PROPORTIONS (ASTM D-2487)

| | | | Examples |
|----------------|--------------------------|---|--------------------------------|
| Adjective Form | GRAVELLY SANDY | >30% to <50% coarse grained component in a fine-grained soil | GRAVELLY LEAN CLAY |
| | CLAYEY SILTY | >12% to <50% fine grained component in a coarse-grained soil | SILTY SAND |
| "With" | WITH GRAVEL WITH SAND | >15% to <30% coarse grained component in a fine-grained soil | FAT CLAY WITH GRAVEL |
| | WITH GRAVEL WITH SAND | >15% to <50% coarse grained component in a coarse-grained soil | POORLY GRADED GRAVEL WITH SAND |
| | WITH SILT WITH CLAY | >5% to <12% fine grained component in a coarse-grained soil | POORLY GRADED SAND WITH SILT |

III. GLOSSARY OF MISCELLANEOUS TERMS

| SYMBOLS | Unified Soil Classification Symbols are shown above as group symbols. A dual symbol "-" indicates the soil belongs to two groups. A borderline symbol "/" indicates the soil belongs to two possible groups. |
|---------------------|--|
| FILL. | Man-made deposit containing soil, rock and often foreign matter. |
| PROBABLE FILL | Soils which contain no visually detected foreign matter but which are suspect with regard to origin. |
| DISINTEGRATED ROCK | Residual materials with a standard penetration resistance (SPT) between 60 blows per foot and |
| (DR) | refusal. Refusal is defined as a SPT of 100 blows for 2" or less penetration. |
| PARTIALLY WEATHERED | Residual materials with a standard penetration resistance (SPT) between 100 blows per foot and |
| ROCK (PWR) | refusal. Refusal is defined as a SPT of 100 blows for 2" or less penetration. |
| BOULDERS & COBBLES | Boulders are considered rounded pieces of rock larger than 12 inches, while cobbles range from 3 to |
| | 12 inch size. |
| LENSES | 0 to $\frac{1}{2}$ inch seam within a material in a test pit. |
| LAYERS | $\frac{1}{2}$ to 12 inch seam within a material in a test pit. |
| POCKET | Discontinuous body within a material in a test pit. |
| MOISTURE CONDITIONS | Wet, moist or dry to indicate visual appearance of specimen. |
| COLOR | Overall color, with modifiers such as light to dark or variation in coloration. |

| | chnabel | TEST BORING | Project: | Battlefie Bonney | eld Golf Road a | Club V Ind Mu | Water P urray Dr | 'roject ive | | Boring Number: MW-1 Contract Number: 08330106 | | | | | |
|---------------|------------------------|---------------------------------------|-----------|---------------------|--------------------|------------------|---------------------|----------------------|---------------------|--|-------|--------|-------------|--|--|
| Contro | aver Engineering | | | Unesap | eake, V | n ginia | | | 0 | Juneter Of - | 013 | | | | |
| Contra | Chesapeake, V | irginia | | | | | | | Ground Date | awater Obs | Depth | Casing | Caved | | |
| Contra | ctor Foreman: T. Do | nahue | | | | | | | | 11/40 411 | 40.0 | 3 | | | |
| Schnat | el Representative: F | R. Rountree | | | | Er | icounte | ered <u>v</u> | 11/24 | 11:10 AM | 18.0 | | | | |
| Equipn | nent: CME-550X | | | | | С | omplet | ion | 11/26 | 3:07 PM | | | | | |
| Method | I: 2-15/16" O.D. Tri-c | one Roller B | it | | | Ca | sing Pu | ulled | 11/26 | 3:15 PM | | | | | |
| Hamme | er Type: Auto Hamm | er (140 lh) | | | | | | | | | | | | | |
| Dates | Started: 11/24/08 | Finished: | 11/26/08 | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| Groups | Surface Elevation | Q 4 (ft) | Total Do | oth: 00 | 0.4 | | | | | | | | | | |
| Ground | | 9.3 (11) | i otar De | ptn: 90. | | .L | | | | | | 1 | L | | |
| DEPTH (ft) | MATERIAL | DESCRIPTI | ON | SYME | | LEV (ft) | STRA TUM | S DEPTH | | • | TESTS | RE | MARKS | | |
| | | · · · · · · · · · · · · · · · · · · · | | | | | | | | | | Mud r | otary probe | | |
| - | | | | | | - | | | | | | 10 10 | | | |
| - | | | | | - | | - | | | | | | | | |
| - | | | | | | | - | | | | | | | | |
| - | | | | | - | | - | | | | | | | | |
| | | | | | | | - | - 5 - | 1 | | | | | | |
| | | | | | _ | | | | | | | | | | |
| _ | | | | | | | _ | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | - | | | | | | | | |
| - | | | | | ~~ | | - | | | | | | | | |
| | | | | | | | - | - 10 - | | | | | | | |
| - | | | | | - | | - | | | | | | | | |
| | | | | | - | | - | | | | | | | | |
| | | | | | - | - | 4 | | | | | | | | |
| _ | | | | | | | | | | | | | | | |
| | | | | | | | | 45 | | | | | | | |
| | | | | | | |] | - 15 - | | | | | | | |
| | | | | | | | - | | | | | | | | |
| | | | | | - | | - | | | | | | | | |
| _ | |) SAND WIT | TH SILT. | 7 | | - | - | + $+$ | | | | NORF | OLK | | |
| _ | fine to medium gra | ined sand, v | vet, dark | | | | - | \ | (7+9+9+9 REC=24" | , 100% | | FORM | ATION | | |
| | Q. ~) | | | SP-SM | | | 4 | - 20 + | 1 | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | 40.0 | B1 | | | | | | | | |
| 22.0 - | POORLY GRADED | D SAND, fine | e to | | - | 12.9 - | | | | | | | | | |
| - | estimated <5% silt | inu, wet, gfa | у, | SP | | - | | $ \uparrow \uparrow$ | S-2, SPT | | | | | | |
| - | | | | | | - | - |) | REC=24 | , 100% | | | | | |
| Ĺ | | | | | | | | <u> </u> | <u> </u> | | | | | | |

TEST BORING LOG REVISED MW BORING LOGS.GPJ SCHWABEL DATA TEMPLATE 2008_07_06.GDT_2/09

| | Chnabel BORING | | | Golf Club \ ad and Mu | Nater P urray Dr | 'roject ive | | Boring Number: MW- | | |
|---------------|---|---------------------------------|-----------|--------------------------|---------------------|----------------|---|--|--|--|
| Schna | abel Engineering LOG | | Chesapeal | ke, Virginia | | | | Sheet: 2 of 3 | | |
| DEPTH (ft) | MATERIAL DESCRI | PTION | SYMBO | ELEV (ft) | STRA TUM | SA DEPTH | MPLING | TESTS | REMARKS | |
| | POORLY GRADED SAND, medium grained sand, wet, estimated <5% silt <i>(continue</i> | fine to gray, <i>ed</i>) | SP | | | 30 - | S-3, SPT 6+7+8+14 REC=24", 10 | 00% | NORFOLK FORMATION (continued) | |
| | | | | | | - 35 - | S-4, SPT 14+20+24+2 REC=24", 1(| 22 00% | | |
| | SILTY SAND, fine to mediu sand, wet, gray | m grained | SM | | B1 | | S-5, SPT 4+6+6+6 REC=24", 1(| 00% | | |
| | | | | | | - 45 | S-6, SPT 3+3+2+3 REC=24", 1 | 00% | | |
| | grained sand, wet, dark gray | num / | SC | | | - 50 - | (S-7, SPT 2+3+3+4 REC=24", 1) | 00% | | |
| - | LEAN CLAY WITH SAND, n gray, contains mica | noist, dark | CL | | B2 | | S-8, SPT 2+2+2+2 REC=24", 1 UD-1 REC=16", 6 | PP =0.50 tsf PP =1.25 tsf PP =0.25 tsf | 2 15/16" tri-cone roller bit used during sampling to 55 feet. 8 1/4" I.D. hollow stem augers used to set the 6" casing to 53 feet. 5 7/8" tri-cone roller bit used during sampling | |
| | | | | | | | S-9, SPT | PP =0.25 tsf | durii | |

TEST BORING LOG REVISED MW BORING LOGS.GPJ SCHNABEL DATA TEMPLATE 2008_07_06.GDT_2/2/09

(continued)

| Schnabel Engineering LOG | | Battlefi Bonney Chesar | eid G / Roa | d and Mu , Virginia | /Vater P urray Dri | roject ive | | Boring Number: IVIVV Contract Number: 08330106 Sheet: 3 of 3 | | | | |
|----------------------------|---|---|----------------------|------------------------|-----------------------|----------------|-------------|--|---|-----------|--------------|---|
| DEPTH (ft) | MATERIAL | . DESCRIPT | ION | SYM | BOL | ELEV (ft) | STRA TUM | S/ DEPTH | MPLING | | TESTS | REMARKS |
| | LEAN CLAY WIT gray, contains mic | ∃ SAND, mo ca <i>(continuec</i> | ist, dark 1) | CL | | | B2 | - 60 | 1+2+2+2 REC=24", 10 UD-2 REC=15", 63 | 00% 3% | PP =0.25 tsf | from 55 to 90 feet and to se well. NORFOLK FORMATION (continued) |
| 62.0 - - - - - | SILTY SAND, fine sand, wet, greenis 10% shells | e to medium ; sh gray, estir | grained nated 5 - | | | 52.9 - | | - 65 - | / S-10, SPT 4+8+5+7 REC=24", 11 | 00% | | Two-inch monitoring we installed to 90 feet upon completion. |
| - | Changes to conta estimated <5% sh | ins lean clay Iells | layers, | SM | | | C1 | | S-11, SPT 6+11+12+1(REC=24", 1 | 0 00% | | YORKTOWN FORMATION |
| - | | | | | | | | | - 3+8+10+12 REC=24", 1 | 00% | | |
| 77.0 - | LEAN CLAY WITH contains silty sand | 1 SAND, wet I lenses | t, gray, | CL | | 67.9 | C2 | 80 - | S-13, SPT 3+6+6+11 REC=24", 1 | 00% | PP =1.25 tsf | |
| 82.0 - | CLAYEY SAND, fi grained sand, wet estimated 5 - 10% | ine to mediu , greenish gr shells | m ay, | sc | | 72.9 | - C1 | 85 - | S-14, SPT 6+12+14+1 REC=24", 1 | 4 100% | | |
| 87.0 - | SILTY SAND, fine sand, wet, greenis <5% shells | to medium s sh gray, estin | grained nated | SM | | 77.9 | | | S-15, SPT 6+14+18+2 REC=24*, 1 | 2 100% | | |

| Schna | | TEST BORING LOG | Project: | Battlefie Bonney Chesap | ld Golf Road a ∋ake, V | Club \ nd Mu irginia | Vater P Irray Dr | roject ive | | Boring I Contrac Sheet: | Number: t Number: 1 of 2 | 08330106 | MW-2 |
|--|-----------------------|-----------------------|-----------|-------------------------------|------------------------------|---|---------------------|---------------|-------|-------------------------------|--------------------------------|--|---|
| Contrac | ctor: Fishburne Dril | ling | | | | | | | Groun | dwater Obs | ervations | | |
| Contra | Unesapeake, | virginia onahue | | | | ļ | | | Date | Time | Depth | Casing | Caved |
| Schnah | el Representative: | R. Rountree | | | | En | counte | ered 🕎 | 11/25 | 11:31 AM | 5.0' | | |
| Equipm | ent: CME-550X | | | | | С | omplet | ion | 11/26 | 3:42 PM | | | |
| Method | l: 4-1/4" I.D. Hollow | Stem Auger | | | | Ca | sing Pu | lled | 11/26 | 4:21 PM | | | |
| | ····· | | | | | | | · | | | | | |
| Dates | Started: 11/25/08 | Finished: | 11/25/08 | | | | | | | | | | |
| Ground | Surface Elevation | : 9.0 (ft) | Total Dep | th: 45. | 0 ft | | | | | | | | |
| DEPTH | | | | | F | IFV | STRA | s | | | | | |
| (ft) | MATERIA | | | SYMB | | (ft) | TUM | DEPTH | DAT | Ā | TESTS | RE | MARKS |
| | | | Ţ | | | - - - - | | | | | | Elevat referei of con (assur 45.5 fr Boring for stri descri | ion need to top crete curb ned 100.0), probe to eet; see j Log MW-1 ata ptions. |
| EST BORING LOG REVISED MW BORING LOGS.GPJ SCHNABEL DATA TEMPLATE 2008_07_06.GDT 2/2/09 | | | | | | - - - - - - - - - - - - - - - - - - - | | | | | | Two-ir monits install feet u compl | nch pring well ed to 45.04 pon etion. |

| Schna | | TEST BORING LOG | Project: | t: Battlefield Golf Club Water Project Bonney Road and Murray Drive Chesapeake, Virginia | | | | | | | Bori Con | ng Number: tract Number: 08 | MW-2 |
|---------------|----------------------|-----------------------|----------|--|--------------|-------------|------|---------|----------------|-------|-------------|--------------------------------|-------------|
| DEPTH (ft) | MATERIAL DESCRIPTION | | SYMB | OL | ELEV (ft) | STRA TUM | DEPT | SA H | MPLING DATA | Offer | TESTS | REMARKS | |
| | | | | | | | | | | | | | |
| | | | | | | | | | , , | | | | |
| | | | | | | | | - 30 - | | | | | |
| | | | | | | | | | | | | | |
| - | | | | | | | | - 35 - | | | | | |
| - | | | | | | | | | | | | | |
| | | | | | | - u | | | | | | | |
| | | | | | | | | - 40 | | | | | |
| - | | | | | | | | | | | | | |
| | | | | | | | | 45 | | | | | |

Bottom of Boring at 45.0 ft. Observation well installed upon completion.

CONSTRUCTION DETAILS FOR MONITORING WELL MW-1

BORING NUMBER: MW-1 SCREEN SIZE AND TYPE:10 FT, NO. 10 SLOT PVC CASING SIZE AND TYPE: 2 IN. SCH. 40 PVC FLUSH JOINT FILTER PACK MATERIAL:NO. 2 FILTER SAND DEVELOPMENT: SUBMERSIBLE PUMP

CONTRACT NO.: 08330106 DATE WATER LEVEL OBTAINED: 12-1-08 DATE INSTALLED: 11-26-08 DATE DEVELOPED: 12-1-08



CONSTRUCTION DETAILS FOR MONITORING WELL MW-2

BORING NUMBER: MW-2 SCREEN SIZE AND TYPE: 10 FT, NO. 10 SLOT PVC CASING SIZE AND TYPE: 2 IN. SCH. 40 PVC FLUSH JOINT FILTER PACK MATERIAL:NO. 2 FILTER SAND DEVELOPMENT: SUBMERSIBLE PUMP

CONTRACT NO.: 08330106 DATE WATER LEVEL OBTAINED:12-1-08 DATE INSTALLED: 11-25 & 26-08 DATE DEVELOPED: 12-1-08



APPENDIX B

Laboratory Analytical Chemical Data

Certificates of Analysis and Chains of Custody

1204 MURRAY DRIVE



Improving the environment, one client at a time...

225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: www.reiclabs.com

January 22, 2009

Mr. Russell Rountree SCHNABEL ENGINEERING SOUTH LLC 300 ED WRIGHT LN SUITE 1 NEWPORT NEWS VA 23606

TEL: (757) 947-1220 FAX (757) 947-1220

RE: 08330106

Dear Mr. Russell Rountree:

Order No.: 0812H90

REI Consultants, Inc. received 1 sample(s) on 12/23/2008 for the analyses presented in the following report.

Please note two changes you may see on your report.

- Results for "Dissolved" parameters will be shown under a separate sample ID, rather than as a separate analysis under the same sample ID. The sample ID for "Dissolved" parameters will include "Field Filtered" or "Lab Filtered", as appropriate.
- Metals results will no longer be identified as "Total" or "Total Recoverable". The methods have not been changed, only their appearance on the report.

If you have any questions regarding these results, please do not hesitate to call.

Sincerely,

ine c Mar

Scott Gross Project Manager





improving the environment, one client at a time ...

225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: www.reiclabs.com

| | D | 00 | | WO#: | 0812H90 |
|------------------|-------------------|-------------|---------|-------|-----------|
| Report Narrative | Project Manager:: | Scott Gross | nor Man | Date: | 1/22/2009 |

CLIENT: SCHNABEL ENGINEERING SOUTH LL Project: 08330106

All analyses were performed using documented laboratory SOPs that incorporate appropriate quality control procedures as described in the applicable methods. REI Consultants, Inc. (REIC) technical managers have verified compliance of reported results with the REIC's Quality Program and SOPs, except as noted in this case narrative. Any deviation from compliance is explained below and/or identified within the body of this report by a qualifier footnote which is defined at the bottom of each page.

All samples were analyzed using the methods stated in the analytical report without modification, unless otherwise noted.

All sample results are reported on an "as-received" wet weight basis unless otherwise noted.

Results reported for sums of individual parameters, such as Total Trihalomethanes (TTHM) and Total Haloacetic Acids (HAA5), may vary slightly from the sum of the individual parameter results. This apparent anomaly is caused by rounding individual results and summations at reporting, as required by EPA.

Following standard laboratory protocol, sample preservation, such as pH, is verified at time of extraction or analysis based on client requested parameters. Improper preservation is noted on the analytical bench sheet, extraction log, or preservation log and client is notified by close of following business day. All results are reported using preservation compliant samples unless otherwise noted in the analytical report.

The test results in this report meet all NELAP requirements for parameters for which accreditations are required or available. Any exceptions are noted in this report. This report may not be reproduced, except in full, without the written approval of REIC.

In compliance with federal guidelines and standard operating procedures, all reports, including raw data and supporting quality control, will be disposed of after five years unless otherwise arranged by the client via written notification or contract requirement.

If you have any questions please contact the project manager whose name is listed above.

REI Consultants, Inc.

Analytical Results

Date: 02-Feb-09

CLIENT: SCHNABEL ENGINEERING SOUTH LLC

Client Sample ID: 1204 MURRAY DRIVE Project: 08330106

Site ID: BATTLEFIELD GOLF CLUB

WorkOrder: 0812H90 Lab ID 0812H90-01A DateReceived 12/23/2008 Collection Date: 12/22/2008 4:45:00 PM Matrix: DRINKING WATER

| Anal | yses | | Result | Units | | Qual | PQL | MCL | Prep Date | Date Analyzed |
|-------|----------|-------------------------------|--------------|-------|-----------|-------------|-------------------|---------------|----------------------|------------------------|
| MET | ALS BY | (ICP | | | E20 | 0.7 | | | Analyst: Bl | |
| Alur | ninum | | 0.188 | mg/L | | | 0.100 | 0.200 | 12/24/08 12:16 | PM 12/31/08 12:27 AM |
| Bor | nc | | 0.163 | mg/L | | | 0.100 | NA | 12/24/08 12:16 | PM 12/31/08 12:27 AM |
| Iron | | | 0.184 | mg/L | | | 0.100 | 0.300 | 12/24/08 12:16 | PM 12/31/08 12:27 AM |
| Mag | nesium | | 18.8 | mg/L | | | 0.500 | NA | 12/24/08 12:16 | PM 12/31/08 12:27 AM |
| Mar | iganese | | ND | mg/L | | | 0.050 | 0.050 | 12/24/08 12:16 | PM 12/31/08 12:27 AM |
| Silic | a (as Si | 02) | 19.2 | mg/L | | | 0.210 | NA | 12/24/08 12:16 | PM 12/29/08 2:46 PM |
| Sod | ium | | 106 | mg/L | | | 0.500 | NA | 12/24/08 12:16 | PM 12/31/08 12:27 AM |
| MET/ | ALS BY | ICP-MS | | | E20 | 0.8 | | | Analyst: Bl | M |
| Anti | mony | | ND | mg/L | | | 0.0010 | 0.0060 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Arse | enic | | ND | mg/L | | | 0.0050 | 0.0100 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Bari | um | | ND | mg/L | | | 0.100 | 2.00 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Вегу | rilium | | ND | mg/L | | | 0.0020 | 0.0040 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Cad | mium | | ND | mg/L | | | 0.0010 | 0.0050 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Chro | mium | | 0.0052 | mg/L | | | 0.0050 | 0.100 | 12/24/08 12:16 | FM 12/29/08 4:01 PM |
| Cob | əlt | | ND | mg/L | | | 0.100 | NA | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Cop | per | | ND | mg/L | | | 0.0500 | 1.30 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Lead | \$ | | ND | mg/L | | | 0.0050 | 0.0150 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Moly | bdenum | 1 | ND | mg/L | | | 0.100 | NA | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Nick | el | | ND | mg/L | | | 0.0100 | 0.100 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Sele | nium | | ND | mg/L | | | 0.0050 | 0.0500 | 12/24/08 12:16 | PM 12/29/08 4:01 PM |
| Silve | r | | ND | mg/L | | | 0.0500 | NA | 12/24/08 12:16 | 9 PM 12/29/08 4:01 PM |
| Thal | lium | | ND | mg/L | | | 0.0010 | 0.0020 | 12/24/08 12:16 | SPM 12/29/08 4:01 PM |
| Vana | adium | | ND | mg/L | | | 0.0500 | NA | 12/24/08 12:16 | 9 PM 12/29/08 4:01 PM |
| Zinc | | | 0.0151 | mg/L | | | 0.0100 | 5.00 | 12/24/08 12:16 | 9 PM 12/29/08 4:01 PM |
| HARD | NESS, | CALCIUM | | | SM23 | 40 B | | | Analyst: B | þ |
| Hard | ness, C | alcíum (As CaCO3) | 67.4 | mg/L | | | 1.00 | NA | | 12/31/08 12:27 AM |
| HARD | NESS | | | | SM23 | 40 B | | | Analyst: B | Р |
| Hard | ness, To | otal (As CaCO3) | 145 | mg/L | | | 1.00 | NA | 12/24/08 12:16 | 3 PM 12/31/08 12:27 AM |
| MERC | URY, 1 | FOTAL. | | | E24 | 5.1 | | | Analyst: C | GW |
| Merc | ury | | ND | mg/L | | | 0.0010 | 0.0020 | 12/24/08 12:08 | 3 PM 12/30/08 10:49 AM |
| РСВ | | | | | E50 |)5 | | | Analyst: S | ub |
| Aroc | or 1016 | | See Attached | | | | NA | NA | | |
| Aroci | or 1221 | | See Attached | | | | NA | NA | | |
| Aroci | or 1232 | | See Attached | | | | NA | NA | | |
| Aroci | or 1242 | | See Attached | | | | NA | NA | | |
| Arocl | or 1248 | | See Attached | | | | NA | NA | | |
| Key: | MCL | Maximum Contaminant Level | | Qual | ifiers: B | Analyte de | tected in the ass | ociated Met | hod Blank | |
| | MDL | Minimum Detection Limit | | | E | Estimated | Value above qu | antitation ra | nge | |
| | NA | Not Applicable | | | Н | Holding tir | mes for preparat | ion or analy | sis exceeded | |
| | ND | Not Detected at the PQL or Mi | DL | | S | Spike/Surr | ogate Recovery | outside acce | epted recovery limit | |

PQL Practical Quantitation Limit

* Value exceeds Maximum Contaminant Level

Page 2 of 5

TIC Tentatively Identified Compound, Estimated Concentrati
| REI Consulta | nts, Inc. | Analytical | Results | Date: 02 | ?-Feb-09 | | | | | |
|-------------------------|---------------|-----------------|---------|--|----------|------------------|-------------------|--|--|--|
| CLIENT: S | CHNABEL ENG | GINEERING SOUTH | LLC | WorkOrder | : 081 | 2H90 Lab ID | 0812H90-01A | | | |
| Client Sample ID: 1 | 204 MURRAY I | DRIVE | | DateReceive | d 12/ | 23/2008 | | | | |
| Project: () | 8330106 | | | Collection Date: 12/22/2008 4:45:00 PM | | | | | | |
| Sita ID: B | ATTI SEIGI DA | | | Matrix | | INVING WATER | > | | | |
| Site iD. | | | | | DK | | ` | | | |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed | | | |
| РСВ | | | E505 | | | Analyst: Sub | ÷ | | | |
| Aroclor 1254 | | See Attached | | NA | NA | | | | | |
| Aroclor 1260 | | See Attached | | NA | NA | | | | | |
| Chlordane | | See Attached | | NA | NA | | | | | |
| Toxaphene | | See Attached | | NA | NA | | | | | |
| EMIVOLATILE ORG | GANIC COMPOL | INDS | E525.2 | | | Analyst: Sub | 1 | | | |
| Alachlor | | See Attached | | NA | NA | | | | | |
| Atrazine | | See Attached | | NA | NA | | | | | |
| Benzo(a)pyrene | | See Attached | | NA | NA | | | | | |
| Di(2-ethylhexyl)adipate | ; | See Attached | | NA | NA | | | | | |
| Di(2-ethylhexyl)phthala | ate | See Attached | | NA | NA | | | | | |
| Endrin | | See Attached | | NA | NA | | | | | |
| gamma-BHC | | See Attached | | NA | NA | | | | | |
| Heptachlor | | See Attached | | NA | NA | | | | | |
| Heptachlor epoxide | | See Attached | | NA | NA | | | | | |
| Hexachlorobenzene | | See Attached | | NA | NA | | | | | |
| Hexachlorocyclopenta | diene | See Attached | | NA | NA | | | | | |
| Methoxychlor | | See Attached | | NA | NA | | | | | |
| Simazine | | See Attached | | NA | NA | | | | | |
| ARBAMATES 531.1 | l | | E531.1 | | | Analyst: Sul | 3 | | | |
| Aldicarb | | See Attached | | NA | NA | | | | | |
| Aldicarb sulfone | | See Attached | | NA | NA | | | | | |
| Aldicarb sulfoxide | | See Attached | | NA | NA | | | | | |
| Carbofuran | | See Attached | | NA | NA | | | | | |
| Oxamyl | | See Attached | | NA | NA | | | | | |
| LYPHOSATE 547 | | | E547 | | | Analyst: Sul | 2 | | | |
| Glyphosate | | See Attached | | NA | NA | | | | | |
| NDOTHALL 548.1 | | | E548.1 | | | Analyst: Sul | b | | | |
| Endothall | | See Attached | | NA | NA | | | | | |
| IQUAT 549.2 | | | E549.2 | | | Analyst: Sul | 5 | | | |
| Diquat | | See Attached | | NA | NA | | | | | |
| IOXIN | | | SW8280 | | | Analyst: Sul | b | | | |
| 2,3,7,8-TCDD | | See Attached | | NA | NA | | | | | |
| EMIVOLATILE ORG | ANIC COMPOU | NDS BY EPA | E504.1 | | | Analyst: JG | | | | |
| 1.2-Dibromo-3-chloropr | opane | ND mg/L | | 0.000020 0 | .000200 | 01/02/09 1:30 Pl | M 01/02/09 5:53 F | | | |

Date: 02-Feb-09

| Key: | MCL | Maximum Contaminant Level Q |)ualifiers: | в | Analyte detected in the associated Method Blank | |
|------|-----|--|-------------|---|--|-------------|
| | MDL | Minimum Detection Limit | | Е | Estimated Value above quantitation range | |
| | NA. | Not Applicable | | Н | Holding times for preparation or analysis exceeded | |
| | ND | Not Detected at the PQL or MDL | | S | Spike/Surrogate Recovery outside accepted recovery | y limit |
| | PQL | Practical Quantitation Limit | | ٠ | Value exceeds Maximum Contaminant Level | Page 3 of 5 |
| | TIC | Tentatively Identified Compound, Estimated Concent | rati | | | |

| REI Consul | tants, Inc. | Analytical I | Results | Date: 02-Feb-09 | | | | | | | |
|---------------------|------------------|-----------------|-------------|-----------------|-----------|---------------------|-------------------|--|--|--|--|
| CLIENT: | SCHNABEL EN | GINEERING SOUTH | LLC | WorkOrde | er: 08 | 12H90 Lab ID | 0812H90-01A | | | | |
| Client Sample ID | : 1204 MURRAY | DRIVE | | DateReceiv | ved 12/ | 23/2008 | | | | | |
| Project: | 08330106 | | | Collection | Date: 12/ | /22/2008 4:45:00 PI | M | | | | |
| Site ID: | BATTLEFIELD | GOLF CLUB | | Matrix: | DR | INKING WATER | | | | | |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed | | | | |
| SEMIVOLATILE (| ORGANIC COMPO | UNDS BY EPA | E504.1 | | | Analyst: JG | | | | | |
| 1,2-Dibromoethan | e | ND mg/L | | 0.000020 | 0.000050 | 01/02/09 1:30 PM | 01/02/09 5:53 PM | | | | |
| SEMIVOLATILE (| ORGANIC COMPO | UNDS | F515.1 | | | Analyst: JG | | | | | |
| 2,4,5-TP (Silvex) | | ND ma/L | 201011 | 0.000608 | 0.0500 | 12/23/08 2:00 PM | 12/30/08 12:00 AM | | | | |
| 2,4-D | | ND mg/L | | 0.000122 | 0.0700 | 12/23/08 2:00 PM | 12/30/08 12:00 AM | | | | |
| Dalapon | | ND mg/L | | 0.00790 | 0.200 | 12/23/08 2:00 PM | 12/30/08 12:00 AM | | | | |
| Dinoseb | | ND mg/L | | 0.000122 | 0.00700 | 12/23/08 2:00 PM | 12/30/08 12:00 AM | | | | |
| Pentachloropheno | I | ND mg/L | | 0.000608 | 0.00100 | 12/23/08 2:00 PM | 12/30/08 12:00 AM | | | | |
| Picloram | | ND mg/L | | 0.000608 | 0.500 | 12/23/08 2:00 PM | 12/30/08 12:00 AM | | | | |
| VOLATILE ORGA | | 6 | E524.2 | | | Analyst: SDG | | | | | |
| Benzene | | ND µg/L | | 1.0 | 5.0 | | 12/30/08 1:37 PM | | | | |
| Carbon tetrachloric | te | ND µg/L | | 1.0 | 5.0 | | 12/30/08 1:37 PM | | | | |
| 1,2-Dichiorobenzei | ne | ND µg/L | | 1.0 | 600 | | 12/30/08 1:37 PM | | | | |
| 1,4-Dichlorobenzei | ne | ND µg/L | | 1.0 | 75.0 | | 12/30/08 1:37 PM | | | | |
| 1,2-Dichloroethane | ÷ | ND µg/L | | 1.0 | 5.0 | | 12/30/08 1:37 PM | | | | |
| 1,1-Dichloroethene | ; | ND µg/L | | 1.0 | 7.0 | | 12/30/08 1:37 PM | | | | |
| cis-1,2-Dichloroeth | ene | ND µg/L | | 1.0 | 70.0 | | 12/30/08 1:37 PM | | | | |
| trans-1,2-Dichloroe | ethene | ND µg/L | | 1.0 | 100 | | 12/30/08 1:37 PM | | | | |
| 1,2-Dichloropropan | ne | ND µg/L | | 1.0 | 5.0 | | 12/30/08 1:37 PM | | | | |
| Ethylbenzene | | ND µg/L | | 1.0 | 700 | | 12/30/08 1:37 PM | | | | |
| Methylene chloride | | ND µg/L | | 1.0 | 5.0 | | 12/30/08 1:37 PM | | | | |
| Styrene | | ND µg/L | | 1.0 | 100 | | 12/30/08 1:37 PM | | | | |
| Tetrachloroethene | | ND µg/L | | 1.0 | 5.0 | | 12/30/08 1:37 PM | | | | |
| Surr: 1,2-Dichlor | obenzene-d4 | 80.1 %REC | | 75-125 | NA | | 12/30/08 1:37 PM | | | | |
| Surr: 4-Bromoflu | iorobenzene | 85.0 %REC | | 75-125 | NA | | 12/30/08 1:37 PM | | | | |
| RESIDUAL CHLO | RINE - LAB TEST, | HOLD TIME E | SM4500-CL-G | | | Analyst: CC | | | | | |
| Chlorine, Total Res | sidual | ND µg/L | | 100 | NA | | 12/24/08 10:00 AM | | | | |
| TURBIDITY | | | SM2130 B | | | Analyst: CC | | | | | |
| Turbidity | | 0.65 NTU | * | 0.50 | 0.50 | | 12/24/08 9:30 AM | | | | |
| COLIFORM BY P/ | A | | SM9223 B | | | Analyst: CC | | | | | |
| Fecal Coliform | | ABSENT NA | | NA | NA | 12/23/08 2:15 PM | 12/24/08 2:15 PM | | | | |
| Total Coliform | | ABSENT NA | | NA | NA | 12/23/08 2:15 PM | 12/24/08 2:15 PM | | | | |
| CYANIDE | | | E335.4 | | | Analyst: BA | | | | | |
| Cyanide, Total | | ND mg/L | | 0.020 | NA | | 12/24/08 9:00 AM | | | | |

| Key: | MCL | Maximum Contaminant Level Qua | alifiers: | В | Analyte detected in the associated Method Blank |
|------|-----|--|-----------|---|--|
| | MDL | Minimum Detection Limit | | E | Estimated Value above quantitation range |
| | NA | Not Applicable | | Н | Holding times for preparation or analysis exceeded |
| | ND | Not Detected at the PQL or MDL | | S | Spike/Surrogate Recovery outside accepted recovery limit |
| | PQL | Practical Quantitation Limit | | * | Value exceeds Maximum Contaminant Level Page 4 of 5 |
| | TIC | Tentatively Identified Compound, Estimated Concentration | i | | |

| CLIENT: | SCHNABEL ENGINE | ERING SOUTH L | LC | WorkOrder | . 081 | 2H90 Lab ID | 0812H90-01A |
|----------------------|----------------------|---------------|-------------|--------------|----------------|-----------------|-------------------|
| Client Sample | ID: 1204 MURRAY DRIV | /E | | DateReceive | e d 12/ | 23/2008 | |
| Project: | 08330106 | | | Collection E | Date: 12/ | 22/2008 4:45:00 | PM |
| Site ID: | BATTLEFIELD GOL | F CLUB | | Matrix: | DR | INKING WATE | R |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed |
| ANIONS BY IC | N CHROMATOGRAPHY | | E300.0 | | | Analyst: CV | v |
| Chloride | | 136 mg/L | | 10.0 | 250 | | 12/29/08 6:39 PM |
| Fluoride | | 0.46 mg/L | | 0.20 | 4.00 | | 12/29/08 6:39 PM |
| Sulfate | | 13.9 mg/L | | 5.00 | 250 | | 12/29/08 6:39 PM |
| ANIONS BY IO | N CHROMATOGRAPHY | | E300.0 | | | Analyst: CV | V |
| Nitrogen, Nitrat | e-Nitrite | ND mg/L | | 0.10 | 10.0 | | 01/01/09 8:42 AM |
| TOTAL DISSO | LVED SOLIDS | | SM2540 C | | | Analyst: DS | A |
| Total Dissolved | l Solids | 401 mg/L | | 1 | 500 | | 12/23/08 6:05 PM |
| ALKALINITY | | | SM2320 B | | | Analyst: DS | A |
| Alkalinity, Total | (As CaCO3) | 162 mg/L | | 1.0 | NĂ | | 12/23/08 3:06 PM |
| CORROSIVITY | , LANGELIER INDEX | | SM2330 B | | | Analyst: IL | |
| Langelier Index | | 0.14 at 20 °C | | NA | NA | | 01/05/09 12:00 AM |
| PH - LAB TEST | I, HOLD TIME EXPIRED | | SM4500-H+-B | | | Analyst: DS | SA |
| рН | | 8.07 SU | | NA | NA | | 12/23/08 3:06 PM |
| | BON, TOTAL | | SM5310 C | | | Analyst: DS | SA |
| Total Organic C | arbon | 1.45 mg/L | | 1.00 | NA | · | 12/24/08 7:12 AM |
| | | | | | | | |

Analytical Results

Date: 02-Feb-09

| Key: | MCL | Maximum Contaminant Level | Qualifiers: | В | Analyte detected in the associated Method Blank | |
|------|-----|---------------------------|-------------|---|---|--|
| | MDL | Minimum Detection Limit | | Ε | Estimated Value above quantitation range | |

NA Not Applicable

REI Consultants, Inc.

ND Not Detected at the PQL or MDL

PQL Practical Quantitation Limit

٠

H Holding times for preparation or analysis exceeded s Spike/Surrogate Recovery outside accepted recovery limit

Page 5 of 5 Value exceeds Maximum Contaminant Level

TIC Tentatively Identified Compound, Estimated Concentrati



REI Consultants, Inc. 225 Industrial Park Rd. P.O. Box 286, Beaver, WV 25813 Phone: 304-255-2500 or 800-999-0105 FAX: 304-255-2572 e-mail: rlabs@reiclabs.com

| CLIENT: Schnabel Engineering |
|---------------------------------------|
| ADDRESS: 300 Ed Wrightlame, Suites |
| CITY/STATE/ZIP: Noupur News, VA 23606 |
| BILL TO: Same |
| CITY/STATE/ZIP: |
| PURCHASE ORDER # |
| QUOTE # |

CHAIN OF CUSTODY RECORD NO. 263754 CONTACT PERSON: <u>Lusicall</u> Romtrice TELEPHONE #: (757)947-1720 3606 FAX #: (757)947-1725 E-MAIL ADDRESS: <u>Womtrice@-schnabel-ong.cm</u> SITE ID & STATE: <u>Bastehold Golf Club Water Project</u> PROJECT ID: 08330106 SAMPLER: <u>Russell Romtrice</u>

| | | | | | | | | | | | _ | _ | | | | PF | RESE | RVAT | IVE (| CODE | S | | | |
|------------------------------|-------------------------|------------------------|------------------|---------------|----------|-------|---------|----------|----------|-------------|--------|----------------|-----|-----|------|---------|------|------------------|-------|------------|-------------|-------|-------|-----------|
| | TURNARC | UND TIME | PRES | SERVATIVES | NOTE PI | RESER | RVATIVE | ES ->> | 14 | J.d. | 1 | 4 | | | | | | 1 | | | | | | |
| | REQUIR | EMENTS | 0 No | Preservative | i. | | / | 21 | 1 | 2 | 5 | r , | / , | / | / | / | / | / | / | / / | / / | / | | |
| SAMPLE LOG | REGULAR: | | 1 Hy | drochloric Ad | cicl | | 1 | 02/ | 5 | 5/ | 00 | W | / | / | 1 | 1 | 1 | / / | / | / | / | / | | |
| 1 | *RUSH: | 5-Day | 2 Nit | tric Acid | | | Se Ante | 1 | 4 | 100 | * 7 | 19 | / | / | / | / | / | / | / | / | / / | | | |
| AND | | 3-Day | 3 Su | furic Acid | | / | 2 | Y | F | 5 | 3/ | / | / | / | / | 1 | / / | / / | / | / / | / | | | |
| | | 2-Day | 4 So | dium Thiosul | fate | 1 | 3/1 | W r | Y at | 7-8 | ¥ | / | / | / | / | / | / | / | / | / | / | | | |
| ANALYSIS REQUEST | | 1-Day | 5 So | dium Hydroxi | ide / | 3 | N | J | de la | U. | / | / | / / | 1 | () | / , | / | / / | / / | / / | (| | | |
| | *Rush work needs prior | Laboratory approval an | 6 Zir | nc Acetate | 1 | 3/0 | */ | 5/ 1 | 1 | 5/ | / | / | / | / | / | / | / | / | / | / | | | | |
| | will include surcharges | | 7 EC | ATC | AME | 10 | 12 | 5 | Je la | 2 | / / | | / , | / | | / | / | /) | / | / | | | | |
| | NO. & TYPE OF | SAMPLING | | SAMPLE | | N. | 17 | ¥. | y . | 27 | / | / | / | / | / | / | / | ' / | / | | | | | |
| SAMPLE ID | CONTAINERS | DATE / TIME | MATRIX | COMP / GRA | B / V | 9/10 | 14 | 1.54 | A | 7 | | / | / | / | / | / | / | / | / | | 0 | COMME | NTS | |
| 1204 MURRAY DRIVE | 20 | 12-22-08 | W | 6 | | 1 | / | 1 | 1 | | | | | | | | | | | | | | | |
| | | | | | | 4 | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | - | XE | ser | atta | eled | |
| | | | | | | | | | | | | | | | | | | | | au | nah | sir 0 | avan | netus |
| | | | | | | | | | | | | | | | | | | | | Su | mn | ary | | |
| | | | | | | | | | | | | | | | | | | | | 31 | | 1 | | |
| | | | | | | | | 1 | N | | | | | | | | | | | | | | | |
| | | | | | | | | | 1 | - | - | - 1 | VO | A | st | res | to | 5 | zer | - 0 | lie | nt. | | 4 |
| Λ | | | _ | | | | | | | | | | | | | | | 0 | | | A | 7 1. | 2/2 | 3/08 |
| Martil K | 12/22/08 | 17 | 60.00000000 | | 12-23 | - | | | | an reaction | | and the second | | | 1 | | | alde satisfiered | | | | | | |
| Relinquished by: (Signature) | Date/Time | Receiva | ed by: (Signatur | e) | Date/Tim | 10 | | B | elinquis | hed by: | (Signa | ture) | | | Da | te/Time | | | R | leceived l | by: (Signat | ure) | | Date/Time |
| Relinquished by: (Signature) | Date/Time | Receive | ed by: (Signatur | e) | Date/Tin | ne . | Tempera | ture Upo | Arriva | 1 | °C | | | FAX | (Re | esu | lts | | | | A | Emai | l Res | ults |
| | | | | | h | - 20 | de | - | | | | | | | | | | | | | 1 | | | |



www.pacelabs.com

Report Prepared for:

Scott Gross REI Consultants, Inc. 225 Industrial Park Dr. Beaver WV 25813

REPORT OF LABORATORY ANALYSIS FOR 2,3,7,8-TCDD

Report Summary:

Enclosed are analytical results of one drinking water sample analyzed for 2,3,7,8-TCDD content. This sample was analyzed according to Method 1613B by High Resolution Gas Chromatography/High Resolution Mass Spectrometry.

The results reported for this sample and the associated quality control samples were all within the criteria described in Method 1613B; with the exception of a blank internal standard recovery below the target range for the method. If you have any questions or concerns regarding these results, please contact Nate Habte, your Pace Project Manager.

Report Prepared Date: January 12, 2009 Pace Analytical Services, Inc. 1700 Elm Street Minneapolis, MN 55414 Phone: 612.607.1700 Fax: 612.607.6444

Report Information:

Pace Project #: 1087001 Sample Receipt Date: 12/30/2008 Client Project #: 0812H90 Client Sub PO #: N/A State Cert #: 9952C

Invoicing & Reporting Options:

The report provided has been invoiced as a Level 2 Drinking Water Report. If an upgrade of this report package is requested, an additional charge may be applied.

Please review the attached invoice for accuracy and forward any questions to Nate Habte, your Pace Project Manager.

This report has been reviewed and prepared by:

For Nate Habte

Nate Habte, Project Manager (612) 607-6407 (612) 607-6444 (fax) natnael.habte@pacelabs.com



Report of Laboratory Analysis

This report should not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc.

The results relate only to the samples included in this report.

| TEL: | 304.255,2500 | F | AX: 304.255.257 | 2 | | · · · · · | | | ÷ | |
|--------------------------|---|----------------------------|-----------------------|---------------------------------------|------------------|------------------|---------------------------------------|--|----------|------------------|
| | | | • • | | | • | | ۰ ۰ | | |
| Subcor P/ 17 Mi | ntractor: ACE ANALYTICA 700 Elm St. Suite inneapolis, MN 5 | AL SERVICES 200 5414 | INC. 7 | TEL: (919) 596-193 FAX: Acct #: | 35 | | | · · · · · · · · · · · · · · · · · · · | | 23-Dec-08 |
| | | | | | | | | Requested Tests | | |
| . S | ample ID | Matrix | Date Collected | Bottle Type | SW8280 | | ······ | <u> </u> | | |
| 08 | 12H90-01A | Onnking Water | 12/22/2008 4:45:00 | PIALS, PLASTIC, GLA | | I | · · · · · | <u> </u> | | |
| · . | | | | | 237 | F. TCO | n D | • . • | · | |
| | •. | | | | | - | • | | | |
| | | | | | • | · · · · · | | 1 | | |
| | | | · · · · · | | | | | | | |
| | | | | · | • | | | · · · · · | | |
| | · · · | · | - °, | • | ·· · | · · · | • • | | | |
| | 1 - A Contract | | | | | | | | | |
| · · · | | | | | | | · · | | | |
| | | • | · . | | · · | | - | | | |
| а 2 т | · · · | | | | | | | | | |
| | • | | · | | | | • | | | |
| · • • • • • | • • | | | | | · · · | | | | |
| Ge | neralComments: | State Cod | ie: VA | | . <u>.</u> | | | | <u> </u> | |
| | | After anal | ysis, the samples don | ot need to be returned ar | no can be dispos | ed per your stan | dard laborato | ry practices. | | |
| | | خ ا | the state | er en er | | ~ / | | • | | |
| | | . W | Method | 1615 per s | COTT G. | (2) (2-1 | 30/08 | <u>. </u> | | |
| , | | <u> </u> | | · · · · · · · · · · · · · · · · · · · | | · · · · | · · · · · · · · · · · · · · · · · · · | · · · | | Date/Time |
| | | • 1 | 1 | Da | te/1 me | | | | | - Water I have |
| | | | ¥ . | in Inter | Le - Mar | Berning L | | PI | | 7.43 |
| Re | linguished by | - 7/ | 1 | I CILL | 103 8 10 | Received by | γ: <u>Λ</u> | A | | |

Report No.....1087001_1613DW

| | Sample Condition Upon Recei | 30 |
|--|---|---|
| Face Analytical Client Na | me: <u>REI</u> | Project # /278 7007 |
| Courier: Fed Ex UPS USPS Tracking #: 12 26x 71313(| Client Commercial Pace Other 2 03 27 /es 2 no Seals intact: yes | Sptional Broj. Due Date: Proj. Name: |
| Packing Waterial: Bubble Wrap | ble Bags [] None [] Other | Temp Blank: Yes NO |
| Inermometer Used 80344042, 179425 | Type of ice: Wel Blue None | Date and initials of person examini |
| Cooler Temperature 2.02 | Biological Lissue is Frozen: Yes No | contents: 2/30/0881 |
| Chain of Clistody Present: | Edea Chua Chua Ia | |
| Chain of Custody Filled Out | | |
| Chain of Custody Pallaquished | | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, |
| Sampler Name & Signature on COC | CLITES LINE LINA S. | <u></u> |
| Samples Arrived within Hold Time | ETTAS EINO LINA 14. | n an |
| Short Hold Time Analyzie (<72br) | | |
| Buch Turn Around Time Desugged | | <u></u> |
| Sufficient Volume: | | ₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩ |
| Correct Containers Lloed | | والمواد المحال والمحال والمحال والمحالية والمحالية والمحال والمحال والمحال والمحال والمحال والمحال والمحال والم |
| "Pace Containers Used | | |
| Costainers infact | | , |
| Fillered volume received for Dissolved tests | | المعادين المحمد والمعارية والمعارية والمعارية والمعارية والمعارية والمعارية والمعارية والمعارية والمعارية والم |
| Sample Labels match COC: | Pixes DNo DN/A 12 | <u></u> |
| Includes date/time/ID/Analysis Matrix: | WT | |
| All containers needing acid/base preservation have been | DYAS DINA 13 | n - |
| Checked. Noncompliance are noted in 13. All containers needing preservation are found to be in compliance with EPA recommendation. | DYES CINO DNIA | |
| Exceptions: VOA,Coliform, TOC, Oli and Grease, Wi-DRO (water) | □Yes DNo Initial when completed | Lot # of added preservative |
| Samples checked for dechlorination: | Dyes ONO DNA 14. | |
| Headspace in VOA Vials (>6mm): | DYOS DNO DNA 15. | 0.95.41 II 19-19-19-19-19-19-19-19-19-19-19-19-19-1 |
| Trip Blank Present: | CIYes DNO DN/A 16. | |
| Trip Blank Custody Seals Present | | |
| Paœ Trip Blank Lot # (if purchased): | | ariyaya waxaya ay aray ay bahayayaya yawaa karaya baya ayaa, bi daba a baya waxaa ay |
| Hent Notification/ Resolution: Person Contacted: Comments/ Resolution: | Date/Time: | Field Data Required? Y / N |
| | | |
| Project Manager Review: | | Dato: 12/30/08 |

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Report Noof hold 08700 arest and of temp, incorrect containers)



Pace AnalyticalServices, Inc. 1700 Elm Street - Suite 200 Minneapolis, MN 55414

Drinking Water Analysis Results 2,3,7,8-TCDD -- USEPA Method 1613B

Tel: 612-607-1700 Fax: 612-607-6444

Sample ID.....0812H90-01A

Client......REI Consultants, Inc. Lab Sample ID....1087001001

Date Collected 12/22/2008 Date Received 12/30/2008 Date Extracted.....01/05/2009

| | Sample 0812H90-01A | Method Blank | Lab Spike | Lab Spike Dup |
|-----------------------|-----------------------|-----------------|--------------|------------------|
| [2,3,7,8-TCDD] | ND | ND | | |
| RL | 5 pg/L | 5 pg/L | aa 10 | ** |
| 2,3,7,8-TCDD Recovery | | | 99% | 102% |
| Spike Recovery Limit | | | 73-146% | 73-146% |
| RPD | | | 2. | 8% |
| IS Recovery | 70% | 30% ! | 75% | 64% |
| IS Recovery Limits | 31-137% | 31-137% | 25-141% | 25-141% |
| CS Recovery | 85% | 77% | 96% | 83% |
| CS Recovery Limits | 42-164% | 42-164% | 37-158% | 37-158% |
| Filename | R90106A17 | R90106A05 | R90106A03 | R90106A04 |
| Analysis Date | 01/06/2009 | 01/06/2009 | 01/06/2009 | 01/06/2009 |
| Analysis Time | 16:06 | 10:24 | 09:27 | 09:53 |
| Analyst | SMT | SMT | SMT | SMT |
| Volume | 0.963L | 0.900L | 0.907L | 0.913L |
| Dilution | NA | NA | NA | NA |
| ICAL Date | 12/31/2008 | 12/31/2008 | 12/31/2008 | 12/31/2008 |
| CCAL Filename | R90106A02 | R90106A02 | R90106A02 | R90106A02 |

ţ = Outside the Control Limits

ND = Not Detected

hey and M. Chora Analyst:

RL = Reporting Limit

Limits = Control Limits from Method 1613 (10/94 Revision), Tables 6A and 7A

- = Relative Percent Difference of Lab Spike Recoveries RPD
- IS

= Internal Standard [2,3,7,8-TCDD-¹³C] = Cleanup Standard [2,3,7,8-TCDD-³⁷Cl] CS



the standard in safety

Underwriters Laboratories

LABORATORY REPORT

This report contains pages. (including the cover page)

If you have any questions concerning this report, please do not hesitate to call us at (800) 332-4345 or (574) 233-4777.

This report may not be reproduced, except in full, without written approval from Underwriters Laboratories Inc. (UL).

Underwitters Laboratories Inc. 110 S. Hill Street, South Bond, 10 46817-2702 USA 7:: 600 332:43457 Pr: 574:233:82077 Wi: II com

UL-SBN-REP-F-007-01

Effective Date: October 6, 2008

(cover) Page 1 of 1



218270

Final

Standard Written

Not Supplied

Laboratory Report

Report:

Priority:

Status:

PWS ID:

Attn: Joy Mullins 225 Airport Industrial Park Road P.O. Box 286 Beaver, WV 25813

Copies

to: None

| | Sampl | e Information | | ····· | |
|------------|-------------|---------------|--------------------------|------------------|-------------------------|
| UL ID # | Client ID | Method | Collected Date / Time | Collected By: | Received Date / Time |
| 1998296 | 0812H90-01A | 505 | 12/22/08 16:45 | Client | 12/30/08 09:30 |
| 1998297 | 0812H90-01A | 525.2 | 12/22/08 16:45 | Client | 12/30/08 09:30 |
| 1998298 | 0812H90-01A | 531.1 | 12/22/08 16:45 | Client | 12/30/08 09:30 |
| 1998299 | 0812H90-01A | 547 | 12/22/08 16:45 | Client | 12/30/08 09:30 |
| 1998300 | 0812H90-01A | 548.1 | 12/22/08 16:45 | Client | 12/30/08 09:30 |
| 1998301 | 0812H90-01A | 549.2 | 12/22/08 16:45 | Client | 12/30/08 09:30 |
| 1998301 | 0812H90-01A | 549.2 | 12/22/08 16:45 | Client | 12/30/ |

Note: Sample containers, except for Method 549.2, were provided by the client.

Note: The samples submitted for Methods 548.1 and 549.2 analysis were received outside the seven day hold time. The client was notified of the situation and analysis was authorized by Scott Gross of REIC.

Note: In the Method 549.2 analysis, the diquat recovery in the MS (33%) was outside the acceptance limits of 63-97%.

Note: In the Method 525.2 analysis, the di(2-ethylhexyl)phthalate recovery in the LFB (142%) was outside the acceptance limits of 70-130%.

Note: In the Method 525.2 analysis, the di(2-ethylhexyl)phthalate recovery in the FBL (206%) was outside the acceptance limits of 50-200%.

Note: In the Method 525.2 analysis, heptachlor epoxide is not reportable in the sample submitted due to matrix interference.

Detailed quantitative results are presented on the following pages.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call Traci Chlebowski at (574) 233-4777.

Note: This report may not be reproduced, except in full, without written approval from Underwriters Laboratories (UL).

| 1 | • | AIA | • | \mathcal{O} | |
|------|----|-------|--------|---------------|---|
| Xin1 | 1. | 11.11 | there. | Y | • |
| //W | れん | LAU | UTU | 10- | - |
| | | | | | |

Authorized Signature

Client Name: REIC Report #: 218270 Project Manager

Page 1 of 2

Underwriters Laboratories Inc. 110 S. Hill Street, South Bend, IN 46617-2702 USA T:: 800.332.4345 / F:: 574.233.8207 / W:: ul.com

Sampling Point: 0812H90-01A

PWS ID: Not Supplied

ţ

_

Participa -

| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed | UL ID# |
|-----------------|---------------------------|--------|---|------|--------|--------|---------------------|----------------|-----------|
| 12674-11-2 | Aroclor 1016 | 505 | *** | 0.08 | < 0.08 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 11104-28-2 | Aroclor 1221 | 505 | | 0.19 | < 0.19 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 11141-16-5 | Aroclor 1232 | 505 | a de la Marine de la Marine | 0.23 | < 0.23 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 53469-21-9 | Aroclor 1242 | 505 | •••• | 0.26 | < 0.26 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 12672-29-6 | Aroclor 1248 | 505 | | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 11097-69-1 | Aroclor 1254 | 505 | ، سمب | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 11096-82-5 | Aroclor 1260 | 505 | and the second | 0.2 | < 0.2 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 57-74-9 | Chlordane | 505 | 2 * | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 8001-35-2 | Toxaphene | 505 | 3* | 1.0 | < 1.0 | ug/L | 12/31/08 13:50 | 12/31/08 22:07 | 1998296 |
| 15972-60-8 | | 525.2 | 2* | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 309-00-2 | Addrin Addrin | 525.2 | en de reconstruction dans Secons | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 1912-24-9 | Atrazine | 525.2 | 3* | 0.1 | < 0,1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 50-32-8 | Benzo[a]pyrene | 525.2 | 0.2 * | 0.02 | < 0.02 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 58-89-9 | gamma-BHC (Lindane) | 525.2 | 0.2 * | 0.02 | < 0.02 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 23184-66-9 | Butachior | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 60-57-1 | Dieldrín | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 103-23-1 | Di(2-ethylhexyl)adipate | 525.2 | 400 * | 0.6 | < 0.6 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 117-81-7 | Di(2-ethylhexyl)phthalate | 525.2 | 6 * | 0.6 | 0.8 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 72-20-8 | Endrín | 525.2 | 2 * | 0.01 | < 0.01 | j ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 76-44-8 | Heptachlor | 525.2 | 0.4 * | 0.04 | < 0.04 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 1998297 |
| 118-74-1 | Hexachlorobenzene | 525.2 | 1* | 0,1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 77-47-4 | Hexachlorocyclopentadiene | 525.2 | 50 * | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 72-43-5 | Methoxychlor | 525.2 | 40 * | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 51218-45-2 | Metolachlor | 525.2 | | 0.1 | < 0,1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 21087-64-9 | Metribuzin | 525.2 | | 0,1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 1918-16-7 | Propachlor | 525.2 | e | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 122-34-9 | Simazine | 525.2 | 4* | 0.07 | < 0.07 | ug/L | 12/31/08 09:30 | 12/31/08 21:08 | 199829 |
| 116-06-3 | Aldicarb | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 1646-88-4 | Aldicarb sulfone | 531.1 | | 0.7 | < 0.7 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 1646-87-3 | Aldicarb sulfoxide | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 63-25-2 | Carbaryl | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 1563-66-2 | Carbofuran | 531.1 | 40 * | 0.9 | < 0.9 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 6655-82-6 | 3-Hydroxycarbofuran | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 6752-77-5 | Methomyl | 531.1 | ن) , 140 میں اور | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 3135-22-0 | Oxamyl | 531.1 | 200 * | 1.0 | < 1.0 | ug/L | 12/31/08 08:20 | 12/31/08 18:34 | 199829 |
| 1071-83-6 | Glyphosate | 547 | 700 * | 6.0 | < 6.0 | ug/L | 12/31/08 13:00 | 01/02/09 18:55 | 199829 |
| 145-73-3 | Endothall | 548.1 | 100 * | 9.0 | < 9.0 | ug/L | 12/31/08 08:05 | 01/02/09 16:15 | 199830 |
| 85-00-7 | Diquat | 549.2 | 20 * | 0.4 | < 0.4 | ug/L | 12/31/08 08:20 | 12/31/08 13:08 | 199830 |

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

† UL has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

| | | | | سايد بالجراب المعارية المراج | | · · · · · · · · · · · · · · · · · · · | | |
|---|-----------------|----------------------------------|---------------------------|------------------------------|--|---------------------------------------|---|-------------|
| | Rea Limit Type: | : | MCL | : | SMCL | 5 | AL | |
| S | | محاد والتبر منتجع لترق بمردا وال | Contraction of the second | an and search descensions | Contraction and the state of the second state of t | a construction of property states and | د هم. الدارية، المعادية، و ي أو أو أو أرور الروار الروار إلى و | name arrive |
| | Symbol: | | * | t. | ۸ | ł. | 1 | 1 |
| | | | | | | | A REAL CONTRACTOR AND AND AN | |

170 173035

CHAIN-OF-CUSTODY RECORD

2

Page 1 of 1

) all but 549.2

2.8°C wet

REI Consultants, Inc. 225 Industrial Park Drive Beaver, WV 25813

TEL: 304.255.2500 FAX: 304.255.2572

Subcontractor:

| | | ES TEL: | (574) 233-4777 | Jav Jav | an | aq | <i>S</i> a | 21 | 8270 | |
|---------------|----------------|--------------------------|----------------|---------|--------|--------|---------------|---------|----------|-----------|
| SOUTH BEND, I | IN 46617 | Acct #: | | ,09% | 19982 | 19962 | 1998291 | 1998300 | 1998301 | 23-Dec-08 |
| | | | | | | R | equested Test | s | | |
| Sample ID | Matrix | Date Collected | Bottle Type | E505 | E525.2 | E531.1 | E547 | E548.1 | (E549.2) | |
| 0812H90-01A | Drinking Water | 12/22/2008 4:45:00 PIALS | , PLASTIC, GLA | 1 | 1 | 1 | 1 | 1_ | 1 |] |

548 + 549 roved out of HT pm 123008

General Comments: State Code: VA After analysis, the samples do not need to be returned and can be disposed per your standard laboratory practices. Date/Time Date/Time 9 25 /05 e 1600 Received by: UPS Relinquished by: 123608 0930 Vmu Received by: Relinquished by:

1208 MURRAY DRIVE



225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: www.reiclabs.com

January 22, 2009

Mr. Russell Rountree SCHNABEL ENGINEERING SOUTH LLC 300 ED WRIGHT LN SUITE 1 NEWPORT NEWS VA 23606

TEL: (757) 947-1220 FAX (757) 947-1220

RE: 08330106

Dear Mr. Russell Rountree:

Order No.: 0812H94

REI Consultants, Inc. received 1 sample(s) on 12/23/2008 for the analyses presented in the following report.

Please note two changes you may see on your report.

- Results for "Dissolved" parameters will be shown under a separate sample ID, rather than as a separate analysis under the same sample ID. The sample ID for "Dissolved" parameters will include "Field Filtered" or "Lab Filtered", as appropriate.
- Metals results will no longer be identified as "Total" or "Total Recoverable". The methods have not been changed, only their appearance on the report.

If you have any questions regarding these results, please do not hesitate to call.

Sincerely,

and the

Scott Gross Project Manager





225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: <u>www.reiclabs.com</u>

Improving the environment, one client at a time...

| יי אר אר אריש | D 1 (M | A H A | | WO#: | 0812H94 |
|------------------|-----------------------|--------------|--|-------|-----------|
| Report Narrative | Project Manager:: | Scott Gross | | Date: | 1/22/2009 |
| | | - | CONTRACTOR OF CONT | | |

CLIENT:SCHNABEL ENGINEERING SOUTH LLProject:08330106

All analyses were performed using documented laboratory SOPs that incorporate appropriate quality control procedures as described in the applicable methods. REI Consultants, Inc. (REIC) technical managers have verified compliance of reported results with the REIC's Quality Program and SOPs, except as noted in this case narrative. Any deviation from compliance is explained below and/or identified within the body of this report by a qualifier footnote which is defined at the bottom of each page.

All samples were analyzed using the methods stated in the analytical report without modification, unless otherwise noted.

All sample results are reported on an "as-received" wet weight basis unless otherwise noted.

Results reported for sums of individual parameters, such as Total Trihalomethanes (TTHM) and Total Haloacetic Acids (HAA5), may vary slightly from the sum of the individual parameter results. This apparent anomaly is caused by rounding individual results and summations at reporting, as required by EPA.

Following standard laboratory protocol, sample preservation, such as pH, is verified at time of extraction or analysis based on client requested parameters. Improper preservation is noted on the analytical bench sheet, extraction log, or preservation log and client is notified by close of following business day. All results are reported using preservation compliant samples unless otherwise noted in the analytical report.

The test results in this report meet all NELAP requirements for parameters for which accreditations are required or available. Any exceptions are noted in this report. This report may not be reproduced, except in full, without the written approval of REIC.

In compliance with federal guidelines and standard operating procedures, all reports, including raw data and supporting quality control, will be disposed of after five years unless otherwise arranged by the client via written notification or contract requirement.

If you have any questions please contact the project manager whose name is listed above.

REI Consultants, Inc.

Analytical Results

Date: 02-Feb-09

.

| CLI | ENT: | SCHNABEL ENG | JINEERING SOUTH L | LC | WorkOrde | r: 081 | 2H94 Lab II | 0812H94-01A |
|-------|---------------|--------------------------|-------------------|-----------------------------|---------------------|---------------|----------------------|----------------------|
| Clier | it Sample] | ID: 1208 MURRAY I | DRIVE | | DateReceiv | /ed 12/ | 23/2008 | |
| Proje | ect: | 08330106 | | | Collection | Date: 12/ | 22/2008 4:25:00 | PM |
| Site | íD: | BATTLEFIELD (| GOLF CLUB | | Matrix: | DR | INKING WATE | ER |
| Anal | yses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed |
| MET | ALS BY ICI | þ | | F200.7 | | ····· | Analyst: B | > |
| Alur | ninum | | 0.267 ma/L | * | 0.100 | 0.200 | 12/24/08 12:16 | PM 12/31/08 12:32 AM |
| Bor | on | | 0.111 mg/L | | 0.100 | NA | 12/24/08 12:16 | PM 12/31/08 12:32 AM |
| Iron | | | 1.79 mg/L | * | 0.100 | 0.300 | 12/24/08 12:16 | PM 12/31/08 12:32 AM |
| Mag | Inesium | | 18.9 mg/L | | 0.500 | NA | 12/24/08 12:16 | PM 12/31/08 12:32 AM |
| Man | iganese | | 0.186 mg/L | * | 0.050 | 0.050 | 12/24/08 12:16 | PM 12/31/08 12:32 AM |
| Silic | a (as SiO2) | | 27.6 ma/L | | 0.210 | NA | 12/24/08 12:16 | PM 12/29/08 2:52 PM |
| Sod | ium | | 81.1 mg/L | | 0.500 | NA | 12/24/08 12:16 | PM 12/31/08 12:32 AM |
| MET | ALS BY IC | P-MS | | E200.8 | | | Analyst: BI | M |
| Antii | mony | | ND ma/L | | 0.0010 | 0.0060 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Arse | nic | | ND ma/L | | 0.0050 | 0.0100 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Bari | um | | ND mg/L | | 0.100 | 2.00 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Bery | /lium | | ND mg/L | | 0.0020 | 0.0040 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Cad | mium | | ND mo/L | | 0.0010 | 0.0050 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Chro | mium | | 0.0071 mg/L | | 0.0050 | 0.100 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Coba | alt | | ND mg/L | | 0.100 | NA | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Сор | per | | ND mg/L | | 0.0500 | 1.30 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Lead | ł | | ND mg/L | | 0.0050 | 0.0150 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Moly | bdenum | | ND ma/L | | 0.100 | NA | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Nick | el | | ND mo/L | | 0.0100 | 0.100 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Sele | nium | | ND mg/L | | 0.0050 | 0.0500 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Silve | r | | ND mg/L | | 0.0500 | NA | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Thal | lium | | ND ma/L | | 0.0010 | 0.0020 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Vana | adium | | ND ma/L | | 0.0500 | NA | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| Zinc | | | 0.0218 mg/L | | 0.0100 | 5.00 | 12/24/08 12:16 | PM 12/29/08 4:19 PM |
| HARD | NESS, CA | LCIUM | | SM2340 B | | | Analyst: B | р |
| Hard | ness, Calciu | m (As CaCO3) | 104 mg/L | | 1.00 | NA | | 12/31/08 12:32 AM |
| HARD | NESS | | | SM2340 B | | | Analyst: B | P |
| Hard | ness, Total (| As CaCO3) | 182 mg/L | | 1.00 | NA | 12/24/08 12:16 | PM 12/31/08 12:32 AM |
| MERC | URY, TOT | AL | | E245.1 | | | Analyst: C | GW |
| Merc | ury | | ND mg/L | | 0.0010 | 0.0020 | 12/24/08 12:08 | PM 12/30/08 10:50 AM |
| РСВ | | | | E505 | | | Analyst: S | ub |
| Arocl | or 1016 | | See Attached | | NA | NA | | |
| Arocl | or 1221 | | See Attached | | NA | NA | | |
| Arocl | or 1232 | | See Attached | | NA | NA | | |
| Arocl | or 1242 | | See Attached | | NA | NA | | |
| Aroci | or 1248 | | See Attached | | NA | NA | | |
| Key: | MCL Max | kimum Contaminant Level | Quali | fiers: B Analyte | detected in the as | sociated Met | hod Blank | |
| | MDL Min | imum Detection Limit | | E Estimat | ed Value above qu | antitation ra | nge | |
| | NA Not | Applicable | | H Holding | g times for prepara | tion or analy | sis exceeded | |
| | ND Not | Detected at the PQL or M | DL | S Spike/S | urrogate Recovery | outside acce | epted recovery limit | |
| | PQL Prac | tical Quantitation Limit | | Value e | xceeds Maximum | Contaminant | t Level Page | 2 of 5 |

PQL Practical Quantitation Limit

TIC Tentatively Identified Compound, Estimated Concentrati

| REI Consultants, Inc. | | Analytic | al Results | Date: 02 | 2-Feb-09 | | |
|-----------------------------|------------------------------|---------------------------|------------|--------------------------|------------------|------------------------|--------------------|
| CLIENT: Client Sample ID | SCHNABEL EI : 1208 MURRAY | NGINEERING SOU ' DRIVE | TH LLC | WorkOrder DateReceive | r: 081 ed 12/ | 2H94 Lab ID 23/2008 | 0812H94-01A |
| Project: | 08330106 | | | Collection I | Date: 12/ | 22/2008 4:25:00 | PM |
| Site ID: | BATTLEFIELI | OGOLF CLUB | | Matrix: | DR | INKING WATE | R |
| Analyses | | Result Ur | nits Qual | PQL | MCL | Prep Date | Date Analyzed |
| PCB | | | E505 | | | Analyst: Su | b |
| Aroclor 1254 | | See Attached | | NA | NA | | |
| Aroclor 1260 | | See Attached | | NA | NA | | |
| Chlordane | | See Attached | | NA | NA | | |
| Toxaphene | | See Attached | | NA | NA | | |
| SEMIVOLATILE O | | DUNDS | E525.2 | | | Analyst: Su | b |
| Alachlor | | See Attached | | NA | NA | | |
| Atrazine | | See Attached | | NA | NA | | |
| Benzo(a)pyrene | | See Attached | | NA | NA | | |
| Di(2-ethylhexyl)adir | pate | See Attached | | NA | NA | | |
| Di(2-ethvlhexvl)pht | halate | See Attached | | NA | NA | | |
| Endrin | | See Attached | | NA | NA | | |
| gamma-BHC | | See Attached | | NA | NA | | |
| Hentachlor | | See Attached | | NA | NA | | |
| Hentachlor enoxide | | See Attached | | NA | NA | | |
| Hexachiorobenzene | e | See Attached | | NA | NA | | |
| Hexachlorocyclope | ntadiene | See Attached | | NA | NA | | |
| Methoxychlor | illadierie | See Attached | | NA | NA | | |
| Simazine | | See Attached | | NA | NA | | |
| CARBAMATES 53 | 4 4 | | E531 1 | | | Analyst: Su | b |
| Aldicarh | | See Attached | L001.1 | NΔ | NΔ | , manjon o a | ~ |
| Aldicarb sulfone | | See Attached | | NA | NΔ | | |
| Aldicarb sulfoxide | | See Attached | | | ΝΔ | | |
| Corthofuron | | See Attached | | NA | NA NA | | |
| Oxamvl | | See Attached | | NA | NA | | |
| | _ | | - | | | Arrichter O | |
| GLYPHOSATE 547 | 7 | | E547 | | | Analyst: Su | a |
| Glyphosate | | See Attached | | NA | NA | | |
| ENDOTHALL 548. | 1 | | E548.1 | | | Analyst: Su | b |
| Endothall | | See Attached | | NA | NA | | |
| DIQUAT 549.2 | | | E549.2 | | | Analyst: Su | b |
| Diquat | | See Attached | 201012 | NA | NA | · · | |
| | | | SW(8280 | | | Analyst Su | b |
| 2,3,7,8-TCDD | | See Attached | 5410200 | NA | NA | | |
| SEMIVOLATILE O | RGANIC COMPO | UNDS BY EPA | E504.1 | | | Analyst: JO | 3 |
| 1,2-Dibromo-3-chlor | ropropane | ND mg/ | L | 0.000020 0 |).000200 | 01/02/09 1:30 F | M 01/02/09 6:07 PM |

| Key: | MCL | Maximum Contaminant Level | Qualifiers: | в | Analyte detected in the associated Method Blank | | |
|------|-----|--|-------------|---|--|-------------|--|
| | MDL | Minimum Detection Limit | | E | Estimated Value above quantitation range | | |
| | NA | Not Applicable | | H | Holding times for preparation or analysis exceeded | | |
| | ND | Not Detected at the PQL or MDL | | S | Spike/Surrogate Recovery outside accepted recover | y limit | |
| | PQL | Practical Quantitation Limit | | * | Value exceeds Maximum Contaminant Level | Page 3 of 5 | |
| | TIC | Tentatively Identified Compound, Estimated Concent | trati | | | | |

REI Consultants, Inc. **Analytical Results**

Date: 02-Feb-09

| CLIENT: S | SCHNABEL ENGI | NEERING SOUTH | LLC | WorkOrde | er: 081 | 2H94 Lab ID | 0812H94-01A |
|------------------------|-------------------|---------------|-------------|------------|-----------|--------------------|-------------------|
| Client Sample ID: 1 | 208 MURRAY DR | IVE | | DateRecei | ved 12/ | 23/2008 | |
| Project: (| 8330106 | | | Collection | Date: 12/ | 22/2008 4:25-00 P | M |
| Site ID: H | BATTLEFIELD GC | DLF CLUB | | Matrix: | DR | INKING WATER | |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed |
| SEMIVOLATILE OR | GANIC COMPOUN | DS BY EPA | E504.1 | | | Analyst: JG | |
| 1,2-Dibromoethane | | ND mg/L | | 0.000020 | 0.000050 | 01/02/09 1:30 PM | 01/02/09 6:07 PM |
| SEMIVOLATILE OR | GANIC COMPOUN | DS | E515.1 | | | Analyst: JG | |
| 2,4,5-TP (Silvex) | | ND ma/L | | 0.000607 | 0.0500 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| 2,4-D | | ND mg/L | | 0.000121 | 0.0700 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Dalapon | | ND ma/L | | 0.00789 | 0.200 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Dinoseb | | ND ma/L | | 0.000121 | 0.00700 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Pentachlorophenol | | ND mo/L | | 0.000607 | 0.00100 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Picloram | | ND mg/L | | 0.000607 | 0.500 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| VOLATILE ORGANI | C COMPOUNDS | | E524.2 | | | Analyst: SDG | |
| Benzene | | ND ug/L | | 1.0 | 5.0 | • | 12/29/08 10:46 AM |
| Carbon tetrachloride | | ND µg/L | | 1.0 | 5.0 | | 12/29/08 10:46 AM |
| 1,2-Dichlorobenzene | | ND µg/L | | 1.0 | 600 | | 12/29/08 10:46 AM |
| 1,4-Dichlorobenzene | | ND ug/L | | 1.0 | 75.0 | | 12/29/08 10:46 AM |
| 1,2-Dichloroethane | | ND ug/L | | 1.0 | 5.0 | | 12/29/08 10:46 AM |
| 1,1-Dichloroethene | | ND µa/L | | 1.0 | 7.0 | | 12/29/08 10:46 AM |
| cis-1,2-Dichloroethene | e | ND µg/L | | 1.0 | 70.0 | | 12/29/08 10:46 AM |
| trans-1,2-Dichloroethe | ene | ND µg/L | | 1.0 | 100 | | 12/29/08 10:46 AM |
| 1,2-Dichloropropane | | ND µg/L | | 1.0 | 5.0 | | 12/29/08 10:46 AM |
| Ethylbenzene | | ND ug/L | | 1.0 | 700 | | 12/29/08 10:46 AM |
| Methylene chloride | | ND µa/L | | 1.0 | 5.0 | | 12/29/08 10:46 AM |
| Styrene | | ND ug/L | | 1.0 | 100 | | 12/29/08 10:46 AM |
| Tetrachloroethene | | ND ua/L | | 1.0 | 5.0 | | 12/29/08 10:46 AM |
| Surr: 1,2-Dichlorobe | enzene-d4 | 88.2 %REC | | 75-125 | NA | | 12/29/08 10:46 AM |
| Surr: 4-Bromofluoro | benzene | 94.5 %REC | | 75-125 | NA | | 12/29/08 10:46 AM |
| RESIDUAL CHLORIN | NE - LAB TEST, HO | OLD TIME E | SM4500-CL-G | | | Analyst: CC | |
| Chlorine, Total Residu | al | ND µg/L | | 100 | NA | - | 12/24/08 11:30 AM |
| TURBIDITY | | | SM2130 B | | | Analyst: CC | |
| Turbidity | | 2.87 NTU | * | 0.50 | 0.50 | | 12/24/08 9:30 AM |
| COLIFORM BY P/A | | | SM9223 B | | | Analyst: CC | |
| Fecal Coliform | | ABSENT NA | | NA | NA | 12/23/08 2:57 PM | 12/24/08 2:57 PM |
| Total Coliform | | ABSENT NA | | NA | NA | 12/23/08 2:57 PM | 12/24/08 2:57 PM |
| CYANIDE | | | E335.4 | | | Analyst: BA | |
| Cyanide, Total | | ND mg/L | | 0.020 | NA | | 12/24/08 9:00 AM |

MCL Maximum Contaminant Level Key: Qualifiers: B Analyte detected in the associated Method Blank MDL Minimum Detection Limit Е Estimated Value above quantitation range NA Not Applicable Н Holding times for preparation or analysis exceeded

ND

Not Detected at the PQL or MDL

PQL Practical Quantitation Limit

Spike/Surrogate Recovery outside accepted recovery limit s

Page 4 of 5 Value exceeds Maximum Contaminant Level *

TIC Tentatively Identified Compound, Estimated Concentrati

| REI Consu | ultants, Inc. | Analytical Res | sults | Date: 02 | ?-Feb-09 | | |
|----------------------|----------------------|-----------------|------------|---------------------|----------|----------------|-------------------|
| CLIENT: | SCHNABEL ENGINE | ERING SOUTH LLC | , , | WorkOrder | : 08 | 12H94 Lab I | D 0812H94-01A |
| Client Sample | ID: 1208 MURRAY DRIV | Έ | | DateReceive | d 12/ | /23/2008 | |
| Project: | 08330106 | | | Collection D | ate: 12/ | 22/2008 4:25:0 | 0 PM |
| Site ID: | BATTLEFIELD GOL | F CLUB | | Matrix: | DR | INKING WAT | ER |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed |
| ANIONS BY IO | N CHROMATOGRAPHY | | E300.0 | | | Analyst: C | w |
| Chloride | | 124 mg/L | | 5.00 | 250 | | 12/30/08 11:04 PM |
| Fluoride | | 0.33 mg/L | | 0.20 | 4.00 | | 12/30/08 11:04 PM |
| Sulfate | | 24.2 mg/L | | 5.00 | 250 | | 12/30/08 11:04 PM |
| ANIONS BY IO | N CHROMATOGRAPHY | | E300.0 | | | Analyst: C | W |
| Nitrogen, Nitrate | e-Nitrite | ND mg/L | | 0.10 | 10.0 | · | 01/01/09 9:01 AM |
| TOTAL DISSOL | LVED SOLIDS | | SM2540 C | | | Analyst: D | SA |
| Total Dissolved | Solids | 377 mg/L | | 1 | 500 | · | 12/23/08 6:05 PM |
| ALKALINITY | | | SM2320 B | | | Analvst: D | SA |
| Alkalinity, Total | (As CaCO3) | 156 mg/L | | 1.0 | NA | | 12/24/08 7:45 AM |
| CORROSIVITY. | LANGELIER INDEX | | SM2330 B | | | Analyst: II | - |
| Langelier Index | | -0.77 at 20 °C | | NA | NA | | 01/05/09 12:00 AM |
| PH - LAB TEST | , HOLD TIME EXPIRED | SI | M4500-H+-B | | | Analyst: D | SA |
| рH | | 6.98 SU | | NA | NA | | 12/24/08 7:45 AM |
| | BON, TOTAL | | SM5310 C | | | Analyst: C | SA |
| Total Organic Ca | arbon | 2.01 mg/L | | 1.00 | NA | | 12/24/08 7:12 AM |

| Key: | MCL | Maximum Contaminant Level | Qualifiers: | в | Analyte detected in the associated Method Blank | |
|------|------|---|-------------|---|--|-------------|
| | MDL | Minimum Detection Limit | | Έ | Estimated Value above quantitation range | |
| | NA | Not Applicable | | Н | Holding times for preparation or analysis exceeded | |
| | ND | Not Detected at the PQL or MDL | | S | Spike/Surrogate Recovery outside accepted recovery | limit |
| | PQL. | Practical Quantitation Limit | | * | Value exceeds Maximum Contaminant Level | Page 5 of 5 |
| | TIC | Tentatively Identified Compound, Estimated Concer | ntrati | | | |



REI Consultants, Inc. 225 Industrial Park Rd. P.O. Box 286, Beaver, WV 25813 Phone: 304-255-2500 or 800-999-0105 FAX: 304-255-2572 e-mail: rlabs@reiclabs.com

| CHAIN | C |
|--------------------------------------|---|
| CLIENT: Schnedel Farmering | |
| ADDRESS: 300 5 Wryht Lane Sube I | |
| CITY/STATE/ZIP: Napont News VA 23606 | |
| BILL TO: Some | |
| CITY/STATE/ZIP: | |
| PURCHASE ORDER # | |
| QUOTE # | |

| DF CUSTODY RECORD NO. 283753 | |
|--|----|
| CONTACT PERSON: Fuszell Romance | |
| TELEPHONE #: 157-947-1220 | |
| FAX #: 07 947-1225 | |
| E-MAIL ADDRESS: Nontroca schnakel-cap, cm | 24 |
| SITE ID & STATE: Batlefield Golf Club Weder Property | |
| PROJECT ID: 08330106 | |
| SAMPLER: Russell Romance | |
| | |

| | | | | | | | | PRI | ESERVAT | TIVE CODES | |
|-------------------------------|---|---|---------------------------|---------------|---|---------------|-------|-----------|---------|--------------------------|-----------|
| | TURNAROUND TIME | PRESERVATIVES | NOTE PRES | ERVATIVES - | | | | | | | |
| | REQUIREMENTS | 0 No Preservative | è | | 14 | 6/3 | | 11 | | ///// | |
| SAMPLE LOG | REGULAR: | 1 Hydrochloric Ad | sic | 0011 | 14 | 2 1 | * / . | / / / | / / | | |
| | *RUSH: 5-Day | 2 Nitric Acid | | ALL . | 24 | AN' | / / | | / / | | |
| AND | 3-Day | 3 Sulfuric Acid | | 12/2 | y y | - 7 | / / | /// | 11 | | |
| | 2-Day | 4 Sodium Thiosul | fate / | 5 × | - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 | 7 / | / / | | / / | | |
| ANALYSIS REQUEST | 1-Day | 5 Sodium Hydroxi | ide d | 8/ 30/ S | N.V. | | / / | 111 | | | |
| | *Ruch work peads prior Laboratory approval or | 6 Zinc Acetate | 120 | 25/ 5 | 127 | / / | | | / / | / / | |
| | will include surcharges | 7 EDTA | Shua | x re V | 4 20 20 | | / / | /// | | | |
| | NO. & TYPE OF SAMPLING | SAMPLE | 1/3 | 193 | XX | / / | | / / / | / / | / | |
| SAMPLE ID | CONTAINERS DATE / TIME | MATRIX COMP / GRA | B | J.J.L | 14 Ja | / / | / / | 11 | / / | COMMENTS | 6 |
| 1209 Merray Dave | 20 222-08 | W G | IV | 11 | 1 | 1 | 1 | | | | |
| | | | | | | | | | | | |
| | | | | | | | + | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | V See attac | red |
| | | | | | | | | | | analysis pavo | meters |
| | | | | | | | | | | Summany | |
| | | | | | | | | | | 1 | |
| | | | | | 1 | | | | | | |
| | | | | | 4 | NO | Ast | bestos | pr. | r client. | |
| 1 1 | | | | | | | | | | SG 12 | 123/08 |
| Authing ished by: (Signature) | - 7:00 Date/Time Geceiv | , ed by: (Signature) | Date/Time | | Relinquished by | : (Signature) | | Date/Time | | Received by: (Signature) | Date/Time |
| Relinquished by: (Signature) | Date/Time Receiv | ed by: (Signature) | Date/Time | Temperature U | pon Arrival | °C | 🗆 F/ | X Resul | ts | 🙇 Email R | esults |
| | | nya mangka ng Pang Tangga ng Pangka ng Pa | Cast Contract Sectors and | tes | ex | | | | | | |



www.pacelabs.com

Report Prepared for:

Scott Gross REI Consultants, Inc. 225 Industrial Park Dr. Beaver WV 25813

REPORT OF LABORATORY ANALYSIS FOR 2,3,7,8-TCDD

Report Summary:

This report contains results of one drinking water sample analyzed to determine 2,3,7,8-TCDD content. This sample was analyzed according to Method 1613 by High Resolution Gas Chromatography/High Resolution Mass Spectrometry.

Report Prepared Date: January 8, 2009 Pace Analytical Services, Inc. 1700 Elm Street Minneapolis, MN 55414 Phone: 612.607.1700 Fax: 612.607.6444

Report Information:

Pace Project #: 1086999 Sample Receipt Date: 12/30/2008 Client Project #: 0812H94 Client Sub PO #: N/A State Cert #: 9952C

Invoicing & Reporting Options:

The report provided has been invoiced as a Level 2 Drinking Water Report. If an upgrade of this report package is requested, an additional charge may be applied.

Please review the attached invoice for accuracy and forward any questions to Nate Habte, your Pace Project Manager.

This report has been reviewed and prepared by:

For Nate Habte

Nate Habte, Project Manager (612) 607-6407 (612) 607-6444 (fax) natnael.habte@pacelabs.com



Report of Laboratory Analysis

This report should not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc.

The results relate only to the samples included in this report.

| TEL ALACCARA | | | | 2 | 1086419 |
|--|--|-------------------------|-----------------------------------|---------------------------------------|-----------|
| TEL. 304.255.2500 | 0 FAX: 304.255.2572 | | | · · · · · · · · · · · · · · · · · · · | |
| Subcontractor: PACE ANALYTIC/ 1700 Elm St. Suite | AL SERVICES INC. TE 200 FA | L: (919) 596-1935 X: | • | | |
| Minneapolis, MN 5 | 55414 Ac | ct#: | | | 23-Dec-08 |
| Sample ID | Matrix Date Collected | Bottle Type SW8280 | 201 | Requested Tests | |
| 0812H94-01A | Drinking Water 12/23/2008 2:20:22 P | IALS, PLASTIC, GLA 1 | | | (CO) |
| General Comments: | State Code: VA After analysis, the samples do not | 2J7F – | すこう Jisposed per your standard | laboratory practices. | |
| | Method 1613 | per Scott G. (| D 12/30/08 | | |
| and the second sec | . / 1. | Date/Time |] | | Date/Time |

| | Sample/Condition | n Upon Receip | | |
|--|-----------------------------|--|--|--|
| Sace Analytical Client Nat | ne: <u>REL</u> | | Project # 108 | 169991 |
| Courtor: \Box Fed Ex \Box UPS \Box USPS \Box Tracking #: 12.26×71313616 | Client Commercial 2 0327 | Pace Other | Optional Proj. Dile Proj. Nam | Date: |
| Custody Seal on Cooler/Box Present: | res 🖵 no Seals | intact: 🔲 yes | no | <u> </u> |
| Packing Material: 🔲 Bubble Wrap | ble Bags 🔲 None | Other | Temp Blank: Yes | No <u>~</u> |
| Thermometer Used 80344042, 179425 | Type of Ice: Wet | Blue None | Samples on ice, cooling | g process has begun |
| Cooler Temperature 500 Temp should be above freezing to 6°C | Biological Tissue i | ls Frozen: Yes No Comments: | contents: | 20/05 X |
| Chain of Custody Present: | BYes DNO DN/A | 1. | | |
| Chain of Custody Filled Out: | | 2. | وروار و المحمد المحم | د مراجع مروحه المراجع و مراجع و مراجع و المراجع المراجع المراجع و المراجع و المراجع و المراجع و المراجع و |
| Chain of Custody RelInguished: | EYes DNO DN/A | 3. | | چىرىغىغ مىچاھا يىىلا كالىكى، سىيى ئا يىغاط ھىرى خىرى خىرى تى ت |
| Sampler Name & Signature on COC: | DYes DNO DNA | 4. | سه معلوم کر ان اور ا ان اور ان اور | |
| Samples Arrived within Hold Time: | Elves Ino Inia (| 5. | | بالان مطبقه المرضوب برجماد ومحمد القرير المشاهد المرضو المرضوع |
| Short Hold Time Analysis (<72hr): | CIYes 12100 CINVA 6 | 3. | ى يې پېرې سې دې پې د د د د د د د د د د د د د د د د د د د | ىلىد ئىلىدىدىن _{كى} تى بىلەر ، بىن بىلەل ^ي ىلىدىدىن بىلەر بىلەر بىل |
| Rush Turn Around Time Requested: | OYes ONO DNA 7 | · | | المحرب والمربق والمربع والمربع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع |
| Sufficient Volume: | EYes DNO DNA 8 | | | |
| Correct Containers Used: | CAYAS DNO DN/A 9 | | | |
| -Pace Containers Used: | UYOS DINO UNA | | | |
| Containers Intact | | 0. | | |
| Fillered volume received for Dissolved tests | UYes DNG DNIA 1' | 1. | | والمسارحة والمراجع والمستر والمراجع المراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع |
| Sample Labels inatch COC: | ETYOS DNO DNA 12 | 2. | | |
| -Includes date/time/ID/Analysis Matrix: | W7 | | | |
| All containers needing acld/base preservation have been checked. Noncompliance are noted in 13. | DYOS DINO DINA 13 | | | |
| All containers needing preservation are found to be in compliance with EPA recommendation. | | | | |
| Excellions: VOA.Coliform, TOC, Oil and Grease, Wi-DRO (water) | Dives DNo Cor | lai when mpleted | Lot # of added | |
| Samples checked for dechlorination | | ************************************** | | |
| Headspace in VOA Vials (>6mm): | Dyes ZNo DN/A 15 | | , | |
| Trip Blank Present | Dyes DNO DN/A 16 | | | |
| Trip Blank Custody Seals Present | | | | |
| Pace Trip Blank Lot # (if purchased): | | | ~ ~ | |
| Client Notification/ Resolution: Person Contacted: | Date/Time | | Field Data Required? | ¥ / N |
| Comments/ Resolution: | | | | ····· |
| K | | | ۰. | |
| | | | | |
| ۲۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰ | \sim | | /. | |
| Project Manager Review; | (¥ | | Date: <u>/2/3</u> 0 | / 08 |

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNRE 3 of 4 Certification Report Noo! hold Description of temp, incorrect containers)



Pace AnalyticalServices, Inc. 1700 Elm Street - Suite 200 Minneapolis, MN 55414

Tel: 612-607-1700

Fax: 612-607-6444

Drinking Water Analysis Results 2,3,7,8-TCDD -- USEPA Method 1613B

Sample ID.....0812H94-01A Client......REI Consultants, Inc. Lab Sample ID.....1086999001

Date Collected 12/23/2008 Date Received 12/30/2008 Date Extracted.....01/06/2009

| | Sample 0812H94-01A | Method Blank | Lab Spike | Lab Spike Dup |
|-----------------------|-----------------------|-----------------|--------------|------------------|
| [2,3,7,8-TCDD] | ND | ND | | |
| RL | 5 pg/L | 5 pg/L | | ~ = |
| 2,3,7,8-TCDD Recovery | | | 104% | 105% |
| Spike Recovery Limit | | ~* | 73-146% | 73-146% |
| RPD | | | 0. | 5% |
| IS Recovery | 53% | 52% | 68% | 48% |
| IS Recovery Limits | 31-137% | 31-137% | 25-141% | 25-141% |
| CS Recovery | 84% | 86% | 85% | 75% |
| CS Recovery Limits | 42-164% | 42-164% | 37-158% | 37-158% |
| Filename | R90106B06 | R90106B05 | R90106B03 | R90106B04 |
| Analysis Date | 01/06/2009 | 01/06/2009 | 01/06/2009 | 01/06/2009 |
| Analysis Time | 22:45 | 22:16 | 21:19 | 21:48 |
| Analyst | SMT | SMT | SMT | SMT |
| Volume | 0.962L | 0.934L | 0.935L | 0.913L |
| Dilution | NA | NA | NA | NA |
| ICAL Date | 12/31/2008 | 12/31/2008 | 12/31/2008 | 12/31/2008 |
| CCAL Filename | R90106B02 | R90106B02 | R90106B02 | R90106B02 |

= Outside the Control Limits 1

ND = Not Detected

hy million Analyst:

- RL = Reporting Limit
- Limits = Control Limits from Method 1613 (10/94 Revision), Tables 6A and 7A
- RPD = Relative Percent Difference of Lab Spike Recoveries
- IS
- = Internal Standard [2,3,7,8-TCDD-¹³C] = Cleanup Standard [2,3,7,8-TCDD-³⁷Cl²] CS

Project No.....1086999



the standard in safety

Underwriters Laboratories

LABORATORY REPORT

This report contains pages. (including the cover page)

If you have any questions concerning this report, please do not hesitate to call us at (800) 332-4345 or (574) 233-4777.

This report may not be reproduced, except in full, without written approval from Underwriters Laboratories Inc. (UL).

Underwiners Labitatories inc. 110 S. Hill Street, South Bend, 17 40517-2702 USA T.: 800-332 43457 F.: 574,233.82077 W: 18.com

Effective Date: October 6, 2008



Underwriters Laboratories

Laboratory Report

Client: REIC

Joy Mullins 225 Airport Industrial Park Road P.O. Box 286 Beaver, WV 25813 Report: Priority: Status: PWS ID: 218268 Standard Written Final Not Supplied

| 00 | p۱ | es | |
|----|----|----|--|
| t | o: | | |

None

Attn:

| Sample Information | | | | | | | | | |
|--------------------|-------------|--------|--------------------------|------------------|-------------------------|--|--|--|--|
| UL ID# | Client ID | Method | Collected Date / Time | Collected By: | Received Date / Time | | | | |
| 1998288 | 0812H94-01A | 505 | 12/23/08 14:20 | Client | 12/30/08 09:30 | | | | |
| 1998289 | 0812H94-01A | 525.2 | 12/23/08 14:20 | Client | 12/30/08 09:30 | | | | |
| 1998290 | 0812H94-01A | 531.1 | 12/23/08 14:20 | Client | 12/30/08 09:30 | | | | |
| 1998291 | 0812H94-01A | 548.1 | 12/23/08 14:20 | Client | 12/30/08 09:30 | | | | |
| 1998292 | 0812H94-01A | 547 | 12/23/08 14:20 | Client | 12/30/08 09:30 | | | | |
| 1998293 | 0812H94-01A | 549.2 | 12/23/08 14:20 | Client | 12/30/08 09:30 | | | | |
| | | | | | | | | | |

Report Summary

Note: Sample containers, except for Method 549.2, were provided by the client.

Note: The samples submitted for Methods 549.2 and 548.1 were analyzed outside the seven day hold time. The client was notified of the situation and analysis was authorized by Scott Gross of REIC.

Note: In the Method 525.2 analysis, heptachlor epoxide is not reportable in the sample submitted due to matrix interference.

Detailed quantitative results are presented on the following pages.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call Traci Chlebowski at (574) 233-4777.

Note: This report may not be reproduced, except in full, without written approval from Underwriters Laboratories (UL).

REIC

218268

Authorized Signature

Client Name: Report #:

ject Manager

Page 1 of 2

Underwriters Laboratories Inc. 110 S. Hill Street, South Bend, IN 46617-2702 USA T:: 800,332,4345 / F:: 574.233.8207 / W:: ul.com

Sampling Point: 0812H94-01A

PWS ID: Not Supplied

| A | | | - | | | | | A seal and a | 1 |
|-----------------|---------------------------|--------|--|------|--------|-------|---------------------|----------------|-----------|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed | UL ID# |
| 12674-11-2 | Aroclor 1016 | 505 | | 0.08 | < 0.08 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 1998288 |
| 11104-28-2 | Aroclor 1221 | 505 | aaa | 0.19 | < 0.19 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 1998288 |
| 11141-16-5 | Aroclor 1232 | 505 | | 0.23 | < 0.23 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 199828 |
| 53469-21-9 | Aroclor 1242 | 505 | | 0.26 | < 0,26 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 199828 |
| 12672-29-6 | Aroclor 1248 | 505 | | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 199828 |
| 11097-69-1 | Aroclor 1254 | 505 | 14 'n Hamelyn a Dybyn 1990 | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 199828 |
| 11096-82-5 | Aroclor 1260 | 505 | ير وروديوني به يونيو دروني د | 0.2 | < 0.2 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 199828 |
| 57-74-9 | Chiordane | 505 | 2* | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 199828 |
| 8001-35-2 | Toxaphene | 505 | 3* | 1.0 | < 1.0 | ug/L | 12/31/08 13:50 | 12/31/08 21:20 | 199828 |
| 15972-60-8 | Alachlor | 525.2 | 2* | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 309-00-2 | Aldrin | 525.2 | and a second s | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 1912-24-9 | Atrazine | 525.2 | 3* | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 50-32-8 | Benzo[a]pyrene | 525.2 | 0.2 * | 0.02 | < 0.02 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 58-89-9 | gamma-BHC (Lindane) | 525.2 | 0.2 * | 0.02 | < 0.02 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 23184-66-9 | Butachlor | 525.2 | *** | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 60-57-1 | Dieldrin | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 103-23-1 | Di(2-ethylhexyl)adipate | 525.2 | 400 * | 0.6 | < 0.6 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 117-81-7 | Di(2-ethylhexyl)phthalate | 525.2 | 6* | 0.6 | < 0.6 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 72-20-8 | Endrin | 525.2 | 2* | 0.01 | < 0.01 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 76-44-8 | Heptachlor | 525.2 | 0.4 * | 0.04 | < 0.04 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 118-74-1 | Hexachlorobenzene | 525.2 | 1* | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 77-47-4 | Hexachlorocyclopentadiene | 525.2 | 50 * | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 72-43-5 | Methoxychlor | 525.2 | 40 * | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 51218-45-2 | Metolachlor | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 21087-64-9 | Metribuzin | 525.2 | *** | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 1918-16-7 | Propachior | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 122-34-9 | Simazine | 525.2 | 4 * | 0.07 | < 0.07 | ug/L | 12/31/08 09:30 | 12/31/08 20:29 | 199828 |
| 116-06-3 | Aldicarb | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 1646-88-4 | Aldicarb sulfone | 531,1 | | 0.7 | < 0.7 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 1646-87-3 | Aldicaro sulfoxide | 531.1 | atata da seria da seria. National da seria da | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 63-25-2 | Carbaryl | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 1563-66-2 | Carbofuran | 531.1 | 40 * | 0.9 | < 0.9 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 6655-82-6 | 3-Hydroxycarbofuran | 531.1 | **** **** | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 6752-77-5 | Methomyl | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 23135-22-0 | Oxamyl | 531,1 | 200 * | 1.0 | < 1.0 | ug/L | 12/31/08 08:20 | 12/31/08 17:58 | 199829 |
| 1071-83-6 | Glyphosate | 547 | 700 * | 6.0 | < 6.0 | ug/L | 12/31/08 13:00 | 01/02/09 18:29 | 199829 |
| 145-73-3 | Endothall | 548.1 | 100 * | 9.0 | < 9.0 | ug/L | 12/31/08 08:05 | 01/02/09 15:59 | 199829 |
| 85-00-7 | Digitat | 549.2 | 20 * | 04 | < 0.4 | uo/L | 12/31/08 08:20 | 12/31/08 12:53 | 199829 |

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

† UL has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

| | A REAL POINT OF A REAL POINT AND A REAL | a second s | the second se | المفارية الماري والمار | an na ao amin'ny tanàna mandritra dia kaominina mandritra dia kaominina dia kaominina dia kaominina dia kaomini | | | |
|-----|---|---|---|---|---|------------------------------|--|------------------------------|
| 1 | Reg Limit Type: | | MCL | 1 | SMCL | ÷ | AL | : |
| | 1. A set the set of a set o | المحاف المروك موجر والمراجع | ما رمان الدار المعرومين ومحمد والمحمد ما والا | · · · · · · · · · · · · · · · · · · · | الالالاحاد بالمحيدين والمتعار والمحمد المحمو المحمو والالا المعرودات | and the second second second | Contraction and contract of actions where the con- | and the second second second |
| | Symbol: | | * | : | ^ | | 1 | |
| • • | The second se | | | e na prime an an air an | . The care of the terms of the second second second second | | and showing only and she she - | |

173034

CHAIN-OF-CUSTODY RECORD

Page 1 of 1

| 225 Industrial Park Beaver, WV 25813 | Drive | | | | | | | | | |
|--|--------------------------------|--------------------------|------------------------|------|--------|-----------|----------------|------------|--------|-----------|
| TEL: 304.255.2500 |) FA | X: 304.255.2572 | | | | | | pm 250 | | |
| Subcontractor: UNDERWRITERS 110 SOUTH HILL SOUTH BEND, IN | LABORATORIE STREET 46617 | S TEL: FAX: Acct#: | (<u>5</u> 74) 233-477 | 17 | f late | 2 1998 AT |) blog | 2 21 21 | 8268 | 23-Dec-08 |
| | | | | | | R | lequested Test | s 1940 | M | e |
| Sample ID | Matrix | Date Collected | Bottle Type | E505 | E525.2 | (E531.1) | E547 | (E548.1) | E549.2 | : |
| 0812H94-01A | Drinking Water | 12/23/2008 2:20:22 PIALS | 6, PLASTIC, GLA | 1 | 1 | 1 | 1 | 1 | 1 | · |

) all but 549.2

25

548+549 rovd on last day of HT pm 1230

General Comments:

State Code: VA

REI Consultants, Inc.

After analysis, the samples do not need to be returned and can be disposed per your standard laboratory practices.

| · / // | Date/Time | | Date/Time |
|------------------|------------|------------------|-------------|
| Relinquished by: | Kalose 100 | Received by: UPS | |
| Relinquished by: | · | Received by: | 123008 0930 |
| | | 10 | |

FIELD BLANK



225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: <u>www.reiclabs.com</u>

January 22, 2009

Mr. Russell Rountree SCHNABEL ENGINEERING SOUTH LLC 300 ED WRIGHT LN SUITE 1 NEWPORT NEWS VA 23606

TEL: (757) 947-1220 FAX (757) 947-1220

RE: 08330106

Dear Mr. Russell Rountree:

Order No.: 0812I02

REI Consultants, Inc. received 1 sample(s) on 12/23/2008 for the analyses presented in the following report.

Please note two changes you may see on your report.

- Results for "Dissolved" parameters will be shown under a separate sample ID, rather than as a separate analysis under the same sample ID. The sample ID for "Dissolved" parameters will include "Field Filtered" or "Lab Filtered", as appropriate.
- Metals results will no longer be identified as "Total" or "Total Recoverable". The methods have not been changed, only their appearance on the report.

If you have any questions regarding these results, please do not hesitate to call.

Sincerely,

ame c Sus

Scott Gross Project Manager





Improving the environment, one client at a time...

225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: <u>www.reiclabs.com</u>

| | | | | WO#: | 0812102 |
|-------------------------|-------------------|-------------|----------------|-------|-----------|
| Report Narrative | Project Manager:: | Scott Gross | Pro Providence | Date: | 1/22/2009 |

CLIENT:SCHNABEL ENGINEERING SOUTH LLProject:08330106

All analyses were performed using documented laboratory SOPs that incorporate appropriate quality control procedures as described in the applicable methods. REI Consultants, Inc. (REIC) technical managers have verified compliance of reported results with the REIC's Quality Program and SOPs, except as noted in this case narrative. Any deviation from compliance is explained below and/or identified within the body of this report by a qualifier footnote which is defined at the bottom of each page.

All samples were analyzed using the methods stated in the analytical report without modification, unless otherwise noted.

All sample results are reported on an "as-received" wet weight basis unless otherwise noted.

Results reported for sums of individual parameters, such as Total Trihalomethanes (TTHM) and Total Haloacetic Acids (HAA5), may vary slightly from the sum of the individual parameter results. This apparent anomaly is caused by rounding individual results and summations at reporting, as required by EPA.

Following standard laboratory protocol, sample preservation, such as pH, is verified at time of extraction or analysis based on client requested parameters. Improper preservation is noted on the analytical bench sheet, extraction log, or preservation log and client is notified by close of following business day. All results are reported using preservation compliant samples unless otherwise noted in the analytical report.

The test results in this report meet all NELAP requirements for parameters for which accreditations are required or available. Any exceptions are noted in this report. This report may not be reproduced, except in full, without the written approval of REIC.

In compliance with federal guidelines and standard operating procedures, all reports, including raw data and supporting quality control, will be disposed of after five years unless otherwise arranged by the client via written notification or contract requirement.

If you have any questions please contact the project manager whose name is listed above.

| REI Co | onsultants, Inc. | Analytical R | Date: 0 | 2-Feb-09 | | | | | | |
|--------------|----------------------------|---------------------|-----------------|--------------------|---------------|----------------------------|--|--|--|--|
| CLIENT: | SCHNABEL E | NGINEERING SOUTH LI | .C | WorkOrde | r: 081 | 0812I02 Lab ID 0812I02-01A | | | | |
| Client San | ple ID: FIELD BLAN | ζ. | | DateReceiv | ed 12/ | 23/2008 | | | | |
| Project | 08330106 | | | Collection | Date: 12/ | 22/2008 5-30-00 | PM | | | |
| Site ID: | BATTI EFIFI | | | Matrix | Date: 12, | INKING WATE | R | | | |
| | | | | matrix. | | | Data Analuzad | | | |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed | | | |
| METALS B | YICP | | E200.7 | | | Analyst: BF | • | | | |
| Aluminum | | ND mg/L | | 0.100 | 0.200 | 12/24/08 12:16 | PM 12/31/08 12:38 AM | | | |
| Boron | | ND mg/L | | 0.100 | NA | 12/24/08 12:16 | PM 12/31/08 12:38 AM | | | |
| Iron | | ND mg/L | | 0.100 | 0.300 | 12/24/08 12:16 | PM 12/31/08 12:38 AM | | | |
| Magnesiun | n | ND mg/L | | 0.500 | NA | 12/24/08 12:16 | PM 12/31/08 12:38 AM | | | |
| Manganese | Ð | ND mg/L | | 0.050 | 0.050 | 12/24/08 12:16 | PM 12/31/08 12:38 AM | | | |
| Silica (as S | SiO2) | ND mg/L | | 0.210 | NA | 12/24/08 12:16 | PM 12/29/08 2:57 PM | | | |
| Sodium | | ND mg/L | | 0.500 | NA | 12/24/08 12:16 | PM 12/31/08 12:38 AM | | | |
| METALS B | Y ICP-MS | | E200.8 | | | Analyst: B | ٨ | | | |
| Antimony | | ND mg/L | | 0.0010 | 0.0060 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Arsenic | | ND mg/L | | 0.0050 | 0.0100 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Barium | | ND mg/L | | 0.100 | 2.00 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Beryllium | | ND mg/L | | 0.0020 | 0.0040 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Cadmium | | ND mg/L | | 0.0010 | 0.0050 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Chromium | | ND mg/L | | 0.0050 | 0.100 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Cobalt | | ND mg/L | | 0.100 | NA | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Copper | | ND mg/L | | 0.0500 | 1.30 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Lead | | ND mg/L | | 0.0050 | 0.0150 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Molybdenu | m | ND mg/L | | 0.100 | NA | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Nickel | | ND mg/L | | 0.0100 | 0.100 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Selenium | | ND mg/L | | 0.0050 | 0.0500 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Silver | | ND mg/L | | 0.0500 | NA | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Thallium | | ND mg/L | | 0.0010 | 0.0020 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Vanadium | | ND mg/L | | 0.0500 | NA | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| Zinc | | ND mg/L | | 0.0100 | 5.00 | 12/24/08 12:16 | PM 12/29/08 4:24 PM | | | |
| HARDNESS | S, CALCIUM | | SM2340 B | | | Analyst: Bl | 5 | | | |
| Hardness, (| Calcium (As CaCO3) | ND mg/L | | 1.00 | NA | | 12/31/08 12:38 AM | | | |
| HARDNESS | 3 | | SM2340 B | | | Analyst: Bl | 2 | | | |
| Hardness, 1 | Fotal (As CaCO3) | 1.47 mg/L | | 1.00 | NA | 12/24/08 12:16 | PM 12/31/08 12:38 AM | | | |
| MERCURY. | TOTAL | | E245.1 | | | Analyst: C | GW | | | |
| Mercury | | ND mg/L | | 0.0010 | 0.0020 | 12/24/08 12:08 | PM 12/30/08 10:52 AM | | | |
| РСВ | | | E505 | | | Analyst: Si | ub | | | |
| Aroclor 101 | 6 | See Attached | | NA | NA | | | | | |
| Aroclor 122 | 1 | See Attached | | NA | NA | | | | | |
| Aroclor 123 | 2 | See Attached | | NA | NA | | | | | |
| Aroclor 1243 | 2 | See Attached | | NA | NA | | | | | |
| Aroclor 1248 | 8 | See Attached | | NA | NA | | | | | |
| Key: MCL | Maximum Contaminant L | evel Oualifi | iers: B Analvte | detected in the as | sociated Met | hod Blank | ······································ | | | |
| MDL | Minimum Detection Limit | | E Estimate | ed Value above ou | antitation ra | nge | | | | |
| NA | Not Applicable | | H Holding | times for prepara | tion or analy | sis exceeded | | | | |
| ND | Not Detected at the POL o | r MDL | S Spike/S | urrogate Recoverv | outside acco | epted recovery limit | | | | |
| PQL | Practical Quantitation Lim | it | * Value e | ceeds Maximum | Contaminan | t Level Page | 2 of 5 | | | |
| * | • | | | | | | | | | |

TIC Tentatively Identified Compound, Estimated Concentrati

| REI Consultants, Inc. Analytica | | | esults | Date: 02 | 2-Feb-09 | | |
|---------------------------------|-----------------|---------------------|--------|---------------------|-------------|-------------------|--------------------|
| CLIENT: | SCHNABEL EN | INGINEERING SOUTH L | LC | WorkOrder | r: 081 | 2102 Lab II | 0812I02-01A |
| Client Sample | ID: FIELD BLANK | • | | DateReceiv | ed 12/ | 23/2008 | |
| Project: | 08330106 | | | Collection E | Date: 12/ | 22/2008 5:30:00 |) PM |
| Site ID: | BATTLEFIELD | GOLF CLUB | | Matrix: | DR | INKING WATI | ER |
| Analyses | ····· | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed |
| РСВ | , | | E505 | | | Analyst: Su | du |
| Aroclor 1254 | | See Attached | | NA | NA | - | |
| Aroclor 1260 | | See Attached | | NA | NA | | |
| Chlordane | | See Attached | | NA | NA | | |
| Toxaphene | | See Attached | | NA | NA | | |
| SEMIVOLATILE ORGANIC COMPOUNDS | | E525.2 | | | Analyst: Su | du | |
| Alachlor | | See Attached | | NA | NA | | |
| Atrazine | | See Attached | | NA | NA | | |
| Benzo(a)pyren | e | See Attached | | NA | NA | | |
| Di(2-ethylhexyl) |)adipate | See Attached | | NA | NA | | |
| Di(2-ethylhexyl) |)phthalate | See Attached | | NA | NA | | |
| Endrin | | See Attached | | NA | NA | | |
| gamma-BHC | | See Attached | | NA | NA | | |
| Heptachlor | | See Attached | | NA | NA | | |
| Heptachlor epo | xide | See Attached | | NA | NA | | |
| Hexachloroben | zene | See Attached | | NA | NA | | |
| Hexachlorocycl | opentadiene | See Attached | | NA | NA | | |
| Methoxychlor | | See Attached | | NA | NA | | |
| Simazine | | See Attached | | NA | NA | | |
| ARBAMATES | 5 531.1 | | E531.1 | | | Analyst: S | ub |
| Aldicarb | | See Attached | | NA | NA | | |
| Aldicarb sulfone | 3 | See Attached | | NA | NA | | |
| Aldicarb sulfoxid | de | See Attached | | NA | NA | | |
| Carboluran | | See Attached | | NA | NA | | |
| Oxamyl | | See Attached | | NA | NA | | |
| LYPHOSATE | 547 | | E547 | | | Analyst: S | ub |
| Glyphosate | | See Attached | | NA | NA | | |
| NDOTHALL 5 | 48.1 | | E548.1 | | | Analyst: S | ub |
| Endothall | | See Attached | | NA | NA | | |
| QUAT 549.2 | | | E549.2 | | | Analyst: S | ub |
| Diquat | | See Attached | | NA | NA | | |
| IOXIN | | | SW8280 | | | Analyst: S | ub |
| 2,3,7,8-TCDD | | See Attached | | NA | NA | | |
| EMIVOLATILE | E ORGANIC COMPO | UNDS BY EPA | E504.1 | | | Analyst: J | G |
| 1,2-Dibromo-3-c | chloropropane | ND mg/L | | 0.000020 0 | .000200 | 01/02/09 1:30 | PM 01/02/09 6:21 F |
| | | | | | | | |

.

| Key: | MCL | Maximum Contaminant Level | Qualifiers: | В | Analyte detected in the associated Method Blank | |
|------|-----|--|-------------|---|--|-------------|
| | MDL | Minimum Detection Limit | | Е | Estimated Value above quantitation range | |
| | NA | Not Applicable | | Н | Holding times for preparation or analysis exceeded | |
| | ND | Not Detected at the PQL or MDL | | S | Spike/Surrogate Recovery outside accepted recovery | y limit |
| | PQL | Practical Quantitation Limit | | * | Value exceeds Maximum Contaminant Level | Page 3 of 5 |
| | TIC | Tentatively Identified Compound, Estimated Concent | trati | | | |

| REI Consu | ultants, Inc. | Analytical] | Results | Date: (| 02-Feb-09 | | |
|-------------------|-------------------|-----------------|-------------|------------|-----------|--------------------|-------------------|
| CLIENT: | SCHNABEL EN | GINEERING SOUTH | LLC | WorkOrde | er: 08 | 12102 Lab ID | 0812102-01A |
| Durter 4 | ID. TIELD BLANK | | | DateReceiv | veu 12/ | 23/2006 | |
| Project: | 08330106 | | | Collection | Date: 12/ | 22/2008 5:30:00 Pr | VI |
| Site ID: | BATTLEFIELD | GOLF CLUB | | Matrix: | DR | UNKING WATER | |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed |
| SEMIVOLATILE | E ORGANIC COMPOU | JNDS BY EPA | E504.1 | | | Analyst: JG | |
| 1,2-Dibromoeth | ane | ND mg/L | | 0.000020 | 0.000050 | 01/02/09 1:30 PM | 01/02/09 6:21 PM |
| SEMIVOLATILE | E ORGANIC COMPOU | JNDS | E515.1 | | | Analyst: JG | |
| 2,4,5-TP (Silvex | :) | ND mg/L | | 0.000603 | 0.0500 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| 2,4-D | | ND mg/L | | 0.000121 | 0.0700 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Dalapon | | ND mg/L | | 0.00783 | 0.200 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Dinoseb | | ND mg/L | | 0.000121 | 0.00700 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Pentachlorophe | nol | ND mg/L | | 0.000603 | 0.00100 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| Picloram | | ND mg/L | | 0.000603 | 0.500 | 12/23/08 2:00 PM | 12/30/08 12:00 AM |
| VOLATILE ORG | GANIC COMPOUNDS | | E524.2 | | | Analyst: SDG | |
| Benzene | | ND µg/L | | 1.0 | 5.0 | | 12/30/08 2:09 PM |
| Carbon tetrachic | pride | ND µg/L | | 1.0 | 5.0 | | 12/30/08 2:09 PM |
| 1,2-Dichloroben: | zene | ND µg/L | | 1.0 | 600 | | 12/30/08 2:09 PM |
| 1,4-Dichloroben: | zene | ND µg/L | | 1.0 | 75.0 | | 12/30/08 2:09 PM |
| 1,2-Dichloroetha | ine | ND µg/L | | 1.0 | 5.0 | | 12/30/08 2:09 PM |
| 1,1-Dichloroethe | ne | ND µg/L | | 1.0 | 7.0 | | 12/30/08 2:09 PM |
| cis-1,2-Dichloroe | ethene | ND µg/L | | 1.0 | 70.0 | | 12/30/08 2:09 PM |
| trans-1,2-Dichlor | roethene | ND µg/L | | 1.0 | 100 | | 12/30/08 2:09 PM |
| 1,2-Dichloroprop | ane | ND µg/L | | 1.0 | 5.0 | | 12/30/08 2:09 PM |
| Ethylbenzene | | ND µg/L | | 1.0 | 700 | | 12/30/08 2:09 PM |
| Methylene chlori | de | 15.0 µg/L | • | 1.0 | 5.0 | | 12/30/08 2:09 PM |
| Styrene | | ND µg/L | | 1.0 | 100 | | 12/30/08 2:09 PM |
| Tetrachloroether | 1e | ND µg/L | | 1.0 | 5.0 | | 12/30/08 2:09 PM |
| Surr: 1,2-Dich | lorobenzene-d4 | 85.4 %REC | | 75-125 | NA | | 12/30/08 2:09 PM |
| Surr: 4-Bromo | fluorobenzene | 85.8 %REC | | 75-125 | NA | | 12/30/08 2:09 PM |
| RESIDUAL CHL | ORINE - LAB TEST, | HOLD TIME E | SM4500-CL-G | | | Analyst: CC | |
| Chlorine, Total R | tesidual | ND µg/L | | 100 | NA | · | 12/24/08 11:30 AM |
| TURBIDITY | | | SM2130 B | | | Analyst: CC | |
| Turbidity | | ND NTU | | 0.50 | 0.50 | | 12/24/08 9:30 AM |
| COLIFORM BY | P/A | | SM9223 B | | | Analyst: CC | |
| Fecal Coliform | | ABSENT NA | | NA | NA | 12/23/08 3:49 PM | 12/24/08 3:49 PM |
| Total Coliform | | ABSENT NA | | NA | NA | 12/23/08 3:49 PM | 12/24/08 3:49 PM |
| CYANIDE | | | E335.4 | | | Analvst: BA | |
| Cyanide, Total | | ND ma/L | 200014 | 0.020 | NA | Antonyou Dri | 12/24/08 9:00 AM |
| - | | | | | | | |

| Key: | MCL | Maximum Contaminant Level | Qualifiers: | В | Analyte detected in the associated Method Blank |
|------|-----|--------------------------------|-------------|---|--|
| | MDL | Minimum Detection Limit | | Е | Estimated Value above quantitation range |
| | NA | Not Applicable | | Н | Holding times for preparation or analysis exceeded |
| | ND | Not Detected at the PQL or MDL | | S | Spike/Surrogate Recovery outside accepted recovery limit |
| | PQL | Practical Quantitation Limit | | * | Value exceeds Maximum Contaminant Level Page 4 of 5 |

TIC Tentatively Identified Compound, Estimated Concentrati

REI Consultants, Inc. Analytical Results

Date: 02-Feb-09

| CLIENT: | SCHNABEL ENGINE | LC | WorkOrder: 0812102 Lab ID 0812102-01A | | | | | | | |
|----------------------|-------------------|----------------|---------------------------------------|-------------------------|----------|------------------|-------------------|--|--|--|
| Client Sample I | D: FIELD BLANK | | | DateReceived 12/23/2008 | | | | | | |
| Project: | 08330106 | | | Collection D | ate: 12/ | /22/2008 5:30:00 | PM | | | |
| Site ID: | BATTLEFIELD GOL | F CLUB | | Matrix: | DR | INKING WATE | R | | | |
| Analyses | | Result Units | Qual | PQL | MCL | Prep Date | Date Analyzed | | | |
| ANIONS BY ION | CHROMATOGRAPHY | | E300.0 | | | Analyst: CW | 1 | | | |
| Chloride | | ND mg/L | | 1.00 | 250 | | 12/30/08 11:22 PM | | | |
| Fluoride | | ND mg/L | | 0.20 | 4.00 | | 12/30/08 11:22 PM | | | |
| Sulfate | | ND mg/L | | 5.00 | 250 | | 12/30/08 11:22 PM | | | |
| ANIONS BY ION | CHROMATOGRAPHY | | E300.0 | | | Analyst: CW | 1 | | | |
| Nitrogen, Nitrate- | Nitrite | 0.41 mg/L | | 0.10 | 10.0 | | 01/01/09 9:39 AM | | | |
| TOTAL DISSOL | VED SOLIDS | | SM2540 C | | | Analyst: DS | A | | | |
| Total Dissolved S | Solids | 1 mg/L | | 1 | 500 | | 12/24/08 10:07 PM | | | |
| ALKALINITY | | | SM2320 B | | | Analyst: DS | A | | | |
| Alkalinity, Total (A | As CaCO3) | 4.1 mg/L | | 1.0 | NA | | 12/24/08 7:45 AM | | | |
| CORROSIVITY, I | LANGELIER INDEX | | SM2330 B | | | Analyst: IL | | | | |
| Langelier Index | | -6.51 at 20 °C | | NA | NA | | 01/05/09 12:00 AM | | | |
| PH - LAB TEST, | HOLD TIME EXPIRED | | SM4500-H+-B | | | Analyst: DS | A | | | |
| рН | | 6.08 SU | | NA | NA | | 12/24/08 7:45 AM | | | |
| ORGANIC CARE | ON, TOTAL | | SM5310 C | | | Analyst: DS | A | | | |
| Total Organic Car | rbon | ND mg/L | | 1.00 | NA | · | 12/24/08 8:59 PM | | | |

| | •••• | | | | | |
|------|------|---|-------------|---|--|------|
| Key: | MCL | Maximum Contaminant Level | Qualifiers: | в | Analyte detected in the associated Method Blank | |
| | MDL | Minimum Detection Limit | | Е | Estimated Value above quantitation range | |
| | NA | Not Applicable | | Н | Holding times for preparation or analysis exceeded | |
| | ND | Not Detected at the PQL or MDL | | S | Spike/Surrogate Recovery outside accepted recovery limit | |
| | PQL | Practical Quantitation Limit | | * | Value exceeds Maximum Contaminant Level Page 5 | of 5 |
| | TIC | Tentatively Identified Compound, Estimated Concen | trati | | | |



REI Consultants, Inc. 225 Industrial Park Rd. P.O. Box 286, Beaver, WV 25813 Phone: 304-255-2500 or 800-999-0105 FAX: 304-255-2572 e-mail: rlabs@reiclabs.com

| | CHAIN C |
|----------------------------------|---------|
| CLIENT: Schnabel Enincomy | 2 |
| ADDRESS: 300 Edwright Lane | SouteI |
| CITY/STATE/ZIP: Nay para News, V | A-23602 |
| BILL TO: Some | |
| CITY/STATE/ZIP: | |
| PURCHASE ORDER # | |
| QUOTE # | |

| OF CUSTODY RECORD | NO. 263752 |
|-----------------------------|----------------------|
| CONTACT PERSON: | Romone |
| TELEPHONE #: 757-9-6 | 7-1220 |
| FAX #: 157947-1225 | - |
| E-MAIL ADDRESS: Mount | ne Schnabel-eng, cm |
| SITE ID & STATE: Battlefred | Gulf aub Wader Ageot |
| PROJECT ID: 0730(06 | |
| SAMPLER: | |

| | | and the second | | | - | | | | 2 | | | | neor | INAWI | IVE CODE | 3 | | |
|------------------------------|-------------------------|--|-----------------|-----------|---------|--------------|-------------|-------------|-----------|-----|---------|--------|------|-------|------------|--------------------------------------|---------|-----------|
| | TURNARC | OUND TIME | PRESERVATIN | ES NOTE | PRESER | ATIVES - | 2 4 | | -5 | | | | | | | | | |
| | REQUIF | REMENTS | 0 No Preserv | ative | | 1 | 15 | N/ | 5 7 | Y | / / | / / | / | / | / / / | | | |
| SAMPLE LOG | REGULAR: | | 1 Hydrochio | ic Acid | | 072 | S. | 5 | X J | 7 / | / | / | / / | / / | // | / / | | |
| | *RUSH: | 5-Day | 2 Nitric Acid | | | 1 all | 2 3 | 26 | 3/ | / | / | | / | / | /// | / / | | |
| AND | | 3-Day | 3 Sulfuric Ac | id | / | a/V | 3 | 47 | 19 | / / | / / | / | 1 | / / | // | / | | |
| | | 2-Dav | 4 Sodium Th | iosulfate | Che Che | 15 | \$ | \$ 3 | / | / | / | / / | ' / | / | /// | / | | |
| ANALYSIS REQUEST | | 1-Dav | 5 Sodium Hy | droxide | 12 | 5 3 | 1.58 | S | / | / / | / / | / | / | / / | / / / | | | |
| | *Bush work needs prior | Laboratory approval and | 6 Zinc Aceta | te / | 3/0 | 35 | 9 | F. | / / | / | / | / / | / / | / | / / | | | |
| | will include surcharges | associatory approval and | 7 EDTA | 100 | \$/ J | 2/3 | 1 | S | / | / | / / | / / | / | / / | / / | | | |
| | NO. & TYPE OF | SAMPLING | SAM | PLE / | E. | 1 3 | 8 | N | / / | | / | / | / / | / / | / | | | |
| SAMPLE ID | CONTAINERS | DATE / TIME M | ATRIX COMP | GRAB | 20 | TEXA | .74 | 1 | / | / | / / | / / | / | / | / | COMM | IENTS | |
| FIELD REAME | 20 | 12-02-08 | WG | 1 | 11 | 11 | 11 | | | | | | | | | | | |
| | | 1.1 | | | | | | | - | | | | - | | 11 | | | |
| | | | | | | | + + | | | - | | | | ++ | | | | |
| | | | | | | | | | | | | | | | | territe and the second second second | | |
| | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | |
| | | | | | 1 | _ | | | | 1 | | | - | | | | | |
| | | | | | | | + | - | | | | | | | | | | |
| | | | | | | | | | _ | | | | | | | | | |
| | | | | | | | | P | 2/ | VO | 1/5 | best | 25 | Pa | r clie | nt- | | |
| | | | | | | | | | | | | | | | | Ste | | |
| 1 1 | | | | | | | | | | | | | | | | 12/ | 23/08 | |
| Tull | morane, | | 9 | 12.23 | 00 | l | <u></u> | | | | doursel | 1 | 1 | | - | | | |
| Relinquished by: (Signature) | Date/Time | Received | w: (Signature) | Date/T | Ime | | Relinquis | shad by: (S | Signature |) | | Date/T | me | | Received b | y: (Signature) | | Date/Time |
| | | / | | | | / | | - | | | FAX | Res | ults | | | 🔀 Ema | ail Res | ults |
| Relinquished by: (Signature) | Date/Time | Received b | iy: (Signature) | Date/T | ime T | emperature l | lpon Antiva | ai | °C | | | | | | | | | |

Fon EX


www.pacelabs.com

Report Prepared for:

Scott Gross REI Consultants, Inc. 225 Industrial Park Dr. Beaver WV 25813

REPORT OF LABORATORY ANALYSIS FOR 2,3,7,8-TCDD

Report Summary:

Enclosed are analytical results of one drinking water sample analyzed for 2,3,7,8-TCDD content. This sample was analyzed according to Method 1613B by High Resolution Gas Chromatography/High Resolution Mass Spectrometry.

The results reported for this sample and the associated quality control samples were all within the criteria described in Method 1613B; with the exception of a blank internal standard recovery below the target range for the method. If you have any questions or concerns regarding these results, please contact Nate Habte, your Pace Project Manager.

Report Prepared Date: January 12, 2009 Pace Analytical Services, Inc. 1700 Elm Street Minneapolis, MN 55414 Phone: 612.607.1700 Fax: 612.607.6444

Report Information:

Pace Project #: 1087000 Sample Receipt Date: 12/30/2008 Client Project #: 0812I02 Client Sub PO #: N/A State Cert #: 9952C

Invoicing & Reporting Options:

The report provided has been invoiced as a Level 2 Drinking Water Report. If an upgrade of this report package is requested, an additional charge may be applied.

Please review the attached invoice for accuracy and forward any questions to Nate Habte, your Pace Project Manager.

This report has been reviewed and prepared by:

For Nate Habte

Nate Habte, Project Manager (612) 607-6407 (612) 607-6444 (fax) natnael.habte@pacelabs.com



Report of Laboratory Analysis

This report should not be reproduced, except in full, without the written consent of Pace Analytical Services, Inc.

The results relate only to the samples included in this report.

| Beaver, WV 25813 | ive | | UIIAIN-UI- | | |
|----------------------------------|--|---|--|---------------------|-----------|
| TEL: 304.255.2500 | FAX: 304.255.2572 | | | · 2 | 18-roc |
| PACE-MN | | | • | | |
| Subcontractor: EMSL_NAL_TICAL | | | | • | |
| 107 HADDON AV | FA FA | X: | | | |
| | | | | | 23-Dec-08 |
| Sample ID | Matrix Date Collected | Bottle Type SW8280 | | Requested Tests | |
| 0812102-01A Dri | king Water 12/23/2008 2:45:09 F | PIALS, PLASTIC, GLA 1 | | | |
| | | 2378 | - TEOD | | |
| • | | | | | |
| | | | | · · · · · | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | \$ |
| | | | | | |
| | | | | | |
| General Commente | | | | | |
| General Comments: | State Code: VA After analysis, the samples do no | t need to be returned and can be d | isposed per your standard la | boratory practices. | |
| General Comments: | State Code: VA After analysis, the samples do no () Me fhod 1613 | t need to be returned and can be din $O(C) = S(coT) + S(coT)$ | isposed per your standard la | boratory practices. | |
| General Comments; | State Code: VA After analysis, the samples do no I Me fhood 1613 | t need to be returned and can be dependent of \mathcal{L}_{1} of \mathcal{L}_{2} | isposed per your standard la $\frac{12}{36} \frac{1}{58}$ | boratory practices. | |
| General Comments: | State Code: VA After analysis, the samples do no I Me thod 1613 | t need to be returned and can be di per Scott G. (e Date/Time | isposed per your standard la $\frac{12}{3} \cdot \frac{1}{58}$ | boratory practices. | Date/Time |
| General Comments: | State Code: VA After analysis, the samples do no I Me thod 1613 | t need to be returned and can be di per Scott Gr. (e Date/Time <u>Pr/ks/bge/Ko</u> t | isposed per your standard la 12/30/08 | boratory practices. | Date/Time |

| | Samples Conclution Upon Reading | |
|--|--|--|
| Analytical Client Nan | ne: <u>RE</u> [| Project # 187.cc |
| Courler: C Fed Ex UPS USPS C Tracking #: 12 26x 713136/6 Custody Seal on Cooler/Box Present: Uy | Client Commercial Pace Other 2 0327 es Pho Seals intact: yes | Octional Proj. Bue Date: Proj. Name |
| Packing Material: Bubble Wrap | ole Bags 🔲 None 🗍 Other | Temp Blank: Yes No |
| Cooler Temperature 80344042, 179425 Temp should be above freezing to 6°C | Type of Ice: (Wet_)Blue None Biological Tissue is Frozen: Yes No Comments: | Samples on Ice, cooling process has begun Date and initials of person exemining contents: 27 30/08 8 10 |
| Chain of Custody Present: | ETYOS IJNO DN/A 1. | and the second |
| Chain of Custody Filled Out: | AYes DNO DN/A 2. | |
| Chain of Gustody Relinguished: | 1 Y85 DNO DN/A 3. | |
| Sampler Name & Signature on COC: | UYes 10 No 01/4 4. | |
| Samples Arrived within Hold Time: | | |
| Short Hold Time Analysis (<72hr): | □Yes 12No 13N/A 6, | • |
| Rush Turn Around Time Requested: | DY88 BNO DINA 7. | |
| Sufficient Volume: | EIYes INO IINA 8. | |
| Correct Containers Used: | DITOS DINO DINA 9. | |
| -Pace Containers Used: | DYOS DINO DNIA | |
| Containers Intact: | ØYes □NO □NA 10. | |
| Filtered volume received for Dissolved tests | Dyes Dito DN/A 11. | |
| Sample Labels match COC: | 2 Yes . No DN/A 12. | |
| Includes date/time/ID/Analysis Matrix: All containers needing acid/base preservation have been checked. Noncompliance are noted in 13. | [] Yes ⊡N/A []3. | |
| All containers needing preservation are found to be in compliance with EPA recommendation. | | |
| Exceptions: VOA, Coliform, TOC, Oil and Grease, Wi-DRO (water) | TYes DNo Initial when completed | Lot # of added preservative |
| Samples checked for dechlorination: | □Yes □N/A 14. | ······································ |
| Headspace in VOA Vials (>6mm): | DYes 20 0 DN/A 15. | |
| Trip Blank Present: | DYes ZINO DNIA 16. | |
| Trip Blank Custody Seals Present | DYes DNO DNA | |
| Pace Trip Blank Lot # (if purchased): | | |
| Client Notification/ Resolution: | <u></u> | Field Data Required? . Y / N |
| Person Contacted: | Date/Time: | NAMA 2 |
| Comments/ Resolution: | | |
| | | |
| Project Manager Review: | <u>(</u>) | Date: 12/30/08 |

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Certification Containers Page 3 of 4

تعريقون ا



Pace AnalyticalServices, Inc. 1700 Elm Street - Suite 200 Minneapolis, MN 55414

Drinking Water Analysis Results 2,3,7,8-TCDD -- USEPA Method 1613B

Tel: 612-607-1700 Fax: 612-607-6444

Sample ID......0812102-01A

Client.....REI Consultants, Inc. Lab Sample ID....1087000001 Date Collected.....12/23/2008 Date Received.....12/30/2008 Date Extracted.....01/05/2009

| | Sample 0812102-01A | Method Blank | Lab Spike | Lab Spike Dup |
|-----------------------|-----------------------|-----------------|--------------|------------------|
| [2,3,7,8-TCDD] | NÐ | ND | | |
| RL | 5 pg/L | 5 pg/L | | |
| 2,3,7,8-TCDD Recovery | | | 99% | 102% |
| Spike Recovery Limit | | | 73-146% | 73-146% |
| RPD | | | 2. | 8% |
| IS Recovery | 60% | 30% ! | 75% | 64% |
| IS Recovery Limits | 31-137% | 31-137% | 25-141% | 25-141% |
| CS Recovery | 87% | 77% | 96% | 83% |
| CS Recovery Limits | 42-164% | 42-164% | 37-158% | 37-158% |
| Filename | R90106A16 | R90106A05 | R90106A03 | R90106A04 |
| Analysis Date | 01/06/2009 | 01/06/2009 | 01/06/2009 | 01/06/2009 |
| Analysis Time | 15:37 | 10:24 | 09:27 | 09:53 |
| Analyst | SMT | SMT | SMT | SMT |
| Volume | 0.955L | 0.900L | 0.907L | 0.913L |
| Dilution | NA | NA | NA | NA |
| ICAL Date | 12/31/2008 | 12/31/2008 | 12/31/2008 | 12/31/2008 |
| CCAL Filename | R90106A02 | R90106A02 | R90106A02 | R90106A02 |

! = Outside the Control Limits

ND = Not Detected

RL = Reporting Limit

- Limits = Control Limits from Method 1613 (10/94 Revision), Tables 6A and 7A
- RPD = Relative Percent Difference of Lab Spike Recoveries
- IS = Internal Standard $[2,3,7,8-TCDD^{-13}C]$
- CS = Cleanup Standard $[2,3,7,8-TCDD-{}^{37}CI^2]$

her mille the Analyst:

Project No.....1087000



the standard in safety

Underwriters Laboratories

LABORATORY REPORT

This report contains, pages. (including the cover page)

If you have any questions concerning this report, please do not hesitate to call us at (800) 332-4345 or (574) 233-4777.

This report may not be reproduced, except in full, without written approval from Underwriters Laboratories Inc. (UL).

Underwinters Laboratories Inc. 110 S. Hill Stroet, South Bend, IR 40817-2702 USA 11: 600-332:43457 Ft; 574,233-82077 W:: vl.com

Ì

Effective Date: October 6, 2008



Laboratory Report

Client: REIC

Attn: Joy Mullins 225 Airport Industrial Park Road P.O. Box 286 Beaver, WV 25813 Report: Priority: Status: PWS ID: 218271 Standard Written Final Not Supplied

Copies to:

None

| | Sample Information | | | | | | | | |
|-----------|--------------------|--------|--------------------------|------------------|-------------------------|--|--|--|--|
| UL ID# | Client ID | Method | Collected Date / Time | Collected By: | Received Date / Time | | | | |
| 1998304 | 0812102-01A | 505 | 12/23/08 14:45 | Client | 12/30/08 09:30 | | | | |
| 1998305 | 0812102-01A | 525.2 | 12/23/08 14:45 | Client | 12/30/08 09:30 | | | | |
| 1998306 | 0812102-01A | 531.1 | 12/23/08 14:45 | Client | 12/30/08 09:30 | | | | |
| 1998307 | 0812102-01A | 547 | 12/23/08 14:45 | Client | 12/30/08 09:30 | | | | |
| 1998308 | 0812102-01A | 548.1 | 12/23/08 14:45 | Client | 12/30/08 09:30 | | | | |
| 1998309 | 0812102-01A | 549.2 | 12/23/08 14:45 | Client | 12/30/08 09:30 | | | | |

Report Summary

Note: Sample containers, except for Method 549.2, were provided by the client.

Note: The samples submitted for Methods 549.2 and 548.1 analysis were analyzed outside the seven day hold time. The client was notified of the situation and analysis was authorized by Scott Gross of REIC.

Note: In the Method 525.2 analysis, heptachlor epoxide is not reportable in the sample submitted due to matrix interference.

Detailed quantitative results are presented on the following pages.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call Traci Chlebowski at (574) 233-4777.

Note: This report may not be reproduced, except in full, without written approval from Underwriters Laboratories (UL).

Authorized Signature

Client Name: Report #:

: REIC 218271

ct Manag

0-09 Date

Page 1 of 2

Underwriters Laboratories Inc. 110 S. Hill Street, South Bend, IN 46617-2702 USA T:: 800.332.4345 / F:: 574.233.8207 / W:: ul.com

Sampling Point: 0812I02-01A

PWS ID: Not Supplied

اند

| S. States and the | Semi-volatile Organic Chemicals | | | | | | | | | | |
|-------------------|---|--------|------------------------|-------|--------|--------|---------------------|----------------|-----------|--|--|
| Analyte ID # | Analyte | Method | Reg Limit | MRL† | Result | Units | Preparation Date | Analyzed | UL ID# | | |
| 12674-11-2 | Aroclor 1016 | 505 | | 0.08 | < 0.08 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 11104-28-2 | Arocior 1221 | 505 | u ar i sa chra | 0.19 | < 0.19 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 11141-16-5 | Aroclor 1232 | 505 | | 0.23 | < 0.23 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 53469-21-9 | Aroclor 1242 | 505 | 6 | 0.26 | < 0.26 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 12672-29-6 | Aroclor 1248 | 505 | | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 11097-69-1 | Aroclor 1254 | 505 | •••• | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 11096-82-5 | Aroclor 1260 | 505 | | 0.2 | < 0.2 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 57-74-9 | Chlordane | 505 | 2* | 0.1 | < 0.1 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 8001-35-2 | Toxaphene | 505 | 3* | 1.0 | < 1.0 | ug/L | 12/31/08 13:50 | 12/31/08 22:54 | 1998304 | | |
| 15972-60-8 | Alachior | 525.2 | 2* | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 309-00-2 | and on the second se | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 1912-24-9 | Atrazine | 525.2 | 3* | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 50-32-8 | Benzo[a]pyrene | 525.2 | 0.2 * | 0.02 | < 0.02 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 58-89-9 | gamma-BHC (Lindane) | 525.2 | 0.2 * | 0.02 | < 0.02 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 23184-66-9 | | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 60-57-1 | | 525.2 | | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 103-23-1 | Di(2-ethylhexyl)adipate | 525.2 | 400 * | , 0,6 | < 0.6 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 117-81-7 | Di(2-ethylhexyl)phthalate | 525.2 | 6* | 0.6 | < 0.6 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 72-20-8 | Endrin | 525.2 | 2 * | 0.01 | < 0.01 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 76-44-8 | Heptachlor | 525.2 | 0.4 * | 0.04 | < 0.04 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 118-74-1 | Hexachlorobenzene | 525.2 | 1* | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 77-47-4 | Hexachlorocyclopentadiene | 525.2 | 50 * | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 72-43-5 | Methoxychlor | 525.2 | 40 * | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 51218-45-2 | Metolachlor | 525.2 | ••• | 0,1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 21087-64-9 | Metribuzin | 525.2 | *** | 0.1 | < 0.1 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 199830 | | |
| 1918-16-7 | Propachlor | 525.2 | | 0.1 | < 0.1 | i ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 122-34-9 | Simazine | 525.2 | 4* | 0.07 | < 0.07 | ug/L | 12/31/08 09:30 | 12/31/08 21:47 | 1998305 | | |
| 116-06-3 | Aldicarb | 531.1 | | 0.5 | < 0.5 | ปg/L | 12/31/08 08:20 | 12/31/08 19:11 | 1998306 | | |
| 1646-88-4 | Aldicarb sulfone | 531.1 | nununuu vi viit | 0.7 | < 0.7 | ug/L | 12/31/08 08:20 | 12/31/08 19:11 | 1998300 | | |
| 1646-87-3 | Aldicarb sulfoxide | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 19:11 | 1998308 | | |
| 63-25-2 | Carbaryl | 531.1 | | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 19:11 | 1998300 | | |
| 1563-66-2 | Carbofuran | 531.1 | 40 • | 0.9 | < 0.9 | ug/L | 12/31/08 08:20 | 12/31/08 19:11 | 1998300 | | |
| 16655-82-6 | 3-Hydroxycarbofuran | 531.1 | *** | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 19:11 | 199830 | | |
| 16752-77-5 | Methomyl | 531.1 | electric Als delectric | 0.5 | < 0.5 | ug/L | 12/31/08 08:20 | 12/31/08 19:11 | 1998300 | | |
| 23135-22-0 | Oxamyl | 531.1 | 200 * | 1.0 | < 1.0 | ug/L | 12/31/08 08:20 | 12/31/08 19:11 | 1998300 | | |
| 1071-83-6 | Glyphosate | 547 | 700 * | 6.0 | < 6.0 | ug/L | 12/31/08 13:00 | 01/02/09 19:47 | 199830 | | |
| 145-73-3 | | 548.1 | 100 * | 9.0 | < 9.0 | ug/L | 12/31/08 08:05 | 01/05/09 19:40 | 199830 | | |
| 85-00-7 | Diquat | 549.2 | 20 * | 0.4 | < 0.4 | ug/L | 12/31/08 08:20 | 12/31/08 13:24 | 1998309 | | |

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

† UL has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

| · · · · · · · · · · · · · · · · · · · | The second strategies a second s | and a second sec | an an anna an an anna an an an an an an | A REPORT AND A CONTRACT OF A REPORT OF A |
|---|--|--|---|--|
| Reg Limit Type: | MCL | SMCL | ł. | AL |
| and the second | and the second | a second s | and the second second second second second second | na anto branche a success a second second second |
| Symbol: | * | (A | | 1 |
| the second se | | · · · · · · · · · · · · · · · · · · · | and the second and the second s | · · · · · · · · · · · · · · · · · · · |



)

CHAIN-OF-CUSTODY RECORD

Page 1 of 1

| REI Consultants, Inc | 2. | |
|---------------------------|-------------------|--|
| 225 Industrial Park Drive | | |
| Beaver, WV 25813 | | |
| TEL: 304.255.2500 | FAX: 304.255.2572 | |

State Code: VA

| Subcontractor: UNDERWRITERS LABORATORIES | | s tel: | (574) 233-477 | 7 | | | | 2182 | 71 | | |
|---|------------------------------|----------------------|------------------------|-----------------|----------|---------|-----------|------------------------|---------------|---------|-----------|
| | 110 SOUTH HII SOUTH BEND, | L STREET IN 46617 | FAX: Acct# | | 10096354 | 1996335 | 10918-300 | 4998 307 | 1998308 | 1998309 | 23-Dec-08 |
| | Sample ID | Matrix | Date Collected | Bottle Type | E505 | E525.2 | E531.1 | equested Test E547) | s (E548.1) | E549.2 | |
| | 0812102-01A | Drinking Water | 12/23/2008 2:45:09 PML | S, PLASTIC, GLA | 1 | | 1 | 1 | 1. | | |

CALL AND AND SHALL SHALL

2.8°C

548+549 nova last day of HT pm

General Comments:

3

After analysis, the samples do not need to be returned and can be disposed per your standard laboratory practices.

| · / Date/Time | Date/Tir | ne |
|--------------------------------|-----------------------------|--------|
| Relinquished by: cf 1/25 / 160 | Too Received by: | |
| Relinquished by: | Received by: fmllf 123008 0 | 730 |
| | 110 | ·····- |

APPENDIX C

Soil Laboratory Test Data

Summary of Laboratory Tests (1 Sheet) Gradation Curves (2 Sheets) Hydraulic Conductivity Determination (2 Sheets)

| Su | Summary Of Laboratory Tests Appendix Sheet 1 of 1 Project Number: 08330106 | | | | | | | | | | |
|---------------|--|----------------|--------------------------------------|------------------------------|-------------------------|--------------|---------------|------------------|----------------------------|---------------------------|---------------------------|
| Boring No. | Sample Depth ft Elevation ft | Sample Type | Description of Soil Specimen | Wet Natural Density (pcf) | Natural Moisture (%) | Liquid Limit | Plastic Limit | Plasticity Index | % Passing No. 200 Sieve | % Passing No. 40 Sieve | % Retained No. 4 Sieve |
| MW-1 | 55.0-57.0 | Tube | LEAN CLAY (CL), contains sand - gray | 116.1 | 37.0 | 38 | 24 | 14 | 98.8 | 99.9 | 0.0 |
| MW-1 | 60.0-62.0 | Tube | LEAN CLAY WITH SAND (CL) - gray | 115.3 | 37.6 | 33 | 23 | 10 | 81.3 | 98.1 | 0.2 |
| Notes: | Notes: 1. Soil tests in general accordance with ASTM standards. 2. Soil classifications are in general accordance with ASTM D2487(as applicable), based on testing indicated and visual classification. 3. Key to abbreviations: NP=Non-Plastic; indicates no test performed | | | | | | | | | | |

المراجعة فيقطع فراف فقوقهم فتنزي والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع

;



. .

• •

.



.

· .

• • •

| chnabel | Hydraulic Con | ductivity De | etermination | | | | |
|--|---|---------------------------------------|--|-----------|--|--|--|
| Using Flexible Wall Permeameter (ASTM D5084) | | | | | | | |
| Project: | Battlefield Golf Club Water P | Project | Schnabel No.: | 08330106 | | | |
| | Bonney Road and Murray Dr | onney Road and Murray Drive | | MW-1 | | | |
| Location: | Chesapeake, VA | | Depth: | 55-57 ft. | | | |
| | S | pecimen Data | | | | | |
| Specimen Type: | Tube Sample | | Cell Press., psi: | 40.0 | | | |
| Consol. Stress (psi): | 20.0 | | Back Press., psi: | 20.0 | | | |
| Soil Description: | LEAN CLAY (CL), contains s | and - gray | Specific Gravity: | 2.68 | | | |
| Remarks: | Gs assumed. | | | | | | |
| | Initial | Final | | | | | |
| Height (in.): | 1.33 | 1.32 | Liquid Limit (LL): | 38 | | | |
| Diameter (in.): | 2.885 | 2.84 | Plasticity Index (PI): | 14 | | | |
| Volume (in ³): | 8.67 | 8.35 | % < No. 200 Sieve: | 98.8 | | | |
| Volume (cm ³): | 142.1 | 136.8 | | | | | |
| /loist Unit Weight (pcf): | 114.9 | 118.4 | | | | | |
| Moisture Content (%): | 37.0 | 35.9 | | | | | |
| Dry Unit Weight (pcf): | 83.9 | 87.1 | | | | | |
| Saturation: | 100 | 100 | | | | | |
| Void Ratio: | 0.99 | 0.92 | | | | | |
| | ······ | Test Data | | | | | |
| | Permeant: | De-Aired Water | | | | | |
| | Hydraulic Gradient: | 5 | | | | | |
| Hydraulic | Conductivity (k _{20C}), cm/sec: | 8.3E-07 | | | | | |
| | Hydraulic | Conductivity vs. F | low | | | | |
| 1.0E-05 | | | | | | | |
| | | | | | | | |
| | ······································ | · · · · · · · · · · · · · · · · · · · | ······································ | | | | |
| , ci | ······ | | | | | | |
| (k200C) | | | | | | | |
| vity | | | | | | | |
| 1.0E-06 | | | | | | | |
| Sond | | · · · · · · · · · · · · · · · · · · · | ······ | | | | |
| iii | | | | | | | |
| dran | | | | | | | |
| <i>≩</i> | | | | | | | |
| | | | | <u></u> | | | |
| 1.00-07 | | | | | | | |

FlexPerm 8/2006 Rev. 1

| Schnabel | Hydraulic Cor | nductivity De | etermination | |
|---------------------------------------|--|----------------------|---------------------------------------|------------|
| Schnabel Engineering | Using Elexible W | /all Permeameter | (ASTM D5084) | 12/22/2008 |
| Projec | t. Battlefield Golf Club Water | Proiect | Schnabel No : | 08330106 |
| | Ronney Road and Murray I | Drive | Boring No : | MW-1 |
| Locatio | n: Chesaneake VA | 5///0 | Denth: | 60-62 ft |
| | in onocapount, pri | | 00 02 11 | |
| Specimen Tvo | e: Tube Sample | | Cell Press., psi: | 45.0 |
| Consol, Stress (ps | i): 25.0 | - | Back Press., psi: | 20.0 |
| Soil Descriptio | n: LEAN CLAY WITH SAND (| - ′CL) - arav | Specific Gravity: | 2.68 |
| | | <u>/</u> | | |
| Remark | s: Gs assumed. | | | |
| | · · · · · · · · · · · · · · · · · · · | | | |
| | | T | | |
| · · · · · · · · · · · · · · · · · · · | Initial | Final | | |
| Height (in | .): 1.34 | 1.31 | Liquid Limit (LL): | 33 |
| Diameter (in | .): 2.886 | 2.78 | Plasticity Index (PI): | 10 |
| Volume (in | ?): <u>8.75</u> | 7.97 | % < No. 200 Sieve: | 81.3 |
| Volume (cm | '): <u>143.3</u> | 130.6 | | |
| Moist Unit Weight (pc | f): <u>117.0</u> | 127.9 | | |
| Moisture Content (% | b): 29.5 | 28.9 | | |
| Dry Unit Weight (pc | f): 90.4 | 99.2 | | |
| Saturatio | n: 93 | 100 | | |
| Void Rati | 0.85 | 0.69 | _] | |
| | | Test Data | | |
| | Permeant: | De-Aired Water | | |
| | Hydraulic Gradient: | 5 | | |
| Hydraul | ic Conductivity (k _{20C}), cm/sec: | 1.7E-06 | | |
| | | | | |
| | Hydrauli | c Conductivity vs. F | low | |
| 1.0E-05 | | | | |
| | | | | |
| lsec | | | | |
| Ë | | | ····· | |
| 50C) ³ | | | | |
| ty (F | *++ | •• | | |
| 3 1.0E-06 | | | | |
| ng | | | · · · · · · · · · · · · · · · · · · · | |
| <u>ů</u> | | | | |
| | | | | |
| Hydr | · | | ····· | ., |
| - | | | | |
| 1.0E-07 | | | | |
| 0.0 | 0.2 0.4 0.6 | 0.8 1.0 | 1.2 1.4 1.6 | 1.8 2.0 |
| | | Flow, cu. cm | | |
| | | | | |

FlexPerm 8/2006 Rev. 1

APPENDIX G Existing Well Groundwater Quality Data

 Table 1: Existing Well Information

 Water Supply Feasibility Study

 Murray Drive -- Whittamore Road Project
 City of Chesapeake, VA

| | Well Donth | Scroon Interval | Viold |
|----------------------|------------|---|---------------------------------------|
| Address | (ft bgs) | (ft bgs) | (gpm) |
| Blue Ridge Road | | | |
| 1505 Blue Ridge | 60 | 50-60 | ····· |
| 1521 Blue Ridge | 93 | 60-70 | |
| Centerville Turnpike | | an sha an | ······ |
| 815 Centerville | 60 | 50-60 | · · · · · · · · · · · · · · · · · · · |
| 1020 Centerville | 80 | 70-80 | |
| 1104 Centerville | 105 | 95-105 | |
| Murray Drive | | har ann an | |
| 1101 Murray | 123 | 100-123 | 1999 |
| 1104 Murray | 122 | 107-122 | 18 |
| 1204 Murray | 80 | 67-80 | 12 |
| 1205 Murray | | 70-80 | |
| 1208 Murray | 50 | 40-50 | 25 |
| 1212 Murray | | 46 | |
| 1215 Murray | 43 | 38-43 | 25 |
| 1220 Murray | | 42 | |
| 1300 Murray | 80 | 75-80 | |
| 1304 Murray | | 45 | |
| 1305 Murray | 42 | 32-42 | 25 |
| 1312 Murray | | 45 | ····· |
| 1313 Murray | 80 | 50-80 | 20 |
| 1316 Murray | 130 | 70-130 | 20 |
| 1317 Murray | 48 | 43-48 | 25 |
| 1320 Murray | 80 | 65-80 | 18 |
| 1324 Murray | 90 | 85-90 | 10 |
| 1325 Murray | 32 | 25-32 | 15 |
| 1328 Murray | 45 | 35-45 | 20 |
| 1329 Murray | 53 | 42-53 | |
| 1379 Murray | 53 | 42-53 | 20 |
| Whittamore Road | | | |
| 1405 Whittamore | 55 | 40-55 | 10 |
| 1407 Whittamore | 41 | 20-40 | |
| 1469 Whittamore | 42 | 37-42 | |

SUMMARY

| # of wells w/ screen interval info | 29 |
|------------------------------------|--------|
| Screen interval =20-40 ft bgs | 4 |
| =40-70 ft bgs | 16 |
| =70-90 ft bgs | 5 |
| >100 ft bgs | 4 |
| Average well depth= | 71 ft |
| # of wells w/ yield data | 14 |
| Average yield= | 19 gpm |

· · · . •

R:\VA_Chesapeake\20602001\Eng_Data\Analytical Data\Existing Well Info.xls

. . . .

. •

Table 2: Existing Well Water Quality

Water Supply Feasibility Study

Murray Drive -- Whittamore Road Project

City of Chesapeake, VA

| Address | Dete | 4.0 | Re | C - | Cd | Dh | 60 | 1.0 | v | Ha | B | 6 | Mo | NI | 70 | Sh | Ro | TI | C 11 | Fo | CN | E |
|------------------|----------|---------|---------|------------|----------|---------|----------|----------|---------|----------|--------|---------|---------|---------|---------|---------|----------|---------|-------------|----------|---------|--------|
| Address | Date | (ma/L) | (mg/L) | (ma/L) | (ma/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) |
| Primary MCL | | 0.010 | 2.000 | 0.100 | 0.005 | 0.015 | 0.050 | 1, | N/A | 0.002 | (| N/A | | N/A | | 0.006 | 0.004 | 0.002 | 1.3 | (| 0.2 | 4 |
| Secondary MCL | | | | | | | | 0.100 | | | | | 0.050 | | 5.000 | | | | | 0.3 | | 2 |
| WHO | | | | | | | | | | | 0.500 | | | | | | | | | | | |
| Blue Ridge Ro | bad | | | | | | | | | | | | | | | | | | | | | |
| 1505 Blue Ridge | 12/05/01 | < 0.002 | <0.1 | < 0.0005 | 0.0005 | < 0.001 | < 0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | 0,26 | < 0.05 | 0.034 | < 0.003 | 0.0008 | < 0.001 | < 0.015 | 1.1.1944 | < 0.005 | <0.1 |
| 1521 Blue Ridge | 12/04/01 | <0.002 | <0.1 | < 0.0005 | < 0.0001 | < 0.001 | <0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | < 0.001 | < 0.015 | <0.1 | < 0.005 | <0.1 |
| 1533 Blue Ridge | 04/14/08 | < | 0.0740 | < | < | < | < | < | < | < | 0.2000 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| Centerville Tu | rnpike | | | | | | | | | | | | | | | | | | | | | |
| 815 Centerville | 12/03/01 | 0.004 | <0.1 | 0.001 | 0.0001 | 0.003 | <0.002 | <0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | < 0.05 | <0.015 | < 0.003 | <0.0001 | < 0.001 | <0.015 | <0.1 | < 0.005 | <0.1 |
| 833 Centerville | 04/08/08 | < | 0.0260 | < | < | < | < | < | < | < | 0.0340 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 901 Centerville | 04/08/08 | < | < | < | < | 0.0100 | < | < | < | < | 0.0840 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 905 Centerville | 12/04/01 | <0.002 | <0.1 | < 0.0005 | 0.0002 | 0.005 | <0.002 | <0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | < 0.05 | <0.015 | < 0.003 | <0.0001 | < 0.001 | 0.115 | <0.1 | <0.005 | <0.1 |
| 909 Centerville | 04/14/08 | < | < | < | < | 0.0020 | < | < | < | < | 0.0580 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 911 Centerville | 04/14/08 | < | < | < | < | < | < | < | < | < | 0.0190 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1004 Centerville | 12/05/01 | <0.002 | <0.1 | < 0.0005 | <0.0001 | 0.009 | < 0.002 | <0.0002 | NT | <0.0002 | NT | NT | 0.17 | < 0.05 | 0.04 | < 0.003 | 0.0005 | <0.001 | 0.402 | 5.55 | < 0.005 | <0.1 |
| 1004 Centerville | 12/05/01 | < 0.002 | <0.1 | <0.0005 | <0.0001 | 0.002 | <0.002 | <0.0002 | NT | < 0.0002 | NT | NT | 0.18 | < 0.05 | 0.04 | < 0.003 | 0.0005 | < 0.001 | 0.362 | B.67 | < 0.005 | <0.1 |
| 1020 Centerville | 12/03/01 | <0.002 | <0.1 | <0.0005 | 0.0002 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | NI | NI | 0.07 | <0.05 | <0.015 | <0.003 | <0.0001 | <0.001 | <0.015 | 1.97 | <0.005 | <0.1 |
| 1102 Centerville | 04/07/08 | < | < | < | < | < | < 0.002 | < | | < 0.0002 | 0.0410 | | | NI | NI | INI | NI | NI | NI | INI | NI | NI |
| 1104 Centerville | 04/08/08 | <0.002 | <0.1 | 0.001 | 0.0001 | 0.001 | <0.002 | <0.0002 | | <0.0002 | 0.0530 | NT | 0.04 | NT | NT | <0.003 | NT | NT | NT | NT | <0.005 | NT |
| 1200 Centerville | 04/08/08 | | ~ | ~ | ~ | 0.0020 | | ~ | ~ | ~ | 0.0550 | NT | NT | | NT | NT | NT | NT | NT | NT | NT | NT |
| 1200 Centerville | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.0440 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1216 Centerville | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.0450 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1224 Centerville | 12/04/01 | <0.002 | <0.1 | <0.0005 | < 0.0001 | <0.001 | < 0.002 | <0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | <0.05 | < 0.015 | < 0.003 | <0.0001 | < 0.001 | < 0.015 | <0.1 | <0.005 | <0.1 |
| 1224 Centerville | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.0440 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1228 Centerville | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.0450 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| Murray Drive | | | | | | | | | | | | | | | | | | | | | | |
| 1101 Murray | 12/10/01 | < 0.002 | <0.1 | < 0.0005 | < 0.0001 | <0.001 | < 0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | < 0.001 | <0.015 | 0.19 | < 0.005 | 0.24 |
| 1101 Murray | 04/06/08 | < | 0.1020 | < | < | < | < | < | < | < | < | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1101 Murray | 04/06/08 | < | 0.0690 | < | 0.0015 | 0.0020 | < | < | < | < | 0.0200 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1101 Murray | 07/18/08 | <0.0020 | <0.005 | <0.001 | <0.0005 | <0.001 | <0.0020 | < 0.001 | <0.005 | <0.0002 | 0.108 | < 0.005 | < 0.005 | < 0.005 | <0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1101 Murray | 07/18/08 | <0.0020 | 0.083 | <0.001 | <0.0005 | 0.001 | < 0.0020 | < 0.001 | < 0.005 | < 0.0002 | 0.022 | < 0.005 | 0.250 | < 0.005 | < 0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1104 Murray | 12/06/01 | < 0.002 | <0.1 | < 0.0005 | <0.0001 | < 0.001 | < 0.002 | <0.0002 | NT | <0.0002 | NT | NT | < 0.03 | < 0.05 | <0.015 | < 0.003 | < 0.0001 | < 0.001 | <0.015 | <0.1 | <0.005 | 0.24 |
| 1104 Murray | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.1370 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1104 Murray | 07/18/08 | <0.0020 | < 0.005 | <0.001 | <0.0005 | 0.011 | <0.0020 | <0.001 | < 0.005 | < 0.0002 | 0.148 | < 0.005 | < 0.005 | < 0.005 | 0.147 | NT | NT | NT | NT | NT | NT | NT |
| 1105 Murray | 11/30/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | 0.001 | < 0.002 | <0.0002 | NT | <0.0002 | NT | NT | < 0.03 | <0.05 | < 0.015 | < 0.003 | < 0.0001 | 0.001 | 0.069 | <0.1 | < 0.005 | 0.17 |
| 1105 Murray | 04/07/08 | < | < | < | < | < | < | < | < | < | 0.1500 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1105 Murray | 07/18/08 | <0.0020 | <0.005 | <0.001 | <0.0005 | < 0.001 | < 0.0020 | <0.001 | <0.005 | <0.0002 | 0.159 | < 0.005 | <0.005 | < 0.005 | 0.009 | NT | NT | NT | NT | NT | NT | NT |
| 1108 Murray | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.1150 | NT | NT | I NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1108 Murray | 07/18/08 | <0.0020 | <0.005 | <0.001 | <0.0005 | <0.001 | <0.0020 | <0.001 | <0.005 | <0.0002 | 0.122 | <0.005 | 0.007 | <0.005 | 0.010 | NT | NT | NT | NT | NT | NT | NT |
| 1109 Murray | 04/07/08 | < 0.000 | 0.0100 | < | 0.0005 | 0.0010 | < | < | < | < 0.0000 | 0.0180 | NI | NI | NI | NI | N1 | NI | NI | NI | NI | NI | NI |
| 1112 Murray | 12/04/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | 0 1420 | NI | <0.03 | <0.05 | <0.015 | <0.003 | <0.0001 | <0.001 | <0.015 | 0.19 | <0.005 | 0.2 |
| 1112 Multay | 04/07/08 | 5 | S | 5 | 5 | 1 | | 1 | < | < | 0.1430 | IN1 | | INI | INI | INT | IN I | IN I | INI | NI | IN I | INI |

R:\VA_C

2

4

¥.

| | | | | | | | | | 1 | 1 | | 1 | | 1 | - | | | | | | | |
|----------------------|----------|----------|---------|----------|----------|----------|-----------|-----------|---------|----------|--------|--------------|---------|---------|---------|---------|----------|---------|---------------|--------|---------|--------|
| | | | | | | | | | | | | | | | | | | | | | | |
| Construction and the | | | | | | | | | | | | | | | | MIC2000 | | | in the second | | | |
| Address | Date | As | Ba | Cr | Cd | Pb | Se | Ag | V | Hg | В | Co | Mn | Ni | Zn | Sb | Be | TI | Cu | Fe | CN | F |
| | | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) |
| Primary MCL | | 0.010 | 2.000 | 0.100 | 0.005 | 0.015 | 0.050 | | N/A | 0.002 | | N/A | | N/A | | 0.006 | 0.004 | 0.002 | 1.3 | | 0.2 | 4 |
| Secondary MCL | | | | | | | | 0.100 | | | | | 0.050 | | 5.000 | | | | | 0.3 | | 2 |
| WHO | | | | | | | | | | | 0.500 | | | | | | | | | | | |
| Murray Drive | | | | | | | | | | | | | | | | | | | | | | |
| 1112 Murrow | 10/04/04 | <0.002 | <0.1 | -0 000E | <0.0004 | 0.001 | <0.002 | 1 <0 0000 | I NT | <0.0002 | NIT | NT | <0.02 | 1 <0.0F | -0.045 | <0.002 | -0.0001 | <0.001 | <0.01E | -0.1 | -0.00F | 0.40 |
| 1113 Murray | 12/04/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | 0.001 | <0.002 | <0.0002 | | <0.0002 | N1 | | <0.03 | <0.05 | 1<0.015 | <0.003 | <0.0001 | <0.001 | <0.015 | <0.1 | <0.005 | 0.16 |
| 1113 Murray | 04/07/08 | < 0.0000 | < 0.005 | ×0.001 | < 0.000F | 0.0010 | < no.0000 | 1 10 001 | ×0.005 | < 0.0000 | 0.1640 | INI I INI | INI INI | NI | | NI | NI | NI | NI | NI | NI | NI |
| 1113 Murray | 07/19/08 | <0.0020 | <0.005 | <0.001 | <0.0005 | <0.001 | <0.0020 | <0.001 | <0.005 | <0.0002 | 0.180 | <0.005 | <0.005 | <0.005 | 0.006 | NI | NI | NI | NI | NI | NI | NI |
| 1116 Murray | 12/06/01 | <0.002 | <0.1 | <0.0005 | 0.0001 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | NI | NI | <0.03 | <0.05 | <0.015 | <0.003 | <0.0001 | <0.001 | <0.015 | 0.22 | < 0.005 | 0.24 |
| 1116 Murray | 05/12/08 | < | < | < | < | < | < | < | < | < | 0.1620 | NI | NI | NI | NI | NT | NT | NT | NT | NT | NT | NT |
| 1117 Murray | 12/04/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | < 0.001 | <0.002 | <0.0002 | NT | <0.0002 | NT | NT | < 0.03 | < 0.05 | <0.015 | < 0.003 | <0.0001 | 0.001 | <0.015 | 0.27 | <0.005 | 0.18 |
| 1117 Murray | 04/08/08 | < | < | < | < | < | < | < | < | < | 0.1440 | NT | NT | NT | I NT | NT | NT | NT | NT | NT | NT | NT |
| 1117 Murray | 07/18/08 | <0.0020 | < 0.005 | < 0.001 | <0.0005 | < 0.001 | <0.0020 | < 0.001 | < 0.005 | <0.0002 | 0.158 | < 0.005 | < 0.005 | < 0.005 | < 0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1120 Murray | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.1720 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1120 Murray | 07/18/08 | <0.0020 | < 0.005 | <0.001 | <0.0005 | < 0.001 | <0.0020 | < 0.001 | < 0.005 | <0.0002 | 0.187 | < 0.005 | < 0.005 | < 0.005 | < 0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1121 Murray | 04/07/08 | < | < | < | < | 0.0010 | < | < | < | < | 0.0200 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1124 Murray | 12/06/01 | <0.002 | <0.1 | <0.0005 | 0.0001 | 0.004 | < 0.002 | <0.0002 | NT | <0.0002 | NT | NT | < 0.03 | < 0.05 | 0.021 | < 0.003 | < 0.0001 | <0.001 | <0.015 | 12.31 | <0.005 | 0.26 |
| 1124 Murray | 04/06/08 | < | 0.1220 | < | < | < | < | < | < | < | < | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1124 Murray | 07/18/08 | <0.0020 | < 0.005 | < 0.001 | <0.0005 | <0.001 | <0.0020 | < 0.001 | < 0.005 | <0.0002 | 0.128 | < 0.005 | 0.007 | < 0.005 | <0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1125 Murray | 11/30/01 | <0.002 | <0.1 | <0.0005 | 0.0001 | 0.002 | <0.002 | < 0.0002 | NT | 0.0007 | NT | NT | < 0.03 | < 0.05 | <0.015 | < 0.003 | < 0.0001 | 0.002 | <0.015 | 0.15 | <0.005 | 0.16 |
| 1125 Murray | 04/14/08 | < | < | < | < | < | < | < | < | < | 0.1890 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1200 Murray | 04/06/08 | < | 0.2080 | < | < | < | < | < | < | < | < | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1200 Murray | 07/19/08 | <0.0020 | <0.005 | < 0.001 | < 0.0005 | < 0.001 | <0.0020 | < 0.001 | < 0.005 | <0.0002 | 0.220 | <0.005 | < 0.005 | < 0.005 | <0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1201 Murray | 12/10/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | <0.001 | <0.002 | <0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | < 0.05 | <0.015 | < 0.003 | < 0.0001 | < 0.001 | <0.015 | 0.23 | < 0.005 | 0.29 |
| 1201 Murray | 04/06/08 | < | 0.1950 | < | < | < | < | < | < | < | < | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1201 Murray | 07/19/08 | <0.0020 | < 0.005 | < 0.001 | < 0.0005 | < 0.001 | <0.0020 | < 0.001 | < 0.005 | < 0.0002 | 0.206 | < 0.005 | < 0.005 | < 0.005 | 0.013 | NT | NT | NT | NT | NT | NT | NT |
| 1204 Murray | 12/04/01 | < 0.002 | <0.1 | <0.0005 | < 0.0001 | < 0.001 | < 0.002 | < 0.0002 | NT | <0.0002 | NT | NT | < 0.03 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | < 0.001 | < 0.015 | | <0.005 | 0.25 |
| 1204 Murray | 04/08/08 | < | < | < | < | < | < | < | < | < | 0.1590 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1204 Murray | 07/19/08 | < 0.0020 | < 0.005 | < 0.001 | < 0.0005 | < 0.001 | < 0.0020 | < 0.001 | < 0.005 | < 0.0002 | 0.174 | < 0.005 | 0.008 | < 0.005 | 0.138 | NT | NT | NT | NT | NT | NT | NT |
| 1205 Murray | 04/07/08 | < | < | < | < | < | < | < | < | < | 0.1550 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1205 Murray | 07/19/08 | < 0.0020 | < 0.005 | < 0.001 | < 0.0005 | < 0.001 | <0.0020 | < 0.001 | < 0.005 | < 0.0002 | 0.167 | < 0.005 | 0.006 | < 0.005 | < 0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1208 Murray | 12/04/01 | < 0.002 | <0.1 | 0.001 | < 0.0001 | 0.006 | < 0.002 | 0.0003 | NT | < 0.0002 | NT | NT | 0.11 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | < 0.001 | 1.623 | 1:07 | < 0.005 | 0.19 |
| 1208 Murray | 04/12/08 | < | 0.0070 | < | < | 0.0020 | < | < | < | < | 0.1130 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1209 Murray | 04/06/08 | < | 0.1920 | < | < | ALC: NO. | < | < | < | < | < | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1209 Murray | 07/19/08 | < 0.0020 | < 0.005 | < 0.001 | < 0.0005 | | < 0.0020 | < 0.001 | < 0.005 | <0.0002 | 0.202 | < 0.005 | 0.008 | < 0.005 | < 0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1212 Murray | 04/27/08 | < | 0.0080 | < | < | 0.0050 | < | < | < | < | 0.1310 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1213 Murray | 04/06/08 | < | 0.3960 | < | < | 0.0010 | < | < | < | < | < | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1213 Murray | 04/27/08 | < | < | < | < | 0.0020 | < | < | < | < | 0.4020 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1213 Murray | 07/19/08 | < 0.0020 | < 0.005 | < 0.001 | < 0.0005 | 0.006 | 0.0029 | < 0.001 | <0.005 | < 0.0002 | 0.403 | <0.005 | <0.005 | <0.005 | <0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1215 Murray | 12/06/01 | < 0.002 | <0.1 | < 0.0005 | 0.0004 | < 0.001 | < 0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | <0.05 | 0.026 | <0.003 | <0.0001 | <0.001 | <0.015 | <0.1 | <0.005 | 0.29 |
| 1215 Murray | 04/06/08 | < | 0.1040 | < | < | < | < | < | < | < | < | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1215 Murray | 07/18/08 | <0.0020 | 0.017 | <0.001 | <0.0005 | <0.001 | <0.0020 | <0.001 | <0.005 | <0.0002 | 0.116 | <0.005 | 0 119 | <0.005 | <0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1216 Murray | 04/07/08 | < | < | < | < | < | < | < | < | < | 0.2940 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1216 Murray | 04/27/08 | < | < | < | < | 0.0020 | < | < | < | < | 0.3010 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1216 Murray | 07/19/08 | <0.0020 | <0.005 | <0.001 | <0.0005 | <0.001 | 0.0020 | <0.001 | <0.005 | <0.0002 | 0.305 | <0.005 | 0.010 | <0.005 | <0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1219 Murray | 04/12/08 | < | 0.0120 | < | < | < | < | < | < | < | 0.0800 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1220 Murray | 04/07/08 | < | 0.0120 | < | < | < | < | < | ~ | ~ | 0.1040 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1220 Murray | 07/18/08 | <0.0020 | 0.012 | <0.001 | <0.0005 | 0.004 | <0.0020 | <0.001 | <0.005 | <0.0002 | 0.112 | <0.005 | 0.000 | <0.005 | 0.112 | NT | NT | NT | NT | NT | NIT | NT |
| 1220 Mullay | 01110/00 | -0.0020 | 0.012 | -0.001 | -0.0003 | 0.004 | -0.0020 | -0.001 | -0.005 | -0.0002 | 0.115 | 1-0.005 | 0.030 | -0.005 | 0.113 | | INT | INT | INT | INI | INI | INT |

.

•

5

| | | | | 1 | 1 | 1 | 1 | 1 | | 1 | | 1 | T | | | | | | 1 | - | | |
|-----------------|----------|---------|----------|----------|---------------|------------------|-----------|-----------|--------|-----------------|---------|---------------|-------------|-----------|---------|---------|---|---------|---------|---------|---|--------|
| | | | | | | | | | | | | | | | | | | | | | | 1 |
| Address | Date | Δs | Ba | Cr | Cd | Pb | Se | Aa | V | На | в | Co | Mn | Ni | Zn | Sb | Be | TI | Cu | Fe | CN | F |
| Address | Buto | (mg/L) | (mg/L) | (mg/L) | (ma/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (ma/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (ma/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) |
| Primary MCL | | 0.010 | 2.000 | 0.100 | 0.005 | 0.015 | 0.050 | (| N/A | 0.002 | (| N/A | 1 (| N/A | 1 | 0.006 | 0.004 | 0.002 | 1.3 | (| 0.2 | 4 |
| Secondary MCL | | | | | | | | 0,100 | 1 | | | | 0.050 | | 5.000 | | | | | 0.3 | | 2 |
| WHO | | | | | | | | - | 1 | | 0.500 | | 1 0.000 | | | | | | | | | |
| Menney Duise | | | | | | | | | | | | - | | | | | | | | | | |
| Murray Drive | 11/00/04 | | | | 0.0004 | 1 .0 004 | 1 .0.000 | | 1 117 | 1 .0 0000 | | 1 117 | 0.00 | | | | | 0.004 | | | | 0.10 |
| 1300 Murray | 11/30/01 | <0.002 | <0.1 | <0.0005 | 0.0001 | <0.001 | <0.002 | <0.0002 | | <0.0002 | NI | NI | 0.28 | <0.05 | <0.015 | <0.003 | <0.0001 | 0.001 | <0.015 | 1.88 | <0.005 | 0.12 |
| 1300 Murray | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.0670 | NI | NI | NI | NI | NI | NI | NI | NI | NI | NI | NI |
| 1301 Murray | 11/30/01 | <0.002 | <0.1 | <0.0005 | 0.0001 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | NI | NI | <0.03 | <0.05 | <0.015 | <0.003 | <0.0001 | 0.002 | <0.015 | 81.27 | <0.005 | 0.23 |
| 1301 Murray | 04/07/08 | < | < | < | < | 0.0010 | < | < | < | < | 0.5600 | NI | NI | NI | NI | | NI | NI | NI | NI | NI | NI |
| 1301 Murray | 07/19/08 | <0.002 | <0.005 | <0.001 | <0.0005 | 0.001 | 0.0045 | <0.001 | <0.005 | <0.0002 | 0.586 | <0.005 | <0.005 | <0.005 | <0.005 | | NI | | NI | NI | NI | NI |
| 1304 Murray | 04/14/08 | < | < | < | < | 0.0040 | < | < | < | < | 0.0420 | NI | | | NI | | | | NI | | | NI |
| 1304 Murray | 04/27/08 | < | 0.0160 | < | < | 0.0040 | < | < | < | < | 0.0500 | NI | | NI | | | | | NI | NI | NI | NI |
| 1305 Murray | 04/12/08 | < | < | < | < | < | < | < | < | < | 0.0490 | NI | | NI | | NI | | NI | | NI | NI | NI |
| 1305 Murray | 04/12/08 | < | 0.0210 | < | < | 0.0030 | < | < | < | < | 0.0680 | NI | NI I | NI I | INI INI | NI | NI I 10 0001 | NI | NI | NI | NI | NI |
| 1308 Murray | 12/10/01 | <0.002 | <0.1 | <0.0005 | 0.0004 | 0.003 | <0.002 | <0.0002 | NI | <0.0002 | NI OFFO | NI | <0.03 | <0.05 | <0.015 | <0.003 | <0.0001 | <0.001 | 1.04 | <0.1 | <0.005 | 0.36 |
| 1308 Murray | 04/27/08 | < | 0.0220 | < | 0.0008 | 0.0020 | < | < | < | < | 0.0550 | NI | NI | NI | NI | NI | NI | NI | NI | NI | NI | NI |
| 1309 Murray | 04/12/08 | < | 0.0240 | <u> </u> | < <u><</u> | 0.0020 | < | < | < | < | 0.0490 | INT | | I INI | INI | | | | NI | NI | NI | NI |
| 1312 Murray | 04/14/08 | < | 0.0780 | < | 0.0010 | 0.0070 | < | < | < | < | 0.0500 | NI | NI | NI | NI | NI | NI | | NI | NI | NI | NI |
| 1313 Murray | 04/12/08 | < | 0.0140 | < | 0.0008 | < | < | < | < | < | < | NI | | NI | | NI | NI | NI | NI | NI | NI | NI |
| 1316 Murray | 04/08/08 | < | 0.0300 | < | 0.0010 | < | < | < | < | < | 0.0090 | NI | NI | NI | NI | NI | NI | NI | NI | NI | NI | NT |
| 1317 Murray | 11/30/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | NI | NI | 0.23 | < 0.05 | <0.015 | <0.003 | <0.0001 | 0.001 | <0.015 | TE | <0.005 | 0.23 |
| 1317 Murray | 04/06/08 | < | 0.0180 | < | 0.0007 | < | < | < | < | < | 0.0200 | NI | NI | NI | NI | NI | NI | NI | NI | NT | NT | NT |
| 1320 Murray | 11/30/01 | <0.002 | <0.1 | <0.0005 | 0.0002 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | NI | NI | <0.03 | <0.05 | <0.015 | <0.003 | <0.0001 | 0.002 | 0.051 | 0.16 | <0.005 | 0.12 |
| 1320 Murray | 04/08/08 | < | < | < | < | < | < | < | < | < | 0.2150 | NI | NI 0.047 | NI | NI | NI | | | NI | NI | NI | NT |
| 1320 Murray | 07/19/08 | <0.0020 | 0.027 | <0.001 | <0.0005 | 0.0040 | <0.0020 | <0.001 | <0.005 | <0.0002 | 0.269 | <0.005 | 0.017 | <0.005 | 0.021 | NI | | | NI | NI | NT | NT |
| 1321 Murray | 04/08/08 | < | < | < | < | 0.0010 | < | < | < NT | < | 0.0070 | NI | NI | NI | NI | NI | NI | NI | NI | NI | NI | NI |
| 1324 Murray | 12/03/01 | <0.002 | <0.1 | <0.0005 | 0.0001 | 0.002 | <0.002 | <0.0002 | NI | <0.0002 | | NI | <0.03 | <0.05 | <0.015 | <0.003 | <0.0001 | <0.001 | <0.015 | <0.1 | <0.005 | 0.17 |
| 1324 Murray | 04/06/08 | | 0.0110 | ~ | 0.0000 | Statement of the | ~ | | < | ~ | 0.0130 | NT | | | | | | NI | | | | NI |
| 1324 Murray | 14/27/06 | <0.002 | 0.0110 | <0.0005 | 0.0008 | <0.001 | <0.000 | 1 -0 0000 | NT | < 0.0000 | 0.0200 | NI | IN1 | INI CO OF | INI | NI | INI | INI INI | INI INI | NI IO I | NI | NI |
| 1325 Murray | 04/12/09 | <0.002 | <u> </u> | <0.0005 | 0.0001 | <0.001 | <0.002 | <0.0002 | INI | <0.0002 | 0.0000 | NIT | 1 <0.03 | <0.05 | 1<0.015 | <0.003 | 140.0001 | <0.001 | <0.015 | <0.1 | <0.005 | 0.25 |
| 1325 Murray | 07/10/08 | <0.0020 | 0.0100 | <0.001 | <0.0012 | 0.001 | <0.0020 | <0.001 | <0.005 | <0.0002 | 0.0090 | NI | 0.209 | <0.005 | 0.011 | INT | INT | INT | INT | INT | INT | NI |
| 1229 Murray | 07/19/00 | -0.0020 | 0.009 | -0.001 | -0.0005 | 0.001 | 1 -0.0020 | -0.001 | -0.005 | 1 0.0002 | 0.010 | 1 < 0.005 | 0.290 | <0.005 | 0.011 | | | | | | | |
| 1320 Murray | 12/10/01 | <0.002 | <0.1 | 0.001 | 0.0001 | <0.001 | <0.002 | 1 <0 0002 | NT | <0.0002 | NT | NIT | <0.02 | <0.05 | <0.015 | <0.002 | <0.0001 | 0.000 | <0.015 | <0.1 | <0.005 | 0.27 |
| 1329 Murray | 04/06/08 | <0.002 | <0.1 | 0.001 | 0.0001 | <0.001 | <0.002 | ~0.0002 | | <0.0002 | 0.0140 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | 0.57 |
| 1320 Murray | 05/12/08 | | 0.0110 | | 0.0000 | | | | | | 0.0140 | NT | NT | | NT | NT | | NT | NT | NT | NT | NIT |
| 1379 Murray | 00/12/00 | | 0.0110 | | 0.0003 | | | | | | 0.0130 | INT | INI | | INI | INI | | INT. | | INT | INT | INT |
| Mhittomore B | and | | | | | | | | | | | | | | L | | | | | | | |
| Wintlamore R | Jau | 0.000 | -0.4 | 0.0005 | | 0.000 | | | 1 117 | | L | 1 1 1 1 1 1 1 | | | | | | | | | | |
| 1109 Whittamore | 11/30/01 | 0.003 | <0.1 | <0.0005 | <0.0001 | 0.002 | <0.002 | <0.0002 | NI | <0.0002 | NI | NI | < 0.03 | <0.05 | <0.015 | <0.003 | <0.0001 | <0.001 | <0.015 | <0.1 | <0.005 | <0.1 |
| 1109 Whittamore | 04/07/08 | < | 0.0610 | < | < | 0.0090 | < | < | < | < | 0.0210 | NI | NI | NI | NT | NT | NT | NT | NT | NT | NT | NT |
| 1204 Whittamore | 12/04/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | 0.001 | <0.002 | <0.0002 | NI | <0.0002 | NI | NI | <0.03 | < 0.05 | 0.036 | < 0.003 | <0.0001 | <0.001 | <0.015 | 1 2 6 - | < 0.005 | 0.17 |
| 1404 Whittamore | 04/07/08 | < | 0.0230 | < | < | < | < | < | < | < | 0.0530 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1405 Whittamore | 11/30/01 | <0.002 | <0.1 | <0.0005 | 0.0002 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | NT | NT | < 0.03 | < 0.05 | <0.015 | < 0.003 | < 0.0001 | 0.001 | <0.015 | <0.1 | < 0.005 | 0.12 |
| 1407 Whittamore | 11/30/01 | <0.002 | <0.1 | <0.0005 | 0.0001 | <0.001 | <0.002 | <0.0002 | NI | <0.0002 | NT | NT | <0.03 | <0.05 | <0.015 | < 0.003 | <0.0001 | <0.001 | <0.015 | 0.34 | <0.005 | <0.1 |
| 1408 Whittamore | 04/27/08 | < | 0.0600 | < | < | 0.0010 | < | < | < | < | 0.0870 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1411 Whittamore | 04/12/08 | < | 0.0460 | < | < | 0.0130 | < | < | < | < | 0.1330 | NI | NI | NI | NT | NT | NT | NT | NT | NT | NT | NT |
| 1412 Whittamore | 04/07/08 | < | 0.0590 | < | < | 0.0010 | < | < | < | < | 0.1840 | NI | NI | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1419 Whittamore | 05/12/08 | < | 0.0120 | < | < | < | < | < | < | < | 0.0510 | NT | I NT | I NT | I NT | I NT | I NT | I NT | L NT | NT | NT | NT |

R:\VA_(

| r | | 1 | | | | - | 1 | 1 | 1 | | | 1 | r | 1 | | _ | | | 1 | 1 | 1 1 | |
|-----------------|----------|----------|--------|----------|----------|---------|---------------|----------|---------------|----------|--------|---------|--------|---------|---------|---------|----------|---------|---------|------------|----------|--------|
| | | | | | | | | | | | | | | | | | | | | | | |
| | - | 1 | - | | ~ . | - | | | | | _ | | | | _ | ~ | 100 | | 100 | | | - |
| Address | Date | AS | ва | Cr | Ca | PD | Se | Ag | V | Hg | В | Co | Mn | NI | Zn | SD | Ве | II | Cu | Fe | CN | F |
| Primary MCI | | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) N/Δ | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) |
| Secondary MCL | | 0.010 | 2.000 | 0.100 | 0.000 | 0.010 | 0.000 | 0 100 | 1.11 | 0.002 | | | 0.050 | 11/1 | 5 000 | 0.000 | 0.004 | 0.002 | 1.0 | 0.3 | 0.2 | 2 |
| WHO | | | | | | | | 0.100 | | | 0.500 | - | 0.000 | | 0.000 | _ | | | | 0.0 | <u> </u> | - |
| | | | | | | | | | 1 | | 0.000 | | | | | | | _ | | | | |
| Whittamore Ro | bad | | | | | | | | | | | | | | | | | | | | | |
| 1420 Whittamore | 12/06/01 | < 0.002 | <0.1 | <0.0005 | <0.0001 | 0.001 | <0.002 | <0.0002 | NT | <0.0002 | NT | NT | 0.29 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | < 0.001 | <0.015 | still Life | <0.005 | 0.15 |
| 1420 Whittamore | 12/06/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | 0.001 | <0.002 | <0.0002 | NT | <0.0002 | NT | NT | 0.26 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | < 0.001 | < 0.015 | 1.12 | <0.005 | 0.18 |
| 1420 Whittamore | 04/08/08 | < | 0.0430 | < | < | < | < | < | < | < | 0.9050 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1428 Whittamore | 04/12/08 | < | 0.0300 | < | < | < | < | < | < | < | 0.6120 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1428 Whittamore | 07/18/08 | <0.0020 | 0.032 | < 0.001 | <0.0005 | < 0.001 | <0.0020 | < 0.001 | < 0.005 | <0.0002 | 0.713 | < 0.005 | 0.181 | < 0.005 | < 0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1433 Whittamore | 11/30/01 | < 0.002 | <0.1 | < 0.0005 | 0.0002 | 0.001 | < 0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | 0.001 | <0.015 | <0.1 | <0.005 | 0.11 |
| 1436 Whittamore | 12/06/01 | < 0.002 | <0.1 | < 0.0005 | 0.0002 | 0.010 | < 0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | <0.05 | <0.015 | < 0.003 | < 0.0001 | < 0.001 | <0.015 | <0.1 | <0.005 | 0.17 |
| 1436 Whittamore | 12/06/01 | < 0.002 | <0.1 | < 0.0005 | < 0.0001 | 0.001 | < 0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | < 0.03 | < 0.05 | < 0.015 | < 0.003 | < 0.0001 | < 0.001 | < 0.015 | <0.1 | < 0.005 | 0.18 |
| 1436 Whittamore | 04/12/08 | < | 0.0150 | < | < | < | < | < | < | < | 0.3290 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1436 Whittamore | 07/18/08 | < 0.0020 | 0.025 | < 0.001 | < 0.0005 | < 0.001 | < 0.0020 | < 0.001 | < 0.005 | < 0.0002 | 0.385 | < 0.005 | 0.138 | < 0.005 | < 0.005 | | | | | | | |
| 1437 Whittamore | 04/27/08 | < | 0.0740 | < | < | 0.0010 | < | < | < | < | 0.0450 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1439 Whittamore | 04/07/08 | < | 0.0220 | < | < | 0.0010 | < | < | < | < | 0.0140 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1440 Whittamore | 04/14/08 | < | 0.0910 | < | < | < | < | < | < | < | 0.0290 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1441 Whittamore | 11/30/01 | < 0.002 | < 0.1 | < 0.0005 | < 0.0001 | < 0.001 | < 0.002 | < 0.0002 | NT | < 0.0002 | NT | NT | 0.08 | < 0.05 | 0.021 | < 0.003 | < 0.0001 | 0.001 | 0.032 | 0.8 | < 0.005 | 0.1 |
| 1441 Whittamore | 04/14/08 | < | < | < | < | 0.0010 | < | < | < | < | 0.0220 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1443 Whittamore | 04/07/08 | < | 0.0190 | < | < | 0.0030 | < | < | < | < | 0.0060 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1445 Whittamore | 04/06/08 | < | 0.0120 | < | < | 0.0010 | < | < | < | < | 0.0370 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1448 Whittamore | 04/06/08 | < | 0.0370 | 0.0010 | < | 0.0020 | < | < | < | < | 0.0450 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1451 Whittamore | 04/14/08 | < | 0.0220 | < | < | < | < | < | < | < | 0.0770 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1453 Whittamore | 04/14/08 | < | < | < | < | 0.0030 | < | < | < | < | 0.0410 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1457 Whittamore | 04/06/08 | < | < | < | < | < | < | < | < | < | 0.0280 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1457 Whittamore | 04/27/08 | < | 0.0220 | < | < | 0.0020 | < | < | < | < | 0.0320 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1461 Whittamore | 04/07/08 | < | 0.0230 | < | < | < | < | < | < | < | 0.0330 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1463 Whittamore | 04/07/08 | < | 0.0220 | < | < | < | < | < | < | < | 0.0160 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1465 Whittamore | 04/07/08 | < | 0.0200 | < | < | < | < | < | < | < | 0.0250 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1469 Whittamore | 12/06/01 | <0.002 | <0.1 | <0.0005 | <0.0001 | <0.001 | <0.002 | <0.0002 | NT | <0.0002 | NT | NT | 01 | <0.05 | <0.015 | <0.003 | <0.0001 | <0.001 | 0.03 | 1.14 | <0.005 | 0.21 |
| 1473 Whittamore | 12/10/01 | <0.002 | <0.1 | 0.008 | <0.0001 | 0.008 | <0.002 | 0.0004 | NT | <0.0002 | NT | NT | <0.03 | <0.05 | 0.04 | <0.003 | <0.0001 | <0.001 | 0 447 | 0.24 | <0.005 | 0.24 |
| 1473 Whittamore | 04/07/08 | < | 0.0140 | < | < | 0.0010 | < | < | < | < | 0.0140 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1605 Whittamore | 04/14/08 | 2 | 0.0360 | 6 | ~ | < | < | < | ~ | 1 | 0.1210 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1600 Whittamore | 04/12/08 | | 0.0350 | | - | 0.0020 | | 2 | | | 0.1130 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT |
| 1600 Whittomore | 07/12/08 | <0.0020 | 0.0330 | <0.001 | <0.0005 | 0.0020 | <0.0020 | <0.001 | <0.005 | 1<0.0002 | 0.1128 | <0.005 | 0.721 | <0.005 | 0.012 | NT | NT | NT | NT | NT | NT | NT |
| 1609 Whittamore | 0//10/08 | 10.0020 | 0.034 | 1 10.001 | <0.0005 | 0.002 | <0.0020 | 1 -0.001 | -0.005 | 10.0002 | 0.120 | NT | NT | -0.003 | NT | NT | NT | NT | I NT | NT | NT | NT |
| 1612 Whittomere | 07/10/08 | 100000 | 0.0300 | 20.001 | <0.0005 | 20.001 | <0.0020 | <0.001 | <0.005 | <0.0002 | 0.1030 | <0.005 | 0.212 | <0.005 | <0.005 | NT | NT | NT | NT | NT | NT | NT |
| 1612 Whittemore | 07/19/08 | 10.0020 | 0.029 | <0.001 | 0.0005 | <0.001 | <0.0020 | 1 10.001 | 1 < 0.005 | 10.0002 | 0.110 | NT | U.213 | NT | NIT | | | NT | | | NT | NT |
| 1613 Whitteman | 04/14/08 | | 0.0190 | | 0.0013 | | \rightarrow | | | | 0.0740 | NIT | NT | NT | NT | NT | | NT | NT | NT | NT | NT |
| 1621 Whittemore | 04/08/08 | < | 0.0110 | < < | 0.0005 | | | | | | 0.0100 | NT | NT | NT | NT | NT | NT | NT | NT | NT | NT | NIT |
| 1629 Whittamore | 04/14/08 | < | 0.0330 | | < | ~ | ~ | | | | 0.0780 | | | | INI | | | | INI | INT | IN I | INT |
| Fentress Road | | | | | | | | | | | | | - | | | | | | | | | |
| 1441 Fentress | 12/04/01 | <0.002 | <0.1 | < 0.0005 | < 0.0001 | 0.002 | < 0.002 | <0.0002 | NT | < 0.0002 | NT NT | NT | 0.230 | < 0.05 | <0.015 | < 0.003 | < 0.0001 | < 0.001 | < 0.015 | 3.2 | <0.005 | <0.1 |

Re-test without softener.

į,

4

ξ.

Barn or irrigation water source NT - Not tested for this analyte



Improving the environment, one client at a time...

SCHNABEL ENGINEERING SOUTH LLC

225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: <u>www.reiclabs.com</u>

÷.,

|208 HURRAY DR WELL SCREEN 40-50Ft Columbia Aquifer

TEL: (757) 947-1220 FAX (757) 947-1220

Mr. Russell Rountree

300 ED WRIGHT LN SUITE 1 NEWPORT NEWS VA 23606

RE: 08330106

Dear Mr. Russell Rountree:

Order No.: 0812H94

REI Consultants, Inc. received 1 sample(s) on 12/23/2008 for the analyses presented in the following report.

Please note two changes you may see on your report.

- Results for "Dissolved" parameters will be shown under a separate sample ID, rather than as a separate analysis under the same sample ID. The sample ID for "Dissolved" parameters will include "Field Filtered" or "Lab Filtered", as appropriate.
- Metals results will no longer be identified as "Total" or "Total Recoverable". The methods have not been changed, only their appearance on the report.

If you have any questions regarding these results, please do not hesitate to call.

Sincerely,

hac Rus

Scott Gross Project Manager





225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: <u>www.reiclabs.com</u>

Improving the environment, one client at a time...

| Report Narrative | Project Manager:: | Scott Gross | here c | Man | WO#: Date: | 0812H94 |
|-------------------------|-------------------|-------------|--------|-----|---------------|---------|
| | | | | | | |

CLIENT:SCHNABEL ENGINEERING SOUTH LLProject:08330106

All analyses were performed using documented laboratory SOPs that incorporate appropriate quality control procedures as described in the applicable methods. REI Consultants, Inc. (REIC) technical managers have verified compliance of reported results with the REIC's Quality Program and SOPs, except as noted in this case narrative. Any deviation from compliance is explained below and/or identified within the body of this report by a qualifier footnote which is defined at the bottom of each page.

All samples were analyzed using the methods stated in the analytical report without modification, unless otherwise noted.

All sample results are reported on an "as-received" wet weight basis unless otherwise noted.

Results reported for sums of individual parameters, such as Total Trihalomethanes (TTHM) and Total Haloacetic Acids (HAA5), may vary slightly from the sum of the individual parameter results. This apparent anomaly is caused by rounding individual results and summations at reporting, as required by EPA.

Following standard laboratory protocol, sample preservation, such as pH, is verified at time of extraction or analysis based on client requested parameters. Improper preservation is noted on the analytical bench sheet, extraction log, or preservation log and client is notified by close of following business day. All results are reported using preservation compliant samples unless otherwise noted in the analytical report.

The test results in this report meet all NELAP requirements for parameters for which accreditations are required or available. Any exceptions are noted in this report. This report may not be reproduced, except in full, without the written approval of REIC.

In compliance with federal guidelines and standard operating procedures, all reports, including raw data and supporting quality control, will be disposed of after five years unless otherwise arranged by the client via written notification or contract requirement.

If you have any questions please contact the project manager whose name is listed above.

| CLIENT: S | SOUTH LLC | Work | Order: | 0812H9 |)4 | | |
|------------------------|-------------------|--------|--------|----------|-----------|-----------|------------------------|
| Client Sample ID: 1 | 208 MURRAY DRIVE | | | Lab II |): | 0812H9 | 94-01A |
| Project: 0 | 8330106 | | | Collect | tion Date | : 12/22/2 | 008 4:25:00 PM |
| Site ID: C | HESAPEAKE WATER | MAIN | I, VA | Matrix | c: | DRINK | ING WATER |
| Analyses | F | Result | Units | Qual | MDL | PQL | Date Analyzed |
| | | | | F200 7 | | | Analyst: BP |
| Aluminum | | 0.267 | ma/L | * | NA | 0.100 | 12/31/2008 12:32:00 AM |
| Boron | | 0.111 | ma/L | | NA | 0.100 | 12/31/2008 12:32:00 AM |
| Iron | | 1.79 | ma/L | * | NA | 0.100 | 12/31/2008 12:32:00 AM |
| Magnesium | | 18.9 | ma/L | | NA | 0.500 | 12/31/2008 12:32:00 AM |
| Manganese | | 0.186 | ma/L | * | NA | 0.050 | 12/31/2008 12:32:00 AM |
| Silica (as SiO2) | | 27.6 | ma/L | | NA | 0.210 | 12/29/2008 2:52:00 PM |
| Sodium | | 81.1 | mg/L | | NA | 0.500 | 12/31/2008 12:32:00 AM |
| METALS BY ICP-MS | ì | | | E200.8 | | | Analyst: BM |
| Antimony | | ND | ma/L | | NA | 0.0010 | 12/29/2008 4:19:09 PM |
| Arsenic | | ND | ma/L | | NA | 0.0050 | 12/29/2008 4:19:09 PM |
| Barium | | ND | ma/L | | NA | 0.100 | 12/29/2008 4:19:09 PM |
| Bervillium | | ND | ma/L | | NA | 0.0020 | 12/29/2008 4:19:09 PM |
| Cadmium | | ND | mg/L | | NA | 0.0010 | 12/29/2008 4:19:09 PM |
| Chromium | (| 0.0071 | mg/L | | NA | 0.0050 | 12/29/2008 4:19:09 PM |
| - Cobalt | | ND | mg/L | | NA | 0.100 | 12/29/2008 4:19:09 PM |
| ~ Copper | | ND | mg/L | | NA | 0.0500 | 12/29/2008 4:19:09 PM |
| Lead | | ND | mg/L | | NA | 0.0050 | 12/29/2008 4:19:09 PM |
| Molvbdenum | | ND | mg/L | | NA | 0.100 | 12/29/2008 4:19:09 PM |
| Nickel | | ND | mg/L | | NA | 0.0100 | 12/29/2008 4:19:09 PM |
| Selenium | | ND | mg/L | | NA | 0.0050 | 12/29/2008 4:19:09 PM |
| Silver | | ND | mg/L | | NA | 0.0500 | 12/29/2008 4:19:09 PM |
| Thallium | | ND | mg/L | | NA | 0.0010 | 12/29/2008 4:19:09 PM |
| Vanadium | | ND | mg/L | | NA | 0.0500 | 12/29/2008 4:19:09 PM |
| Zinc | (| 0.0218 | mg/L | | NA | 0.0100 | 12/29/2008 4:19:09 PM |
| HARDNESS, CALCIL | JM | | | SM2340 B | | | Analyst: BP |
| Hardness, Calcium (As | CaCO3) | 104 | mg/L | | NA | 1.00 | 12/31/2008 12:32:00 AM |
| HARDNESS | | | | SM2340 B | | | Analyst: BP |
| Hardness, Total (As Ca | aCO3) | 182 | mg/L | | NA | 1.00 | 12/31/2008 12:32:00 AM |
| MERCURY, TOTAL | | | | E245.1 | | | Analyst: CGW |
| Mercury | | ND | mg/L | | NA | 0.0010 | 12/30/2008 10:50:00 AM |
| SEMIVOLATILE OR | GANIC COMPOUNDS B | Y EPA | N N | E504.1 | | | Analyst: JG |
| 1,2-Dibromo-3-chloropr | opane | ND | mg/L | | NA C | .000020 | 1/2/2009 6:07:05 PM |
| 1,2-Dibromoethane | | ND | mg/L | | NA C | .000020 | 1/2/2009 6:07:05 PM |

REI Consultants. Inc. **Analytical Results**

Date: 08-Jan-09

MCL Maximum Contaminant Level MDL Minimum Deteo

Not Applicable

Key:

NA

ND

В

*

Analyte detected in the associated Method Blank Estimated Value above quantitation range

Value exceeds Maximum Contaminant Level

. 9

Holdinghings for proparation or analysis exceeded Spike Surrogate Recovery outside accepted recovery limits

Not Detected at the POL or MDI PQL Practical Quantitation Limit

TIC Tentatively Identified Compound, Estimated Concentration

on Limî

Page 2 of 4

| CLIENT: SCHNABEL F Client Sample ID: 1208 MURRA Project: 08330106 Site ID: CHESAPEAK Analyses SEMIVOLATILE ORGANIC COM 2,4,5-TP (Silvex) | ENGINEERING S Y DRIVE E WATER MAIN Result POUNDS ND ND ND ND ND | SOUTH L J, VA Units mg/L mg/L mg/L mg/L mg/L mg/L | LC Work(Lab ID Collect Matrix Qual E515.1 | Drder: ion Da : MDL NA NA NA | 0812H94 0812H94 te: 12/22/20 DRINKI PQL 0.000607 0.000121 0.00789 | -01A 08 4:25:00 PM NG WATER Date Analyzed Analyst: JG 12/30/2008 12/30/2008 |
|--|--|---|---|--|--|---|
| Client Sample ID: 1208 MURRA Project: 08330106 Site ID: CHESAPEAK Analyses SEMIVOLATILE ORGANIC COM 2,4,5-TP (Silvex) | Y DRIVE E WATER MAIN Result POUNDS ND ND ND ND ND ND | J, VA Units mg/L mg/L mg/L mg/L mg/L mg/L | Lab ID Collect Matrix Qual E515.1 | : ion Da : MDL NA NA NA | 0812H94 te: 12/22/20 DRINKII PQL 0.000607 0.000121 0.00789 | -01A 08 4:25:00 PM NG WATER Date Analyzed Analyst: JG 12/30/2008 12/30/2008 |
| Project: 08330106 Site ID: CHESAPEAK Analyses SEMIVOLATILE ORGANIC COM | E WATER MAIN Result POUNDS ND ND ND ND ND ND | J, VA Units mg/L mg/L mg/L mg/L mg/L mg/L | Collect Matrix Qual E515.1 | ion Da : MDL NA NA NA | te: 12/22/20 DRINKI PQL 0.000607 0.000121 0.00789 | 08 4:25:00 PM NG WATER Date Analyzed Analyst: JG 12/30/2008 12/30/2008 |
| Site ID: CHESAPEAK Analyses SEMIVOLATILE ORGANIC COM | E WATER MAIN Result POUNDS ND | J, VA Units mg/L mg/L mg/L mg/L mg/L mg/L | Qual E515.1 | MDL NA NA NA | 0.000607 0.000121 0.00789 | Date Analyzed Analyst: JG 12/30/2008 12/30/2008 |
| Analyses SEMIVOLATILE ORGANIC COM 2,4,5-TP (Silvex) | E WATER MAIN Result POUNDS ND ND ND ND ND ND ND ND ND | mg/L mg/L mg/L mg/L mg/L mg/L mg/L | E515.1 | MDL NA NA NA | PQL 0.000607 0.000121 0.00789 | Date Analyzed Analyst: JG 12/30/2008 12/30/2008 |
| Analyses SEMIVOLATILE ORGANIC COM 2,4,5-TP (Silvex) | Result POUNDS ND | Units mg/L mg/L mg/L mg/L mg/L | Qual E515.1 | MDL NA NA NA | PQL 0.000607 0.000121 0.00789 | Date Analyzed Analyst: JG 12/30/2008 12/30/2008 |
| SEMIVOLATILE ORGANIC COM | POUNDS ND ND ND ND NDS ND | mg/L mg/L mg/L mg/L mg/L | E515.1 | NA NA NA | 0.000607 0.000121 0.00789 | Analyst: JG 12/30/2008 12/30/2008 |
| 2,4,5-TP (Silvex) | ND ND ND ND ND NDS | mg/L mg/L mg/L mg/L mg/L mg/L | | NA NA NA | 0.000607 0.000121 0.00789 | 12/30/2008 12/30/2008 |
| | ND ND ND ND NDS ND | mg/L mg/L mg/L mg/L mg/L | | NA NA NA | 0.000121 0.00789 | 12/30/2008 |
| 2,4-D | ND ND ND NDS ND | mg/L mg/L mg/L mg/L | | NA NA | 0.00789 | |
| Dalapon | ND ND NDS ND | mg/L mg/L mg/L | | NA | | 12/30/2008 |
| Dinoseb | ND ND NDS ND | mg/L mg/L | | | 0.000121 | 12/30/2008 |
| Pentachlorophenol | ND NDS ND | mg/L | | NA | 0.000607 | 12/30/2008 |
| Picloram | NDS | | | NA | 0.000607 | 12/30/2008 |
| VOLATILE ORGANIC COMPOUN | ND | | E524.2 | | | Analyst: SDG |
| Benzene | | ua/L | | NA | 1.0 | 12/29/2008 10:46:00 AM |
| Carbon tetrachloride | ND | ua/L | | NA | 1.0 | 12/29/2008 10:46:00 AM |
| 1 2-Dichlorobenzene | ND | ua/L | | NA | 1.0 | 12/29/2008 10:46:00 AM |
| 1 4-Dichlorobenzene | ND | ug/i | | NA | 1.0 | 12/29/2008 10:46:00 AM |
| 1 2-Dichloroethane | | ua/l | | NA | 1.0 | 12/29/2008 10:46:00 AM |
| 1 1-Dichloroethene | | μg/ μα/Ι | | NA | 1.0 | 12/29/2008 10:46:00 AM |
| cis. 1 2-Dichloroethene | | р9/с ца/I | | ΝΔ | 1.0 | 12/20/2008 10:46:00 AM |
| and 1.2 Dichloroothono | | µg/L ug/l | | | 1.0 | 12/20/2008 10:46:00 AM |
| | | µg/L | | | 1.0 | 12/29/2008 10:46:00 AM |
| Ethylbonzono | | µg/⊏ ug/l | | | 1.0 | 12/29/2008 10:46:00 AM |
| Mothylono oblorido | | µg/⊏ µg/l | | | 1.0 | 12/29/2008 10:46:00 AM |
| Shrono | | µg/⊏ ug/l | | | 1.0 | 12/29/2008 10:46:00 AM |
| Tetrapheresthere | | µg/L | | | 1.0 | 12/29/2008 10:46:00 AM |
| Petrachioloethene | 000 | | | 110 | 75 125 | 12/20/2008 10:46:00 AM |
| Sum 1,2-Dichlorobenzene-d4 | 00.2 | | | | 75-125 | 12/29/2008 10:46:00 AM |
| Surr: 4-Bromonuorobenzene | 94.5 | %REC | | | 70-125 | 12/29/2006 10:46.00 AW |
| RESIDUAL CHLORINE - LAB TES | ST, HOLD TIME I | Ξ | SM4500-CL-C | 3 | | Analyst: CC |
| Chlorine, Total Residual | ND | µg/L | | NA | 100 | 12/24/2008 11:30:00 AM |
| TURBIDITY | | | SM2130 B | | | Analyst: CC |
| Turbidity | 2.87 | NTU | * | NA | 0.50 | 12/24/2008 9:30:00 AM |
| COLIFORM BY P/A | | | SM9223 B | | | Analyst: CC |
| Fecal Coliform | ABSENT | NA | | NA | NA | 12/24/2008 2:57:00 PM |
| Total Coliform | ABSENT | NA | | NA | NA | 12/24/2008 2:57:00 PM |
| CYANIDE | | | E335.4 | | | Analyst: BA |
| Cyanide, Total | ND | mg/L | | NA | 0.020 | 12/24/2008 9:00:00 AM |
| ANIONS BY ION CHROMATOGR | APHY | | E300.0 | | | Analyst: CW |
| Chloride | 124 | mg/L | | NA | 5.00 | 12/30/2008 11:04:00 PM |
| MCI Mavimum Contaminant I | aval | | D Anal-ta | detectod | in the proprieted | Mathod Dlank |
| Key: MDL Minimum Contaminant L | | - M | D Analyte | uciccied ed@Value | an une associated l | richlud Diallk |
| NA Not Analicante | | $\Lambda \Lambda$ | HHadino | timbe for | r orenaration area | nalysis exceeded |
| ND Not Depoted at the DOL | | V | d Chiltele | urroate | Recovery outerde | accented recovery limite |
| POI Practical Quantitation Lin | anit | | * Value | vceede M | aximum Conterni | nant Level |
| TIC Tantativaly Identified Con | mound Estimated Or | contration | value e. | reccus IVI | | num LOYOI |

. . . .

. . .

. .

ļ.

.

| REI Cons | Analy | tical Re | esults | Da | te: 08-Jai | n-09 | |
|-------------------|------------------------|----------|-----------|-------------|-------------------|----------|------------------------|
| CLIENT: | SCHNABEL ENGINE | ERING S | SOUTH LLO | C WorkC | Order: | 0812H94 | |
| Client Sample | e ID: 1208 MURRAY DRIV | Е | | Lab ID | : | 0812H94 | I-01A |
| Project: | 08330106 | | | Collect | ion Date: | 12/22/20 | 08 4:25:00 PM |
| Site ID: | CHESAPEAKE WATI | ER MAIN | J, VA | Matrix | : | DRINKI | NG WATER |
| Analyses | | Result | Units | Qual | MDL | PQL | Date Analyzed |
| ANIONS BY IC | ON CHROMATOGRAPHY | | | E300.0 | | | Analyst: CW |
| Fluoride | | 0.33 | mg/L | | NA | 0.20 | 12/30/2008 11:04:00 PM |
| Sulfate | | 24.2 | mg/L | | NA | 5.00 | 12/30/2008 11:04:00 PM |
| ANIONS BY IC | ON CHROMATOGRAPHY | | | E300.0 | | | Analyst: CW |
| Nitrogen, Nitrat | e-Nitrite | ND | mg/L | | NA | 0.10 | 1/1/2009 9:01:00 AM |
| TOTAL DISSO | VED SOLIDS | | | SM2540 C | | | Analyst: DSA |
| Total Dissolved | Solids | 377 | mg/L | | NA | 1 | 12/23/2008 6:05:00 PM |
| | | | | SM2320 B | | | Analyst: DSA |
| Alkalinity, Total | (As CaCO3) | 156 | mg/L | | NA | 1.0 | 12/24/2008 7:45:00 AM |
| CORROSIVITY | Y, LANGELIER INDEX | | | SM2330 B | | | Analyst: IL |
| Langelier Index | | -0.77 | at 20 °C | | NA | NA | 1/5/2009 |
| PH - LAB TES | T, HOLD TIME EXPIRED | | | SM4500-H+-E | 3 | | Analyst: DSA |
| pН | | 6.98 | SU | | NA | NA | 12/24/2008 7:45:00 AM |
| ORGANIC CA | RBON, TOTAL | | | SM5310 C | | | Analyst: DSA |
| Total Organic C | Carbon | 2.01 | mg/L | | NA | 1.00 | 12/24/2008 7:12:00 AM |

| Kev | MCL | Maximum Contaminant Level B Analyte detected in the associated Method Blank |
|------|-----|---|
| ncy. | MDL | Minimum Betechor Limit |
| | NA | Not Applicable |
| | ND | Not Detected at the POL of MDV |
| | PQL | Practical Quantitation Limit * Value exceeds Maximum Contaminant Level |
| | TIC | Tentatively Identified Compound, Estimated Concentration |

£

11

1.

. 7

ł



Improving the environment, one client at a time...

SCHNABEL ENGINEERING SOUTH LLC

225 Industrial Park Drive Beaver, WV 25813 TEL: 304,255.2500 FAX: 304,255.2572 Website: <u>www.reiclabs.com</u>

1204 MURRAY DR. WELL SCREEN 67-8042 YORKTOWN - EASTOVER A GUIFER

TEL: (757) 947-1220 FAX (757) 947-1220

Mr. Russell Rountree

300 ED WRIGHT LN SUITE 1 NEWPORT NEWS VA 23606

RE: 08330106

Dear Mr. Russell Rountree:

Order No.: 0812H90

REI Consultants, Inc. received 1 sample(s) on 12/23/2008 for the analyses presented in the following report.

Please note two changes you may see on your report.

- Results for "Dissolved" parameters will be shown under a separate sample ID, rather than as a separate analysis under the same sample ID. The sample ID for "Dissolved" parameters will include "Field Filtered" or "Lab Filtered", as appropriate.
- Metals results will no longer be identified as "Total" or "Total Recoverable". The methods have not been changed, only their appearance on the report.

If you have any questions regarding these results, please do not hesitate to call.

Sincerely,

Loc C. Mous

Scott Gross Project Manager





225 Industrial Park Drive Beaver, WV 25813 TEL: 304.255.2500 FAX: 304.255.2572 Website: <u>www.reiclabs.com</u>

WO#:

Date:

0812H90

Improving the environment, one client at a time...

Report Narrative Project Manager:: Scott Gross

CLIENT:SCHNABEL ENGINEERING SOUTH LLProject:08330106

All analyses were performed using documented laboratory SOPs that incorporate appropriate quality control procedures as described in the applicable methods. REI Consultants, Inc. (REIC) technical managers have verified compliance of reported results with the REIC's Quality Program and SOPs, except as noted in this case narrative. Any deviation from compliance is explained below and/or identified within the body of this report by a qualifier footnote which is defined at the bottom of each page.

All samples were analyzed using the methods stated in the analytical report without modification, unless otherwise noted.

All sample results are reported on an "as-received" wet weight basis unless otherwise noted.

Results reported for sums of individual parameters, such as Total Trihalomethanes (TTHM) and Total Haloacetic Acids (HAA5), may vary slightly from the sum of the individual parameter results. This apparent anomaly is caused by rounding individual results and summations at reporting, as required by EPA.

Following standard laboratory protocol, sample preservation, such as pH, is verified at time of extraction or analysis based on client requested parameters. Improper preservation is noted on the analytical bench sheet, extraction log, or preservation log and client is notified by close of following business day. All results are reported using preservation compliant samples unless otherwise noted in the analytical report.

The test results in this report meet all NELAP requirements for parameters for which accreditations are required or available. Any exceptions are noted in this report. This report may not be reproduced, except in full, without the written approval of REIC.

In compliance with federal guidelines and standard operating procedures, all reports, including raw data and supporting quality control, will be disposed of after five years unless otherwise arranged by the client via written notification or contract requirement.

If you have any questions please contact the project manager whose name is listed above.

| REI Consulta | nts, Inc. | Analy | ytical Res | sults | D | ate: 08-Ja | 1 n- 09 |
|-----------------------|-------------|-------------|------------|----------|-----------|------------|------------------------|
| CLIENT: | SCHNABEL EN | GINEERING S | SOUTH LLC | Work | Order: | 0812H9 | 0 |
| Client Sample ID: | 1204 MURRAY | DRIVE | | Lab II |): | 0812H9 | 0-01A |
| Project: (| 08330106 | | | Collec | tion Date | · 12/22/20 | 008 4:45:00 PM |
| Site ID: | CHESAPEAKE | WATER MAD | JVA | Matrix | | DRINK | ING WATER |
| | | | ·, · / · | 1414111 | 1. | | |
| Analyses | | Result | Units | Qual | MDL | PQL | Date Analyzed |
| METALS BY ICP | | | | E200.7 | | | Analyst: BP |
| Aluminum | | 0.188 | mg/L | | NA | 0.100 | 12/31/2008 12:27:00 AM |
| Boron | | 0.163 | mg/L | | NA | 0.100 | 12/31/2008 12:27:00 AM |
| Iron | | 0.184 | mg/L | | NA | 0.100 | 12/31/2008 12:27:00 AM |
| Magnesium | | 18.8 | mg/L | | NA | 0.500 | 12/31/2008 12:27:00 AM |
| Manganese | | ND | mg/L | | NA | 0.050 | 12/31/2008 12:27:00 AM |
| Silica (as SiO2) | | 19.2 | mg/L | | NA | 0.210 | 12/29/2008 2:46:00 PM |
| Sodium | | 106 | mg/L | | NA | 0.500 | 12/31/2008 12:27:00 AM |
| METALS BY ICP-M | s | | | E200.8 | | | Analyst: BM |
| Antimony | | ND | mg/L | | NA | 0.0010 | 12/29/2008 4:01:58 PM |
| Arsenic | | ND | mg/L | | NA | 0.0050 | 12/29/2008 4:01:58 PM |
| Barium | | ND | mg/L | | NA | 0.100 | 12/29/2008 4:01:58 PM |
| Beryllium | | ND | mg/L | | NA | 0.0020 | 12/29/2008 4:01:58 PM |
| Cadmium | | ND | mg/L | | NA | 0.0010 | 12/29/2008 4:01:58 PM |
| Chromium | | 0.0052 | mg/L | | NA | 0.0050 | 12/29/2008 4:01:58 PM |
| Cobalt | | ND | mg/L | | NA | 0.100 | 12/29/2008 4:01:58 PM |
| Copper | | ND | mg/L | | NA | 0.0500 | 12/29/2008 4:01:58 PM |
| Lead | | ND | mg/L | | NA | 0.0050 | 12/29/2008 4:01:58 PM |
| Molybdenum | | ND | mg/L | | NA | 0.100 | 12/29/2008 4:01:58 PM |
| Nickel | | ND | mg/L | | NA | 0.0100 | 12/29/2008 4:01:58 PM |
| Selenium | | ND | mg/L | | NA | 0.0050 | 12/29/2008 4:01:58 PM |
| Silver | | ND | mg/L | | NA | 0.0500 | 12/29/2008 4:01:58 PM |
| Thallium | | ND | mg/L | | NA | 0.0010 | 12/29/2008 4:01:58 PM |
| Vanadium | | ND | mg/L | | NA | 0.0500 | 12/29/2008 4:01:58 PM |
| Zinc | | 0.0151 | mg/L | | NA | 0.0100 | 12/29/2008 4:01:58 PM |
| HARDNESS, CALCI | UM | | | SM2340 B | | | Analyst: BP |
| Hardness, Calcium (A | s CaCO3) | 67.4 | mg/L | | NA | 1.00 | 12/31/2008 12:27:00 AM |
| HARDNESS | | | | SM2340 B | | | Analyst: BP |
| Hardness, Total (As C | aCO3) | 145 | mg/L | | NA | 1.00 | 12/31/2008 12:27:00 AM |
| MERCURY, TOTAL | | | | E245.1 | | | Analyst: CGW |
| Mercury | | ND | mg/L | | NA | 0.0010 | 12/30/2008 10:49:00 AM |
| SEMIVOLATILE OR | GANIC COMPO | UNDS BY EPA | N N | E504.1 | | | Analyst: JG |
| 1,2-Dibromo-3-chlorop | oropane | ND | mg/L | | NA 0 | .000020 | 1/2/2009 5:53:07 PM |
| 1,2-Dibromoethane | | ND | mg/L | | NA 0 | .000020 | 1/2/2009 5:53:07 PM |
| | | | | | | | |

В

*

Key: MCL Maximum Contaminant Level

MDL Minimum Detection Limit

NA Not Applicable

ND Not Detected at the PQL or MDI

PQL Practical Quantitation Limit

TIC Tentatively Identified Compound, Estimated Concentration

Estimated Value above quantitation range
 Hoding times for preparation or analysis exceeded
 Spike/surrogate Recovery outside accepted recovery limits

Analyte detected in the associated Method Blank

Value exceeds Maximum Contaminant Level

Page 2 of 4

| REI Consultants, Inc. | | Analytical Results | | | S Date: 08-Jan-09 | | | |
|-----------------------------------|-----------------------------------|--------------------|----------|-------------|--------------------------|-------------|------------------------|--|
| CLIENT: | SCHNABEL ENGINI | EERING S | SOUTH LL | C Work(| Order: | 0812H9 | 00 | |
| Client Sample ID: 1204 MURRAY DRI | | VE | | Lab ID |); | 0812H9 | 00-01A | |
| Project: | 08330106 | | | Collect | tion Da | te: 12/22/2 | 008 4:45:00 PM | |
| Site ID: | Site ID: CHESAPEAKE WATER MAIN VA | | | Matrix | Matrix DRINKING WATER | | | |
| | | | | | | | | |
| Analyses | | Result | Units | Qual | MÐL | PQL | Date Analyzed | |
| SEMIVOLATILE C | RGANIC COMPOUNE | S | | E515.1 | | | Analyst: JG | |
| 2,4,5-TP (Silvex) | | ND | mg/L | | NA | 0.000608 | 12/30/2008 | |
| 2,4-D | | ND | mg/L | | NA | 0.000122 | 12/30/2008 | |
| Dalapon | | ND | mg/L | | NA | 0.00790 | 12/30/2008 | |
| Dinoseb | | ND | mg/L | | NA | 0.000122 | 12/30/2008 | |
| Pentachlorophenol | | ND | mg/L | | NA | 0.000608 | 12/30/2008 | |
| Picloram | | ND | mg/L | | NA | 0.000608 | 12/30/2008 | |
| VOLATILE ORGANIC COMPOUNDS | | E524.2 | | | Analyst: SDG | | | |
| Benzene | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| Carbon tetrachloride | 9 | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| 1,2-Dichlorobenzene | e | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| 1,4-Dichlorobenzene | e | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| 1,2-Dichloroethane | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| 1,1-Dichloroethene | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| cis-1,2-Dichloroethene | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| trans-1,2-Dichloroethene | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| 1,2-Dichloropropane | 9 | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| Ethylbenzene | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| Methylene chloride | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| Styrene | | ND | μg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| Tetrachloroethene | | ND | µg/L | | NA | 1.0 | 12/30/2008 1:37:00 PM | |
| Surr: 1 2-Dichlorobenzene-d4 | | 80.1 | %REC | | | 75-125 | 12/30/2008 1:37:00 PM | |
| Surr: 4-Bromofluc | probenzene | 85.0 | %REC | | | 75-125 | 12/30/2008 1:37:00 PM | |
| RESIDUAL CHLO | RINE - LAB TEST, HOI | LD TIME I | Ē | SM4500-CL-0 | G | | Analyst: CC | |
| Chlorine, Total Resid | dual | ND | µg/L | | NA | 100 | 12/24/2008 10:00:00 AM | |
| TURBIDITY | | | | SM2130 B | | | Analyst: CC | |
| Turbidity | | 0.65 | NTU | * | NA | 0.50 | 12/24/2008 9:30:00 AM | |
| COLIFORM BY P/ | A | | | SM9223 B | | | Analyst: CC | |
| Fecal Coliform | | ABSENT | NA | | NA | NA | 12/24/2008 2:15:00 PM | |
| Total Coliform | | ABSENT | NA | | NA | NA | 12/24/2008 2:15:00 PM | |
| CYANIDE | | | | E335.4 | | | Analyst: BA | |
| Cvanide Total | | ND | ma/l | | NA | 0.020 | 12/24/2008 9:00:00 AM | |
| Sydinas, rotai | | | | | | 0.020 | 1 | |
| ANIONS BY ION C | HROMATOGRAPHY | | | E300.0 | | | Analyst: CW | |
| Chloride | | 136 | mg/L | | NA | 10.0 | 12/29/2008 6:39:00 PM | |
| | | | | | | | | |

MCL Maximum Contaminant Level Key:

ND

. 7

MDL Minimum Detection Limit NA

Estimated Value above quantitation range

Analyte detected in the associated Method Blank

Not Applicable Not Defected at the PQL of MDL

S.

В

*

Holdingtimes for preparation or analysis exceeded Spike/Surrogate Recovery outside accepted recovery limits Value exceeds Maximum Contaminant Level

PQL Practical Quantitation Limit

TIC Tentatively Identified Compound, Estimated Concentration

Page 3 of 4

| REI Consulta | nts, Inc. | Analy | vtical Ro | esults | D | ate: 08-Jai | n-09 | |
|---|-----------------------------------|----------------------|--------------|-------------------|----------|--------------------|--|--|
| CLIENT: S Client Sample ID: 1 | CHNABEL ENGINE 204 MURRAY DRIV | ERING S E | SOUTH LL | C Work(Lab ID | Order: | 0812H90 0812H90 |))-01A | |
| Project: 0 | 8330106 | | | Collect | ion Date | : 12/22/20 | 08 4:45:00 PM | |
| Site ID: | CHESAPEAKE WATH | PEAKE WATER MAIN, VA | | Matrix | Matrix: | | DRINKING WATER | |
| Analyses | | Result | Units | Qual | MDL | PQL | Date Analyzed | |
| ANIONS BY ION CH | ROMATOGRAPHY | | | E300.0 | | | Analyst: CW | |
| Fluoride Sulfate | | 0.46 13.9 | mg/L mg/L | | NA NA | 0.20 5.00 | 12/29/2008 6:39:00 PM 12/29/2008 6:39:00 PM | |
| ANIONS BY ION CH Nitrogen, Nitrate-Nitrite | ROMATOGRAPHY | ND | mg/L | E300.0 | NA | 0.10 | Analyst: CW 1/1/2009 8:42:00 AM | |
| TOTAL DISSOLVED Total Dissolved Solids | SOLIDS | 401 | mg/L | SM2540 C | NA | 1 | Analyst: DSA 12/23/2008 6:05:00 PM | |
| ALKALINITY Alkalinity, Total (As Ca | CO3) | 162 | mg/L | SM2320 B | NA | 1.0 | Analyst: DSA 12/23/2008 3:06:00 PM | |
| CORROSIVITY, LAN Langelier Index | IGELIER INDEX | 0.14 | at 20 °C | SM2330 B | NA | NA | Analyst: IL 1/5/2009 | |
| PH - LAB TEST, HO | LD TIME EXPIRED | 8.07 | SU | SM4500-H+-E | B NA | NA | Analyst: DSA 12/23/2008 3:06:00 PM | |
| ORGANIC CARBON Total Organic Carbon | , TOTAL | 1.45 | mg/L | SM5310 C | NA | 1.00 | Analyst: DSA 12/24/2008 7:12:00 AM | |

MCL Maximum Contaminant Level Key: MDL Minimum Detection Limit

Not Applicable

NA

ND

В Analyte detected in the associated Method Blank Estimated Value above quantitation range

<u>s</u>

*

Holding times for preparation or analysis exceeded

Spike/Surrogate Recovery outside accepted recovery limits

Value exceeds Maximum Contaminant Level

Not Detected at the PQL PQL Practical Quantitation Limit

Tentatively Identified Compound, Estimated Concentration TIC

of MDI

Page 4 of 4

- 6

APPENDIX H Vicinity Groundwater Quality Data from VDEQ

| Form GW-2 | C | OMMONWEA | TH OF VIRGINIA | |
|--|------------------------------|--|---|--|
| 1978-10,000 | WA | TER WELL CO | MPLETION REPORT | ICM No. 234-136 |
| State Water Control Board | (Certi | fication of Con | npletion/County Permit) | |
| P. O. Box 11143 2111 North Hamilton St. | | | SW | CB Permit |
| Richmond, Va. 23230 | | | Cou | Inty Permit |
| county/city ches | apeatre | | Certi Thi | fication of inspecting official: s well does does not |
| \mathcal{A} | | County/C | ity Stamp mee | et code/low requirements. |
| Virginia Plane Coordinates | =0 | ILB | Dat | e |
| F | @Well Designation of | Number 72 | 9-136 | For Office Use |
| Latitude & Longitude | Address | | <u> </u> | |
| 36° 42° CT N | | Sou | <u>11-А</u> Тах | Map I.D. No |
| 710 07 49" W | Phone | | Sub | division |
| Topo. Map No | | CINCR | Sec | tion |
| © Elevationft. | Orilling Contractor 7 11 | 3005 | Bloc | ck |
| © Formation | Address | - 100 TAN | Lot | |
| © Lithology | n ich ha | end us | Clas | s Well 1 , IIA, |
| River Basin | Phone | | IIB | , IIIA, IIIB |
| © Frovince | WELL LOCATION | lfaat/m | iles direction) of | IIIQ II(E |
| Cuttings to la Terret | and | foot/miles /s | irection) of | |
| Water Analysis | (If possible please | include map showi | ng location marked) | |
| Aquifer Test | Date started | • Da | e completed | Type rig Falling (F15 |
| Depth to bedrock Hole size (Also include ream (0, 5) inches from (1, 5) inches from | ed zones) to to | 400 ft. 4000 ft. | Stabilized measured pumping Stabilized yield gpr Natural Flow: Yes No Comment on quality | water levelft n afterhours h, flow rateg pm |
| unches trom | to | ft. | 3. WATER ZONES: From | То |
| ©Casing size (I.D.) and materia | al n | 5 m | FromTo | . From To |
| • <u>7</u> inches from | to | <u>fl.</u> | From To | . From To |
| Wit per foot | or wall thickness | in | 4. USE DATA: | Linear of Marian |
| @ inches from | | f1 | Itrigation East and | Livestock watering |
| Material | | | Manufacturing Fi | re safety Cleaning |
| Wt. per toot | or wall thickness | in. | Recreation Aesthe | tic , Cooling or heating |
| einches from | 10 | ft. | Injection, Other | bsevustion |
| Material | | | Type of facility Domestic | , Public water supply |
| Wt. per foot | _or wall thickness | in. | Public institution | Farm, Industry |
| • Screen size and mesh for eac | h zone (where applicat | 37 . | Commercial, Other | 1 |
| Mesh size | (0 | | 5. PUMP DATA: Type | 9 Rated H.P. |
| inches trom | to | | Intake depth9Capa | cityathead |
| Mesh size | Type | | Pressure tack | 1.00 |
| a inches from | 10 | f1 | Sample tan | , LOC. |
| Mesh size | Туре | ······································ | Well vent Process | |
| o inches from | 10 | ft. | Gate valve Check | valve (when required) |
| Mesh size | Туре | | Electrical disconnect switch | n on power supply |
| [©] Gravel pack | | | 7. DISINFECTION: Well disinfec | ted yes no |
| [©] From | to | ft. | Date, Disin | fectant used |
| @ From | to | ft. | Amount | , Hours used |
| Jut | 6 T | | 8. ABANDONMENT (where appli | cable) © yesno |
| PFrom to | | | Casing pulled yes n | not applicable |
| errom 10 | n., Type | | Plugging grout From | material |

Sow GI-A

Plugging grout From

Groundwater Research Station 77-9 (78-3) Fentress

Total Depth:400' U.S.G.A. 7.5 Quad Fentress Lat: 36'42' 27"

Long: 76°07'49"

| Depth | Geology | Hydraulic Conductivity | |
|--------|--|--|-------------------|
| o-10' | Poorly sorted, Sub-Angular, Silt(80) and Very Fine Sand(20%) to Medium Qu Sand. Trace Hornblende | %) 20 GPD/FT. uartz | .2 |
| 10-20' | Well sorted, Sub-Angular, Fine to Me Quartz Sand. Trace Hornblende, He mat ite, Mica | edium 400 GPD/F | FT. ² |
| 20-30' | Bimodally sorted, Sub-Anagular, Sil and Fine and Medium Quartz sand.(70) Trace Limonite, Magnetite, Chlorite | t(30%) 150 GPD/F1 %) • | т. ² |
| 30-40' | Poorly sorted, Sub-Angular, Silt(209 Coarse (10%) Quartz Sand(40% Medium Trace Glauconite, Magnetite, Mica, (| %) to | r. ² |
| 40-50' | Poorly sorted, Sub-Angular, Silt(609 Very Fine to Coarse (20%) Quartz Sam (Medium Sand 20%)) Glauconite, Iron Stains, Hematite, washed out). | %) to 200 GPD/F1 nd. (Sand | т. ² |
| 50-60' | Poorly sorted, Sub-Angular, Very Fin Quartz Sand. Glauconite, Chlorite. | ne to Coarse 600 GPD/F | FT. ² |
| 60-70' | Poorly sorted, Sub-Angular, Silt (20 Rounded Very Coarse (20%) Quartz Sau sand is 30%) Hornblende, Glauconite, Feldspar. | 9%)to Well 300 GPD/F nd.(Medium | FT. ² |
| 70-80' | Poorly sorted, Sub-Angular, Silt(20) Coarse (20%) Quartz Sand. (Medium Sand is 20%) Limey. Shell Fragments, Glauconite, Magnet | %) to Very 450 GPD/F ite. | гт. ² |
| 80-90 | Poorly sorted, Sub-Angular, Silt(10 Coarse Quartz Sand. (Coarse 30%)(Lir Shell Fragments, Plagioclase Grains Hornblende. | %) to Very 400 GPD/ ney) , Glauconite, | /FT. ² |

-*8
| 90-100 | Poorly sorted, Sub-Angular, Clay and Silt | 100 GPD/FT.2 |
|---|---|---|
| | (30%) to Very Fine (30%) to Coarse Quartz Sand. | |
| | (Limey) Ilmenite, Shell Fragments, Glau c onite, Asbestos (Serpenite) | |
| 100-110 | Poorly sorted, Sub-Angular, Silt (50%)(Fine to Medium Sand)30%) (Very Limey) Echinoid Spines, Glauconite, Shell FRagments (20%),Fish bone, Gypsum. | 20 GPD/FT. ² |
| 110-120 | (Sa m e) Coquina (Very Lim e y) Kyanite Trace | 20 GPD/FT. ² |
| 120-130 | (Same) | 20 GPD/FT. ² |
| 130-140 | Poorly sorted, Sub-Angular, Silt(30%) Very Fine Sand (40%) to Coarse Quartz Sand. (Very Limey) | 30 GPD/FT. ² |
| | Shell Fragments(20%), Fish bone, Echinoid Spines, Magnetite, Silt and Clay Washed Out. | |
| 140-150 | Poorly sorted, Sub-Angular, Clay(20%) and Silt(70%) Coarse sand(5%)(Very Limey) Shell Fragments, (5%), Limonite. | 10 GPD/FT. ² |
| 150-160 160-170 170-180 180-190 | (Same) (Same) More Clay(30%)(No Coarses) (Same) (Same) Glauconite (5%) | 10 GPD/FT.2 1 GPD/FT.2 1 GPD/FT.2 1 GPD/FT.2 1 GPD/FT.2 |
| 190-200 200-210 | (Same) (Same) Glauconite (10%) | 1 GPD/FT. ² 1 GPD/FT. |
| 210-220 220-230 230-240 240-250 250-260 | (Same) Glauconite 20% (Same) (Same) More Clay (Same) (Same) More Clay | 1 GPD/FT.2 1 GPD/FT.2 .8 GPD/FT.2 .8 GPD/FT.2 .5 GPD/FT.2 |
| 260-270 270-280 | (Same) (Sam e) | .5 GPD/FT. ² .5 GPD/FT. ² |
| 280-290 | Poorly sorted, Sub-Angular, Tan(Iron Oxide) Fine to Medium (30%) Quartz Sand and (Clay and Silt)(70%)(Limey) Glauconite<1% | 1.5 GPD/FT. ² |
| 290-300 | Clay (30%) and Silt (60%)(Limonite Nodules 2%) (Limey) 5% Shell and Pebbles. | 1.o GPD/FT. ² |
| 300-310 | (Same) No Limonite(Very Slightly Limey) | 1.0 GPD/FT. ² |
| 310-320 | (Same) Large Well Rounded Pebbles | 1.0 GPD/FT. ² |

۱. ۱

| 320-330 | (Same) | 1.0 GPD/FT. ² |
|---------|---|--------------------------|
| 330-340 | (Same) | .8 GPD/FT. ² |
| 340-400 | (SAme)Gradually Increasing in Clay Content (Very Slightly Limey) | .7 GPD/FT. ² |

TOTAL DEPTH: 400'

| Sample | <u>Time</u> | <u>Time</u> | Sample | Agency | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | Sample |
|--------------|-------------|--------------------|---------------|-------------|-----------------|---------------|------------------|-------------|
| Datetim e | datum | <u>datum</u> | <u>Medium</u> | Collecting | Source | logic | <u>logic</u> | <u>type</u> |
| | | <u>reliability</u> | <u>Code</u> | Sample, | | <u>Event</u> | <u>Condition</u> | |
| | | <u>code</u> | | <u>Code</u> | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1000.02 | ECT | T | WC | USGS- | · 0 | ٥ | Δ | Q |
| 1989-03- | EST | | WG | USGS- | 9 | 9 | A | 9 |
| 2003-08- | EDT | K | WG | WRD | 9 | 9 | A | 9 |

USGS 364227076074701 61B 2 SOW 091A

Chesapeake City, Virginia

Hydrologic Unit Code 03010205 Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 97.0 feet below land surface.

The depth of the hole is 400 feet below land surface.

This well is completed in the UPPER CHESAPEAKE GROUP (121CSPKU) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|--|
| | Less |
| < | than. |
| M | Presence verified but not quantifie d. |

| Value | Descript |
|----------|----------|
| Qualifie | ion |
| r Code | 1011 |

| | Diluted |
|---|----------|
| | sample: |
| | method |
| | hi range |
| d | exceeded |

| 5 | Project | Labor- | | | | | | Specif- | Hydro- |
|---|---------------|-------------|---------|---------|----------------|---------|---------|---------|---------|
| | Code | atory | | | | | | ic | gen |
| | | sample | | | Agency | Flow | Color, | conduc- | ion, |
| | | comme nt | Sam- | Temper- | ana- | rate, | water, | tance, | water, |
| | | | pling | ature, | lyzing | instan- | fltrd, | wat unf | unfltrd |
| | | | depth, | water, | sample, | taneous | Pt-Co | uS/cm | calcd, |
| | · · · | | feet | deg C | code | gal/min | units | 25 degC | mg/L |
| | 1.54 | | (00003) | (00010) | <u>(00028)</u> | (00059) | (00080) | (00095) | (00191) |
| | | RR:CA- | | | | | | | |
| | 4451089 | 7,NA=20 | | 16.8 | 80020 | | 15 | 1650 | 0.00010 |
| | 24829RC X6 | 0 | 50.0 | 18.2 | 80020 | 4.1 | | 1690 | 0.00004 |

| | | | | | ANC, | Carbon- | Bicar- | |
|---------|---------|---------|---------|---------|---------|---------|---------|-------------|
| | Dis- | pH, | pH, | | wat unf | ate, | bonate, | |
| | solved | water, | water, | Carbon | fixed | wat flt | wat fit | Ammoni a |
| Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt | infl pt | water, |
| solved | percent | field, | lab, | water, | field, | titr., | titr., | fltrd, |
| oxygen, | of sat- | std | std | unfltrd | mg/L as | field, | field, | mg/L |
| mg/L | uration | units | units | mg/L | CaCO3 | mg/L | mg/L | as N |
| (00300) | (00301) | (00400) | (00403) | (00405) | (00410) | (00452) | (00453) | (00608) |
| | | | | | | | | |
| | | 7.0 | 7.4 | 57 | 294 | | | 1.20 |
| 2.1 | 23 | 7.4 | 7.5 | | | 0.0 | 331 | |
| | | | | | | | | |

•

| Ammoni a | Nitrate | | | | | | | |
|-------------|-------------------|---------|---------|---------|---------|---------|---------|---------|
| + | + | Phos- | | | | | | |
| org-N, | nitrite | phorus, | Organic | Hard- | | Magnes | | |
| water, | water | water, | carbon, | ness, | Calcium | ium, | Sodium, | Sodium |
| unfitrd | fitrd, | unfltrd | water, | water, | water, | water, | water, | adsorp- |
| mg/L | mg/L | mg/L | unfitrd | mg/L as | fltrd, | fltrd, | fltrd, | tion |
| as N | as N | as P | mg/L | CaCO3 | mg/L | mg/L | mg/L | ratio |
| (00625) | (00631) | (00665) | (00680) | (00900) | (00915) | (00925) | (00930) | (00931) |
| | | | | | | | | |
| 1.2 | <u>< 0.100</u> | 0.25 | 5.6 | 270 | 59.0 | 29.0 | 240 | 6.4 |
| | | | (| 250 | 57.4 | 26.3 | 210 | 5.8 |
| | | | | | | | | |

had

| Potos | Chlor | | Fluor | Cillion | | Iron, | |
|---------|--|--|---|--|--|---|--|
| Potas- | Chlor- | | Fluor- | Silica, | | water, | |
| sium, | ide, | Sulfate | ide, | water, | Boron, | unfltrd | Iron, |
| water, | water, | water, | water, | fltrd, | water, | recover | water, |
| fltrd, | fltrd, | fltrd, | fltrd, | mg/L as | fltrd, | -able, | fltrd, |
| mg/L | mg/L | mg/L | mg/L | SiO2 | ug/L | ug/L | ug/L |
| (00935) | (00940) | (00945) | (00950) | (00955) | (01020) | (01045) | (01046) |
| | | | | | ~ | | |
| 18.0 | 420 | 27.0 | 0.30 | 37.0 | 470) | 5000 | 440 |
| 22.8 | <u>358 d</u> | 14.1 | 0.20 | 42.4 | | | 599 |
| | | | | (| | 300 | |
| | Potas- sium, water, fltrd, mg/L (00935) 18.0 22.8 | Potas- sium,Chlor- ide,sium,ide,water,water,fltrd,fltrd,mg/Lmg/L(00935)(00940)18.042022.8358 d | Potas-Chlor-sium,ide,Sulfatewater,water,water,fltrd,fltrd,fltrd,mg/Lmg/Lmg/L(00935)(00940)(00945)18.042027.022.8358 d14.1 | Potas-Chlor-Fluor-sium,ide,Sulfateide,water,water,water,water,fltrd,fltrd,fltrd,fltrd,mg/Lmg/Lmg/Lmg/L(00935)(00940)(00945)(00950)18.042027.00.3022.8358 d14.10.20 | Potas- Chlor- Fluor- Silica, sium, ide, Sulfate ide, water, water, water, water, water, fltrd, fltrd, fltrd, fltrd, fltrd, mg/L as mg/L mg/L mg/L mg/L siO2 (00935) (00940) (00945) (00950) (00955) 18.0 420 27.0 0.30 37.0 (22.8) | Potas- Chlor- Fluor- Silica, sium, ide, Sulfate ide, water, Boron, water, water, water, water, fltrd, fltrd, water, fltrd, fltrd, fltrd, fltrd, mg/L as fltrd, mg/L mg/L mg/L mg/L SiO2 ug/L (00935) (00940) (00945) (00950) (00955) (01020) 18.0 420 27.0 0.30 37.0 470 22.8 358 d 14.1 0.20 42.4 42.4 | Potas-Chlor-Fluor-Silica,Iron, water,sium,ide,Sulfateide,water,Boron,unfitrdwater,water,water,water,fltrd,water,recoverfltrd,fltrd,fltrd,fltrd,mg/L asfltrd,-able,mg/Lmg/Lmg/LMg/LSiO2ug/Lug/L(00935)(00940)(00945)(00950)(00955)(01020)(01045)18.042027.00.3037.0470500022.8358 d14.10.2042.44705000 |

Sco WHO

| Mangan | | | | Alka- | Depth | Alka- | Residue | Residue |
|---------|---------|---------|---------|---------|---------|---------|-------------|---------|
| ese, | | | | linity, | to | linity, | on | water, |
| water, | Mangan | | Alum- | wat flt | water | wat flt | evap. | fltrd, |
| unfltrd | ese, | Zinc, | inum, | fxd end | level | inf tit | at | sum of |
| recover | water, | water, | water, | lab, | below | field, | 180deg C | consti- |
| -able, | fltrd, | fltrd, | fltrd, | mg/L as | LSD, | mg/L as | wat flt | tuents |
| ug/L | ug/L | ug/L | ug/L | CaCO3 | meters | CaCO3 | mg/L | mg/L |
| (01055) | (01056) | (01090) | (01106) | (29801) | (30210) | (39086) | (70300) | (70301) |
| | | | | | | | | |
| 50 | 15.0 | 8 | 20 | | 2.31 | | 1070 | 1010 |
| | 14.0 | | | 276 | 2.62 | 271 | 930 | 896 |

.

ऽ० २°

| | | | | Pump | | Depth | Depth | Depth |
|---------|-------------|---------|----------------|---------|----------------|---------|---------|---------|
| | | | | or flow | | to top | to bot | to |
| Residue | | | | period | Sam- | sample | sample | water |
| water, | Ammoni a | Bromide | | prior | pling | intrval | intrval | level, |
| fltrd, | water, | water, | Sample | to sam- | condi- | feet | feet | feet |
| tons/ | fltrd, | fltrd, | purpose | pling, | tion, | below | below | below |
| acre-ft | mg/L | mg/L | code | minutes | code | LSD | LSD | LSD |
| (70303) | (71846) | (71870) | <u>(71999)</u> | (72004) | <u>(72006)</u> | (72015) | (72016) | (72019) |
| 1.46 | 1.55 | | | | | 92.00 | 97.00 | 7.58 |
| 1.26 | | 1.14 d | 10.00 | 45 | 0.10 | 97.00 | 92.00 | 8.60 |

| | | | Contraction of the local division of the loc |
|----------------|---------|---------|--|
| | Specif. | ANC, | |
| | conduc- | wat unf | |
| | tance, | fixed | Sulfide |
| Sam- | wat unf | end pt, | water, |
| pling | lab, | lab, | unfltrd |
| method, | uS/cm | mg/L as | field, |
| code | 25 degC | CaCO3 | mg/L |
| <u>(82398)</u> | (90095) | (90410) | (99119) |
| | | | |
| | 1710 | 288 | |
| 4040 | 1620 | | M |

Form GW-2 1978-10,000

| COMMONWEALTH | OF | VIRGINIA | |
|--------------|----|------------|--|
| COMMONTERET | 0. | Villandire | |

WATER WELL COMPLETION REPORT

• BWCM No. 234-65

Sow 91-B

1.1

| State Water Control Board | (Certifica | tion of Com | pletion/County Permit) |
|--|---------------------------|----------------------------------|--|
| P. O. Box 11143 | | | CW/CD Dames |
| 2111 North Hamilton St. Bichmond Va 23230 | | | County Permit |
| | 1 | | |
| county (city) Chi | esepeatre | | Certification of inspecting official: This well does does not |
| | | County/Cit | ty Stamp meet code/low requirements. |
| Virginia Plane Coordinates | 1 | 7 | Date |
| N | Owner Shicks | > | Eas Office Use |
| E | Well Designation or Nur | nber | For Onice Ose |
| Latitude & Longitude | Address | | |
| 36 42 67 N | | | Tax Map I.D. No |
| -7607.99 W | Phone | | Subdivision |
| Topo. Map No | a Deillion Contractor | WCB. | Section |
| Elevationft. | Address 7/11 (M | Tent | Block |
| Pormation | Address Cull TV | - ITS MIL | I Lot |
| B River Besin | hich me | ac | |
| Provinces | Phone | | |
| | WELL LOCATION: | (feet/mil | les direction) of |
| Cuttings Offer Transform 15 | and feet/ | miles (du | rection) of |
| Water Analysis | (If possible please incl | ude map showing | g location marked) |
| Aquifer Test | ~ 1 | | They topy |
| | Date started 5 - (| 0- 19 • Date | e completed Type rig Contine CF-/S |
| N: | | | |
| WELL DATA: New ARev | worked Deepened | | 2. WATER DATA [®] Water temperature |
| • Total depth | | ft. | Static water level (unpumped level-measured) |
| ©Depth to bedrock | | ft. | Stabilized measured pumping water level |
| Hole size (Also include ream | ed zones) | - | Stabilized yield gpm after hou |
| • <u>b.5</u> inches from | n_0to06 | <u>)</u> ft. | Natural Flow: Yes No, flow rate g p |
| Inches from | to | tt. | Comment on quality |
| Inches from | to | ft. | 3. WATER ZONES: From To |
| Casing size (I.D.) and materia | al Int | 4n | From To To |
| • 4 inches from | of_0_ to 105 | ft. | From To From To |
| Material JYC | <u> </u> | | 4. USE DATA: |
| Wt. per foot | or wall thickness | in. | Type of use: Drinking, Livestock Watering |
| inches from | 1 to | ft. | Irrigation Food processing , Household |
| Material | a well thick cost | | Manufacturing, Fire safety, Cleaning |
| wt. per foot | Or wait thickness | in. | Recreation, Aesthetic, Cooling or heating |
| inches from | 10 | | injection Other ODCEVISATION |
| Material | or wall thickness | ia. | • Type of facility. Domestic, Public water supply |
| with per root | b zone (where applicable) | 101. | Public institution Farm, Industry |
| • U inches from | 1040 10 106 | O ft. | E DUMP DATA: The |
| Mesh size | Туре | | 5. FOMP DATA: Type 9 Rated H.P. |
| inches from | to | ft. | 6 WELLHEAD: Type well soot |
| @ Mesh size | Туре | | Pressure tank gal Loc |
| inches from | to | ft | Sample tap Measurement port |
| @ Mesh size | Туре | | Well vent Pressure reli if volve |
| inches trom | to | ft | Gate valve Check valve (when required) |
| Mesh size | Туре | *** | Electrical disconnect switch on power supply |
| Gravel pack | | | 7. DISINFECTION: Well disinfected ves |
| [©] From | to | ft. | Date Disinfectant used |
| © From | to | ft | Amount Hours used |
| @ Grout | | | 8. ABANDONMENT (where applicable) ves no |
| © From to | ft., Type | | Casing pulled yes no not applicable |
| © From to | ft., Type | | Plugging grout From to material |
| | | Contraction of the second second | |

...

79-4(A) Fentress Deptin/ /iimelmin) Description Brown to Grag Clay V/Trace med Sand 0-141,0 10-10/200 Gray med To Coarse Sand aftrace Br. Elay 110-160/ 113.0 Med To Very Comse Sand, Trace Shell Frag. & Glaccowit 160-180/6.0 Fine to Coarse Sand, Shell, Glaucowite attrace Clay 180-230/ Med To Coarse Sand, Shell Froz, a/ Abundant Glaucowite 230-260/10.0 VCS, Shellfing Glouconite 260-280/ 30.0 Hard Liney Commented Clauconite with shell & met To Come Spin 280-300/ Fine Sondy clay of Claucon te & shellfrag. 300-1330/9,0 Gran Clary Trace Fine sand, Shell Fing, Olauccuite. 330-4600/115.0 Gray clany 600 -700 580 Green Clay N/Some Sand ; Blacksmed. 700-750/? Pebbles, shellfray, Gray clay of med To find sand. 780 - 800/? Fine to coarse Sond a/few Pebbles, Shells 800-800/? clong Fine To UCS Bul Few Pebbles Traceshell Frag 580-910/3 Michous Silty Fine to Ves ocasional Pebble 1. 1000/2 Micheous S: Hy Clay 4/ JEDER Course Sand. 1000-1080/2 Gray VCS 4/ Pebbles.

| Sample | <u>Time</u> | <u>Time</u> | Sample | Agency | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | <u>Geo-</u> |
|--------------|-------------|--------------------|---------------|-------------------|-----------------|---------------|---------------|--------------|
| Datetim e | datum_ | <u>datum</u> | <u>Medium</u> | <u>Collecting</u> | Source | logic | logic | logic |
| | | <u>reliability</u> | Code | <u>Sample,</u> | | Event | Condition | <u>unit</u> |
| | | <u>code</u> | | <u>Code</u> | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | A | |
| 2001-03- | EST | т | WG | USGS- WRD | 9 | Х | Х | 211CRCS U |
| 2008-06- | EDT | к | WG | USGS- WRD | 9 | Х | x | 211CRCS U |

USGS 364227076074702 61B 5 SOW 091B

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 1,060 feet below land surface.

The depth of the hole is 1,200 feet below land surface.

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the UPPER CRETACEOUS SERIES (211CRCSU) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|--|
| | Less |
| < | than. |
| | Estimate |
| E | d. |
| M | Presence verified but not quantifie d. |

| ्र भू दु | Value Qualifie r Code | Descript ion |
|----------------|-----------------------------|--|
| | Q | Holding time exceeded |
| | с | See laborator y comment |
| | d | Diluted sample: method hi range exceeded |

| Sample | Project | Labor- | | | | | | |
|--------|---------|-------------|---------|---------|---------|----------------|---------|---------|
| type | Code | atory | | | | | | |
| | | sample | | | Baro- | Agency | Flow | Color, |
| | | comme nt | Temper- | Temper | metric | ana- | rate, | water, |
| | | | ature, | ature, | pres- | lyzing | instan- | fltrd, |
| | | | water, | air, | sure, | sample, | taneous | Pt-Co |
| | | | deg C | deg C | mm Hg | code | gal/min | units |
| | | | (00010) | (00020) | (00025) | <u>(00028)</u> | (00059) | (00080) |
| 0 | 4451089 | | 10 5 | | | 80020 | | 4 |
| | 4451106 | | 10.5 | | | 00020 | | |
| 9 | 00 | | 20.0 | 15.7 | 753 | 80020 | 4.0 | |
| | 24829RC | | | ······ | | | | |
| 9 | 20 | | 21.3 | | 757 | | 6.8 | |

) national aquifer.

| Specif- | Hydro- | | | | | | ANC, | Carbon- |
|---------|---------|---------|---------|---------|---------|---------|---------|-----------|
| ic | gen | | Dis- | pН, | pН, | | wat unf | ate, |
| conduc- | ion, | | solved | water, | water, | Carbon | fixed | wat flt |
| tance, | water, | Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt |
| wat unf | unfltrd | solved | percent | field, | lab, | water, | field, | titr., |
| uS/cm | calcd, | oxygen, | of sat- | std | std | unfltrd | mg/L as | field, |
| 25 degC | mg/L | mg/L | uration | units | units | mg/L | CaCO3 | mg/L |
| (00095) | (00191) | (00300) | (00301) | (00400) | (00403) | (00405) | (00410) | (00452) |
| 6000 | 0.00001 | | | 8.0 | 7.9 | 8.7 | 453 | |
| 5780 | 0.00001 | 0.0 | 0.0 | 7.9 | 8.0 | | | < 1 |
| 5880 | | 0.1 | | 7.9 | 8.1 | | | <u>E2</u> |

| Bicar- | | Ammoni a | Nitrate | | | | | |
|---------|-------------|-------------|-------------------|---------|---------|---------|---------|---------|
| bonate, | | + | + | Phos- | | | | |
| wat flt | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | | Magnes |
| infl pt | water, | water, | water | water, | carbon, | ness, | Calcium | ium, |
| titr., | fltrd, | unfltrd | fltrd, | unfltrd | water, | water, | water, | water, |
| field, | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, | fltrd, |
| mg/L | as N | as N | as N | as P | mg/L | CaCO3 | mg/L | mg/L |
| (00453) | (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00915) | (00925) |
| | 2.20 | 2.0 | <u>< 0.100</u> | 0.03 | 0.5 | 87 | 15.0 | 12.0 |
| 554 | · · · | | | | | 87 | 16.6 | 11.0 |
| E 547 | | | | | | | 15.8 d | 10.9 dc |

オオスキ ひっと とんしきま

| Sodium, water, fltrd, mg/L (00930) | Sodium adsorp- tion ratio (00931) | Sodium frac- tion of cations percent (00932) | Potas- sium, water, fltrd, mg/L (00935) | Chlor- ide, water, fltrd, mg/L (00940) | Sulfate water, fltrd, mg/L (00945) | Fluor- ide, water, fltrd, mg/L (00950) | Silica, water, fltrd, mg/L as SiO2 (00955) | Boron, water, fltrd, ug/L (01020) |
|--|---|--|--|---|--|---|---|---|
| 1100 | 51 | 95 | 25.0 | 1500 | 120 | 1 30 | 13.0 | 3600 |
| 1100 | 55 | 05 | 23.0 | 1540 | 100 | 1 40 | 11.0 | 5000 |
| 1100 | 55 | 95 | 27.5 | 1540 | 109 | 1.49 | 11.0 | |
| <u>1200 d</u> | | | 26.8 dc | <u>1590 d</u> | <u>117 d</u> | 1.43 | <u>10.5 dc</u> | |

| | | Mangan- | | | | Alka- | Depth | Alka- |
|---------|---------|---------|---------|---------|---------|---------------|---------|---------|
| Iron, | | ese, | | | | linity, | to | linity, |
| water, | | water, | Mangan | | Alum- | wat flt | water | wat flt |
| unfltrd | Iron, | unfltrd | ese, | Zinc, | inum, | fxd end | level | inf tit |
| recover | water, | recover | water, | water, | water, | lab, | below | field, |
| -able, | fltrd, | -able, | fitrd, | fltrd, | fltrd, | mg/L as | LSD, | mg/L as |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | CaCO3 | meters | CaCO3 |
| (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (29801) | (30210) | (39086) |
| 760 | 110 | 20 | 20 | 20 | 20 | | 14.7 | |
| | 478 | | 18.9 | | | 462 | 20.8 | 455 |
| | 425 dc | | 11.4 dc | | | <u>454 @c</u> | | 452 |

| Residue | Residue | | | | | Pump | | Depth |
|-------------|---------|---------|-------------|---------------|---------|---------|----------------|---------|
| on | water, | | | | Alti- | or flow | | to top |
| evap. | fltrd, | Residue | | | tude | period | Sam- | sample |
| at | sum of | water, | Ammoni a | Bromide | of | prior | pling | intrval |
| 180deg C | consti- | fitrd, | water, | water, | land | to sam- | condi- | feet |
| wat flt | tuents | tons/ | fltrd, | fltrd, | surface | pling, | tion, | below |
| mg/L | mg/L | acre-ft | mg/L | mg/L | feet | minutes | code | LSD |
| (70300) | (70301) | (70303) | (71846) | (71870) | (72000) | (72004) | <u>(72006)</u> | (72015) |
| 3050 | 3060 | 4.15 | 2.83 | | | | | 1040.00 |
| 2940 | 3170 | 3.99 | | 6.12 | 15.0 | 495 | 8.00 | 1040.00 |
| 3260 | | | | <u>5.92 d</u> | 15.0 | 403 | 8.00 | 1040.00 |

| Depth | Depth | | Specif. | ANC, | |
|---------|---------|----------------|---------|---------|-----------|
| to bot | to | | conduc- | wat unf | |
| sample | water | | tance, | fixed | Sulfide |
| intrval | level, | | wat unf | end pt, | water, |
| feet | feet | Sampler | lab, | lab, | unfitrd |
| below | below | type, | uS/cm | mg/L as | field, |
| LSD | LSD | code | 25 degC | CaCO3 | mg/L |
| (72016) | (72019) | <u>(84164)</u> | (90095) | (90410) | (99119) |
| 1060.00 | 48.21 | | 5740 | 463 | |
| 1060.00 | 68.30 | 4040 | 5720 | | |
| 1060.00 | 77.60 | 4040 | 5840 | | <u>M_</u> |

- - 3

Form GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

• BWCM No. 234-66

200 91-C

8 Y.

1. 1.1

(Certification of Completion/County Permit)

| A Water Control Board | (Certification | of Com | pletion/County Permit) | |
|---|---|------------|--------------------------|---------------------------------------|
| North Hamilton St | | | | SWCB Permit |
| Richmond, Va. 23230 | | | | County Permit |
| | N- | | | Certification of inspecting official: |
| County/City Ches | sapeake | | | This well does does not |
| | Ca | ounty/Cit | ty Stamp | meet code/low requirements. |
| [©] Virginia Plane Coordinates | CI | 1 | | Date |
| N | Owner tentress | obs. 0 | UC | Eas Office Line |
| E | Well Designation or Number | | | For Onice Ose |
| Latitude & Longitude | Address | | | |
| 3642 2.8 N | | | | Tax Map I.D. No |
| 7607 49 W | Phone | | | Subdivision |
| Topo. Map No | S(A) | c 8 | | Section |
| © Elevationft. | Drilling Contractor 300 | 00 | | Block |
| © Formation | Address | | | Lot |
| © Lithology | | | | Class Well: 1, IIA, |
| River Basin | Phone | | | 118, 111A, 111B |
| Province | | | | |
| ©Type LogsD | WELL LOCATION: | _feet/mile | esdirection) of | |
| Cuttings ho | andfeet/miles_ | (dir | rection) of | |
| Water Analysis | (if possible please include ma | ap snowing | g location marked) | |
| Aquifer Test | 5 | | E/24/7 | a - ist |
| Depth to bedrock | ed zones) | ft. | ©Stabilized measured p | umping water level1 |
| e size (Also include ream | ed zones) | | Stabilized yield | gpm afterhour |
| a inches from | to | ft. | Natural Flow: Yes | No flow rateg pn |
| ainches from | to | ft. | Comment on quality_ | tystes salty |
| inches from | to | ft. | 3. WATER ZONES: From | nTo |
| Casing size (I.D.) and materia | a a a a b | - | From To | From To |
| Material | | n | From To | . From To |
| | or wall thick part | in | 4. USE DATA: | 1 |
| Wit per 1001 | | | Type of use: Drinking | I, Livestock Watering |
| Material | | IL. | Manufacturing | bod processing, Household |
| Wt per toot | or wall thickness | in. | Recreation | Assthatic Cooling or beature |
| inches trom | to | ft. | Injection Ot | her research |
| Material | | | Type of facility: Dom | estic Public water supply |
| Wt. per foot | or wall thickness | in. | Public institution | |
| e Screen size and mesh for eac | h zone (where applicable) | | Commercial | Other |
| a 3 inches from | 760 10 780 | ft. | 5. PUMP DATA: Type | Bated H P |
| @ Mesh size | Туре | | © Intake depth | |
| o inches trom | to | ft. | 6. WELLHEAD: Type we | li seal |
| [©] Mesh size | Туре | | Pressure tank | gal., Loc. |
| a inches from | to | ft. | Sample tap | , Measurement port |
| @ Mesh size | Туре | | Well vent | Pressure reliativative |
| oinches from | to | ft. | Gate valve | Check valve (when required) |
| Mesh size | Туре | | Electrical disconnec | t switch on power supply |
| ^e Gravel pack | | | 7. DISINFECTION: Well of | disinfected yes no |
| © From | to ft. | | Date | , Disinfectant used |
| © From | toft | | Amount | , Hours used |
| © Grout | 10 | | 8. ABANDONMENT (whe | re applicable) @ yesno |
| From to | ft., Type | | Casing pulled yes | no not applicable |
| From 10 | ft., Type | | Plugging grout From | ntomaterial |

| Sample | <u>Time</u> | <u>Time</u> | <u>Sample</u> | Agency | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | <u>Geo-</u> |
|--------------|-------------|--------------------|---------------|--------------|-----------------|---------------|------------------|--------------|
| Datetim e | datum_ | <u>datum</u> | Medium | Collecting | Source | logic | logic | logic |
| | | <u>reliability</u> | <u>Code</u> | Sample, | | Event | <u>Condition</u> | <u>unit</u> |
| | | <u>code</u> | | Code_ | | | | |
| | | | | | | | | |
| | | | | | | | | - |
| | | | | | | | - | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | WRD | 9 | 9 | А | |
| 1993-07- | EDT | т | WG | USGS- WRD | 9 | 9 | А | |
| 1996-07- | EDT | т | WG | USGS- WRD | 9 | 9 | А | 000SAN D |
| 1998-04- | EDT | т | WG | USGS- WRD | 9 | 9 | А | 000SAN D |
| 2006-06- | EDT | ĸ | WG | USGS- WRD | 9 | 9 | А | 211CRA QU |

USGS 364227076074703 61B 6 SOW 091C

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27 Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 780 feet below land surface.

The depth of the hole is 800 feet below land surface.

PEE DEE Aguifer

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the UPPER CRETACEOUS AQUIFER SYSTEM (211CRAQU) local aq

| Water Quality Remark Code | Descript ion | | |
|------------------------------------|--|--|--|
| < | Less than. | | |
| Μ | Presence verified but not quantifie d. | | |

| 6 . · | Value Qualifie r Code | Descript ion |
|-------|-----------------------------|--|
| | @ | Holding time exceeded |
| | с | See laborator y comment |
| | d | Diluted sample: method hi range exceeded |

.

| Sample | Project | | | | | | | Specif- |
|-------------|---------------|--|---------|---------|----------------|---------|---------|---------|
| <u>type</u> | Code | | | | | | - | ic |
| | | | | Baro- | Agency | Flow | Color, | conduc- |
| | | Temper- | Temper- | metric | ana- | rate, | water, | tance, |
| | | ature, | ature, | pres- | lyzing | instan- | fltrd, | wat unf |
| | | water, | air, | sure, | sample, | taneous | Pt-Co | uS/cm |
| | | deg C | deg C | mm Hg | code | gal/min | units | 25 degC |
| | | (00010) | (00020) | (00025) | <u>(00028)</u> | (00059) | (00080) | (00095) |
| | 4451089 | | | | | | | |
| 9 | 00 | 18.0 | | | 80020 | | 4 | 80000 |
| | 4451089 | 11 11 11 11 11 11 11 11 11 11 11 11 11 | | 1111222 | 10150-00104 | | | |
| 9 | 10 | 19.8 | 34.0 | 766 | 80020 | | | 9400 |
| 0 | 4451106 | 20.0 | 25.5 | 755 | 00000 | 2.0 | | 0500 |
| 9 | 0 | 20.0 | 25.5 | /55 | 80020 | 3.0 | | 9500 |
| 9 | 4451106 | 20.0 | 14.0 | 764 | 80020 | | | 9480 |
| 9 | 24829RC 20 | 19.8 | 23.5 | 751 | 80020 | 8.5 | | 8780 |

) national aquifer. uifer.

| Hydro- | | | | | | ANC, | Carbon- | Bicar- |
|---------|-----------|---------|---------|---------|---------|---------|---------|---------|
| gen | | Dis- | pН, | pН, | | wat unf | ate, | bonate, |
| ion, | | solved | water, | water, | Carbon | fixed | wat fit | wat flt |
| water, | Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt | infl pt |
| unfltrd | solved | percent | field, | lab, | water, | field, | titr., | titr., |
| calcd, | oxygen, | of sat- | std | std | unfitrd | mg/L as | field, | field, |
| mg/L | mg/L | uration | units | units | mg/L | CaCO3 | mg/L | mg/L |
| (00191) | (00300) | (00301) | (00400) | (00403) | (00405) | (00410) | (00452) | (00453) |
| 0.00003 | | | 7.6 | 7.6 | 30 | 617 | | |
| 0.00002 | 0.1 | 0.0 | 7.7 | 7.7 | 29 | | 0.0 | 914 |
| 0.00003 | 0.2 | 2 | 7.5 | 7.6 | 45 | | | 828 |
| 0.00003 | 0.0 | 0.0 | 7.5 | 7.6 | 45 | | 0.0 | 749 |
| 0.00003 | <u>M_</u> | 0.0 | 7.5 | 7.8 | | | 3 | 888 |

•

| | | Ammoni a | Nitrate | | | | | |
|---------|-------------|-------------|-------------------|---------|---------|---------|----------------|----------------|
| Organic | | + | + | Phos- | | | | |
| nitro- | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | | Magnes- |
| gen, | water, | water, | water | water, | carbon, | ness, | Calcium | ium, |
| water, | fltrd, | unfltrd | fitrd, | unfltrd | water, | water, | water, | water, |
| unfltrd | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, | fltrd, |
| mg/L | as N | as N | as N | as P | mg/L | CaCO3 | mg/L | mg/L |
| (00605) | (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00915) | (00925) |
| 0.50 | 5.90 | 6.4 | <u>< 0.100</u> | 0.11 | 5.1 | 200 | 25.0 | 33.0 |
| | | | | | | 190 | 25.0 | 32.0 |
| | | | | | | 180 | 24.0 | 30.0 |
| | | | | | | 210 | 28.6 | 34.0 |
| | | | | | | 190 | <u>25.9 dc</u> | <u>30.9 dc</u> |

| Sodium, water, fltrd, mg/L | Sodium adsorp- tion ratio | Sodium frac- tion of cations percent | Potas- sium, water, fltrd, mg/L | Chlor- ide, water, fltrd, mg/L | Sulfate water, fltrd, mg/L | Fluor- ide, water, fltrd, mg/L | Silica, water, fltrd, mg/L as SiO2 | Boron, water, fltrd, ug/L |
|-------------------------------------|------------------------------------|---|---|--|-------------------------------------|--|--|------------------------------------|
| (00930) | (00931) | (00932) | (00935) | (00940) | (00945) | (00950) | (00955) | (01020) |
| 1900 | 59 | 94 | 55.0 | 2600 | 160 | 1.30 | 16.0 | 6500 |
| 1900 | 59 | 94 | 52.0 | 2500 | 170 | 1.6 | 14.0 | |
| 1800 | 58 | 94 | 57.0 | 2600 | 170 | 1.40 | 16.0 | |
| 1980 | 59 | 94 | 54.5 | 2520 | 167 | 1.21 | 16.8 | |
| 1850 dc | 58 | 94 | 54.4 dc | 2570 d | <u>160 d</u> | 1.32 | <u>15.7 dc</u> | |

| | | | 1 | 1 | | | | |
|---------|---------|---------|------------------|----------------|---------|---------|---------|---------|
| | | Mangan | • | | | Alka- | Depth | Alka- |
| Iron, | | ese, | | | | linity, | to | linity, |
| water, | | water, | Mangan | | Alum- | wat flt | water | wat flt |
| unfltrd | Iron, | unfltrd | ese, | Zinc, | inum, | fxd end | level | fxd end |
| recover | water, | recover | water, | water, | water, | lab, | below | field, |
| -able, | fltrd, | -able, | fltrd, | fitrd, | fitrd, | mg/L as | LSD, | mg/L as |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | CaCO3 | meters | CaCO3 |
| (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (29801) | (30210) | (39036) |
| 8200 | 280 | 40 | 10 | <u>< 10</u> | 20 | | 1.67 | |
| | 130 | | <u>< 10</u> | | | | | |
| | 300 | | <u>< 10.0</u> | | | | | |
| | 278 | | < 40.0 | | | | 0.055 | 610 |
| | 207 dc | | 5.4 dc | | | 725 @c | 2.18 | |

| Alka- | Residue | Residue | | | | | Pump | |
|---------|-------------|---------|---------|-------------|---------------|---------|---------|----------------|
| linity, | on | water, | | | | Alti- | or flow | |
| wat flt | evap. | fltrd, | Residue | | | tude | period | Sam- |
| inf tit | at | sum of | water, | Ammoni a | Bromide | of | prior | pling |
| field, | 180deg C | consti- | fltrd, | water, | water, | land | to sam- | condi- |
| mg/L as | wat flt | tuents | tons/ | fltrd, | fltrd, | surface | pling, | tion, |
| CaCO3 | mg/L | mg/L | acre-ft | mg/L | mg/L | feet | minutes | code |
| (39086) | (70300) | (70301) | (70303) | (71846) | (71870) | (72000) | (72004) | <u>(72006)</u> |
| | 5050 | 5170 | 6.87 | 7.60 | | | | |
| 749 | 5480 | 5150 | 7.45 | | 3.90 | | | |
| 679 | 5230 | 5120 | 7.11 | | 9.90 | 15.0 | 265 | 8.00 |
| 614 | 5110 | 5180 | 6.95 | | 9.29 | | | 8.00 |
| 733 | 5320 | 5160 | 7.23 | | <u>9.69 d</u> | 15.0 | 215 | 8.00 |

| Depth | Depth | Depth | | | Specif. | ANC, | |
|---------|---------|---------|----------------|----------------|---------|---------|----------|
| to top | to bot | to | | | conduc- | wat unf | |
| sample | sample | water | | | tance, | fixed | Sulfide |
| intrval | intrval | level, | Sam- | | wat unf | end pt, | water, |
| feet | feet | feet | pling | Sampler | lab, | lab, | unfltrd |
| below | below | below | method, | type, | uS/cm | mg/L as | field, |
| LSD | LSD | LSD | code | code | 25 degC | CaCO3 | mg/L |
| (72015) | (72016) | (72019) | <u>(82398)</u> | <u>(84164)</u> | (90095) | (90410) | (99119) |
| 760.00 | 780.00 | 5.48 | | | 9100 | 727 | |
| | | | 8010 | 4040 | 9170 | 724 | |
| 760.00 | 780.00 | | | 4040 | 9230 | 729 | |
| 760.00 | 780.00 | 0.18 | | 4040 | 9060 | 729 | |
| 760.00 | 780.00 | 7.15 | | 4040 | 9250 | | <u>M</u> |

| Form GW-2 | COMMONWEALTH OF VIRGINIA | | | | | | |
|---|---|----------------|--|--|--|--|--|
| 1978-10,000 | WATER WELL COMPLETION REPORT OBWCM No. 234-67 | | | | | | |
| State Water Control Board | (Certification | of Com | pletion/County Permit) | | | | |
| P. O. Box 11143 2111 North Hamilton St. Richmond, Va. 23230 | | | SWCB Permit | | | | |
| county (city) ches | apectic | | Certification of inspecting official: This well does does not | | | | |
| .0 | Ca | ounty/Ci | ty Stamp meet code/low requirements. | | | | |
| Virginia Plane Coordinates | C.M | 3.V. | Date | | | | |
| N | •Owner SAUS | | For Office Use | | | | |
| E | Well Designation or Number | Son | <u>YI-D</u> | | | | |
| Latitude & Longitude | Address | | photosofte and a second s | | | | |
| JGOTZ GIN | | | Tax Map I.D. No | | | | |
| - 10 07 49 W | Phone | | Subdivision | | | | |
| Topo. Map No | Shi | 11R | Section | | | | |
| Elevation ft. | Drilling Contractor | ATT: | Block | | | | |
| Pormation | Address CITTO Here | n ITOR | Lot | | | | |
| Cithology | nichaohd | <u></u> | Class Well 1, IIA, | | | | |
| River Basin | Phone | | | | | | |
| Province | WELLLOCATION | lfoot/mil | LIICIIDIIE | | | | |
| Cutting | WELL LOCATION. | _neeumn | | | | | |
| Plater A polyaio | and reet/miles | an showin | ection) of | | | | |
| Q Analysis | in possible presse melade m | | C | | | | |
| Aquiter Test | Date started | Oate | completed Type rig Failing F-/S | | | | |
| X | | | | | | | |
| I. WELL DATA: New A Rev | vorked Deepened | | 2. WATER DATA [®] Water temperature ⁰ F | | | | |
| P Total depth | | ft. | Static water level (unpumped level-measured) ft | | | | |
| Depth to bedrock | | ft. | Stabilized measured pumping water level the stabilized measured pumping water level | | | | |
| Hole size (Also include ream | ed zones) // CP-7- | | *Stabilized yield gpm afterhours | | | | |
| inches from | | ft. | Natural Flow: Yes No, flow rateg pm | | | | |
| inches from | to | ft. | Comment on quality | | | | |
| inches from | το | II. | 3. WATER ZONES: From To | | | | |
| Casing size (I.D.) and materia | 1 0 17 | 2.5 | From To To | | | | |
| Material Material | 10 | n. | From To From To | | | | |
| | | | 4. USE DATA: | | | | |
| e · · · · · | Or wait thickness | III. | Type of use. Drinking, Livestock Watering, | | | | |
| Material | 18 | | Annufacturing Food processing, Household | | | | |
| Wt per toot | or wall thickness | in | Becreation Acathetic Cost | | | | |
| 0 inches trom | | ft | Injection Other Account to | | | | |
| Material | | | Type of facility: Domestic Rubble units supply | | | | |
| Wt. per foot | or wall thickness | in | Public institution | | | | |
| e Screen size and mesh for eac | h zone (where applicable) | | Commercial Other | | | | |
| • // inches from | 17 10 22 | ft. | 5 PLIMP DATA: Type PRated H P | | | | |
| Mesh size | Туре | | Intake depth Capacity at bead | | | | |
| Inches trom | to | ft. | 6. WELLHEAD: TYPE well seal | | | | |
| Mesh size | Туре | | Pressure tank gal Loc | | | | |
| inches from | 10 | ft | Sample tap Measurement port | | | | |
| Mesh size | Туре | | Well vent Pressure relief value | | | | |
| inches from | to | ft. | Gate valve Check valve (when required) | | | | |
| Mesh size | Туре | | Electrical disconnect switch on power supply | | | | |
| @ Gravel pack | | 0.0000 | 7. DISINFECTION: Well disinfected ves | | | | |
| [©] From | to ft. | | Date Disinfectant used | | | | |
| @ From | to ft | | Amount Hours used | | | | |
| arout | | | 8. ABANDONMENT (where applicable) @ves no | | | | |
| • From to | ft., Type | Contact States | Casing pulled yes no not applicable | | | | |
| • From to | ft., Type | | Plugging grout Fromtomaterial | | | | |

Sew 91-D

...

| Sample | Time | <u>Time</u> | Sample | Agency | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | <u>Sample</u> |
|----------|--------|--------------------|---------------|-------------------|-----------------|---------------|---------------|---------------|
| e | datum_ | <u>datum</u> | <u>Medium</u> | <u>Collecting</u> | Source | logic | logic | <u>type</u> |
| | | <u>reliability</u> | Code | Sample, | | <u>Event</u> | Condition | |
| | | <u>code</u> | | <u>Code</u> | | | | |
| | | - | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | А | 9 |
| 2003-08- | EDT | к | WG | USGS- WRD | 9 | 9 | A | 9 |

USGS 364227076074704 61B 7 SOW 091D

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 22.0 feet below land surface.

The depth of the hole is 22.0 feet below land surface.

This well is completed in the QUATERNARY SYSTEM (110QRNR) local aquifer.

| Water Quality Remark Code | Descript ion | | | |
|------------------------------------|--|--|--|--|
| | Less | | | |
| < | than. | | | |
| M | Presence verified but not quantifie d. | | | |

| Value | Descript |
|----------|----------|
| Qualifie | ion |
| r Code | 1011 |

| | Diluted |
|---|----------|
| | sample: |
| | method |
| | hi range |
| d | exceeded |

-

| Project | Labor- | | | | | | Specif- | Hydro- |
|---------------|-------------|---------|---------|----------------|---------|---------|---------|---------|
| Code | atory | | | | | | ic | gen |
| | sample | | | Agency | Flow | Color, | conduc- | ion, |
| | comme nt | Sam- | Temper- | ana- | rate, | water, | tance, | water, |
| | | pling | ature, | lyzing | instan- | fitrd, | wat unf | unfltrd |
| | | depth, | water, | sample, | taneous | Pt-Co | uS/cm | calcd, |
| | | feet | deg C | code | gal/min | units | 25 degC | mg/L |
| | | (00003) | (00010) | <u>(00028)</u> | (00059) | (00080) | (00095) | (00191) |
| · · · · · · · | RR:ALK | | | | | | | |
| 4451000 | | | | | | | | |
| 4451089 | 504-25 | | 15.0 | 80020 | | 13 | 200 | 0 00253 |
| 24829RC | ,50-1-25 | | 10.0 | 00020 | | 1.2 | 200 | 0.00200 |
| X6 | | 19.0 | 18.7 | 80020 | 2.7 | | 325 | 0.00139 |
| 1 | | | | | 1 | | | |
|--------|-----------|---------|---------|---------|---------|---------|---------|---------|
| | | | | | ANC, | Carbon- | Bicar- | |
| | Dis- | pН, | pН, | | wat unf | ate, | bonate, | Organic |
| | solved | water, | water, | Carbon | fixed | wat flt | wat flt | nitro- |
| Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt | infl pt | gen, |
| solved | percent | field, | lab, | water, | field, | titr., | titr., | water, |
| oxygen | , of sat- | std | std | unfltrd | mg/L as | field, | field, | unfltrd |
| mg/L | uration | units | units | mg/L | CaCO3 | mg/L | mg/L | mg/L |
| (00300 |) (00301) | (00400) | (00403) | (00405) | (00410) | (00452) | (00453) | (00605) |
| | | | | | | | | |
| | | 5.6 | 6.0 | 311 | 64 | | | 0.18 |
| 0.5 | 5 | 5.9 | 5.7 | | | 0.0 | 90 | |

| | Ammoni a | Nitrate | | | | Noncarb | | |
|-------------|-------------|-------------------|---------|---------|---------|---------|---------|---------|
| | + | + | Phos- | | | hard- | | |
| Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | ness, | | Magnes- |
| water, | water, | water | water, | carbon, | ness, | wat flt | Calcium | ium, |
| fltrd, | unfltrd | fltrd, | unfltrd | water, | water, | lab, | water, | water, |
| mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | mg/L as | fitrd, | fltrd, |
| as N | as N | as N | as P | mg/L | CaCO3 | CaCO3 | mg/L | mg/L |
| (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00905) | (00915) | (00925) |
| | | | | | | | | |
| 0.120 | 0.30 | <u>< 0.100</u> | 0.06 | 3.0 | 40 | | 6.80 | 5.60 |
| | | | | | 72 | 48 | 11.5 | 10.4 |

| | | Sodium | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | | frac- | Potas- | Chlor- | | Fluor- | Silica, | |
| Sodium, | Sodium | tion | sium, | ide, | Sulfate | ide, | water, | Boron, |
| water, | adsorp- | of | water, | water, | water, | water, | fitrd, | water, |
| fltrd, | tion | cations | fltrd, | fltrd, | fltrd, | fltrd, | mg/L as | fltrd, |
| mg/L | ratio | percent | mg/L | mg/L | mg/L | mg/L | SiO2 | ug/L |
| (00930) | (00931) | (00932) | (00935) | (00940) | (00945) | (00950) | (00955) | (01020) |
| | | | | | | | | |
| 14.0 | 1.0 | 42 | 1.10 | 24.0 | 12.0 | 0.10 | 20.0 (| 40 |
| 17.9 | 0.9 | 35 | 1.38 | 8.08 | 63.4 | < 0.17 | 17.4 | |

WHO

| | | Mangan | | | | Alka- | Depth | Alka- |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Iron, | | ese, | | | | linity, | to | linity, |
| water, | | water, | Mangan | | Alum- | wat fit | water | wat flt |
| unfltrd | Iron, | unfltrd | ese, | Zinc, | inum, | fxd end | level | inf tit |
| recover | water, | recover | water, | water, | water, | lab, | below | field, |
| -able, | fltrd, | -able, | fltrd, | fltrd, | fltrd, | mg/L as | LSD, | mg/L as |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | CaCO3 | meters | CaCO3 |
| (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (29801) | (30210) | (39086) |
| 2.45 | | | | | | | | |
| 12000 | 15000 | 240 | 280 | 36 | 20 | | 0.323 | |
| - | | | 200 | | | 24 | 0 829 | 74 |

| | | | | | | | | 100 C |
|-------------|---------|---------|-------------|---------|----------------|---------|----------------|---------|
| Residue | Residue | | | | | Pump | | Depth |
| on | water, | | | | | or flow | | to top |
| evap. | fltrd, | Residue | | | | period | Sam- | sample |
| at | sum of | water, | Ammoni a | Bromide | | prior | pling | intrval |
| 180deg C | consti- | fltrd, | water, | water, | Sample | to sam- | condi- | feet |
| wat flt | tuents | tons/ | fltrd, | fltrd, | purpose | pling, | tion, | below |
| mg/L | mg/L | acre-ft | mg/L | mg/L | code | minutes | code | LSD |
| (70300) | (70301) | (70303) | (71846) | (71870) | <u>(71999)</u> | (72004) | <u>(72006)</u> | (72015) |
| | | | | | | | | |
| 159 | 137 | 0.22 | 0.15 | | | | | 17.00 |
| 201 | 204 | 0.27 | | 0.15 d | 10.00 | 40 | 0.10 | 22.00 |

| Depth | Depth | - | Specif. | ANC, | |
|-----------|---------|----------------|------------|---------|-----------|
| to bot | to | | conduc- | wat unf | |
| sample | water | | tance, | fixed | Sulfide |
| intrval | level, | Sam- | wat unf | end pt, | water, |
| feet feet | | pling | pling lab, | | unfltrd |
| below | below | method, | uS/cm | mg/L as | field, |
| LSD | LSD | code | 25 degC | CaCO3 | mg/L |
| (72016) | (72019) | <u>(82398)</u> | (90095) | (90410) | (99119) |
| | | | | | |
| 22.00 | 1.06 | | 195 | 62 | |
| 17.00 | 2.72 | 4040 | 215 | | <u>M_</u> |

. . .

Foin GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

234-191 BWCM No.

(Certification of Completion/County Permit)

| 5 5 51 | | | SWCB Permit |
|---|--|--|--|
| Richmond, Va. 23230 | | | County Permit |
| | | | |
| County/City Chocano | ako | | This well does does not |
| county/cityChesape | Country | City Stamp | meet code/low requirements. |
| 9 Virginia Plane Coordinater | County | City Stamp | S |
| N OC | Owner Observation Well | # 91-E | Date |
| FOV | Vell Designation or Number Font | TASS | For Office Use |
| Latituda & Langituda | Address | 1655 | |
| 36 A2! 27" N | | | Tax Map I.D. No. |
| 76 07' 47" W P | hone | | Subdivision |
| Topo Map No. 2B | | | Section |
| ●Elevation 15 ft. ●C | Drilling Contractor SWCB - Cre | ason | Block |
| Formation KLP A | ddress · | | Lot |
| Lithology SD | | | Class Well IIA |
| PRiver Basin 5 P | hone | | 11B , 111A , 111B |
| Province 1 | Fentress [Observation | Well # 91-E] | IIIC IIID IIIE |
| Type Logs E W | VELL LOCATION: (feet/ | miles direction) of | |
| Cuttings No | and feet/miles | (direction) of | |
| Water Analysis Yes | (If possible please include map show | wing location marked) | |
| Aquifer Test NO | | | |
| | Date started 9-29-88 °C | Date completed 11-30-88 | Type rig Mud Rotary |
| | .* | | |
| WELLDATA: New X Rework | ed Deepened | 2. WATER DATA ® Wat | er temperature 60.8 |
| PTotal depth 1831' | ft. | Static water level (und | pumped level-measured) 39.68 TOC |
| Depth to bedrock | ft. | © Stabilized measured p | umping water level 85.0 TOC |
| ble size (Also include reamed z | ones) | ^o Stabilized yield 7. | 9 gpm after 7.5 ho |
| 12 inches from | 0 to 82' ft. | Natural Flow: Yes | No x flow rate. gr |
| © 7 inches from | 83 to 1697' It | Comment on quality | |
| | - Sel sel | CONTRACT OF CONTRACTOR | Salty |
| © 3.5 inches from | 1698' to 1873' ft. | 3 WATER ZONES: From | Salty |
| © 3.5 inches from | 1698'to1873'ft | 3. WATER ZONES: From | Salty nTo FromTo |
| <u>3.5</u> inches from <u>3.5</u> Casing size (1.D.) and material A inches from | 1698' to $1873'$ ft. | 3. WATER ZONES: From To | Salty nTo FromTo |
| <u>3.5</u> inches from <u>3.5</u> inches from <u>4</u> inches from <u>4</u> inches from <u>Material</u> Black Stop | $\frac{1698!}{0} to \frac{1873!}{1697!} tt.$ | 3. WATER ZONES: From From To From To | To To FromTo |
| • <u>3.5</u> inches from <u></u> • Casing size (1.D.) and material • <u>4</u> inches from <u>Material Black Stee</u> | 1698' to <u>1873'</u> ft. <u>0</u> to <u>1697'</u> tt. <u>1</u> wall thickness in | 3. WATER ZONES: From From To From To 4. USE DATA: | To nToTo FromTo |
| <u>3.5</u> inches from Casing size (1.D.) and material <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or | 1698' to 1873' ft. | 3. WATER ZONES: From From To From To 4. USE DATA: Type of use Drinking | Salty nToTo FromTo FromTo |
| | 1698' to 1873' ft. | 3. WATER ZONES: From From To From To 4. USE DATA: Type of use Drinking IrrigationF | Salty nToToTo FromTo FromTo , Livestock Watering pod processing, Household |
| <u>3.5</u> inches from Casing size (I.D.) and material <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot Material <u>Black Stee</u> Wt per foot | 1698' to 1873' ft. | 3. WATER ZONES: From From To From To 4. USE DATA: Type of use Drinking Irrigation From Manufacturing Becreation | Salty nToToTo FromToTo FromToTO_CTO_TOC_TOC |
| <u>3.5</u> inches from Casing size (1.D.) and material <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot Material <u>Black Stee</u> Wt. per foot Material <u>Black Stee</u> Wt. per foot or | 1698' to 1873' ft. | 3. WATER ZONES: From FromTo FromTo 4. USE DATA: Type of use Drinking IrrigationFo Manufacturing Recreation | Salty n To From To From To |
| • <u>3.5</u> inches from • Casing size (I.D.) and material • <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot • <u>2</u> inches from Material <u>Black Stee</u> Wt. per foot or • inches from | 1698' to 1873' ft. 0 to 1697' ft. 1 | 3. WATER ZONES: From FromTo FromTo 4. USE DATA: Type of use Drinking IrrigationFo Manufacturing Recreation InjectionO | Salty nToToTo FromToTo FromToToTo |
| <u>3.5</u> inches from <u>3.5</u> inches from <u>4</u> inches from <u>Material Black Stee</u> Wt.per foot or <u>2</u> inches from <u>Material Black Stee</u> Wt.per toot or <u>0</u> inches from <u>Material Black Stee</u> Wt.per toot or <u>0</u> inches from | 1698' to 1873' ft. | 3. WATER ZONES: From FromTo FromTo 4. USE DATA: Type of use Drinking IrrigationFo Manufacturing RecreationOt ©Type of facility Dom | Salty n To From To From To . Livestock Watering od processing , Household . Fire safety Cleaning Aesthetic Cooling or heating her Observation estic , Public water supply |
| • <u>3.5</u> inches from • Casing size (I.D.) and material • <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or • <u>2</u> inches from Material <u>Black Stee</u> Wt. per foot or Material | 1698' to 1873' ft. 0 to 1697' ft. 1 | 3. WATER ZONES: From To To To To To To 4. USE DATA: Type of use Drinking Irrigation Fo Manufacturing Recreation Injection Ot @Type of facility Dom Public institution | Salty n To From To From To |
| • <u>3.5</u> inches from • Casing size (1.D.) and material • <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or • <u>2</u> inches from Material <u>Black Stee</u> Wt. per foot or • inches from Material Wt. per foot or • Screen size and mesh for each zo | 1698' to 1873' ft. 0 to 1697' ft. 1 | 3. WATER ZONES: From To To To To To To 4. USE DATA: Type of use Drinking Irrigation From Injection From Injection Ot @Type of facility Dom Public institution Commercial | Salty n To From To From To |
| <u>3.5</u> inches from Casing size (1.D.) and material <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or <u>2</u> inches from Material <u>Black Stee</u> Wt. per toot or <u>9</u> inches from Material Wt. per foot or Oscreen size and mesh for each zo <u>9</u> inches from | 1698' to 1873' ft. 0 to 1697' ft. 1 | 3. WATER ZONES: From To To To To To To 4. USE DATA: Type of use Drinking Irrigation Fo Manufacturing Recreation Injection Ot Ot Public institution Commercial 5. PUMP DATA: Type | Salty n To From To From To Outprocessing Active Vatering Fire safety Cleaning Aesthetic Cooling or heating her Observation estic Public water supply Farm Industry Other Observation 9 Rated H.P. |
| • <u>3.5</u> inches from • Casing size (1.D.) and material • <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or • <u>2</u> inches from Material <u>Black Stee</u> Wt. per foot or • inches from Material or • inches from • Material or • inches from • Mesh size 020 Ty | 1698' to 1873' ft. 0 to 1697' ft. 1 | 3. WATER ZONES: From To To To To To To 4. USE DATA: Type of use Drinking Irrigation From Injection Ot Recreation Injection Ot Ot Public institution Commercial 5. PUMP DATA: Type | Salty n To From To From To o From pod processing Household pod processing Household Fire safety Cleaning Aesthetic Cooling or heating her Observation estic Public water supply Gaservation 9 Rated H P. |
| <u>3.5</u> inches from Casing size (1.D.) and material <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot Material <u>Black Stee</u> Wt. per toot Material <u>Black Stee</u> Wt. per toot material Wt. per foot material Wt. per foot or o Material wt. per foot mores from @ mches from @ Mesh size @ Mash circ | 1698' to 1873' ft. 0 to 1697' ft. 1 | 3. WATER ZONES: From From To From To 4. USE DATA: Type of use Drinking Irrigation From Manufacturing Recreation Injection Ot OType of facility Dom Public institution Commercial 5. PUMP DATA: Type Intake depth 6. WELLHEAD: Type we | Salty nToToTo FromToTo pod processingHousehold pod processingHousehold pod processingHousehold pod processing Cleaning AestheticCooling or heating herObservation estic Public water supply Other |
| e 3.5 inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. 1626' to 1821' ft. 'wall thickness in. in. 1626' ft. in. wall thickness in. in. ft. in. in. wall thickness in. in. ft. in. wall thickness in. in. in. in. to 1831' ft. iso 1831' ft. in. iso 1831' ft. in. iso 192' 1831' ft. iso 192' ft. in. iso 192' 1831' ft. iso iso ft. iso iso iso ft. iso ft. | 3. WATER ZONES: From From To From To 4. USE DATA: Type of use Drinking Irrigation From Manufacturing Recreation Injection Of OType of facility Dom Public institution Commercial 5. PUMP DATA: Type Intake depth 6. WELLHEAD: Type we Pressure tank | Salty nToTo FromTo FromTo pod processing bod processing Aesthetic |
| • 3.5 inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. 1626' to 1821' ft. 'wall thickness in. in. 1626' ft. wall thickness in. in. ft. wall thickness in. ft. wall thickness in. ft. wall thickness in. ft. ve (where applicable) 1831' ft. is pipe Base ft. ft. is pipe is pipe ft. is pipe is pipe ft. | 3. WATER ZONES: From FromTo FromTo 4. USE DATA: Type of use Drinking IrrigationFo Manufacturing RecreationOr InjectionOr ©Type of facility Dom Public institution Commercial 5. PUMP DATA: Type ©Intake depth 6. WELLHEAD: Type we Pressure tank Sample tap | Salty nToTo FromTo FromTo pod processing pod processing |
| • <u>3.5</u> inches from • Casing size (1.D.) and material • <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or • <u>2</u> inches from Material <u>Black Stee</u> Wt. per toot or • inches from • Mesh size O20 Ty • inches from • Mesh size Ty • Mesh size Ty | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. 1626' to 1821' ft. 'wall thickness in. 1821' ft. in. wall thickness in. ft. in. ft. wall thickness in. in. ft. wall thickness in. in. ft. wall thickness in. ft. in. ne (where applicable) 1831' ft. 1821' to 1831' ft. 'pe | 3. WATER ZONES: FromTo FromTo FromTo 4. USE DATA: Type of use Drinking IrrigationFo Manufacturing Recreation InjectionOf ©Type of facility Dom Public institution Commercial 5. PUMP DATA: Type ©Intake depth 6. WELLHEAD: Typc we Pressure tank Sample tap Well vent | Salty nToTo FromTo FromTo pod processing Nethetic Aesthetic Aesthetic Cleaning Aesthetic Cleaning Aesthetic Cleaning Aesthetic Cleaning Aesthetic Cleaning Aesthetic Cleaning Aesthetic Cleaning Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic Aesthetic |
| • <u>3.5</u> inches from • Casing size (1.D.) and material • <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or • <u>2</u> inches from Material <u>Black Stee</u> Wt. per toot or • inches from • Material or • Screen size and mesh for each zo • <u>2</u> inches from • Mesh size O20 Ty • inches from • Mesh size Ty • inches from | 1698' to 1873' ft. 0 to 1697' ft. 1 | 3. WATER ZONES: FromTo FromTo FromTo 4. USE DATA: Type of use Drinking IrrigationFo Manufacturing Recreation InjectionOt ©Type of facility Dom Public institution Commercial 5. PUMP DATA: Type ©Intake depth 6. WELLHEAD: Typc we Pressure tank Sample tap Well vent | Salty nToToTo FromToToTo FromToTOT |
| <u>3.5</u> inches from Casing size (1.D.) and material <u>Material Black Stee</u> Wt. per foot <u>9</u> inches from <u>9</u> Mesh size Ty <u>9</u> inches from <u>9</u> Mesh size Ty <u>9</u> inches from <u>9</u> Mesh size Ty <u>9</u> inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. 1626' ft. 1626' to 1821' ft. wall thickness in. ft. ve SS Pipe Base ft. | 3. WATER ZONES: FromToToToTo | Salty nToToTo FromToToToTo FromToTO_TO |
| • 3.5 inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. in. 1626' to 1821' ft. 'wall thickness in. in. in. wall thickness in. in. in. wall thickness in. in. in. wall thickness in. in. in. ne (where applicable) 1831' ft. 1821' to 1831' ft. 'pe to ft. ft. | 3. WATER ZONES: FromToToTo | Salty nToToTo FromToToTo FromToTOT |
| • <u>3.5</u> inches from • Casing size (1.D.) and material • <u>4</u> inches from Material <u>Black Stee</u> Wt. per foot or • <u>2</u> inches from Material <u>Black Stee</u> Wt. per toot or • inches from • Mesh size <u>020</u> Ty • inches from • Mesh size Ty • inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. in. 1626' to 1821' ft. 'wall thickness in. in. in. wall thickness in. in. in. wall thickness in. in. in. wall thickness in. in. in. ne (where applicable) 1831' ft. 1821' to 1831' ft. 'pe | 3. WATER ZONES: FromToToTo | Salty nToToTo FromToToTo FromToTO_TO |
| • 3.5 inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. in. 1626' to 1821' ft. 'wall thickness in. in. in. wall thickness in. in. in. ine (where applicable) 1831' it. it. ipe | 3. WATER ZONES: FromTo FromTo FromTo 4. USE DATA: Type of use IrrigationFor Manufacturing Recreation Injection, Ot © Type of facility Out © Type of facility Out © Type of facility Out © Type of facility 0. UNP DATA: Type © Intake depth 0. WELLHEAD: Typc we example tap Well vent Gate valve Electrical disconneed 7. DISINFECTION: Well Date Amount | Salty nTo FromTo FromTo FromTo FromTo Roughts of the set of the |
| • 3.5 inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. in. 1626' to 1821' ft. 'wall thickness in. in. in. wall thickness in. in. in. ine (where applicable) 1831' it. it. ine (where applicable) 1831' it. it. ine (where into into into into into into into into | 3. WATER ZONES: From To To To | Salty n To From To From To From To |
| • 3.5 inches from | 1698' to 1873' ft. 0 to 1697' ft. 'wall thickness in. in. 1626' to 1821' ft. 'wall thickness in. in. in. wall thickness in. in. it. ine (where applicable) 1831' it. it. ine (where applicable) 1831' it. it. ine (where ine (where applicable) it. it. it. ine (where applicable) it. it. it. <td< td=""><td>3. WATER ZONES: From To To To To To To A. USE DATA: Type of use Drinking Irrigation From To Injection Ot Ot</td><td>Salty n To From To From To From To </td></td<> | 3. WATER ZONES: From To To To To To To A. USE DATA: Type of use Drinking Irrigation From To Injection Ot | Salty n To From To From To From To |

1.18

| | | | | | | | I | |
|--------------|--------------|--------------|---------------|----------------|-----------------|---------------|---------------|-------------|
| Sample | Time | <u>Time</u> | Sample | Agency | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | <u>Geo-</u> |
| Datetim e | <u>datum</u> | <u>datum</u> | <u>Medium</u> | Collecting | Source | logic | logic | logic |
| | | reliability | Code | <u>Sample,</u> | | Event_ | Condition | <u>unit</u> |
| | - 1 | <u>code</u> | | Code | | | | |
| | | | | 1 | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | WRD | 9 | 9 | A | |
| | | | | USGS- | | | | |
| 1993-07- | EDT | T | WG | WRD | 9 | 9 | A | |
| 1998-04- | EDT | т | WG | WRD | 9 | 9 | A | 217PTXN |
| | | | | | | | | |
| | | | | | | | | |
| | | | | USGS- | | | | 24707.0 |
| 2006-06- | EDT | K | WG | WRD | 9 | 9 | A A | 21/PIXN |

USGS 364227076074706 61B 12 SOW 091E

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 1,831.00 feet below land surface.

The depth of the hole is 1,873.00 feet below land surface.

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the PATUXENT FORMATION (217PTXN) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|-----------------|
| | Less |
| < | than. |
| | Greater |
| > | than. |

| E | Estimate d. |
|-----------------------------|--|
| Value Qualifie r Code | Descript ion |
| @ | Holding time exceeded |
| с | See laborator y comment |
| d | Diluted sample: method hi range exceeded |
| n | Below the LRL and above the LT- MDL |

| Sample | Project | Labor- | | | | | | |
|--------|---------------|-----------------------------------|--------|--------|--------|------------|---------|--------|
| type | Code | atory | | | | - | | |
| | | sample | | | Baro- | Agency | Flow | Color, |
| | | comme nt | Temper | Temper | metric | ana- | rate, | water, |
| | | | ature, | ature, | pres- | lyzing | instan- | fltrd, |
| : | | | water, | air, | sure, | sample, | taneous | Pt-Co |
| | | | deg C | deg C | mm Hg | code | gal/min | units |
| | | | -10 | -20 | -25 | <u>-28</u> | -59 | -80 |
| 9 | 4451089 00 | NH4 & NH4+OR G-RR | 16.0 | | | 80020 | | 4 |
| 9 | 4451089 10 | CATIONS DUP'ED | 21.2 | 35.0 | 761 | 80020 | | |
| 7 | 4451106 00 | | 21.0 | 15.0 | 768 | 80020 | | |
| a | 24829RC | A- 1860004 High chloride | 21.6 | 29.6 | 751 | 80020 | 3.8 | |

) national aquifer.

| Specif- | Hydro- | | | | | | ANC, | Carbon- |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| ic | gen | | Dis- | pH, | pН, | | wat unf | ate, |
| conduc- | ion, | | solved | water, | water, | Carbon | fixed | wat flt |
| tance, | water, | Dis- | oxygen, | unfitrd | unfltrd | dioxide | end pt, | infl pt |
| wat unf | unfltrd | solved | percent | field, | lab, | water, | field, | titr., |
| uS/cm | calcd, | oxygen, | of sat- | std | std | unfltrd | mg/L as | field, |
| 25 degC | mg/L | mg/L | uration | units | units | mg/L | CaCO3 | mg/L |
| -95 | -191 | -300 | -301 | -400 | -403 | -405 | -410 | -452 |
| > 8000 | 0.00016 | | | 6.8 | 6.7 | 35 | 113 | |
| 46600 | 0.00004 | 0.1 | 1 | 7.4 | 7.0 | 6.4 | | 0.0 |
| 47600 | 0.00008 | 0.1 | 1 | 7.1 | 6.6 | 12 | | 0.0 |
| 44000 | 0.00005 | 0.1 | 2 | 7.3 | 6.7 | | | 0.0 |

| | | | | | the second of the second se | | and the second | |
|---------|---------|-------------|-------------|-------------------|---|---------|--|---------|
| Bicar- | | | Ammoni a | Nitrate | | | | Noncarb |
| bonate, | Organic | | + | + | Phos- | | | hard- |
| wat flt | nitro- | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | ness, |
| infl pt | gen, | water, | water, | water | water, | carbon, | ness, | wat flt |
| titr., | water, | fitrd, | unfltrd | fltrd, | unfltrd | water, | water, | field, |
| field, | unfltrd | mg/L | mg/L | mg/L | mg/L | unfitrd | mg/L as | mg/L as |
| mg/L | mg/L | as N | as N | as N | as P | mg/L | CaCO3 | CaCO3 |
| -453 | -605 | -608 | -625 | -631 | -665 | -680 | -900 | -904 |
| | | | | | | | | |
| | 5.4 | 3.50 | 8.9 | <u>< 0.100</u> | 0.02 | 0.7 | 3300 | |
| 1.40 | | | | | | | 2000 | 2000 |
| 142 | | | | | | | 3900 | 3800 |
| 116 | | | | | | | 4600 | 4500 |
| | | | | | | | | |
| | | | | | | | | |
| E 109 | | | | | | | 4400 | E 4300 |

•

ł

| Noncarb | | | | | | | | |
|---------|---------|----------|---------|---------|---------|--------------|---------|--------------|
| hard- | | | | | Sodium | | | |
| ness, | | Magnes | | | frac- | Potas- | Chlor- | |
| wat flt | Calcium | ium, | Sodium, | Sodium | tion | sium, | ide, | Sulfate |
| lab, | water, | water, | water, | adsorp- | of | water, | water, | water, |
| mg/L as | fltrd, | fltrd, | fitrd, | tion | cations | fltrd, | fltrd, | fitrd, |
| CaCO3 | mg/L | mg/L | mg/L | ratio | percent | mg/L | mg/L | mg/L |
| -905 | -915 | -925 | -930 | -931 | -932 | -935 | -940 | -945 |
| | 960 | 230 | 8100 | 61 | 84 | 94.0 | 17000 | 580 |
| | 1000 | 350 | 2400 | 17 | 56 | 100 | 15000 | 630 |
| | 1080 | 470 | 9530 | 61 | 81 | 118 | 17200 | 586 |
| | | | | | | | | |
| 4300 | 1010 d | 448 d' 💋 | 8970 d | 59 | 81 | <u>107 d</u> | 17600 d | <u>578 d</u> |

| | | | Iron, | | Mangan- ese, | | | |
|--|--|------------------------------------|--|-----------------------------------|--|--|-----------------------------------|--|
| Fluor- ide, water, fltrd, mg/L | Silica, water, fltrd, mg/L as SiO2 | Boron, water, fitrd, ug/L | water, unfltrd recover -able, ug/L | Iron, water, fltrd, ug/L | water, unfitrd recover -able, ug/L | Mangan ese, water, fltrd, ug/L | Zinc, water, fltrd, ug/L | Alum- inum, water, fltrd, ug/L |
| -950 | -955 | -1020 | (01045) | (01046) | (01055) | (01056) | (01090) | (01106) |
| 0.10 | 16.0 | 5200 | 15000 | 16000 | 3300 | 3400 | 420 | <u>< 50</u> |
| 1.7 | 14.0 | | | 17000 | | 3300 | | |
| < 0.10 | 18.5 | | | 19000 | | 3580 | | |
| 5.0.07 | | | | 18000 d | | 2050 d | | cen N |

| Alka- | Depth | Alka- | Alka- | Residue | Residue | | | |
|---------|---------|---------|---------|-------------|----------------|---------|-------------|---------------|
| linity, | to | linity, | linity, | on | water, | | | |
| wat flt | water | wat flt | wat flt | evap. | fitrd, | Residue | | |
| fxd end | level | fxd end | inf tit | at | sum of | water, | Ammoni a | Bromide |
| lab, | below | field, | field, | 180deg C | consti- | fltrd, | water, | water, |
| mg/L as | LSD, | mg/L as | mg/L as | wat flt | tuents | tons/ | fltrd, | fltrd, |
| CaCO3 | meters | CaCO3 | CaCO3 | mg/L | mg/L | acre-ft | mg/L | mg/L |
| (29801) | (30210) | (39036) | (39086) | (70300) | (70301) | (70303) | (71846) | (71870) |
| | | | : | | | | | |
| | 11.4 | | | 28600 | 27100 | 38.9 | 4.51 | |
| | | | 116 | 32100 | 19600 | 43.7 | | 3.50 |
| | | | 110 | | 1,000 | 10.7 | | |
| | 24.5 | 91 | 95 | 30500 | 29100 | 41.5 | | 62.2 |
| | | | | | · | | | |
| 76 @c | 27.1 | | 90 | 30900 | <u>E 28900</u> | 42.0 | | <u>67.3 d</u> |

| | Pump | | Depth | Depth | Depth | | | Specif. |
|---------|-------------------|----------------|---------|---------------|---------|----------------|----------------|---------------|
| Alti- | or flow | | to top | to bot | to | | | conduc- |
| tude | period | Sam- | sample | sample | water | | | tance, |
| of | prior | pling | intrval | intrval | level, | Sam- | | wat unf |
| land | to sam | condi- | feet | feet | feet | pling | Sampler | lab, |
| surface | pling, | tion, | below | below | below | method, | type, | uS/cm |
| feet | minutes | code | LSD | LSD | LSD | code | code | 25 degC |
| (72000) | £ 7 ₂004) | <u>(72006)</u> | (72015) | (72016) | (72019) | <u>(82398)</u> | <u>(84164)</u> | (90095) |
| | } } | | 1821.00 | 1831.00 | 37.28 | | | 40700 |
| | | | | | X | 8010 | 4040 | 43900 |
| | | 8.00 | 1820.00 | 1830.00 | 80.42 | | 4040 | 41900 |
| 15.0 | 816 | 8 00 | 1820.00 | 1820.00 | 88.00 | | 4040 | E 46000 |
| | | | 1820.00 | 11830.00 , | 199'90 | L | 4040 | <u> 40900</u> |

,

. ' ა

| | ANC, | | | | | | |
|-----|---------|----|---------------------------------------|-----------|-----|-----|-------------|
| | wat unf | | | | | | |
| | fixed | | | | | | |
| | inxed | | | | | | |
| | ena pr, | | | | | | |
| | lab, | | | | | | |
| | mg/L as | | | | | | |
| : | CaCO3 | | | | | | |
| | (90410) | | | | | | |
| | 0.0 | | | | | | · . |
| | 88 | | | | | | |
| • • | 83 | | | | | | |
| | 78 | | | | | | |
| | | | | • * | | | |
| | | | | | • | | |
| | | | | | | | · · |
| | | | | | | | · · · · |
| | | | | | | | |
| | · • • | κ. | | | | · . | |
| | | | | · · · · · | | | |
| | | | | | | | · · · · · · |
| • | | | | | | | |
| | , | | | | | | |
| • | | | | • | | | |
| | | 2 | · · · | | | | |
| | | | · · · · · · · · · · · · · · · · · · · | | | | |
| | | | | | | | |
| | | | | | · · | · . | |
| | | | • • | • | | | |
| | | | | | | | |
| | | | | | | | . * |

• • •

Forn GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT (Certification of Completion/County Permit)

• BWCM No. 234-192

SWCE Permit

35月8日年間日期日

State Water Control Board P. O. Box 11143 2111 North Hamilton St.

| Hichmond, Va. 23230 | | | | | County Permit |
|---|--------------------|-----------------------|------------|--------------------------------------|---------------------------------------|
| | | | | | Certification of inspecting official: |
| County/CityChesapea | ake | | | | This well does does not |
| | | Co | unty/City | y Stamp | S. |
| © Virginia Plane Coordinates | obco | rustion W | | 1_1 | Date |
| N | Owner ODSC. | | STT # 2 | <u> </u> | For Office Use |
| E 4 | Well Designation | n or Number | | | |
| Latitude & Longitude | Address | | | | |
| <u>N</u> | Phone | | the second | | Lax Map I.D. No. |
| <u>76 07' 47" v</u> | r none | | | | Section |
| PElouation 15 ft | Drilling Contrac | tor SWCB - | - Creas | on | Block |
| | Address | circo | CI GUN | | |
| Chithology CD | | | | | Class Well 1 110 |
| Biver Basin 5 | Phone | and the second second | | | |
| | Developer | [Observer | ation M | | |
| | WELL LOCATIO | UDSELVa | (feet/mile | direction) of | |
| Curtings No | and | feet/miles | - (din | ection) of | |
| Water Analysis Voc | · (If possible ple | ase include ma | p showing | location marked) | |
| Aquifer Test NO | | | | | |
| | Date started | 5-23-88 | Date | completed 7-26-88 | Type ug Mud Rotary |
| | | | | | |
| WELL DATA: New X Rewo | rkedDe | epened | | 2. WATER DATA @ Wate | r temperature 60.8 °F |
| © Total depth 13901 | | | ft. | [©] Static water level (unp | umped level measured) 56.72 TOC It |
| Depth to bedrock | | | ft. | Stabilized measured put | imping water level Aroncox 100 ft |
| [©] Hole size (Also include reamed | zones) | | | ^o Stabilized yield 9.4 | gpm after 4.5 hours |
| 3.5 inches from | 0 to | 1124' | ft. | Natural Flow: Yes | No X , flow rateg pm |
| 9 7.25 inches from | to | 1290' | tt. | Comment on quality_ | Salty Hydrogen Sulfide Odor |
| a 3.5 inches from | 1290' 10 | 1390' | ft. | 3. WATER ZONES: From | n To |
| Casing size (I.D.) and material | | | | FromTo | From To |
| 4 inches from | 0 to | 1290' | ft. | FromTo | From To |
| Material Black Stee | <u>1</u> | | | 4. USE DATA: | |
| Wt. per foot | or wall thickness | .237 | in. | Type of use: Drinking | , Livestock Watering |
| 2inches from | 1274 to | 1370' | ft | Irrigation Fo | od processing Household |
| Material Black Stee | 21 | | | Manufacturing | , Fire safety Cleaning |
| Wt. per foot | or wall thickness | | in. | Recreation | Aesthetic, Cooling or heating |
| 2 inches from | 1380' to | 1390' | ft. | Injection Oth | Observation |
| Material | | | _ | Type of facility Dome | estic, Public water supply |
| Wt. per foot | or wall thickness. | | 10 | Public institution _ | Farm, Industry |
| @Screen size and mesh for each | zone (where appl | icable) | 12.1 | Commercial | Other Observation |
| a inches from | _1370' to | 1380.' | ft | 5. PUMP DATA: Type | 9 Rated H.P. |
| Mesh size | Type | | | ©Intake depth | Quapacityathead |
| inches from | to | | ft. | 6 WELLHEAD: Type wel | l'seal |
| Mesh size | l ype | | | Pressure tank | gal., Loc. |
| Inches from | | | f1. | Sample tup | , Measurement port |
| Mesh size | Туре | | | Weli vent | Pressure relief valve |
| Inches from | 10 | | ft. | Gate valve | Check valve (when required) |
| @ Mesh size | Гуре | | | Electrical disconnect | t switch on power supply |
| © Gravel pack | | | | 7. DISINFECTION: Well d | lisinfected yes no |
| • From 1 | 0 | fı. | | Date | , Disinfectant used |
| © From1 | 0 | ft. | | Amount | , Hours used |
| © Grout | | | | 8. ABANDONMENT (when | e applicable) © yesno |
| e From to0 |) It , Type Ben | seal/EZ M | lid | Casing pulled yes | no not applicable |
| © From to | ft., Type | | | Plugging grout From | tonaterial |
| | | | | 1999 - 1977 S. | |

| Sample | Time | <u>Time</u> | <u>Sample</u> | Agency | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | <u>Geo-</u> |
|--------------|--------------|--------------------|---------------|--------------|-----------------|---------------|---------------|-------------|
| Datetim e | <u>datum</u> | <u>datum</u> | <u>Medium</u> | Collecting | Source | logic | logic | logic |
| | | <u>reliability</u> | Code | Sample, | | <u>Event</u> | Condition | <u>unit</u> |
| | | <u>code</u> | | <u>Code</u> | | | | |
| | | | | | | | | |
| | | - 1 | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | A | |
| 1993-07- | EDT | т | WG | USGS- WRD | 9 | 9 | A | |
| 1997-04- | EDT | т | WG | USGS- WRD | 9 | 9 | A | 217PPSC |
| 2006-06- | EDT | ĸ | WG | USGS- WRD | 9 | 9 | A | 217PPSC |

USGS 364227076074707 61B 13 SOW 091F

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 1,390.00 feet below land surface.

The depth of the hole is 1,390.00 feet below land surface.

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP' This well is completed in the PATAPSCO FORMATION (217PPSC) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|-----------------|
| | Less |
| < | than. |
| | Estimate |
| E | d. |

| | Presence |
|---|-----------|
| | verified |
| | but not |
| | quantifie |
| M | d. |

| Value Qualifie r Code | Descript ion |
|-----------------------------|--|
| 0 | Holding time exceeded |
| с | See laborator y comment |
| d | Diluted sample: method hi range exceeded |

P 6

.

| <u>Sample</u> | Project | Labor- | | | | | | |
|---------------|---------|-------------|---------|---------|--------|------------|---------|--------|
| type | Code | atory | | | ſ | | | |
| | | sample | | | Baro- | Agency | Flow | Color, |
| | | comme nt | Temper- | Temper- | metric | ana- | rate, | water, |
| | | | ature, | ature, | pres- | lyzing | instan- | fltrd, |
| | | | water, | air, | sure, | sample, | taneous | Pt-Co |
| | | 1 | deg C | deg C | mm Hg | code | gal/min | units |
| | | | -10 | -20 | -25 | <u>-28</u> | -59 | -80 |
| | | NH4 & | | | | | | |
| | 4451089 | NH4+OR | | | | | | |
| 9 | 00 | G-RR | 16.0 | | | 80020 | | 10 |
| 0 | 4451089 | | 21.0 | 22.0 | 765 | 00000 | | |
| 9 | 4451106 | | 21.0 | 55.0 | 705 | 80020 | | |
| 9 | 00 | | 20.0 | 12.0 | | 80020 | | |
| | 24829RC | | | | | | | |
| 9 | 20 | | 21.0 | 30.0 | 765 | 80020 | 2.9 | |

) national aquifer.

· ,•

| Specif- | Hydro- | | | | | | ANC, | Carbon- |
|---------|--------------------|---------|---------|---------|---------|---------|---------|--------------|
| ic | gen | | Dis- | pН, | pН, | | wat unf | ate, |
| conduc- | ion, | | solved | water, | water, | Carbon | fixed | wat flt |
| tance, | water, | Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt |
| wat unf | unfltrd | solved | percent | field, | lab, | water, | field, | titr., |
| uS/cm | calcd, | oxygen, | of sat- | std | std | unfltrd | mg/L as | field, |
| 25 degC | mg/L | mg/L | uration | units | units | mg/L | CaCO3 | mg/L |
| -95 | - <mark>191</mark> | -300 | -301 | -400 | -403 | -405 | -410 | -452 |
| 9000 | 0.00006 | | | 7.2 | 7.4 | 30 | 242 | |
| 15500 | 0.00003 | 0.1 | 1 | 7.6 | 7.5 | 13 | | 0.0 |
| 15500 | 0.00005 | 0.7 | | 7.3 | 7.6 | 24 | | 0.0 |
| 14200 | 0.00002 | 0.1 | 0.0 | 7.6 | 7.7 | | | <u>E 0.0</u> |

| Bicar- | | | Ammoni a | Nitrate | | | | Noncar |
|--------------|---------|-------------|-------------|-------------------|---------|---------|---------|--------------|
| bonate, | Organic | | + | + | Phos- | | | hard- |
| wat flt | nitro- | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | ness, |
| infl pt | gen, | water, | water, | water | water, | carbon, | ness, | wat flt |
| titr., | water, | fltrd, | unfltrd | fitrd, | unfltrd | water, | water, | field, |
| field, | unfltrd | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | mg/L a |
| mg/L | mg/L | as N | as N | as N | as P | mg/L | CaCO3 | CaCO3 |
| -453 | -605 | -608 | -625 | -631 | -665 | -680 | -900 | -904 |
| | 0.10 | 5.00 | 5.1 | <u>< 0.100</u> | 0.02 | 0.3 | 570 | |
| 313 | | | | | | | 560 | 300 |
| 351 | | | | | | | 560 | 270 |
| <u>E 293</u> | | | | | | | 520 | <u>E 280</u> |

111 IA MARKANANA A

. .

| Noncarb | | | | | | | | |
|---------|--------------|---------------|---------------|---------|---------|---------------|---------------|--------------|
| hard- | | | | | Sodium | | | 2 |
| ness, | | Magnes | | | frac- | Potas- | Chlor- | |
| wat flt | Calcium | ium, | Sodium, | Sodium | tion | sium, | ide, | Sulfate |
| lab, | water, | water, | water, | adsorp- | of | water, | water, | water, |
| mg/L as | fltrd, | fltrd, | fltrd, | tion | cations | fltrd, | fltrd, | fltrd, |
| CaCO3 | mg/L | mg/L | mg/L | ratio | percent | mg/L | mg/L | mg/L |
| -905 | -915 | -925 | -930 | -931 | -932 | -935 | -940 | -945 |
| | | | | | | | | |
| | 120 | 65.0 | 3000 | 55 | 91 | 43.0 | 5000 | 280 |
| | 120 | 63.0 | 3000 | 55 | 91 | 44.0 | 4600 | 290 |
| | 122 | 61.2 | 3110 | 57 | 92 | 54.4 | 5060 | 279 |
| 280 | <u>113 d</u> | <u>58.6 d</u> | <u>2740 d</u> | 52 | 91 | <u>48.6 d</u> | <u>4850 d</u> | <u>263 d</u> |

| Fluor- ide, water, fltrd, mg/L | Silica, water, fltrd, mg/L as SiO2 | Boron, water, fltrd, ug/L | Iron, water, unfltrd recover -able, ug/L | Iron, water, fltrd, ug/L | Mangan- ese, water, unfitrd recover -able, ug/L | Mangan ese, water, fltrd, ug/L | Zinc, water, fltrd, ug/L | Alum- inum, water, fltrd, ug/L |
|--|--|------------------------------------|---|-----------------------------------|---|--|-----------------------------------|--|
| -950 | -955 | -1020 | (01045) | (01046) | (01055) | (01056) | (01090) | (01106) |
| 0.40 | 13.0 | 5200 | 3900 | 3800 | 280 | 220 | 20 | <u>< 20</u> |
| 0.9 | 12.0 | | | 3200 | | 200 | | |
| 0.45 | 13.7 | | | 3870 | | 240 | | |
| 0.43 | <u>13.1 d</u> | | | 4070 d | | <u>244 d</u> | < | |

| Alka- | Depth | Alka- | Alka- | Residue | Residue | | | |
|---------------|---------|---------|---------|-------------|---------------|---------|-------------|---------------|
| linity, | to | linity, | linity, | on | water, | | | |
| wat flt | water | wat flt | wat flt | evap. | fltrd, | Residue | | |
| fxd end | level | fxd end | inf tit | at | sum of | water, | Ammoni a | Bromide |
| lab, | below | field, | field, | 180deg C | consti- | fltrd, | water, | water, |
| mg/L as | LSD, | mg/L as | mg/L as | wat flt | tuents | tons/ | fltrd, | fltrd, |
| CaCO3 | meters | CaCO3 | CaCO3 | mg/L | mg/L | acre-ft | mg/L | mg/L |
| (29801) | (30210) | (39036) | (39086) | (70300) | (70301) | (70303) | (71846) | (71870) |
| | | | | <u></u> | | | | |
| | 17.0 | | | 8900 | 8680 | 12.1 | 6.44 | |
| | | | 256 | 9090 | 8290 | 12.4 | | 3.70 |
| | | 280 | 282 | 8720 | 8900 | 11.9 | | 18.3 |
| <u>249 @c</u> | 23.7 | | 241 | 8830 | <u>E 8260</u> | 12.0 | | <u>18.9 d</u> |

| | Pump | | Depth | Depth | Depth | | | Specif. |
|---------|---------|----------------|---------|---------|---------|----------------|----------------|----------------|
| Alti- | or flow | | to top | to bot | to | | | conduc- |
| tude | period | Sam- | sample | sample | water | | | tance, |
| of | prior | pling | intrval | intrval | level, | Sam- | | wat unf |
| land | to sam- | condi- | feet | feet | feet | pling | Sampler | lab, |
| surface | pling, | tion, | below | below | below | method, | type, | uS/cm |
| feet | minutes | code | LSD | LSD | LSD | code | code | 25 degC |
| (72000) | (72004) | <u>(72006)</u> | (72015) | (72016) | (72019) | <u>(82398)</u> | <u>(84164)</u> | (90095) |
| | | | 1370.00 | 1380.00 | 55.62 | | | 14800 |
| | | | | | | 8010 | 4040 | 15000 |
| | | | 1370.00 | 1380.00 | | | 4040 | 15200 |
| 15.0 | 475 | 8.00 | 1370.00 | 1380.00 | 77.88 | | 4040 | <u>E 10600</u> |

| ANC, | |
|---------|----------|
| wat unf | |
| fixed | Sulfide |
| end pt, | water, |
| lab, | unfltrd |
| mg/L as | field, |
| CaCO3 | mg/L |
| (90410) | (99119) |
| | |
| 246 | |
| 247 | |
| 250 | |
| | <u>M</u> |

)

. . . .

Fo..n GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

• BWCM No. 234-193

.

| (Certification o | f Completion. | /County | Permit) |
|------------------|---------------|---------|---------|
|------------------|---------------|---------|---------|

| te Water Control Board | Certification | 101 0011 | |
|---|--|-------------------|--|
| - 111 North Hamilton St. | | | SWCB Permit |
| Richmond, Va. 23230 | | | County Permit |
| | | | Certification of inspecting official: |
| County/City Ches | sapeake | | This well does does not |
| | | County/Ci | ty Stamp meet code/low requirements. |
| © Virginia Plane Coordinate | s | | Date. |
| | N Owner Observation | Well # | 91-G |
| | E Well Designation or Number | Fentre | ess For Office Use |
| Latitude & Longitude | Address | | |
| 36° 42' 27" | N | | Tax Map I.D. No. |
| | W Phone | | Subdivision |
| [©] Topo, Map No. 2B | - | - | Section |
| © Elevation 15 | tt. Orilling Contractor SWCB | - Creas | SONBlock |
| ©Formation KUP | Address | | Lot |
| Lithology <u>SD</u> | | | Class Well 1 IIA |
| © River Basin 5 | Phone | | |
| @Province | - Fentress [Observ | ation We | ell # 91-G] [IIICIIIDIIIE |
| eType Logs E | WELL LOCATION: | (feet/mi | lesdirection) of |
| Cuttings NO | - and feet/mile | s(di | rection) of |
| Water Analysis Yes | - (IT possible please include | map showin | ig location marked |
| Aquifer Test NO | - Data started 7-28-8 | 8 8 Date | a completed 8-15-88 Turs of Mud Botary |
| | Date started ZO O | Dati | e completed |
| ole size (Also include re <u>12</u> inches fr <u>6.75</u> inches fr <u>3.5</u> inches tr Casing size (I.D.) and mat <u>4</u> inches fr Material Black | amed zones) form 0 to 25' orm 0 to 1000' om 1000' to 1113' erial 0 to 1000' Steel 1000' to 1000' | ft. ft. ft. | Stabilized yield 10 gpm after 3.5 Natural Flow: Yes No X . How rate Comment on quality Salty Hydrogen Sulfide Odd 3. WATER ZONES: From To From To From To From To From To 4. USE DATA: |
| Wr. per foot | or wall thickness .237 | (n. | Type of use Drinking, Livestock Watering |
| © 2inches fr | om <u>987'</u> to <u>1093'</u> | fi | Irrigation Food processing Household |
| Material Black | Steel | | Manufacturing, Fire safety Cleaning |
| Wt. per toot | or wall thickness | in. | Recreation Aesthetic Cooling or heating |
| O inches tr | orn <u>1103'</u> to <u>1113'</u> | ft. | Injection, Other Observation |
| Material Blac | s Steel | | © Type of facility Domestic, Public water supply |
| Wt. per foot | or wall thickness | in. | Public institution Farm Industry |
| © Screen size and mesh for | each zone (where applicable) | | Commercial Other Observation |
| 0 2 inches In | om 1093. to 1103. | ^{II} . | 5. PUMP DATA: Type 9 Rated H P. |
| o Wesh size .020 | Type 55 Pipe base | | Intake depth QCapacity at here |
| inches fr | of | ft. | 6. WELLHEAD: Type well seal |
| o wesh size | Туре | | Pressure tank gal , Loc |
| oinches fr | om to | ft. | Sample tap Measurement port |
| wiesh size | Туре | | Well vent, Pressure relief valve |
| inches fr | om10 | ft. | Gate valve Check valve (when required) |
| @ Mesh size | Туре | | Electrical disconnect switch on power supply |
| ^o Gravel pack | | | 7. DISINFECTION: Well disinfected yes |
| o From | 10 ft. | | Date, Disinfectant used |
| wrom | 10 ft | | Amount, Hours used |
| e Grout | 10001 ft Tune Amin-Col C | oldrool | 8. ABANDONMENT (where applicable) @yesno |
| VFrom U to | LUUU_IL, TYPE AQUA-GEL G | oruseat | Casing pulled yes no not applicable |
| oFrom to | n., Type | | Plugging grout Fromfomaterial |

......

| Sample | Time | <u>Time</u> | Sample | Agency | <u>Analysis</u> | <u>Hydro-</u> | Hydro- | Geo- |
|--------------|--------------|--------------------|--------|-------------------|-----------------|---------------|-----------|--------------|
| Datetim e | <u>datum</u> | <u>datum</u> | Medium | <u>Collecting</u> | Source_ | logic | logic | logic |
| | | <u>reliability</u> | Code | Sample, | - 163 | <u>Event</u> | Condition | unit |
| | | <u>code</u> | | Code_ | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | A | |
| 1993-07- | EDT | т | WG | USGS- WRD | 9 | 9 | A | |
| 1997-04- | EDT | т | WG | USGS- WRD | 9 | 9 | A | 211CRCS U |
| 2006-06- | EDT | к | WG | USGS- WRD | 9 | 9 | A | 211CRCS U |

USGS 364227076074708 61B 14 SOW 091G

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 1,113.00 feet below land surface.

The depth of the hole is 1,113.00 feet below land surface.

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the UPPER CRETACEOUS SERIES (211CRCSU) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|-----------------|
| | Less |
| < | than. |
| | Estimate |
| E | d. |

| | M | Presence verified but not quantifie d. |
|---|---|--|
| l | M | d. |

| Value Qualifie r Code | Descript ion |
|-----------------------------|--|
| Q | Holding time exceeded |
| с | See laborator y comment |
| d | Diluted sample: method hi range exceeded |

| <u>Sample</u> | Project | Labor- | | | | | | |
|---------------|---------------|-------------|---------|---------|---------|----------------|---------|---------|
| <u>type</u> | Code | atory | | | | | | |
| | | sample | | | Baro- | Agency | Flow | Color, |
| | | comme nt | Temper- | Temper- | metric | ana- | rate, | water, |
| | | | ature, | ature, | pres- | lyzing | instan- | fltrd, |
| | | | water, | air, | sure, | sample, | taneous | Pt-Co |
| | - | | deg C | deg C | mm Hg | code | gal/min | units |
| | | | (00010) | (00020) | (00025) | <u>(00028)</u> | (00059) | (00080) |
| | | NH4 & | | | | | | |
| | 4451089 | NH4+OR | | | | | | |
| 9 | 00 | G-RR | 18.0 | | | 80020 | | 22 |
| | 4451089 | BOTTLES | | | | | | |
| 9 | 10 | OK | 20.4 | 32.0 | 765 | 80020 | | |
| | 4451106 | | | | | | | |
| 7 | 00 | | 19.9 | 12.0 | 757 | 80020 | | |
| 9 | 24829RC 20 | | 20.6 | 32.0 | 763 | 80020 | 3.0 | |

) national aquifer.

18 . .

| Specif- | Hydro- | | | | | | ANC, | Carbon- |
|---------|---------|---------|---------|---------|---------|---------|---------|------------|
| ic | gen | | Dis- | pН, | pН, | | wat unf | ate, |
| conduc- | ion, | | solved | water, | water, | Carbon | fixed | wat flt |
| tance, | water, | Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt |
| wat unf | unfltrd | solved | percent | field, | lab, | water, | field, | titr., |
| uS/cm | calcd, | oxygen, | of sat- | std | std | unfltrd | mg/L as | field, |
| 25 degC | mg/L | mg/L | uration | units | units | mg/L | CaCO3 | mg/L |
| (00095) | (00191) | (00300) | (00301) | (00400) | (00403) | (00405) | (00410) | (00452) |
| | | | | | | | | |
| 6000 | 0.00002 | | | 7.7 | 7.9 | 17 | 429 | |
| 6010 | 0.00001 | 0.1 | 1 | 8.0 | 8.0 | 8.5 | | 0.0 |
| 6080 | 0.00001 | | | 8.1 | 8.0 | 6.8 | | 0.0 |
| 5140 | 0.00001 | 0.1 | 0.0 | 8.0 | 8.1 | | | <u>E 2</u> |

| Bicar- | | Ammoni a | Nitrate | | | | | |
|--------------|-------------|-------------|-------------------|---------|---------|---------|---------------|---------------|
| bonate, | | + | + | Phos- | | | 2 | |
| wat flt | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | | Magnes- |
| infl pt | water, | water, | water | water, | carbon, | ness, | Calcium | ium, |
| titr., | fltrd, | unfltrd | fltrd, | unfltrd | water, | water, | water, | water, |
| field, | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, | fltrd, |
| mg/L | as N | as N | as N | as P | mg/L | CaCO3 | mg/L | mg/L |
| (00453) | (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00915) | (00925) |
| | | | | | | | | |
| | 2.80 | 2.8 | <u>< 0.100</u> | 0.03 | 0.1 | 110 | 21.0 | 13.0 |
| 547 | | | | | | 73 | 14.0 | 9.20 |
| 582 | | | | | | 89 | 17.7 | 10.9 |
| <u>E 536</u> | | | | | | 85 | <u>16.8 d</u> | <u>10.3 d</u> |

ł

| Sodium, water, fltrd, mg/L (00930) | Sodium adsorp- tion ratio (00931) | Sodium frac- tion of cations percent (00932) | Potas- sium, water, fltrd, mg/L (00935) | Chlor- ide, water, fltrd, mg/L (00940) | Sulfate water, fltrd, mg/L (00945) | Fluor- ide, water, fltrd, mg/L (00950) | Silica, water, fltrd, mg/L as SiO2 (00955) | Boron, water, fltrd, ug/L (01020) |
|--|---|--|--|---|--|---|---|---|
| 1200 | 51 | 95 | 23.0 | 1600 | 130 | 1 40 | 13.0 | 3500 |
| 1100 | 51 | 95 | 27.0 | 1400 | 120 | 1.5 | 10.0 | 5500 |
| 1100 | 00 | 90 | 27.0 | 1400 | 120 | 1.2 | 10.0 | |
| 1210 | 56 | 96 | 25.2 | 1640 | 122 | 1.42 | 12.6 | |
| 1160 d | 55 | 96 | <u>25.3 d</u> | <u>1370 d</u> | 99.4 d | 1.30 | <u>11.7 d</u> | |

| and the same set of the same set of | 1 | 1 | 1 | | | | 1 | |
|-------------------------------------|--------------|---------|---------------|----------------|----------------|---------------|---------|---------|
| | | Mangan- | | | | Alka- | Depth | Alka- |
| Iron, | | ese, | | | | linity, | to | linity, |
| water, | | water, | Mangan | | Alum- | wat flt | water | wat flt |
| unfltrd | Iron, | unfltrd | ese, | Zinc, | inum, | fxd end | level | fxd end |
| recover | water, | recover | water, | water, | water, | lab, | below | field, |
| -able, | fltrd, | -able, | fltrd, | fitrd, | fltrd, | mg/L as | LSD, | mg/L as |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | CaCO3 | meters | CaCO3 |
| (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (29801) | (30210) | (39036) |
| 800 | 650 | 40 | 40 | <u>< 10</u> | <u>< 10</u> | | 15.6 | |
| | 410 | | 35.0 | | | | | |
| | 658 | | 51.8 | | | | | 480 |
| | <u>922 d</u> | | <u>66.7 d</u> | | | <u>378 @c</u> | 22.4 | |
| Alka- | Residue | Residue | | | | | Pump | |
|-----------|-------------|---------------|---------|-------------|---------------|---------|---------|----------------|
| linity, | on | water, | | | | Alti- | or flow | |
| wat flt | evap. | fltrd, | Residue | | | tude | period | Sam- |
| inf tit | at | sum of | water, | Ammoni a | Bromide | of | prior | pling |
| field, | 180deg C | consti- | fltrd, | water, | water, | land | to sam- | condi- |
| mg/L as | wat flt | tuents | tons/ | fltrd, | fltrd, | surface | pling, | tion, |
| CaCO3 | mg/L | mg/L | acre-ft | mg/L | mg/L | feet | minutes | code |
| (39086) | (70300) | (70301) | (70303) | (71846) | (71870) | (72000) | (72004) | <u>(72006)</u> |
| | | | | | | | | |
| | 3310 | 3270 | 4.50 | 3.61 | | | | |
| 448 | 3340 | 2950 | 4.54 | | 2.30 | | | |
| 477 | 3260 | 3330 | 4.43 | | 6.01 | | | |
| 443 | 2870 | <u>E 2960</u> | 3.90 | | <u>5.18 d</u> | 15.0 | 640 | 8.00 |

| Depth | Depth | Depth | | | Specif. | ANC, | |
|---------|---------|---------|----------------|----------------|---------|---------|----------------------|
| to top | to bot | to | | | conduc- | wat unf | |
| sample | sample | water | | | tance, | fixed | Sulfide |
| intrval | intrval | level, | Sam- | | wat unf | end pt, | water, |
| feet | feet | feet | pling | Sampler | lab, | lab, | unfltrd |
| below | below | below | method, | type, | uS/cm | mg/L as | field, |
| LSD | LSD | LSD | code | code | 25 degC | CaCO3 | mg/L |
| (72015) | (72016) | (72019) | <u>(82398)</u> | <u>(84164)</u> | (90095) | (90410) | <mark>(99119)</mark> |
| 1093.00 | 1103.00 | 51.32 | | | 5880 | 442 | |
| | | | 8010 | 4040 | 5890 | 442 | |
| 1090.00 | 1100.00 | | _ | 4040 | 5980 | 444 | |
| 1090.00 | 1100.00 | 73.42 | | 4040 | 5260 | | <u>M_</u> |

Foun GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

• BWCM No. 234-194

(Certification of Completion/County Permit)

|). Box 11143 | 107-101-101 | | | | 4 | SWICE Parent |
|--|------------------------|--|--|---|--|--|
| (1 North Hamilton St. Bichmond Va 23230 | | | | | | County Permit |
| (inclinition), va. 25250 | | | | | | |
| County/City Chesap | eake | | | | | Certification of inspecting official: This well does does not |
| ······································ | • | Co | unty/Cit | y Stamp | | meet code/low requirements. |
| © Virginia Plane Coordinates | | | | | | Date |
| N | Owner Obser | vation V | Well # | 91-н | | Enc Office Line |
| E | Well Designation or | Number | Fentre | ess | | r or ornice ose |
| Latitude & Longitude | Address | | | | | |
| <u>36° 42' 27" N</u> | - | | | | | Tax Map I.D. No. |
| <u>76° 07' 47" W</u> | Phone | Service and the service of the servi | | | | Subdivision |
| Topo Map No. 2B | | CUTOD | Owon | 200 | | Section |
| • Elevation 15 ft. | Drilling Contractor | SWCB - | · creas | son | | Block |
| ©Formation <u>KVB</u> | Address | | | | | Lot |
| Clithology SD | | | | | | Class Well I, IIA |
| ©River Basin | Phone | 01 | | 7.17 1 01 17 | | 11B 11IA 11IB |
| ©Province 1 | Fentress [| Opserva | tion V | Well # 91-H | ation of | IIID IIIE IIIE |
| a Contraction of the second se | WELL LOCATION | | _ueet/mia | es dire | ction) of | |
| eutrings NO | and | include mai | | location marked | | |
| Water Analysis IES | in possible piedae | mendoe maj | p anowing | g location marked | | |
| - Aquiter rest_NO | Date started 8 | -21-88 | 0 Date | completed 8- | -25-88 | Type up Mud Rotary |
| <u>12</u> inches from <u>6,75</u> inches from <u>3,5</u> inches from <u>3,5</u> inches from <u>4</u> inches from <u>4</u> and the structure <u>4</u> inches from <u>5</u> Material Black Structure <u>2</u> inches from Material Black Structure <u>8</u> and the structure | n | 25' 700' 790' 700' .237 759' | ft. ft. ft. in. ft. in. | Natural Flo Comment 3. WATER 20 From From 4. USE DATA: Type of use Irrigatio Manufac Recreatio | w Yes X on quality S NES: From To To Drinking n Foo cturing | No |
| © 2 inches from | 769' to | 790' | ft. | Injection | n Oth | er Observation |
| Material | | | | Type of fac | ility Dome | stic , Public water supply |
| Wt. per foot | or wall thickness | | in. | Public in | stitution | Farm Industry |
| Screen size and mesh for each | h zone (where applicat | ole) | | Commer | cial | Other Observation |
| © 2 inches from | 759' to | 769' | ft. | 5. PUMP DATA | A: Type | 9 Rated H.P. |
| • Mesh size .020 | Type SS Wire W | rapped | | ©Intake d | epth | © Capacity at head |
| inches from | to | | ft. | 6. WELLHEAD | : Type well | I seal |
| © Mesh size | Туре | | | Pressure | tank | gal , Loc |
| a inches from | | | f1 | Sample i | ар | , Measurement port |
| ^o Mesh size | Type | | | Well ven | I | Pressure relistivalve |
| Inches from | to | | f1 | Gate valv | /e (| Check valve (when required) |
| © Mesh size | Туре | | | Electrica | I disconnect | switch on power supply |
| ^o Gravel pack | | | | 7. DISINFECTI | ON: Well di | isinfected yes no |
| © From | to | f1. | | Date | | Disinfectant used |
| @From | to | ft. | | Amount | | , Hours used |
| ^o Grout | | | | 8. ABANDONN | IENT (where | e applicable) © yes no |
| • From 0 10 70 | 10 11. Type Aqua- | Gel Gold | lseal | Casing pr | ulled yes | no not applicable |
| @From to | ft., Type | | | Plugaina | grout From | to material |

| Sample | <u>Time</u> | <u>Time</u> | Sample | Agency | Analysis | <u>Hydro-</u> | <u>Hydro-</u> | <u>Geo-</u> |
|--------------|--------------|--------------------|--------|--------------|----------|---------------|---------------|-------------|
| Datetim e | <u>datum</u> | <u>datum</u> | Medium | Collecting | Source | logic | logic | logic |
| | | <u>reliability</u> | Code | Sample, | | <u>Event</u> | Condition | <u>unit</u> |
| | | <u>code</u> | | <u>Code</u> | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | _ | | | | | | | |
| 1989-03- | FST | т | WG | USGS- WRD | 9 | 9 | А | |
| 1909-05- | LUI | | | USGS- | | | | 211CRA |
| 2001-03- | EST | т | WG | WRD | 9 | X | Х | QU |
| | | | | USGS- | | | | 211CRA |
| 2006-06- | EDT | K | WG | WRD | 9 | 9 | A | QU |

USGS 364227076074709 61B 15 SOW 091H

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29 The depth of the well is 790.00 feet below land surface. The depth of the hole is 790.00 feet below land surface.

PEE DEE Aquifer

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the UPPER CRETACEOUS AQUIFER SYSTEM (211CRAQU) local aq

| Water Quality Remark Code | Descript ion |
|------------------------------------|--|
| < | Less than. |
| М | Presence verified but not quantifie d. |

| Value Qualifie r Code | Descript ion |
|-----------------------------|--|
| @ | Holding time exceeded |
| с | See laborator y comment |
| d | Diluted sample: method hi range exceeded |

| Sample | Project | Labor- | | | | | | |
|-------------|---------|-------------|---------|---------|---------|----------------|---------|---------|
| <u>type</u> | Code | atory | | | | | | |
| | | sample | | | Baro- | Agency | Flow | Color, |
| | | comme nt | Temper- | Temper- | metric | ana- | rate, | water, |
| | | | ature, | ature, | pres- | lyzing | instan- | fltrd, |
| | | | water, | air, | sure, | sample, | taneous | Pt-Co |
| | | | deg C | deg C | mm Hg | code | gal/min | units |
| | | | (00010) | (00020) | (00025) | <u>(00028)</u> | (00059) | (00080) |
| | | NH4 & | | | | | | |
| | 4451089 | NH4+OR | | | | | | |
| 9 | 00 | G-RR | 16.5 | | | 80020 | | 25 |
| | 4451106 | | | | | | | |
| 9 | 00 | | 20.8 | 23.4 | 744 | 80020 | 6.7 | |
| | 24829RC | | 10.0 | | | | | |
| 9 | 20 | | 18.9 | 23.1 | 751 | 80020 | 3.0 | |

. *

) national aquifer. uifer.

| Specif- | Hydro- | | | | | | ANC, | Carbon- |
|---------|---------|---------|---------|---------|---------|---------|---------|---------------|
| ic | gen | | Dis- | pН, | pН, | | wat unf | ate, |
| conduc- | ion, | | solved | water, | water, | Carbon | fixed | wat flt |
| tance, | water, | Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt |
| wat unf | unfltrd | solved | percent | field, | lab, | water, | field, | titr., |
| uS/cm | calcd, | oxygen, | of sat- | std | std | unfltrd | mg/L as | field, |
| 25 degC | mg/L | mg/L | uration | units | units | mg/L | CaCO3 | mg/L |
| (00095) | (00191) | (00300) | (00301) | (00400) | (00403) | (00405) | (00410) | (00452) |
| 7000 | 0.00001 | | | 8.1 | 7.8 | 10 | 630 | |
| 7800 | 0.00002 | 0.0 | 0.0 | 7.8 | 7.9 | | | <u>< 1</u> |
| 7570 | 0.00001 | 0.1 | 0.0 | 7.9 | 8.0 | | | 4 |

| Bicar- | | Ammoni a | Nitrate | | | | | |
|---------|-------------|-------------|-------------------|---------|---------|---------|----------------|----------------|
| bonate, | | + | + | Phos- | | | | _ |
| wat flt | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | | Magnes- |
| infl pt | water, | water, | water | water, | carbon, | ness, | Calcium | ium, |
| titr., | fltrd, | unfltrd | fltrd, | unfltrd | water, | water, | water, | water, |
| field, | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, | fltrd, |
| mg/L | as N | as N | as N | as P | mg/L | CaCO3 | mg/L | mg/L |
| (00453) | (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00915) | (00925) |
| | 4.40 | 4.3 | <u>< 0.100</u> | 0.19 | 0.9 | 140 | 20.0 | 22.0 |
| 775 | | | | | | 130 | 19.8 | 20.4 |
| 778 | | | | | | 130 | <u>18.7 dc</u> | <u>20.2 dc</u> |

- 8

 $TDS = C_a^{2+} + M_3^{2+} + N_4^{+} + K_1^{+} + C_1^{-} + SO_4^{2-}$ = 18.7 + 26.2 + 1550 + 42.9 + 2140 + 159 = 3930.8 ms/c

| | | Sodium | | | | | | |
|---------|---------|---------|----------------|---------------|--------------|---------|----------------|---------------------|
| | | frac- | Potas- | Chlor- | | Fluor- | Silica, | |
| Sodium, | Sodium | tion | sium, | ide, | Sulfate | ide, | water, | Boron, |
| water, | adsorp- | of | water, | water, | water, | water, | fltrd, | water, |
| fltrd, | tion | cations | fltrd, | fltrd, | fltrd, | fltrd, | mg/L as | fltrd, |
| mg/L | ratio | percent | mg/L | mg/L | mg/L | mg/L | SiO2 | ug/L |
| (00930) | (00931) | (00932) | (00935) | (00940) | (00945) | (00950) | (00955) | (01020) |
| | | | | - | | | | $\langle \ \rangle$ |
| 1700 | 62 | 95 | 39.0 | 2100 | 180 | 1.30 | 11.0 (| 6100 / |
| 1600 | 60 | 95 | 44.0 | 2150 | 156 | 1.47 | 9.94 | |
| 1550 dc | 59 | 95 | <u>42.9 dc</u> | <u>2140 d</u> | <u>159 d</u> | 1.38 | <u>9.91 dc</u> | |

| | | Mangan | | | | Alka- | Depth | Alka- |
|---------|---------|---------|---------|----------------|---------|---------|---------|---------|
| Iron, | | ese, | | | | linity, | to | linity, |
| water, | | water, | Mangan | | Alum- | wat flt | water | wat fit |
| unfitrd | Iron, | unfltrd | ese, | Zinc, | inum, | fxd end | level | inf tit |
| recover | water, | recover | water, | water, | water, | lab, | below | field, |
| -able, | fltrd, | -able, | fltrd, | fltrd, | fitrd, | mg/L as | LSD, | mg/L as |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | CaCO3 | meters | CaCO3 |
| (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (29801) | (30210) | (39086) |
| 4500 | 790 | 50 | 10 | <u>< 10</u> | 30 | | | |
| | 296 | | 24.3 | | | 642 | 0.241 | 636 |
| | 547 dc | | 33.9 dc | | | 638 @c | 1.01 | 646 |

| Residue | Residue | | | | | Pump | | Depth |
|-------------|---------|---------|---------|---------------|---------|---------|----------------|---------|
| on | water, | | | | Alti- | or flow | | to top |
| evap. | fitrd, | Residue | | | tude | period | Sam- | sample |
| at | sum of | water, | Ammoni | Bromide | of | prior | pling | intrval |
| 180deg C | consti- | fltrd, | water, | water, | land | to sam- | condi- | feet |
| wat flt | tuents | tons/ | fitrd, | fltrd, | surface | pling, | tion, | below |
| mg/L | mg/L | acre-ft | mg/L | mg/L | feet | minutes | code | LSD |
| (70300) | (70301) | (70303) | (71846) | (71870) | (72000) | (72004) | <u>(72006)</u> | (72015) |
| 4390 | 4460 | 5.97 | 5.67 | | | | | 759.00 |
| 4580 | 4390 | 6.23 | | 7.82 | 15.0 | 200 | 8.00 | 759.00 |
| 4540 | 4340 | 6.18 | | <u>8.01 d</u> | 15.0 | 499 | 8.00 | 759.00 |

| the second | | | | | |
|---|---------|----------------|---------|---------|---------|
| Depth | Depth | | Specif. | ANC, | |
| to bot | to | 4 | conduc- | wat unf | |
| sample | water | | tance, | fixed | Sulfide |
| intrval | level, | | wat unf | end pt, | water, |
| feet | feet | Sampler | lab, | lab, | unfltrd |
| below | below | type, | uS/cm | mg/L as | field, |
| LSD | LSD | code | 25 degC | CaCO3 | mg/L |
| (72016) | (72019) | <u>(84164)</u> | (90095) | (90410) | (99119) |
| 769.00 | | | 7810 | 633 | |
| 769.00 | 0.79 | 4040 | 7760 | | |
| 769.00 | 3.30 | 4040 | 7910 | | M |

Form GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

• BWCM No. ____234-195

1.1.1

(Certification of Completion/County Permit)

| O. Box 11143 | | | | | SWCB Permit |
|---|--------------------------------|---------------|----------------|--|--|
| T1 North Hamilton St. rrichmond, Va. 23230 | | | | | County Permit |
| | | | | | |
| County/City Chesap | eake | | | | Certification of inspecting official: This well does does not |
| county city | | Co | unty/Ci | tv Stamo | meet code/low requirements. |
| Virginia Plane Coordinates | 1 | 00 | unity / on | () otamp | S. |
| N | Owner Obsei | vation We | ell # 9 | Э1-Ј | Date |
| E | Well Designation | or Number | Fentre | ess | For Office Use |
| Latitude & Longitude | Address | | | | |
| 36° 42' 27" N | | | | | Tax Map I D No |
| 76° 07' 47" W | Phone | | | | Subdivision |
| Topo, Map No. 2B | | CT 10D | 0 | | Section |
| © Elevation 15 ft. | [©] Drilling Contract | or SWCB | - Crea | ison | Block |
| © FormationTA | Address | | | | Lot |
| Lithology <u>SD</u> | | | | | Class Well 1, IIA |
| © River Basin 5 | Phone | | | | IIB |
| Province 1 | Fentress | Observat | ion We | ell <mark># 91-J</mark>] | IIID IIIE |
| e Type Logs E | WELL LOCATIC | JN: | _(feet/mil | esdirection) of | |
| Cuttings NO | and | feet/miles | (di | rection) of | |
| Water Analysis 185 | tri possible pie | ase merade ma | ip snowin | g location marked | |
| Aquiter Test_NO | Data started | 9-1-88 | 0 Date | 9-14-88 | Tung on Mud Rotary |
| | | | | | |
| © Total depth 690' | WorkedDe | epened | ft, | 2. WATER DATA @ Wate @Static water level (unp | er temperature 62.6 sumped level-measured) Flowing |
| ©Depth to bedrock | | | ft | ©Stabilized measured po | umping water level 22.52 |
| 'tole size (Also include ream | ed zones) | | | Stabilized yield 10 | gpm after 2.5ho |
| 7.25 inches from | 1 <u>0</u> to | 602' | ft. | Natural Flow: Yes X | No How rate ess Than 1gr |
| a.5_inches from | 602' to | 690' | ft. | Comment on qualityS | alty, Hydrogen sulfide odor |
| o inches from | to | | ft_ | 3. WATER ZONES: From | nTo |
| Casing size (I.D.) and materi | al | 6001 | ¥2. | From To | From To |
| 4.5 inches from | <u> </u> | 602 | ft. | FromTo | From To |
| Material PVC | | | | 4. USE DATA. | |
| Wt per toot | or wall thickness | 6701 | in. | Type of use Drinking | , Livestock Watering |
| Material Black S | <u></u> | 070 | ft | Irrigation Fo | ood processing Household |
| Wit per toot | | | in | Manufacturing | , Fire safety, Cleaning |
| a 2 unchas trans | 6801 to | 6901 | fr | | Aesthetic Cooling or heating |
| Material Black G | | 0,00 | | Dime of facility D | ODSELVACION |
| Wt per toot | or wall thickness | | 10 | - Type of facility Dom | estic, Public water supply |
| a Screen size and mesh for eac | h zone (where appli | cable) | | Commercial | Other Observation |
| © 2 inches from | 670' 10 | 680' | ft. | 5 PLIMP DATA: Tupo | P R stad H P |
| • Mesh size .010 | Type SS Wire | Wrapped | | Olntake depth | Prated H.P. |
| © inches from | | | ft. | 6. WELLHEAD: Type we | It seat |
| Mesh size | Туре | | | Pressure tank | gal Loc |
| oinches from | 10 | | ft. | Sample tap | Measurement DOr1 |
| Mesh size | Туре | | | Well yent | Pressure relial value |
| o inches from | 10 | | ft | Gate valve | Check valve (when required) |
| @ Mesh size | Туре | | | Electrical disconnec | t switch on power supply |
| Gravel pack | | | Tonet. | 7. DISINFECTION: Well of | lisinfected ves po |
| 0 From | to | ft. | | Date | , Disinfectant used |
| @ From | 10 | ft | | Amount | Hours used |
| Grout | | | | 8. ABANDONMENT (when | re applicable) © veg no |
| oFrom 0 to 60. | 21 It. TypeAqua | -Gel Gold | lseal | Casing pulled ves | no not applicable |
| NE | fr Tune | | and the second | | inter applie able |

OVER

| Sample | <u>Time</u> | <u>Time</u> | Sample | Agency | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | <u>Geo-</u> |
|--------------|-------------|--------------------|---------------|--------------|-----------------|---------------|---------------|-------------|
| Datetim e | datum | <u>datum</u> | <u>Medium</u> | Collecting | Source | logic | logic | logic |
| | | <u>reliability</u> | Code | Sample, | | <u>Event</u> | Condition | <u>unit</u> |
| | | <u>code</u> | | <u>Code</u> | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | A | |
| 1993-07- | EDT | т | WG | USGS- WRD | 9 | 9 | A | |
| 1996-07- | EDT | т | WG | USGS- WRD | 9 | 9 | A | 124EOC N |
| 1998-04- | EDT | т | WG | USGS- WRD | 9 | 9 | A | 124EOC N |
| 2006-06- | EDT | к | WG | USGS- WRD | 9 | 9 | A | 124EOC N |

USGS 364227076074710 61B 16 SOW 091J

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 690.00 feet below land surface.

The depth of the hole is 690.00 feet below land surface.

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the EOCENE SERIES (124EOCN) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|-----------------|
| < | Less than. |
| E | Estimate d. |

| | Presence |
|---|-----------|
| | verified |
| | but not |
| | quantifie |
| М | d. |

| Value Qualifie r Code | Descript ion |
|-----------------------------|--|
| @ | Holding time exceeded |
| С | See laborator y comment |
| d | Diluted sample: method hi range exceeded |

| Sample | Project | Labor- | | | | | | |
|--------|---------------|-----------------|---------|---------|---------|----------------|---------|---------|
| type | Code | atory | | | | | | |
| | | sample | | | Baro- | Agency | Flow | Color, |
| | | comme nt | Temper | Temper- | metric | ana- | rate, | water, |
| | | | ature, | ature, | pres- | lyzing | instan- | fitrd, |
| | | | water, | air, | sure, | sample, | taneous | Pt-Co |
| | | | deg C | deg C | mm Hg | code | gal/min | units |
| | | | (00010) | (00020) | (00025) | <u>(00028)</u> | (00059) | (00080) |
| | 4451089 | NH4 & NH4+OR | | | | | | |
| 9 | 00 | G-RR | 17.0 | | | 80020 | | 7 |
| 9 | 4451089 10 | | 20.6 | 30.0 | 762 | 80020 | | |
| 9 | 4451106 00 | | 21.0 | 35.0 | 761 | 80020 | 3.2 | |
| 9 | 4451106 00 | | 21.0 | 21.0 | 765 | 80020 | | |
| 9 | 24829RC 20 | | 20.9 | 25.5 | 751 | 80020 | 4.7 | |

) national aquifer.

.

| Specif- | Hydro- | | | | | | ANC, | Carbon- |
|---------|---------|-----------|---------|---------|------------|---------|------------|-----------|
| ic | gen | | Dis- | pН, | pН, | | wat unf | ate, |
| conduc- | ion, | | solved | water, | water, | Carbon | fixed | wat flt |
| tance, | water, | Dis- | oxygen, | unfltrd | unfltrd | dioxide | end pt, | infl pt |
| wat unf | unfltrd | solved | percent | field, | lab, | water, | field, | titr., |
| uS/cm | calcd, | oxygen, | of sat- | std | std | unfltrd | mg/L as | field, |
| 25 degC | mg/L | mg/L | uration | units | units | mg/L | CaCO3 | mg/L |
| (00095) | (00191) | (00300) | (00301) | (00400) | (00403) | (00405) | (00410) | (00452) |
| | | | | | 1.27% - 2* | | Herrica de | |
| 8000 | 0.00004 | | | 7.4 | 7.6 | 55 | 716 | |
| 9700 | 0.00002 | 0.1 | 1 | 7.7 | 7.9 | 30 | | 0.0 |
| 9620 | 0.00003 | 0.2 | 2 | 7.5 | 7.7 | 44 | | |
| 9530 | 0.00003 | 0.0 | 0.0 | 7.5 | 7.6 | | | 0.0 |
| 8570 | 0.00003 | <u>M_</u> | 0.0 | 7.5 | 7.8 | | | <u>E2</u> |

| Bicar- | | | Ammoni a | Nitrate | | | | |
|---------|---------|-------------|-------------|-------------------|---------|---------|---------|---------------|
| bonate, | Organic | | + | + | Phos- | | | |
| wat flt | nitro- | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | |
| infl pt | gen, | water, | water, | water | water, | carbon, | ness, | Calcium |
| titr., | water, | fltrd, | unfltrd | fltrd, | unfltrd | water, | water, | water, |
| field, | unfltrd | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, |
| mg/L | mg/L | as N | as N | as N | as P | mg/L | CaCO3 | mg/L |
| (00453) | (00605) | (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00915) |
| | | | | | | | | |
| | 0.20 | 5.00 | 5.2 | <u>< 0.100</u> | 0.02 | 1.5 | 210 | 31.0 |
| 890 | | | | | | | 190 | 19.0 |
| 653 | | | | | | | 200 | 24.0 |
| 787 | | | | | | | 210 | 28.4 |
| E 865 @ | | | | | | | 170 | <u>21.6 d</u> |

| | | | Sodium | | | | | |
|---------------|---------------|---------|---------|---------------|---------------|--------------|---------|---------------|
| Magnes- | | | frac- | Potas- | Chlor- | | Fluor- | Silica, |
| ium, | Sodium, | Sodium | tion | sium, | ide, | Sulfate | ide, | water, |
| water, | water, | adsorp- | of | water, | water, | water, | water, | fltrd, |
| fltrd, | fltrd, | tion | cations | fltrd, | fltrd, | fltrd, | fltrd, | mg/L as |
| mg/L | mg/L | ratio | percent | mg/L | mg/L | mg/L | mg/L | SiO2 |
| (00925) | (00930) | (00931) | (00932) | (00935) | (00940) | (00945) | (00950) | (00955) |
| | | | | | | | | |
| 33.0 | 1900 | 57 | 95 | 4.80 | 2600 | 180 | 1.30 | 18.0 |
| 34.0 | 2200 | 70 | 96 | 11.0 | 2700 | 21.0 | 1.3 | 17.0 |
| 34.0 | 1900 | 58 | 94 | 55.0 | 2700 | 160 | 1.40 | 19.0 |
| 33.8 | 1980 | 60 | 94 | 56.0 | 2500 | 157 | 1.17 | 16.9 |
| <u>29.2 d</u> | <u>1840 d</u> | 61 | 94 | <u>49.8 d</u> | <u>2590 d</u> | <u>149 d</u> | 1.34 | <u>17.0 d</u> |

$$M_{3}^{2+}$$

$$TDS = N_{4}^{+} + KT^{+} + C_{a}^{2+} + C_{1}^{-} + SQ_{4}^{2-}$$

$$= 1840 + 49.8 + 21.6 + 29.2 + 2570 + 169$$

$$= 4679.6 m_{3}/C$$

| | | and the second se | and the second | | | | | | |
|---|--------------|---|--|---------|----------------|---------|----------------|---------|---------|
| | | | | Mangan | | | | Alka- | Depth |
| | | Iron, | | ese, | | | | linity, | to |
| | | water, | | water, | Mangan | | Alum- | wat flt | water |
| | Boron, | unfitrd | Iron, | unfltrd | ese, | Zinc, | inum, | fxd end | level |
| | water, | recover | water, | recover | water, | water, | water, | lab, | below |
| | fltrd, | -able, | fltrd, | -able, | fltrd, | fltrd, | fitrd, | mg/L as | LSD, |
| | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | CaCO3 | meters |
| | (01020) | (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (29801) | (30210) |
| | 6 | | | | | | | | |
| (| 6000) | 740 | 430 | 10 | <u>< 10</u> | 10 | <u>< 10</u> | | |
| | \checkmark | | 100 | | 10 | | | | |
| | | | 210 | | 8.0 | | | | |
| | | | 278 | | 43.7 | | | | 0.000 |
| | | | 307 d | | 5.6 d | | | 712 @c | 1.10 |

·**

500

who

| Alka- | Alka- | Residue | Residue | | | | | Pump |
|---------|---------|-------------|---------------|---------|-------------|---------------|----------|---------|
| linity, | linity, | on | water, | | | | Alti- | or flow |
| wat flt | wat flt | evap. | fltrd, | Residue | | | tude | period |
| fxd end | inf tit | at | sum of | water, | Ammoni a | Bromide | of | prior |
| field, | field, | 180deg C | consti- | fltrd, | water, | water, | land | to sam- |
| mg/L as | mg/L as | wat flt | tuents | tons/ | fltrd, | fltrd, | surface | pling, |
| CaCO3 | CaCO3 | mg/L | mg/L | acre-ft | mg/L | mg/L | feet | minutes |
| (39036) | (39086) | (70300) | (70301) | (70303) | (71846) | (71870) | (72000) | (72004) |
| | | | | | | | | |
| | | 5160 | 5210 | 7.02 | 6.44 | | | |
| | 729 | 5350 | 5450 | 7.28 | | 5.20 | | |
| | 535 | 5300 | 5220 | 7.21 | | 9.70 | 15.0 | |
| 640 | 643 | 5010 | 5180 | 6.81 | | 9.37 | <i>,</i> | |
| | 713 | 5350 | <u>E 5140</u> | 7.28 | | <u>9.71 d</u> | 15.0 | 308 |

Ι.

| | Depth to top | Depth to bot | Depth to | | | Specif. conduc- | ANC, wat unf | |
|---------|-----------------|-----------------|-------------|----------------|----------------|--------------------|-----------------|---------|
| Sam- | sample | sample | water | | | tance, | fixed | Sulfide |
| pling | intrval | intrval | level, | Sam- | | wat unf | end pt, | water, |
| condi- | feet | feet | feet | pling | Sampler | lab, | lab, | unfltrd |
| tion, | below | below | below | method, | type, | uS/cm | mg/L as | field, |
| code | LSD | LSD | LSD | code | code | 25 degC | CaCO3 | mg/L |
| (72006) | (72015) | (72016) | (72019) | <u>(82398)</u> | <u>(84164)</u> | (90095) | (90410) | (99119) |
| | 670.00 | 680.00 | | | | 9190 | 727 | |
| | | | | 8010 | 4040 | 9460 | 719 | |
| | 670.00 | 680.00 | | | 4040 | 9300 | 725 | - |
| 8.00 | 670.00 | 680.00 | 0.00 | | 4040 | 9190 | | |
| 8.00 | 670.00 | 680.00 | 3.60 | | 4040 | 9300 | | M |

Form GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

234-196 BWCM No.

(Certification of Completion/County Permit)

| C Box 11143 | 1.00. | | , | | |
|--|--|--|----------------|--|---|
| (11 North Hamilton St. | | | | | SWCB Permit |
| Richmond, Va. 23230 | | | | | County Permit |
| 2 10:1 | | | | | Certification of inspecting official: |
| County/CityChes | apeake | | | <u></u> | meet code/low requirements |
| | 1 | Col | unty/City | / Stamp | S |
| Virginia Plane Coordinates | an Obro | mation N | 1011 # | 01_ <i>v</i> | Date |
| N | Owner ODSE | IVALION W | err # | <u>91-K</u> | For Office Use |
| E | •Well Designation | or Number | Fentre | SS | |
| Latitude & Longitude | Address | | | | |
| <u>36° 42' 27" N</u> | Phone | | | | Tax Map T.D. No |
| 07 47 W | rnone | | | | Section |
| P Elevetice 15 ft | Oprilling Contracto | SWCB - | Creas | on | Block |
| | Addrees | | OI OUD | 011 | |
| el ubelego SD | Address | | | | |
| Bine Basis 5 | | | | | |
| | Fontmond | [Obgowing | tion W | 611 # 01_K] | |
| | WELL LOCATIO | UDSELVA | lfeet/mile | s direction of | |
| Cuttings No | and | feet/miles | Idire | action) of | |
| Water Analysis Ves | (If possible plea | ise include ma | p showing | location marked) | |
| @Aquitar Tart NO | | | 3 | | |
| Addition Lost NO | Date started | 9-15-88 | © Date | completed 9-19-88 | Iver un Mud Rotary |
| <u>3.5</u> inches from <u>3.5</u> inches from <u>4.5</u> inches from Material <u>PVC</u> Wt. per foot <u>2</u> inches from Material Black St | al to to to | 108' 80' 88' | | Comment on quality 3. WATER ZONES: Fro From To From To 4. USE DATA: Type of use. Drinkin Irrigation F Manufacturing | Hydrogen Sulfide Odor m To From To From To g Livestock Watering ood processing Household |
| Wt. per toot | or wall thickness | | in. | Recreation | Aesthetic Cooling or heating |
| © 2 inches from | 98' 10 | 108' | ft. | Injection , O | ther Observation |
| Material Black St | eel | | | Type of facility Dom | nestic Public water supply |
| Wt. per foot | or wall thickness | | in. | Public institution | Earm Industry |
| @Screen size and mesh for eac | h zone (where applic | able) | | Commercial | Other Observation |
| © | to | 98' | ft. | 5. PUMP DATA: Type | 9 Rated H P. |
| ^o Mesh size010 | Type PVC | | 1123 | ©Intake depth | Q Capacity at head |
| a inches from | to | | ft. | 6. WELLHEAD: Type w | ell seal |
| Mesh size | Туре | | | Pressure tank | gal, Loc. |
| oinches from | | | ft. | Sample tap | , Measurement port |
| o Mesh size | Туре | | | Well vent | Pressure relief valve |
| inches from | to | | ft | Gate valve | , Check valve (when required) |
| ∞ Mesh size | Туре | | | Electrical disconne | ct switch on power supply |
| ^o Gravel pack | *** ********************************** | | | 7. DISINFECTION: Well | disinfected yes no |
| @ From | to | ft. | | Date | , Disinfectant used |
| @ From | to | 11 | | Amount | - Hours used |
| 0 Grout | | | | 8. ABANDONMENT (who | are applicable) © yes |
| @From () 10 9 | Of ft., Type Ama | -Gel Gold | lseal | Casing nulled vas | |
| @From to | ft. Type | and the state of t | and the beauty | Plugeing policy yes | fo not applicable |
| v / 10/1 10 | it., type | | | Plugging grout From | mmaterial |

 $c = 5\pi c$

| Sample | <u>Time</u> | <u>Time</u> | Sample | Agency | <u>Analysis</u> | <u>Hydro-</u> | Hydro- | Sample |
|--------------|-------------|--------------------|---------------|--------------|-----------------|---------------|-----------|-------------|
| Datetim e | datum_ | <u>datum</u> | <u>Medium</u> | Collecting | Source | logic | logic | <u>type</u> |
| | | <u>reliability</u> | Code | Sample, | | Event_ | Condition | |
| | | <u>code</u> | | <u>Code</u> | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | А | 9 |

USGS 364227076074711 61B 17 SOW 091K

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 108.00 feet below land surface.

The depth of the hole is 108.00 feet below land surface.

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the UPPER CHESAPEAKE GROUP (121CSPKU) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|-----------------|
| | Less |
| < | than. |

| Project | | | | Specif- | Hydro- | | | |
|---------------|---------|----------------|---------|---------|---------|---------|---------|---------|
| Code | | | | ic | gen | pН, | pН, | |
| | | Agency | Color, | conduc- | ion, | water, | water, | Carbon |
| | Temper- | ana- | water, | tance, | water, | unfltrd | unfltrd | dioxide |
| | ature, | lyzing | fitrd, | wat unf | unfltrd | field, | lab, | water, |
| | water, | sample, | Pt-Co | uS/cm | calcd, | std | std | unfltrd |
| | deg C | code | units | 25 degC | mg/L | units | units | mg/L |
| | (00010) | <u>(00028)</u> | (00080) | (00095) | (00191) | (00400) | (00403) | (00405) |
| 4451089 00 | 15.5 | 80020 | 17 | 1500 | 0.00005 | 7.3 | 7.7 | 27 |

. . . .

.

) national aquifer.

| ANC, | | | Ammoni a | Nitrate | | | | |
|---------|---------|-------------|-------------|-------------------|---------|---------|---------|---------|
| wat unf | Organic | | + | + | Phos- | | | |
| fixed | nitro- | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | |
| end pt, | gen, | water, | water, | water | water, | carbon, | ness, | Calcium |
| field, | water, | fitrd, | unfltrd | fltrd, | unfltrd | water, | water, | water, |
| mg/L as | unfltrd | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, |
| CaCO3 | mg/L | as N | as N | as N | as P | mg/L | CaCO3 | mg/L |
| (00410) | (00605) | (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00915) |
| 276 | 0.30 | 1.10 | 1.4 | <u>< 0.100</u> | 0.16 | 4.9 (| 240 | 54.0 |
| | | | | | | | haved | |

$$TDS = C_{a}^{2+} + M_{5}^{2+} + M_{a}^{+} + K^{+} + C_{1}^{-} + S_{4}^{2-}$$

$$TDS = S_{4}^{2+} + 26 + 240 + 21 + 340 + 20$$

$$TDS = 70 I_{4}^{2-}$$

| | 1 | | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | | | Sodium | | | | | |
| Magnes | | | frac- | Potas- | Chlor- | | Fluor- | Silica, |
| ium, | Sodium, | Sodium | tion | sium, | ide, | Sulfate | ide, | water, |
| water, | water, | adsorp- | of | water, | water, | water, | water, | fltrd, |
| fltrd, | fltrd, | tion | cations | fitrd, | fitrd, | fitrd, | fltrd, | mg/L as |
| mg/L | mg/L | ratio | percent | mg/L | mg/L | mg/L | mg/L | SiO2 |
| (00925) | (00930) | (00931) | (00932) | (00935) | (00940) | (00945) | (00950) | (00955) |
| 26.0 | 240 | 6.7 | 66 | 21.0 | 340 | 20.0 | 0.20 | 36.0 |

2°

| | | | Mangan | | | | Depth | Residue |
|---------|---------|---------|---------|----------------------|---------|---------|---------|-------------|
| | Iron, | | ese, | | | | to | on |
| | water, | | water, | Mangan- | | Alum- | water | evap. |
| Boron, | unfitrd | Iron, | unfitrd | ese, | Zinc, | inum, | level | at |
| water, | recover | water, | recover | water, | water, | water, | below | 180deg C |
| fltrd, | -able, | fltrd, | -able, | fltrd, | fltrd, | fltrd, | LSD, | wat flt |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | meters | mg/L |
| (01020) | (01045) | (01046) | (01055) | <mark>(01056)</mark> | (01090) | (01106) | (30210) | (70300) |
| 320 | 1000 | 470 | 20 | 12.0 | 6 | < 10 | 1.80 | 897 |

500 3° WHU

| Residue | | | Depth | Depth | Depth | Specif. | ANC, |
|---------|---------|-------------|---------|---------|---------|---------|---------|
| water, | | | to top | to bot | to | conduc- | wat unf |
| fltrd, | Residue | | sample | sample | water | tance, | fixed |
| sum of | water, | Ammoni a | intrval | intrval | level, | wat unf | end pt, |
| consti- | fltrd, | water, | feet | feet | feet | lab, | lab, |
| tuents | tons/ | fltrd, | below | below | below | uS/cm | mg/L as |
| mg/L | acre-ft | mg/L | LSD | LSD | LSD | 25 degC | CaCO3 |
| (70301) | (70303) | (71846) | (72015) | (72016) | (72019) | (90095) | (90410) |
| 905 | 1.22 | 1.42 | 88.00 | 98.00 | 5.92 | 1620 | 282 |

1620 jumho /cm

$$N \cong \frac{1000 \text{K}}{\Lambda_0} = \frac{1000 (1620 \times 10^{-6})}{1 \times 6.4} = 1.28 \times 10^{-2} \text{ Cell}$$

200 mg

Foun GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

• BWCM No. 234-197

ft

11

| (Certification o | Completion, | County | Permit) |
|------------------|-------------|--------|---------|
|------------------|-------------|--------|---------|

State Water Control Board P. O. Box 11143 SWCB Permit 2111 North Hamilton St. Richmond, Va. 23230 County Permit Certification of inspecting official: This well does _____ does not ____ County/City Chesapeake meet code/low requirements. County/City Stamp Virginia Plane Coordinates Date Owner Observation Well # 91-L N For Office Use Well Designation or Number Fentress E Address Latitude & Longitude 27" 36° 42' Tax Map I.D. No. N Subdivision Phone 47" W Topo. Map No._ Section 2B15 Orilling Contractor SWCB - Creason ft. Block © Elevation TY Address © Formation Lot © Lithology SD Class Well 1 _____, IIA River Basin 11B ______, 111A _____, 111B _____ 5 Phone @Province Fentress [Observation Well # 91-L] IIIC _____ IIID _____ IIIE_____ 1 WELL LOCATION: (feet/miles ©Type Logs direction) of E and feet/miles (direction) of © Cuttings NO (If possible please include map showing location marked) Water Analysis Yes Aquifer Test NO Type rig Mud Rotary Date started 9-20-88 • Date completed 9-20-88 I. WELL DATA: New X Reworked Deepened 2. WATER DATA @ Water temperature 60.8 © Total depth 67' Static water level (unpumped level-measured)
 8.75 TOC Stabilized measured pumping water level 9.33 TOC It
 Stabilized yield 10 gpm after 0.5 hour [©]Depth to bedrock ft. [©]Hote size (Also include reamed zones) ft. 9 7.25 inches from 0 to 40¹ Natural Flow: Yes No X , flow rate. • 3.5 inches from 401 to 671 ft. Comment on quality Hydrogen Sulfide Odor 3. WATER ZONES: From To o inches from to ft. From _____ To ____ From _____ То ©Casing size (I.D.) and material © 4.5 inches from 0 to 40' ft From To From To Material PVC 4. USE DATA: Wt_per foot _____ or wall thickness _____ Type of use: Drinking _____, Livestock Watering [©]______ inches from _____37!____ to _____ 57' ft Irrigation _____ Food processing _____, Household _____ Material PVC Manufacturing _____, Fire safety _____. Cleaning ______. Recreation _____. Aesthetic ____. Cooling or heating ______. Wt. per foot _____ or wall thickness _____ in o ______ inches from ______ to ______ ft. Injection ____, Other Observation Type of facility Domestic _____, Public water supply_____ Material Wt. per foot _____or wall thickness ____ Public institution _____ Farm ____ Industry oScreen size and mesh for each zone (where applicable) Commercial ____, Other Observation © 2 inches from 571 to 671 ft. 5. PUMP DATA: Type 9 Rated H.P. Mesh size _____Type _____ 6. WELLHEAD: Type well seal a ______ inches from ______ fo _____ fi © Mesh size _____ Type _____ Pressure tank _____ gal., Loc. _____ o______to____to____ft Sample tap______, Measurement port o Mesh size _____ Type _____ Well vent ______, Pressure reliuf valve ______ e_____inches from ______to ____ft Gate valve _____, Check valve (when required) Mesh size _____Type ____Type ____Type _____Type _____Type _____Type ____Type _____Type ____Type ____Type ____Type ___Type ____Type ___Type __ Electrical disconnect switch on power supply 7. DISINFECTION: Well disinfected ______ yes _____ no ^o Gravel pack • From _____ to _____ ft. Date_____, Disinfectant used © From to ft Amount ______, Hours used _____ 8. ABANDONMENT (where applicable) 9 yes no Grout "From 0 10 401 ft., Type Benseal/EZ Mud Casing pulled yes _____ no ____ not applicable _____ © From to ft., Type Plugging grout From _____to ____material

| Sample | <u>Time</u> | <u>Time</u> | Sample | <u>Agency</u> | <u>Analysis</u> | <u>Hydro-</u> | <u>Hydro-</u> | Sample |
|--------------|-------------|--------------------|---------------|----------------|-----------------|---------------|---------------|-------------|
| Datetim e | datum_ | <u>datum</u> | <u>Medium</u> | Collecting | <u>Source</u> | logic | <u>logic</u> | <u>type</u> |
| | | <u>reliability</u> | Code | <u>Sample,</u> | | Event | Condition | |
| | 5.51 | <u>code</u> | | Code | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | A | 9 |

USGS 364227076074712 61B 18 SOW 091L

Chesapeake City, Virginia Hydrologic Unit Code 03010205 Latitude 36°42'27", Longitude 76°07'47" NAD27 Land-surface elevation 15.00 feet above sea level NGVD29 The depth of the well is 67.00 feet below land surface. The depth of the hole is 67.00 feet below land surface. This well is completed in the QUATERNARY SYSTEM (110QRNR) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|-----------------|
| | Less |
| < | than. |

| | | | Specif- | Hydro- | | | |
|---------------|--|---|--|--|---|---|--|
| | | | ic | gen | pН, | pH, | |
| | Agency | Color, | conduc- | ion, | water, | water, | Carbon |
| Temper- | ana- | water, | tance, | water, | unfltrd | unfltrd | dioxide |
| ature, | lyzing | fltrd, | wat unf | unfltrd | field, | lab, | water, |
| water, | sample, | Pt-Co | uS/cm | calcd, | std | std | unfltrd |
| deg C | code | units | 25 degC | mg/L | units | units | mg/L |
| -10 | <u>-28</u> | -80 | -95 | -191 | -400 | -403 | -405 |
| 16.0 | 80020 | 05 | 200 | 0.00022 | C F | 6.0 | 71 |
| - 1 | Γemper- ature, water, deg C -10 6.0 | Agencyremper-ana-ature,lyzingwater,sample,deg Ccode-10-286.080020 | AgencyColor,remper-ana-water,ature,lyzingfltrd,water,sample,Pt-Codeg Ccodeunits-10-28-806.08002095 | icAgencyColor,conduc-AgencyColor,conduc-remper-ana-water,tance,ature,lyzingfltrd,wat unfwater,sample,Pt-CouS/cmdeg Ccodeunits25 degC-10-28-80-95 | icicgenAgencyColor,conduc-ion,remper-ana-water,tance,water,ature,lyzingfltrd,wat unfunfltrdwater,sample,Pt-CouS/cmcalcd,deg Ccodeunits25 degCmg/L-10-28-80-95-191 | icgenpH,AgencyColor,conduc-ion,water,remper-ana-water,tance,water,unfltrdature,lyzingfltrd,wat unfunfltrdfield,water,sample,Pt-CouS/cmcalcd,stddeg Ccodeunits25 degCmg/Lunits-10-28-80-95-191-400 | icgenpH,AgencyColor,conduc-ion,water,water,Imageana-water,tance,water,unfltrdunfltrdature,lyzingfltrd,wat unfunfltrdfield,lab,water,sample,Pt-CouS/cmcalcd,stdstddeg Ccodeunits25 degCmg/Lunitsunits-10-28-80-95-191-400-403 |

ł

| ANC, | | Ammoni a | Nitrate | | | | | |
|---------|-------------|-------------|---------|---------|---------|---------|---------|---------|
| wat unf | | + | + | Phos- | | | | |
| fixed | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | | Magnes- |
| end pt, | water, | water, | water | water, | carbon, | ness, | Calcium | ium, |
| field, | fltrd, | unfltrd | fltrd, | unfltrd | water, | water, | water, | water, |
| mg/L as | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, | fltrd, |
| CaCO3 | as N | as N | as N | as P | mg/L | CaCO3 | mg/L | mg/L |
| -410 | -608 | -625 | -631 | -665 | -680 | -900 | -915 | -925 |
| 116 | 0.320 | 0.20 | < 0.100 | 0.68 | 1.8 | 87 | 27.0 | 4.80 |

- 'å

| | | Sodium | | | | | | |
|---------|---------|---------|--------|--------|---------|--------|---------|--------|
| | | frac- | Potas- | Chlor- | | Fluor- | Silica, | |
| Sodium, | Sodium | tion | sium, | ide, | Sulfate | ide, | water, | Boron, |
| water, | adsorp- | of | water, | water, | water, | water, | fltrd, | water, |
| fitrd, | tion | cations | fltrd, | fltrd, | fltrd, | fltrd, | mg/L as | fltrd, |
| mg/L | ratio | percent | mg/L | mg/L | mg/L | mg/L | SiO2 | ug/L |
| -930 | -931 | -932 | -935 | -940 | -945 | -950 | -955 | -1020 |
| 21.0 | 1.0 | 33 | 3.30 | 18.0 | 11.0 | 0.20 | 44.0 | 50 |

| | | Mangan- | | | | Depth | Residue | Residue |
|---------|---------|---------|---------|---------|---------|---------|-------------|---------|
| Iron, | | ese, | | | | to | on | water, |
| water, | | water, | Mangan | | Alum- | water | evap. | fltrd, |
| unfltrd | Iron, | unfitrd | ese, | Zinc, | inum, | level | at | sum of |
| recover | water, | recover | water, | water, | water, | below | 180deg C | consti- |
| -able, | fltrd, | -able, | fltrd, | fltrd, | fltrd, | LSD, | wat flt | tuents |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | meters | mg/L | mg/L |
| (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (30210) | (70300) | (70301) |
| 5000 | 5940 | 140 | 152 | 92 | 20 | 2.04 | 191 | 206 |

| | | Depth | Depth | Depth | Specif. | ANC, |
|---------|-------------|---------|---------|---------|---------|---------|
| | | to top | to bot | to | conduc- | wat unf |
| Residue | | sample | sample | water | tance, | fixed |
| water, | Ammoni a | intrval | intrval | level, | wat unf | end pt, |
| fltrd, | water, | feet | feet | feet | lab, | lab, |
| tons/ | fltrd, | below | below | below | uS/cm | mg/L as |
| acre-ft | mg/L | LSD | LSD | LSD | 25 degC | CaCO3 |
| (70303) | (71846) | (72015) | (72016) | (72019) | (90095) | (90410) |
| 0.26 | 0.41 | 57.00 | 67.00 | 6.70 | 278 | 112 |
Fo..n GW-2 1978-10,000

COMMONWEALTH OF VIRGINIA

WATER WELL COMPLETION REPORT

234-198 BWCM No

.

(Certification of Completion/County Permit)

| State Water Control Board | (Certification of | Completion/County Permit, | |
|---|---|---------------------------|---|
| 0. Box 11143 11 North Hamilton St | | | SWCB Permit |
| Hichmond, Va. 23230 | | | County Permit |
| County/City Chega | neake | | Certification of inspecting official: This well does does not |
| county/only criesa | Coun | ty/City Stamp | meet code/low requirements. |
| Virginia Plane Coordinates | 000 | (y, only orange | S |
| N | • Owner Observation Well | 1 # 91-M | |
| E | •Well Designation or Number Fe | entress | For Office Use |
| Latitude & Longitude | Address | | |
| <u>36° 42' 27"</u> N | | | Tax Map I.D. No. |
| <u>76° 07' 47''</u> W | Phone | | Subdivision |
| PElevation 15 ft | Orillion Contractor SWCB - 0 | Treason | Block |
| PEormation OPC | Address | | Lot |
| ©Lithology SD | | | Class Well 1 |
| PRiver Basin 5 | Phone | | IIB IIIA IIIB |
| ©Province 1 | Fentress [Observation | on Well # 91 M] | IIIC IIID IIIE |
| OType Logs E | WELL LOCATION: (fe | et/milesdirection) of | |
| Cuttings NO | andfeet/miles | (direction) of | |
| Water Analysis Yes | (If possible please include map s | howing location marked) | |
| Aquifer Test NO | 0.21.02 | 0.0 | · Mud Potary |
| | Date started 9-21-00 | Date completed 9-21-00 | Type ng Mud Rocary |
| *ole size (Also include ream • inches from • inches from • inches trom • Casing size (I.D.) and materia • A_5 inches from Material Wt. per foot • inches from Material WL. per toot | ed zones) to to al to to to to | | gpm after 1 hou No Xflow rategpr Hydrogen Sulfide Odor nTo |
| © inches from | | ft Injection Ot | Aesthetic Cooling or heating |
| Material | ····· | © Type of facility Dom | estic Public water supply |
| Wt. per foot | or wall thickness | in Public institution | Farm Industry |
| o Screen size and mesh for each | h zone (where applicable) | Commercial | Other Observation |
| • inches from | 10to20! | ft. 5. PUMP DATA: Type | 9 Rated H.P. |
| Mesh size 010 | _ Type Galv. Wire Wrapped | I @Intake depth | © Capacityathead |
| inches from | to | ft. 6. WELLHEAD: Type we | 11 seal |
| o Mesh size | Гуре | Pressure tank | gal_Loc |
| o inches from | to | ft. Sample tap | , Measurement port |
| o Wesh size | l vpe | Well vent, | Pressure reliativalve |
| inches from | 10 | ft Gate valve | Check valve (when required) |
| Wiesh size | Туре | Electrical disconnec | t switch on power supply |
| Gravel pack | 10 201 | 7. DISINFECTION: Well | Jisinfected yes no |
| © From() | 10 <u>20'</u> ft. | Date | , Disinfectant used |
| • FIQIN | 10 ft | Amount | , Hours used |
| OGrout | OI (L TYPE Deseration) | a ABANDONMENT (whe | re applicable) Ø yesno |
|)From 10 | t Type | Lasing pulled yes | no not applicable |
| 10 | IL, IVDG | Plugging grout From | 10 material |

1.00

Fentress

RECORD NUMBER: 99403567 STATION NUMBER: 364227076074713 COLLECTED: 08-20-1994 AT: 1 STATION NAME: 61B 19 Sow 9/-M MEDIUM: 6 STATUS: 9 SOURCE: 9 HYD. CONDITION: 9 SAMPLE TYPE: 9 HYD.

| CC | DDE | PARAMETER NAME | UNITS | VALUE | R | Q | М | Ρ |
|----------|-------|------------------------|------------------|-------|---|---|---|---|
| | 00010 | WATER TEMPERATURE | (DEGREES) | 19.5 | | Ι | | 3 |
| | 00020 | AIR TEMPERATURE | DEGREES | 28.0 | | Ι | | 3 |
| | 00025 | AIR PRESSURE | (MM OF HG) | 763 | | Ι | | 3 |
| | 00027 | COLLECTING AGENCY | (CODE NUMBER) | 1028 | | Т | | 5 |
| | 00028 | ANALYZING AGENCY | (CODE NUMBER) | 80020 | | Н | | 5 |
| | 00059 | FLOW RATE INS. (G/M) | (GALLONS/MINUTE) | 1.5 | | I | | 3 |
| | 00095 | SPECIFIC CONDUCTANCE | US/CM @ 25C | 326 | | Ι | | 3 |
| | 00300 | OXYGEN DISSOLVED | (MG/L) | 0.5 | | Ι | | 3 |
| | 00301 | OXYGEN DIS. PERCENT | % OF SATURATION | 5 | | I | | 3 |
| | 00400 | PH, WH, FIELD | (STANDARD UNITS) | 6.0 | | Ι | | 3 |
| | 00403 | PH, WH, LABORATORY | (STANDARD UNITS) | 6.7 | | Н | A | 2 |
| | 00419 | ALKALINITY, WH, IT, F | (MG/L AS CACO3) | 95 | | Ι | | 3 |
| | 00447 | CARBONATE, WH, IT, F | (MG/L AS CO3) | 0 | | I | | 3 |
| | 00450 | BICARBONATE, WH, IT, F | (MG/L AS HCO3) | 116 | | Ι | | 3 |
| | 00608 | NITROGEN AMMONIA D. | (MG/L AS N) | 0.130 | | Н | в | 3 |
| | 00613 | NITROGEN, NITRITE D. | MG/L AS N | 0.010 | 1 | Н | в | 3 |
| | 00623 | NITRO AMN & ORG DIS | (MG/L AS N) | 0.20 | 1 | Н | С | 2 |
| | 00631 | NO2 + NO3 DISSOLVED | (MG/L AS N) | 0.061 | | Н | в | 3 |
| | 00666 | PHOSPHORUS DISS. | (MG/L AS P) | 0.010 | | Н | C | 3 |
| | 00671 | PHOSPHORUS ORTHO D. | (MG/L AS P) | 0.010 | 1 | Н | В | 3 |
| | 00681 | CARBON ORGANIC DIS. | (MG/L AS C) | 3.5 | | Н | А | 2 |
| COMPUTED | 00900 | HARDNESS TOTAL | (MG/L AS CAO3) | 43 | | | | |
| | 00915 | CALCIUM DISSOLVED | (MG/L AS CA) | 7.0 | | Н | D | 2 |
| | 00925 | MAGNESIUM DISSOLVED | (MG/L AS MG) | 6.2 | | Н | С | 2 |
| | 00930 | SODIUM DISSOLVED | (MG/L AS NA) | 27 | | Н | С | 2 |
| COMPUTED | 00931 | SODIUM ADSORPTION R. | (RATIO) | 2 | | | | |
| COMPUTED | 00932 | SODIUM, PERCENT | PERCENT | 57 | | | | |
| | 00935 | POTASSIUM DISSOLVED | (MG/L AS K) | 1.4 | | Н | В | 2 |
| | 00940 | CHLORIDE DISSOLVED | (MG/L AS CL) | 24 | | Н | J | 2 |
| | 00945 | SULFATE DISSOLVED | (MG/L AS SO4) | 33 | | Н | G | 2 |
| | 00950 | FLUORIDE DISSOLVED | (MG/L AS F) | 0.10 | 1 | Н | В | 2 |
| | 00955 | SILICA DISSOLVED | (MG/L AS SIO2) | 18 | | Н | D | 2 |
| | 01000 | ARSENIC DISSOLVED | (UG/L AS AS) | 8 | | Н | В | 1 |
| | 01005 | BARIUM DISSOLVED | (UG/L AS BA) | 71 | | Н | G | 2 |
| | 01010 | BERYLLIUM DISSOLVED | (UG/L AS BE) | 1 | 1 | Н | G | 1 |
| | 01025 | CADMIUM DISSOLVED | (UG/L AS CD) | 1.0 | 1 | Η | G | 2 |
| | 01030 | CHROMIUM DISSOLVED | (UG/L AS CR) | 6 | | Н | G | 1 |
| | 01035 | COBALT DISSOLVED | (UG/L AS CO) | 2 | | Н | G | 1 |
| | 01040 | COPPER DISSOLVED | (UG/L AS CU) | 1 | 1 | Н | G | 1 |
| | 01046 | IRON DISSOLVED | (UG/L AS FE) | 30000 | | Н | D | 2 |

1

RECORD NUMBER: 99403567 -- CONTINUED

| CODE | PARAMETER NAME | UNITS | VALUE | R | Q | М | Ρ |
|-------|----------------------|--------------|-------|---|---|---|---|
| 01049 | LEAD DISSOLVED | (UG/L AS PB) | 1 | 1 | Н | G | 1 |
| 01056 | MANGANESE DISSOLVED | (UG/L AS MN) | 440 | | Н | G | 2 |
| 01060 | MOLYBDENUM DISSOLVED | (UG/L AS MO) | 1 | 1 | Н | G | 1 |
| 01065 | NICKEL DISSOLVED | (UG/L AS NI) | 1 | 1 | Н | G | 1 |
| 01075 | SILVER DISSOLVED | (UG/L AS AG) | 1.0 | 1 | Н | G | 2 |
| 01090 | ZINC DISSOLVED | (UG/L AS ZN) | 22 | | Н | G | 2 |
| 01095 | ANTIMONY DISSOLVED | (UG/L AS SB) | 1 | 1 | Н | G | 1 |

L

| 01106 | ALUMINUM DISSOLVED | (UG/L AS AL) | 10 | H G 1 |
|-------|-----------------------|--------------|------|---------|
| 01145 | SELENIUM DISSOLVED | (UG/L AS SE) | 1 | 1 H A 1 |
| 04024 | PROPACHLOR DISS REC | (UG/L) | 0.01 | 1 H D 2 |
| 04028 | BUTYLATE DISS REC | (UG/L) | 0 | 1 H D 3 |
| 04035 | SIMAZINE DISS REC | (UG/L) | 0 | 1 H D 3 |
| 04037 | PROMETON DISS REC | (UG/L) | 0 | 1 H D 3 |
| 04040 | DEETHYL ATRAZINE D | (UG/L) | 0 | 1 H D 3 |
| 04041 | CYANAZINE DISS REC | (UG/L) | 0.01 | 1 H D 2 |
| 04095 | FONOFOX DISS REC | (UG/L) | 0 | 1 H D 3 |
| 22703 | URANIUM, NATURAL, DIS | UG/L AS U | 0.40 | 1 H C 2 |
| 30217 | DIBROMOMETHANE, W.W.R | UG/L | 0.2 | 1 H C 1 |
| 32101 | DICHLOROBROMOMETHANE | UG/L | 0.2 | 1 H C 1 |
| 32102 | CARBONTETRACHLORIDE | UG/L | 0.2 | 1 H C 1 |
| 32103 | 1,2-DICHLOROETHANE | UG/L | 0.2 | 1 H C 1 |
| 32104 | BROMOFORM TOTAL | UG/L | 0.2 | 1 H C 1 |
| 32105 | CHLORODIBROMOMETHANE | UG/L | 0.2 | 1 H C 1 |
| 32106 | CHLOROFORM TOTAL | UG/L | 0.2 | 1 H C 1 |
| 34010 | TOLUENE, TOTAL | UG/L | 0.2 | 1 H C 1 |
| 34030 | BENZENE, TOTAL | UG/L | 0.2 | 1 H C 1 |
| 34253 | ALPHA BHC | UG/L | 0 | 1 H D 3 |
| 34301 | CHLOROBENZENE | (UG/L) | 0.20 | 1 H C 2 |
| 34311 | CHLOROETHANE | UG/L | 0.2 | 1 H C 1 |
| 34371 | ETHYLBENZENE TOTAL | (UG/L) | 0.2 | 1 H C 1 |
| 34413 | METHYLBROMIDE TOTAL | (UG/L) | 0.2 | 1 H C 1 |
| 34418 | METHYLCHLORIDE, TOT. | (UG/L) | 0.4 | H C 1 |
| 34423 | METHYLENECHLORIDE | (UG/L) | 0.2 | 1 H C 1 |
| 34475 | TETRACHLOROETHYLENE | (UG/L) | 3.2 | НС2 |
| 34488 | TRICH.FLUOR.METHANE | (UG/L) | 0.2 | 1 H C 1 |
| 34496 | DICHLOROETHANE 1,1 T | (UG/L) | 0.2 | 1 H C 1 |
| 34501 | DICHLOROETHYLENE T. | (UG/L) | 0.2 | 1 H C 1 |
| 34506 | TRICHLOROETHANE T. | (UG/L) | 0.2 | 1 H C 1 |
| 34511 | TRICHLOROETHANE T. | (UG/L) | 0.2 | 1 H C 1 |
| 34516 | 1122TETRACHLORO ETH | (UG/L) | 0.2 | 1 H C 1 |
| 34536 | O-CHLORO-BENZENE U | (UG/L) | 0.20 | 1 H D 2 |

RECORD NUMBER: 99403567 -- CONTINUED

1

| CO | DE . | PARAMETER NAME | UNITS | VALUE | R | Q | М | Р |
|----------|-------|-----------------------|--------|-------|---|---|---|---|
| | 34541 | DICHLOROPROPANE TOT. | (UG/L) | 0.2 | 1 | Н | С | 1 |
| | 34546 | TRANSDICH.ETHENE T. | (UG/L) | 0.2 | 1 | Н | С | 1 |
| | 34551 | 124TRICHLORO-BENZEN | (UG/L) | 0.20 | 1 | Н | D | 2 |
| | 34566 | 13DICHLORO-BENZENE | (UG/L) | 0.20 | 1 | Н | D | 2 |
| | 34571 | 14DICHLORO-BENZENE | (UG/L) | 0.20 | 1 | Н | D | 2 |
| | 34653 | P, P' DDE DISSOLVED | (UG/L) | 0.01 | 1 | Н | D | 2 |
| | 34668 | DICHL.DIFL.METHANE T | (UG/L) | 0.2 | 1 | Н | С | 1 |
| | 34696 | NAPHTHALENE TOTAL | (UG/L) | 0.2 | 1 | Н | D | 1 |
| | 34699 | TR1,3-DICHL.PROPENE | UG/L | 0.2 | 1 | Н | С | 1 |
| | 34704 | CIS1,3-DICHL.PROPENE | UG/L | 0.2 | 1 | Н | С | 1 |
| | 38933 | CHLORPYRIFOS, DISS | UG/L | 0 | 1 | Н | D | 3 |
| | 39175 | VINYLCHLORIDE | UG/L | 0.2 | 1 | Н | С | 1 |
| | 39180 | TRICHLOROETHYLENE | UG/L | 0.2 | 1 | Н | С | 1 |
| | 39341 | LINDANE DISSOLVED | UG/L | 0.01 | 1 | Н | D | 2 |
| | 39381 | DIELDRIN DISSOLVED | UG/L | 0 | 1 | Н | D | 3 |
| | 39415 | METOLACHLOR, WAT.DIS. | UG/L | 0 | 1 | Н | D | 3 |
| | 39532 | MALATHION DISSOLVED | UG/L | 0.01 | 1 | Н | D | 2 |
| | 39542 | PARATHION DISSOLVED | UG/L | 0.02 | 1 | Н | D | 2 |
| | 39572 | DIAZINON DISSOLVED | UG/L | 0 | 1 | Η | D | 3 |
| | 39632 | ATRAZINE, DISS, REC | UG/L | 0.02 | 1 | Н | D | 2 |
| | 39702 | HEXACHLOROBUTADIENE | UG/L | 0.2 | 1 | Н | D | 1 |
| | 46342 | ALACHLOR, DISS, REC. | UG/L | 0 | 1 | Η | D | 3 |
| | 70300 | RESIDUE DIS 180C | MG/L | 163 | | Н | А | 3 |
| COMPUTED | 70301 | DISSOLVED SOLIDS SUM | MG/L | 205 | | | | |

· ,*

: • •

• ,•

| 71870 | BROMIDE DISSOLVED | MG/L AS BR | 0.30 | H E 2 |
|-------|----------------------|--------------|------|---------|
| 71999 | SAMPLE PURPOSE | PURPOSE CODE | 15.0 | I 3 |
| 72000 | ELEV.LSD(FT.AB.NGVD) | FT (NGVD) | 15.0 | I 3 |
| 72004 | PUMP PERIOD (MIN)) | MIN | 24 | I 3 |
| 72006 | SAMPLING CONDITION | CODE NUMBER | 8.00 | I 3 |
| 72015 | DEPTH TOP OF SAM.FT. | FT | 10 | I 3 |
| 72016 | DPTH BOT. OF SAM.FT. | FT | 20 | I 3 |
| 72019 | DEPTH BELOW LAND S. | FT | 5.56 | I 3 |
| 75990 | URANIUM NAT PE DISS | UG/L | 0 | нс З |
| 76000 | RADIUM-228 PE DISS | PCI/L | 0.4 | НС1 |
| 77093 | CIS1,2DICHL.ETHENE,T | UG/L | 0.2 | 1 H C 1 |
| 77128 | STYRENE, TOTAL | UG/L | 0.2 | 1 H C 1 |
| 77168 | 1,1-DICHLOROPROPENE | UG/L | 0.2 | 1 H C 1 |
| 77170 | 2,2-DICHLOROPROPANE | UG/L | 0.2 | 1 H C 1 |
| 77173 | 1,3DICHLPROPANE W W | UG/L | 0.2 | 1 H C 1 |
| 77222 | PSEUDOCUMENE UNF RE | (UG/L) | 0.20 | 1 H C 2 |
| 77223 | ISOPROPYL-BENZENE W | (UG/L) | 0.20 | 1 H C 2 |

RECORD NUMBER: 99403567 -- CONTINUED

1

| CODE | PARAMETER NAME | UNITS | VALUE | RQMP |
|-------|----------------------|--------|-------|---------|
| 77224 | N-PROPYL-BENZENE U | (UG/L) | 0.20 | 1 н с 2 |
| 77226 | MESITYLENE UNF REC | (UG/L) | 0.20 | 1 H C 2 |
| 77275 | O-CHLOROTOLUENE T. | UG/L | 0.2 | 1 H C 1 |
| 77277 | P-CHLORO-TOLUENE U | (UG/L) | 0.20 | 1 H C 2 |
| 77297 | METHANE BROMOCHLORO | (UG/L) | 0.20 | 1 H C 2 |
| 77342 | N-BUTYL-BENZENE U R | (UG/L) | 0.20 | 1 H C 2 |
| 77350 | SEC-BUTYL-BENZENE U | (UG/L) | 0.20 | 1 H C 2 |
| 77353 | TERT-BUTYL-BENZENE | (UG/L) | 0.20 | 1 H C 2 |
| 77356 | P-ISOPROPYLTOLUENE | (UG/L) | 0.20 | 1 H C 2 |
| 77443 | 123TRICHLPROPANE, TO | UG/L | 0.2 | 1 H C 1 |
| 77562 | 1112TETRACHLORO-ETH | (UG/L) | 0.2 | 1 H C 1 |
| 77613 | 1,2,3-TRICHLORO BEN | (UG/L) | 0.20 | 1 H C 2 |
| 77651 | 1,2DIBROMOETHANE,TOT | UG/L | 0.2 | 1 H E 1 |
| 77652 | FREON 113 UNF REC | (UG/L) | 0.2 | 1 H C 1 |
| 78032 | TERTBUTYL METH ETHE | (UG/L) | 0.2 | 1 H C 1 |
| 81366 | RA228 DISS | PCI/L | 1.0 | 1 H C 2 |
| 81551 | XYLENE UNF REC | (UG/L) | 0.20 | 1 H C 2 |
| 81555 | BROMOBENZENE WAT.WH. | UG/L | 0.2 | 1 H C 1 |
| 82625 | DIBROMOCHLOROPROPAN | UG/L | 1.0 | 1 H C 2 |
| 82630 | METRIBUZIN, WAT.DIS. | UG/L | 0.01 | 1 H D 2 |
| 82660 | 26DIETHYLANILINE FL | (UG/L) | 0 | 1 H D 3 |
| 82661 | TRIFLURALIN FIL 0.7 | (UG/L) | 0.01 | 1 H D 2 |
| 82662 | DIMETHOATE FIL 0.7 | (UG/L) | 0.02 | 1 H D 2 |
| 82663 | ETHALFLURALIN FIL . | (UG/L) | 0.01 | 1 H D 2 |
| 82664 | PHORATE FIL 0.7 REC | (UG/L) | 0.01 | 1 H D 2 |
| 82665 | TERBACIL FIL 0.7 RE | (UG/L) | 0.03 | 1 H D 2 |
| 82666 | LINURON FIL 0.7 REC | (UG/L) | 0.04 | 1 H D 2 |
| 82667 | METHYL PARATHION F. | (UG/L) | 0.03 | 1 H D 2 |
| 82668 | EPTC FIL 0.7 REC | (UG/L) | 0 | 1 H D 3 |
| 82669 | PEBULATE FIL 0.7 RE | (UG/L) | 0 | 1 H D 3 |
| 82670 | TEBUTHIURON FIL .7 | (UG/L) | 0.01 | 1 H D 2 |
| 82671 | MOLINATE FIL 0.7 RE | (UG/L) | 0 | 1 H D 3 |
| 82672 | ETHOPROP FIL 0.7 RE | (UG/L) | 0.01 | 1 H D 2 |
| 82673 | BENFLURALIN FIL .7 | (UG/L) | 0.01 | 1 H D 2 |
| 82674 | CARBOFURAN FIL .7 R | (UG/L) | 0.01 | 1 H D 2 |
| 82675 | TERBUFOS FIL 0.7 RE | (UG/L) | 0.01 | 1 H D 2 |
| 82676 | PRONAMIDE FIL .7 RE | (UG/L) | 0 | 1 H D 3 |
| 82677 | DISULFOTON FIL .7 R | (UG/L) | 0.06 | 1 H D 2 |
| 82678 | TRIALLATE FIL .7 RE | (UG/L) | 0 | 1 H D 3 |
| 82679 | PROPANIL FIL 0.7 RE | (UG/L) | 0.02 | 1 H D 2 |
| 82680 | CARBARYL FIL 0.7 RE | (UG/L) | 0.05 | 1 H D 2 |

RECORD NUMBER: 99403567 -- CONTINUED

| CODE | PARAMETER NAME | UNITS | VALUE | R | Q | М | Ρ |
|-------|----------------------|-----------------|-------|---|---|---|---|
| 82681 | THIOBENCARB FIL .7 | (UG/L) | 0 | 1 | Н | D | 3 |
| 82682 | DCPA FIL 0.7 REC | (UG/L) | 0 | 1 | Н | D | 3 |
| 82683 | PENDIMETHALIN F.7 R | (UG/L) | 0.02 | 1 | Н | D | 2 |
| 82684 | NAPROPAMIDE FIL .7 | (UG/L) | 0.01 | 1 | Н | D | 2 |
| 82685 | PROPARGITE FIL .7 R | (UG/L) | 0 | 1 | Н | D | 3 |
| 82686 | METHYL AZINPHOS F.7 | (UG/L) | 0.05 | 1 | Н | D | 2 |
| 82687 | PERMETHRIN FIL .7 R | (UG/L) | 0.02 | 1 | Н | D | 2 |
| 84164 | SAMPLER TYPE CODE | CODE | 4040 | | Ι | | 3 |
| 90095 | SPECIFIC CONDUCTANCE | MICROSIEMENS/CM | 330 | | Η | А | 3 |
| 90410 | ALKALINITY | MG/L AS CACO3 | 36 | | Н | А | 2 |
| 91063 | DIAZINON SURROGATE | (PERCENT) | 110 | | Н | D | 2 |
| 91064 | TERBUTHYLAZINE SURR | (PERCENT) | 120 | | Н | D | 2 |
| 91065 | ALPHA D6 HCH SURROG | (PERCENT) | 97 | | Η | D | 2 |
| 99856 | SAMP VOL SCHED 2001 | (ML) | 968 | | Н | D | 3 |
| 99900 | DISTRICT SPEC 99900 | 99900 | 0.10 | 1 | А | | 2 |
| 99902 | DISTRICT SPEC 99902 | 99902 | 0.10 | 1 | А | | 2 |
| 99903 | DISTRICT SPEC 99903 | 99903 | 0.10 | | А | | 2 |
| 99904 | DISTRICT SPEC 99904 | 99904 | 0.10 | | А | | 2 |
| 99905 | DISTRICT SPEC 99905 | 99905 | 1.00 | | А | | 3 |

CATION/CONDUCTANCE RATIO OUTSIDE LIMITS .92 TO 1.24 RESIDUE AT 180 C/SPECIFIC CONDUCTANCE RATIO OUTSIDE LIMITS .55 TO .81 EXESOLVED SOLIDS/CALCULATED SOLIDS RATIO OUTSIDE LIMITS .9 TO 1.12

1

RECORD NUMBER: 99403567 STATION ID: USGS 364227076074713 STATION NAME: 61B 19 COLLECTION DATE: 08-20-1994 1030 - -

| CATION | S (| (MG/L) | (MEQ/L) | ANIONS | (MG/L) | (MEQ/L) |
|------------|------------|--------|---------|-----------------------|---------|---------|
| CALCIUM, | DISS. MG/L | 7.000 | 0.350 | CHLORIDE, DISS. MG/L | 24.000 | 0.678 |
| MAGNESIUM, | DISS. MG/L | 6.200 | 0.511 | SULFATE, DISS. MG/L | 33.000 | 0.688 |
| SODIUM, | DISS. MG/L | 27.000 | 1.175 | BICARB., WHL, IT, FLD | 116.001 | 1.902 |
| POTASSIUM, | DISS. MG/L | 1.401 | 0.036 | CARB., WHL, IT, FLD | 0.000 | 0.001 |

 URON,
 DISS. UG/L
 30000.000
 1.612
 NO2 + NO3, DISS. AS N
 0.061
 0.005

 MANGANESE,
 DISS. UG/L
 438.000
 0.016
 0.016
 0.016

PERCENT DIFFERENCE = 6.14

1

| RECORD NUMBER: | 994 | 04224 | STATION | NUMBER: | 36373 | 380760 | 053101 | COLLEC | CTED: | 08-20 |)-1994 | AT: | 153 |
|----------------|-----|---------|---------|---------|-------|--------|----------|--------|-------|-------|--------|-----|------|
| STATION NAME: | 62A | 17 | | | | | | | | COUN | VTY: 5 | 50 | |
| MEDIUM: | 6 | STATUS: | 9 | SOURCE: | 9 | HYD. | CONDITIC | N: 9 | SAME | LE TY | (PE: 9 | | HYD. |

| CC | ODE | PARAMETER NAME | UNITS | VALUE | RQMP |
|----------|-------|------------------------|------------------|-------|---------|
| | 00010 | WATER TEMPERATURE | (DEGREES) | 26.0 | I 3 |
| | 00020 | AIR TEMPERATURE | DEGREES | 30.0 | I 3 |
| | 00025 | AIR PRESSURE | (MM OF HG) | 762 | I 3 |
| | 00027 | COLLECTING AGENCY | (CODE NUMBER) | 1028 | I 5 |
| | 00028 | ANALYZING AGENCY | (CODE NUMBER) | 80020 | Н 5 |
| | 00059 | FLOW RATE INS. (G/M) | (GALLONS/MINUTE) | 1.0 | I 3 |
| | 00095 | SPECIFIC CONDUCTANCE | US/CM @ 25C | 381 | I 3 |
| | 00300 | OXYGEN DISSOLVED | (MG/L) | 0.2 | I 3 |
| | 00301 | OXYGEN DIS. PERCENT | % OF SATURATION | 3 | I 3 |
| | 00400 | PH, WH, FIELD | (STANDARD UNITS) | 5.8 | I 3 |
| | 00403 | PH, WH, LABORATORY | (STANDARD UNITS) | 5.7 | H A 2 |
| | 00419 | ALKALINITY, WH, IT, F | (MG/L AS CACO3) | 43 | I 3 |
| | 00450 | BICARBONATE, WH, IT, F | (MG/L AS HCO3) | 52 | I 3 |
| | 00608 | NITROGEN AMMONIA D. | (MG/L AS N) | 0.030 | НВЗ |
| | 00613 | NITROGEN, NITRITE D. | MG/L AS N | 0.010 | 1 Н В З |
| | 00623 | NITRO AMN & ORG DIS | (MG/L AS N) | 0.20 | НС2 |
| | 00631 | NO2 + NO3 DISSOLVED | (MG/L AS N) | 8.00 | НВЗ |
| | 00666 | PHOSPHORUS DISS. | (MG/L AS P) | 0.010 | 1 H C 3 |
| | 00671 | PHOSPHORUS ORTHO D. | (MG/L AS P) | 0.010 | 1 H B 3 |
| | 00681 | CARBON ORGANIC DIS. | (MG/L AS C) | 1.8 | H A 2 |
| COMPUTED | 00900 | HARDNESS TOTAL | (MG/L AS CAO3) | 72 | |
| | 00915 | CALCIUM DISSOLVED | (MG/L AS CA) | 20 | H D 2 |
| | 00925 | MAGNESIUM DISSOLVED | (MG/L AS MG) | 5.4 | H C 2 |
| | 00930 | SODIUM DISSOLVED | (MG/L AS NA) | 41 | H C 2 |
| COMPUTED | 00931 | SODIUM ADSORPTION R. | (RATIO) | 2 | |
| COMPUTED | 00932 | SODIUM, PERCENT | PERCENT | 55 | |
| | 00935 | POTASSIUM DISSOLVED | (MG/L AS K) | 2.6 | Н В 2 |
| | 00940 | CHLORIDE DISSOLVED | (MG/L AS CL) | 53 | Н Ј 2 |
| | 00945 | SULFATE DISSOLVED | (MG/L AS SO4) | 26 | HG2 |
| | 00950 | FLUORIDE DISSOLVED | (MG/L AS F) | 0.10 | 1 H B 2 |
| | 00955 | SILICA DISSOLVED | (MG/L AS SIO2) | 6.0 | HD2 |

.

. .

| Sample Datetim e | <u>Time</u> <u>datum</u> | <u>Time</u> <u>datum</u> <u>reliability</u> | <u>Sample</u> <u>Medium</u> <u>Code</u> | Agency Collecting Sample, | <u>Analysis</u> <u>Source</u> | <u>Hydro-</u> logic Event | <u>Hydro-</u> <u>logic</u> <u>Condition</u> | <u>Sample</u> <u>type</u> |
|------------------------|-----------------------------|---|---|---------------------------------|----------------------------------|---------------------------------|---|------------------------------|
| | | <u>code</u> | | <u>Code</u> | | | | |
| 1989-03- | EST | т | WG | USGS- WRD | 9 | 9 | A | 9 |

USGS 364227076074713 61B 19 SOW 091M

Chesapeake City, Virginia

Hydrologic Unit Code 03010205

Latitude 36°42'27", Longitude 76°07'47" NAD27

Land-surface elevation 15.00 feet above sea level NGVD29

The depth of the well is 20.00 feet below land surface.

The depth of the hole is 20.00 feet below land surface.

This well is completed in the Northern Atlantic Coastal Plain aquifer system (S100NATLCP) This well is completed in the QUATERNARY SYSTEM (110QRNR) local aquifer.

| Water Quality Remark Code | Descript ion |
|------------------------------------|-----------------|
| | Less |
| < | than. |

1 - -1

| Project | | | | Specif- | Hydro- | | | |
|---------------|---------|----------------|---------|---------|---------|---------|---------|---------|
| Code | | | | ic | gen | pH, | pН, | |
| | | Agency | Color, | conduc- | ion, | water, | water, | Carbon |
| | Temper- | ana- | water, | tance, | water, | unfltrd | unfltrd | dioxide |
| | ature, | lyzing | fltrd, | wat unf | unfltrd | field, | lab, | water, |
| | water, | sample, | Pt-Co | uS/cm | calcd, | std | std | unfltrd |
| | deg C | code | units | 25 degC | mg/L | units | units | mg/L |
| | (00010) | <u>(00028)</u> | (00080) | (00095) | (00191) | (00400) | (00403) | (00405) |
| 4451089 00 | 14.0 | 80020 | 15 | 220 | 0.00201 | 5.7 | 6.1 | 238 |

) national aquifer.

. . . **.** .

| ANC, | | Ammoni a | Nitrate | | | | | |
|---------|-------------|------------------|-------------------|---------|---------|---------|---------|---------|
| wat unf | | + | + | Phos- | | | | |
| fixed | Ammoni a | org-N, | nitrite | phorus, | Organic | Hard- | | Magnes- |
| end pt, | water, | water, | water | water, | carbon, | ness, | Calcium | ium, |
| field, | fltrd, | unfltrd | fltrd, | unfltrd | water, | water, | water, | water, |
| mg/L as | mg/L | mg/L | mg/L | mg/L | unfltrd | mg/L as | fltrd, | fltrd, |
| CaCO3 | as N | as N | as N | as P | mg/L | CaCO3 | mg/L | mg/L |
| (00410) | (00608) | (00625) | (00631) | (00665) | (00680) | (00900) | (00915) | (00925) |
| 62 | 0.080 | <u>< 0.20</u> | <u>< 0.100</u> | 0.05 | 2.4 | 38 | 6.20 | 5.40 |

| | | Sodium | | | | | | |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | | frac- | Potas- | Chlor- | | Fluor- | Silica, | |
| Sodium, | Sodium | tion | sium, | ide, | Sulfate | ide, | water, | Boron, |
| water, | adsorp- | of | water, | water, | water, | water, | fltrd, | water, |
| fltrd, | tion | cations | fltrd, | fltrd, | fitrd, | fltrd, | mg/L as | fltrd, |
| mg/L | ratio | percent | mg/L | mg/L | mg/L | mg/L | SiO2 | ug/L |
| (00930) | (00931) | (00932) | (00935) | (00940) | (00945) | (00950) | (00955) | (01020) |
| 17.0 | 1.2 | 49 | 1.10 | 17.0 | 15.0 | 0.10 | 19.0 | 20 |

| | | Mangan | | | | Depth | Residue | Residue |
|---------|---------|---------|---------|---------|---------|---------|-------------|---------|
| Iron, | | ese, | | | | to | on | water, |
| water, | | water, | Mangan | | Alum- | water | evap. | fltrd, |
| unfltrd | Iron, | unfltrd | ese, | Zinc, | inum, | level | at | sum of |
| recover | water, | recover | water, | water, | water, | below | 180deg C | consti- |
| -able, | fltrd, | -able, | fitrd, | fltrd, | fltrd, | LSD, | wat flt | tuents |
| ug/L | ug/L | ug/L | ug/L | ug/L | ug/L | meters | mg/L | mg/L |
| (01045) | (01046) | (01055) | (01056) | (01090) | (01106) | (30210) | (70300) | (70301) |
| 13000 | 14000 | 240 | 270 | 2000 | 20 | 0.884 | 130 | 134 |

| | | Depth | Depth | Depth | Specif. | ANC, |
|---------|-------------|---------|---------|---------|---------|---------|
| | | to top | to bot | to | conduc- | wat unf |
| Residue | | sample | sample | water | tance, | fixed |
| water, | Ammoni a | intrval | intrval | level, | wat unf | end pt, |
| fltrd, | water, | feet | feet | feet | lab, | lab, |
| tons/ | fltrd, | below | below | below | uS/cm | mg/L as |
| acre-ft | mg/L | LSD | LSD | LSD | 25 degC | CaCO3 |
| (70303) | (71846) | (72015) | (72016) | (72019) | (90095) | (90410) |
| 0.18 | 0.10 | 10.00 | 20.00 | 2.90 | 208 | 60 |

-11 ---

APPENDIX I Battlefield Golf Course Groundwater Quality Data TABLE 2A: SUMMARY OF ONSITE GROUNDWATER METALS ANALYSES Battelied Goff Club at Centerville 1001 Centerville Turnpike Chesapeake, VA 23322

| | | | - | - | | - | | ~ | ~ | | _ | _ | _ | | | - | | |
|---------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|--------|-----------|-----------|------------|-----------|--------|--------|--------|---|
| Zn (ua/L) | 510 | 235 | 491 | 91.1 | 805 | 524 | 307 | 130 | 210 | 367.0 | • | 5000 | | | 372.5 | 291.1 | 395.2 | |
| V (ua/L) | 232 | 72.4 | 297 | 45.8 | 384 | 202 | 114 | 39 | 61.2 | 160.8 | | | | | 152.2 | 171.4 | 160.0 | |
| TI (uo/L) | MDL | BDL | MDL | ' | 2.0 | | | | | | | |
| Ag (ua/L) | MDL | BDL | MDL | • | | 100 | | | | | | |
| Se (ua/L) | MDL | BDL | MDL | • | 50.0 | | | | | | | |
| Ni Ua/L) | 166 | 80.2 | 204 | 52 | 299 | 187 | 111 | 35 | 61 | 132.8 | | | | | 123.1 | 128.0 | 138.6 | |
| Mo ua/L) | MDL | 9.6 | MDL | 9.6 | | | | | | | 9.6 | |
| Hg () | 0.23 | MDL | 0.24 | MDL | 0.31 | 0.12 | MDL | BDL | MDL | : | 2.0 | | | | | | | |
| (I Mn a/L) | 1,330 | 416 | 1,300 | 284 | 1,540 | 202 | 572 | 290 | 419 | 784 | | 20 | | | 873 | 792 | 746 | |
| - 3 | 1,000 | 9,100 | 1,500 | 2,200 | 7,700 | 3,700 | 6,300 | 1,000 | 8,900 | 0,156 | | | | | 5,050 | 1,850 | 1,520 | |
| Jon) | 6.0 | 1 | .7 4 | 3 | 26 4 | 8. | 3 | 7 2 | .4 | .1 3 | • | ' | | | .1 2 | .0 | .1 3 | |
| Pb (uo/L) | 0 67 | 0 26 | 0 78 | 0 15 | 0 | 0 66 | 0 36 | 0 | 0 19 | 2 47 | 15 | • | | | 0 47 | 0 47 | 0 47 | |
| Fe (ua/L) | 157,00 | 48,10 | 175,00 | 32,60 | 229,00 | 129,00 | 75,90 | 26,00 | 43,80 | 101,82 | • | 300 | | | 102,55 | 103,80 | 100,74 | |
| Cu (ua/L) | 9.6 | 5.7 | 33 | 4.4 | 44.8 | 32.5 | 12.1 | BDL | 13 | 19.4 | | 1000 | | | 7.7 | 18.7 | 25.6 | |
| Co (ua/L) | 76 | 33.9 | 90.3 | 22 | 148 | 96.3 | 52.1 | 28 | 35.6 | 64.7 | | | | | 55.0 | 56.2 | 72.0 | |
| Cr (uo/L) | 187 | 58.4 | 231 | 34.2 | 302 | 158 | 88 | 29 | 46.7 | 126.1 | 100.0 | | | | 122.7 | 132.6 | 124.9 | |
| Cd (ua/L) | MDL | BDL | MDL | 1 | 5.0 | | | | | | | |
| B uo/L) | 113 | 37.7 | 75.2 | 40.1 | 75.5 | 56.4 | 49.6 | BDL | 44.2 | 61.5 | | | 500 | | 75.4 | 57.7 | 56.4 | |
| Be la/L) | 3.8 | 0.9 | 3.4 | MDL | 5.2 | ę | - | BDL | 0.5 | 2.5 | 4.0 | | | ell | 2.4 | 3.4 | 2.4 | |
| Ba a/L) (i | 284 | 110 | 444 | 94.1 | 463 | 265 | 148 | 82 | 97.6 | 220.9 | 000 | | | age per W | 197 | 269 | 211 | |
| s (n) | 64.6 | 22.7 | 79.8 | 21 | 103 | 71.3 | 39.9 | BDL | 17.4 | 52.5 | 10 21 | | | Aver | 43.7 | 50.4 | 57.9 | |
| A (10 | , | Ļ | Ļ | Ļ | Ļ | Ļ | Ļ | ب | بے | - | 9 10 | Ĺ | | | | | | |
| St (no/ | 700 MD | 800 MD | 200 MD | .100 ME | .000 ME | .500 ME | ,600 ME | 000 BD | 000 ME | 989 | 9.6 | ' - | | | 750 | 650 | 020 | |
| ate Al r (uo/L | 08 86, | 08 26, | 08 99, | 16, 16, | 130, | 08 69, | 08 37, | 12, | 08 26, | 55, | - CL | CL 200 | ne | | 56, | 22, | 55, | |
| * Sample Damo/dv/vi | 5/20/20 | 7/14/20 | 5/20/20 | 7/14/20 | 5/20/20 | 7/14/20 | 7/14/20 | 8/25/20 | 8/25/20 | Mean | Primary M | condary M | 10 Guideli | | : | 1 | : | |
| ample ID # MW-# | 1W-1 | 1W-1 | 1W-2 | 1W-2 | 1W-3 | 1W-3 | 1W-3D | 1W-3 | 1W-3 | | | Sec | W | | MW-1 | MW-2 | MW-3 | |
| U) | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | | | | | | | | | 1 |

MW-1, MW-2 and MW-3 at ~280X above primary MCL for AI. MW-2 and MW-3 at 35 above primary MCL for AS. WW-1 at 4x above primary MCL MW-1, MW-2, MW-3 list above primary MCL for C (~2X) MW-1, MW-2, MW-3 at approximately 300X higher than Secondary MCL for Fe Note:

MW-1, MW-2 and MW-3 at 3X above primary MCL for Pb. MW-1, MW-2 and MW-3 at ~15X above primary MCL for Mn.

TABLE 2B: SUMMARY OF OFFSITE GROUNDWATER METALS ANALYSES Batteled Gort Cup at Centerville 1001 Centerville Tumpike Chesapeake, VA 23322

| Sample | ID # Sample Date | A | Sb | As | Ba | Be | ш | PC | ວັ | ပိ | ŋ | Fe | PP | Mg | Mn | Нg | Mo | īZ | Se | Ag | F | > | Zn |
|--------|------------------|-------------|--------------|--------------|--------------|-------------|--------|--------|------------|-----------|--------------|--------------|---------------|-------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| MW | -# mo/dy/yr | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) | (ng/L) |
| FS-6 | 7/23/2008 | 595 | MDL | MDL | 68.5 | MDL | 33.7 | MDL | MDL | 9.5 | 106 | 2950 | 22 | 3560 | 112 | MDL | MDL | 9.1 | MDL | MDL | MDL | MDL | 55.2 |
| MW-4 | 7/23/2008 | 5,670 | MDL | MDL | 33.7 | 8.1 | 17.5 | MDL | MDL | 132 | MDL | 53,600 | MDL | 59,400 | 1,190 | MDL | MDL | 294 | MDL | MDL | MDL | MDL | 485 |
| MW-5D | 7/23/2008 | 16,100 | MDL | 6.0 | 80.7 | MDL | 65.9 | MDL | 39.5 | 10.6 | 8.4 | 43,400 | 19.9 | 7,760 | 443 | MDL | MDL | 25.2 | MDL | MDL | MDL | 41.4 | 138 |
| | Mean | 7,455 | MDL | 6.0 | 61.0 | 8.1 | 39.0 | MDL | 39.5 | 50.7 | 57.2 | 33317 | 21.0 | 23,573 | 582 | MDL | MDL | 109.4 | MDL | MDL | MDL | 41.4 | 226.1 |
| | Primary MCL | | 6.0 | 10.0 | 2000 | 4.0 | | 5.0 | 100.0 | | | | 15 | | | 2.0 | | | 50.0 | | 2.0 | | |
| | Secondary MCL | 200 | , | | | | | | | | 1000 | 300.0 | | | 50.0 | • | | | | 100 | | | 5000 |
| | WHO Guideline | | | | | | 500 | | | | | | | | | | | | | | | | |
| Note: | FS-6, MW-4 a | ind MW-5D a | łt ~3X, ~28> | (, ~80X abov | ve primary M | ICL for AI. | | | FS-6, MW-4 | and MW-5C |) at ~2+X, ~ | 24X, ~9X abi | ove primary [| MCL for Mn. | | | | | | | | | |

FS-6, MW-4 and MW-5D at ~3X, ~2BX, ~90X above primary MCL for Al. 44 at X2 above primary MCL for Be FS-6, MW-4 and MW-5D at ~10X, ~178X, ~145X above primary MCL for Fe. FS-6, MW-4 and MW-5D Sightly above primary MCL for Pb. Note:

TABLE 3A: SUMMARY OF ONSITE WATER CLASSICAL CHEMICAL PARAMETERS Battefield Goff Course at Centerville 1001 Centerville Turnpike Chesapake, VA 2332

| Sample ID # | | Ca | ō | Ŀ | z | ٩. | × | Na | S04 | AIK | TDS | TSS |
|-------------|------------|---------|--------|--------|-------------|--------|---------|---------|--------|--------|--------|--------|
| #-MM | mo/dy/yr | (n g/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) | (n g/L) | (n g/L) | (mg/L) | (mg/L) | (mg/L) | (mg/L) |
| MW-1 | 5/20/2008 | 47,800 | 49 | 0.15 | 0.14 | 1.6 | 9,140 | 15,100 | 76 | 26 | 290 | 4,800 |
| MW-1 | 7/14/2008 | 23,700 | 20 | 0.16 | 0.079 | 0.75 | 3,980 | 11,900 | 29 | 31 | 230 | 660 |
| MW-2 | 5/20/2008 | 69,500 | 50 | 0.28 | 1.1 | 2.1 | 12,600 | 28,500 | 120 | 28 | 370 | 2,100 |
| MW-2 | 7/14/2008 | 58,800 | 36 | 0.26 | 0.19 | 0.99 | 4,350 | 27,300 | 96 | 89 | 390 | 180 |
| MW-3 | 5/20/2008 | 57,700 | 18 | 0.32 | 0.15 | 2.8 | 14,200 | 22,900 | 140 | 49 | 360 | 2,100 |
| MW-3 | 7/14/2008 | 56,900 | 4 | 0.4 | MDL | MDL | 10,500 | 22,700 | 130 | 61 | 380 | 2,600 |
| MW-3D | 7/14/2008 | 59,000 | 4 | 0.4 | MDL | 0.93 | 7,380 | 23,400 | 130 | 99 | 390 | 1,200 |
| MW-3 | 8/25/2008 | 66,900 | 46 | 0.45 | 0.14 | 0.4 | 4,270 | 25,800 | 130 | 76 | 420 | 1400 |
| MW-3 | 8/25/2008 | 54,000 | 45 | 0.31 | BDL | 0.5 | 4,500 | 24,000 | 130 | 87 | 420 | 560 |
| | Mean | 54,922 | 39 | 0:30 | 0:30 | 1.26 | 7,880 | 22,400 | 115 | 57 | 361 | 1,733 |
| Δ. | rimary MCL | | | | | | | | | | | |
| Sect | ondary MCL | | 250 | 2.0 | | | | | 250 | | 500 | • |
| | | | | 1 | Average per | Well | | | | | | |
| MW-1 | | 35,750 | 35 | 0.16 | 0.11 | 1.18 | 6,560 | 13,500 | 78 | 29 | 260 | 2,730 |
| MW-2 | ; | 64,150 | 43 | 0.27 | 0.65 | 1.55 | 8,475 | 27,900 | 108 | 59 | 380 | 1,140 |
| MW-3 | ı | 58,900 | 39 | 0.38 | 1 | ; | 8,170 | 23,760 | 132 | 68 | 394 | 1,572 |

All samples in Talbe 3A below primary and secondary MCLs Note:

APPENDIX J 2007 City of Chesapeake Water Quality Report

ι,

What's New?

EPA REGULATORY INITIATIVES Arsenic

Arsenic is a naturally occurring mineral in soil, water, air, plants, and animals. Studies have linked long-term, chronic exposure to arsenic in drinking water to cancer. Compliance with the 10 ppb MCL was required in January, 2006. Water providers must include health information and arsenic concentrations in annual reports for water that exceed 5 ppb (one-half of the MCL). We are pleased to report that the levels of arsenic in any of Chesapeake's public water systems are well below the MCL.

Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR)

This rule became final on January 5, 2006. It was developed to improve drinking water quality and provide additional protection from disease-causing microorganisms and contaminants that can form during drinking water treatment. Pathogens, such as Giardia and *Cryptosporidium*, are often found in raw water, and can cause gastro-intestinal illness and other health risks. *Cryptosporidium* is a significant concern in drinking water because it can contaminate surface water such as drinking water sources. It is resistant to chlorine and other disinfectants, and can cause waterborne disease outbreaks.

The purpose of LT2 rule is to reduce the risk associated with *Cryptosporidium* and other pathogenic microorganisms in drinking water. Northwest River Water Treatment Plant (NWRWTP) has voluntarily tested its source water quarterly since 1994. To comply with the rule NWRWTP and LGWTP started this monitoring for *Cryptosporidium*, E. coli, and turbidity in October 2006. This monitoring period will be completed by September 2008.

Stage 2 Disinfectants and Disinfection Byproduct Rule (Stage 2 D/DBPR)

This rule was developed to improve drinking water quality and to provide additional monitoring from disinfection byproducts. Disinfection is required to provide healthy drinking water. However, disinfectants like chlorine and bromate can react with naturally occurring materials in the water to form byproducts such as, Trihalomethanes (THM) and Haloacetic Acids (HAA). Under the Stage 2 D/DBPR, all drinking water systems must conduct an evaluation of their distribution systems, known as an Initial Distribution System Evaluation (IDSE), to identify the locations with higher disinfection byproduct concentrations. These locations will then be used by the systems as the sampling sites for Stage 2 D/DBPR compliance monitoring.

Compliance with the maximum contaminant levels for two groups of disinfection byproducts (TTHM and HAA5) will be calculated for <u>each</u> monitoring location in the distribution system. This approach, referred to as the Locational Running Annual Average (LRAA), differs from previous requirements that determined compliance by calculating the running annual average of samples from all monitoring locations across the system. Sampling all three systems every other month began in July 2007.

lepartment of Public Utilities Post Office Box 15225 Chesapeake, VA 23328

apeake



PRSRT STD US POSTAGE PAID NORFOLK VA PERMIT #427



2007 WATER QUALITY REPORT

City of Chesapeake Department of Public Utilities



WATER...FOR TODAY AND TOMORROW

Want More Information?

If you have any questions about this report or need more information, please contact the Water Quality Laboratory at 757-382-3550. The following telephone numbers are provided for specific issues or

| Customer Service (billing) | 757-382-6352 |
|----------------------------|--------------|
| Laboratory (water quality) | 757-382-3550 |
| Water Quality Hot Line | 757-382-6360 |

Visit our web site for online information at <u>www CryotChesapeable net</u> then click on Public Utilities. Contact us by E-mail at

Our Business Office is located at City Hall, second floor, 306 Cedar Road, Chesapeake, WA 23322. It is open from 8:00 a.m. to 5:00 p.m., Monday through Friday. Address correspondence to Chesapeake Department of Public Utilities, PO. Box 15:25, Chesapeake, VA 2328.

| Public Utilities Director | James K. Walski, P.E. |
|--|-----------------------------|
| Public Utilities Assistant Director | William J. Meyer, Jr., P.E. |
| Financial/Customer Service Administrator | Markiella A. Moore |
| Utility Engineer | S. Dean Perry, P.E. |
| Water Resources Management | |
| Administrator | A Crain Manles |

Water Works Permit Identification Numbers

rthwest River System (including the Lake Gaston Water Treatment Plant) – PWSID 3550051 South Norfolk System – PWSID 3550052 Western Branch System – PWSID 3550050

Public Participation

Public Utilities is an enterprise department and is funded by customer fees, not taxes. However, it is part of the City of Chesapeake govern-ment. Our legislative body is the Chesapeake City Council, which holds hearings on budget and other financial matters, approves contracts, and considers ordinances that create or amend local laws. Some of these matters after: the operation of Public Utilities. The City Council the semitters of the operation of Public Utilities. The City Council meets on the 2nd, 3rd and 4th Tuesdays of each month at 6:30 p.m. in the City Council Chambers, First Floor of the City Hall Building, 306 Cedar Road. The meetings are televised live on WCTV Channel 48, the local government access cable channel, and on the City web site, www.CityOlChosappake.net. Agendas for upcoming meetings are available on the City web site, or may be requested from the City Clerk's office at 757-382-6151

INFORMATION FOR SPECIAL POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer and undergoing chemotherapy, persons such as persons whit cancer and undargoing cheating by persons who have undergone an organ transplant, persons with HVAIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Environmental Protection Agency/Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptasporidium* and other microbiological contaminants are available from the Safe Drinking Water Act Hotline at 1-800-426-4791.

INFORMATION ABOUT SOURCE WATER

A detailed source water assessment was conducted in 2001 by the Hampton Roads Planning District Commission. The Northwest River. like other surface water sources, was determined to have a high susceptibility to contamination. Our deep wells, like other groundwater sources, were determined to be low in susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program. The report consists of maps showing the source water assessment area, an inventory of known land use activities of concern, and documentation of any known contamination within the last 5 years. The report is on file at the Public **Utilities Department**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Substances that may be present in source water include. (1) microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; (2) inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (3) pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and resi-dential uses; (4) organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial process and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; (5) radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure the tap water is safe to drink, the EPA prescribes regulations that limit the amount of contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the similar protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791 or accessing the EPA web site at www.epa.gov/safewater/.

2007 WATER QUALITY TABLE

The table contains the highest level and range, if available, detected by analyses performed in calendar year 2007, or the most recent testing in accordance with the regulations, An additional 180 compounds were tested for and not detected.

| and the second second | | nev | JULAI | LD 30 | DOTA | NOED | |
|--|---|-------------------|--|-------------------------|-------------------------|--|-----------------------|
| Substance (Unit) | MCL | MCLG | NWR & Range | N Highest & Range | P Highest & Range | Likely Source | Meets EPA Stds. |
| Antimony (ppb) | 6 | 6 | 0.06 ND - 0.06 | ND | ND | Discharge from petroleum refineries, fire retardants, ceramics, electronics, solders. | Yes |
| Arsenic (ppb) | 10 | NA | 0.3 ND - 0.3 | ND | ND | Erosion of natural deposits, runoff from orchards, glass and electronics production wastes. | Yes |
| Barium (ppb) | 2000 | 2000 | 24 ND - 24 | 59 27 - 59 | 26 N/A | Erosion of natural deposits, discharge from metal refineries | Yes |
| Chlorine, Total (ppm) *highest quarter avg. | MRDL 4 | MRDLG 4 | 2.82* 0.07 - 4.34 | 2.75* 0.02 - 3.90 | 2.62* 0.01 - 3.32 | Water additive used to control microbes | Yes |
| Chromium (ppb) | 100 | 100 | ND | 2 ND - 2 | 1 N/A | Erosion of natural deposits | Yes |
| Dalapon (ppb) | 200 | 200 | ND | 1.5 ND - 1.5 | ND | Herbicide runoff. | Yes |
| Hexachlorocyclopenta diene (ppb) | 50 | 50 | ND | 0.1 ND - 0.1 | ND | Pesticide component from runoff. | Yes |
| Nickel (ppm) | 50 | 50 | ND | 2 ND - 2 | ND | Pesticide component from runoff. | Yes |
| Nitrate (ppm) | 10 | 10 | 0.22 | 0.4 0.1 - 0.4 | ND | Runoff from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits. | Yes |
| Total Organic Carbon (TOC) (ppm) *lowest annual average | TT (1.00 annual average removal ratio) | NA | 1.20* 1.06 - 1.54 (range of individual readings) | 2.7* 1.3 - 3.1 | 2.6 1.8 - 3.2 | Naturally present in environment. | Yes |
| Selenium (ppb) | 50 | 50 | 0.1 ND - 0.1 | ND | ND | Discharge from petroleum and metal refineries, erosion of natural deposits | Yes |
| Fluoride (ppm) | MCL/ | 1 2 | NWR | N | P | Naturally present in environment, | Yes |
| "highest monthly average | MCLG | Entry Point | #1 Entry Point #2 | | | water additive which promotes strong teeth | |
| | 4 | 1.0° 0.6 - 1.0 | 1.0* 0.8 - 1.1 | 1.0* 0.1 - 1.6 | 0.79 N/A | | |

RADIONUCLIDES

| Substance (Unit) | MCL | MCLO | NWR & LG | | N | P | Likely Source | Monte |
|--|------------|---------------|-------------------|-------|------------------|------------|---|---------------|
| | mor | more | EP #1 | EP #2 | A | | cively cource | EPA Standards |
| Beta/photon emitters' (pCi/L) | 50 | Zoro | 3.48 2.3 - 4.5 | N/A | 3.0 2.7 - 3.0 | 1.8 N/A | Decay of natural and man-made deposits | Yes |
| Gross alpha particle (pCi/L) | 15 | Zero | 0.28 ND - 1.1 | N/A | 1.3 0.3 · 1.3 | ND | Erosion of natural deposits | Yes |
| Combined radium- 226/228° (pCi/L) [tested every 4 years] | 5 | Zero | 0.7 ND - 1.2 | N/A | 1.3 0.6 · 1.3 | 0.4 N/A | Erosion of natural deposits | Yes |
| 1. EPA considers 50 pCiA to | be the lev | el of concern | for Beta particl | 20 | | | | |

| Substance (Unit) | | MCL | | MCLG | 1 | NWR | | LG | N | | P | Likely Source | Meets EPA Stds. |
|--|------|---|------------------------------|---------------------------|--------------------|----------------------------------|----------|---------------------------------|--|-----|----------------------------------|--|--------------------|
| Turbidity – Clarity (NTU) | 0.3, | Max TI, 1 Min. TI, han or eq greater ti | less ual to nan 95% | N/A N/A | 0.0 | 0.26 19 - 0.26 Min. 100 | 0. | 0.13 05 - 0.13 Min 100 | 0.44 N/A Greater than 99.05% | 0.0 | 0.08 4 - 0.08 Min. 100% | Soil runoff | Yes |
| Substance (Unit) | MCL | MCLG | N | NR & LG | | | | N | | P | | Likely | Meets |
| | | | Range a Samplin Sites* | t High g Bunr Avera | est ing ge** | Range Sample Sites | at ng | Highest Bunning Average | Range a Samplin Sites* | g | Highest Ronning Average | Source | EPA Stds. |
| TTHM – Total Trihalomethanes (ppb) | 80* | 0 | ND - 6 | 5 3 | 0 | 33 - 1 | 83 | 51 | 35 - 48 | | 45 | By-product of drinking water chlorination | Yes |
| HAA Haloacetic Acids Acids (ppb) | 60° | 0 | 1 - 27 | 1) | 1 | 4 - 4 | 0 | 27 | 13 - 26 | | 28 | By-product of drinking water chlorination | Yes |

*Range of individual readings **MCL is the highest numring across average allowed for the year

| MICROORGA | NISM | IS | | 1000 C | | | للقيب | | Nor con the loss |
|--------------------------------------|--------------------|--------------------------------------|-------------|--|-----------------------|--------|------------------|-----------------------------|-------------------------|
| Substance MCL | | MC | LG NWR & LG | N | P | Likely | Source | Meets EPA Standards | |
| Total Coliform Bacteria | 5% monti are | or less of hly sample positive | 0 | 0% | 2% in May 0 - 2 | 0 | Natura in the | ally present environment | Yes |
| Monitored Substance (Unit) | | MCL | MCLG | NWR & LG | N | T | Р | Likely Sou | rce |
| Cryptosporidium (organisms/liter) | | None | None | 0.01 (in source water) ND - 0.01 | N/A | | N/A | Warm-blood in the water | led animals living shed |
| Giardia (organisms/liter) | | п | 0 | ND | N/A | | N/A | Warm-blood in the water | led animals living shed |

CAD AND CODDED 100 --- DEDEENTILEL

| ELAD AND COTTEN (30th FERGENTILE) | | | | | | | | | | |
|--|---------------------------------|-----------------------|-------------------------------|----------------------------|----------------------------|------------------------------------|------------------------------|--|--|--|
| Substance (Unit) | MCL | MCLG | NWR & LG 90th % Range | N 90th % Range | pr 90th % Range | Likely Source | Meets EPA Standards | | | |
| Copper (ppm) [house tap] | AL = 1.3 | 1.3 | 0.160 ND - 0.430 | 0.163 0.030 - 0.295 | 0.145 ND - 0.417 | Corrosion of household plumbing | Yes | | | |
| Lead (opb) (house tap) | AL = 15 | 0 | 18° ND - 70 | 7.3 0.2 - 37 | 2.8 0.3 - 9.8 | Corrosion of household plumbing | Yes | | | |
| # of samples above / # of samples above / | AL of 1.3 ppm AL of 15 ppb f | for copper or lead | 0 out of 102 11 out of 102 | 0 out of 30 3 out of 30 | 0 out of 31 0 out of 31 | | NWR & LG - No N & P - Yes | | | |

If a simpler above AL of 15 gob for lead [11 out of 102] 3 courd 30 [0 out d 31] [0 with a simpler analyzed from homes within the City have lead levels above the EPA action issues. In a second round of the simpler analyzed from homes within the City have lead levels above the EPA action issues. The action program are anall percentage of the simpler analyzed from homes within the City have lead levels above the EPA action issues. The observation of the Simpler analyzed from homes within the City have lead levels above the EPA action issues. The city completed the Habit E Clucation program and provide contractives with deactation the simulation and provide contractives with deactation the simulation and provide contractives with deactation the simulation and provide proteinate and provide proteinate and the simulation and provide contractives and provide proteinate and proteinate and provide proteinate an

ADDITIONAL WATER OLIALITY PARAMETERS

| Substance (Unit) | Suggested Limit | NWR & LG highest level and range | N highest level and range | P highest level and range |
|---|--------------------|-------------------------------------|------------------------------|------------------------------|
| Aluminum (ppm) | 0.05 - 0.2 | ND | 0.12 0.02 - 0.12 | ND |
| Ammonia (ppm) | None | 0.65 / 0.49 - 0.65 | N/A | N/A |
| Chéoride (ppm) | 250 | 106 44 - 106 | 21 8 · 21 | 18 N/A |
| Color (CU) | 15 | 2.5 / ND - 2.5 | N/A | N/A |
| Hardness – total (ppm & (grains per gallon)) | None | 30 (2) ND - 30 | 61 <i>(4)</i> 18 - 67 | 30 (2) N/A |
| Iron (ppm) | 0.3 | ND | N/A | N/A |
| Manganese (ppm) | 0.05 | ND | 0.2 ND - 0.2 | N/A |
| Nickel (ppb) | 100 | ND | 0.2 / ND - 0.2 | N/A |
| ph (pH units) | 65-85 | 8.69 (avg.) 6.36 - 8.69 | 7.3 (avg.) 6.6 - 7.9 | 7.7 (avg.) 3.3 - 8.0 |
| Sodium (ppm) | 250 | 83 / 78 - 83 | 40 / 10 - 40 | 61 / N/A |
| Sulfate (ppm) | 250 | 9/ND 9 | 41 / 24 - 41 | 61 / N/A |
| Zinc (ppm) | 5 | 0.565 | N/A | N/A |

Table Definitions

A turk of ULTIMENTS Substances in your drinking water are routinely monitored by the Virginia Department of Health according to Federal and State Regulations. The 2007 Water Quality Table shows the results of doer monitoring for the period of January 1st to December 31st, 2007 unites otherwise stated. In the table and elsewhere in this report you will find many farms and abbreviations are provided to helio you britts understand these terms.

Additional Water Quality Parameters - the npounds that may affect drinkin ithetics such as taste, odor and color

AL (Action Level) – the concentration of a con-taminant which, if exceeded, triggers treatment or other requirements that a water system must

CU (Color Units) - a measure of the color of water. CO Constraints – a measure of the color of water. Detected Substances – compounds detected in Chestpeaks's driving water during calendar year 2007. The SUWA requires that the highest value detected and the range, if available, during the calendar year be provided in the report. An additional 18 compounds were tested for and not detected. A full fist of these test results is avail-able from the Chesspace Water Quality Laboratory at 75-7482-3550.

HAAs (Haloacetic Acids) - byproducts of

IDSE (Initial Distribution System Evaluation) – sites identified in the distribution system with high disinfection byproduct concentrations.

Likely Source - the major sources of the com-pounds detected in finished water.

pounds detected in Insisted water. LG (Lake Gaston Water Treatment Plant) – The highest level and range, if available, of the compounds detected in the Insisted water processed at the Lake Gaston Water Treatment Plant (Entry Point #2), a combined surface water source, Western Branch Weils #1 and #3 and Aquifer Stonge and Recovery (ASR) water sources as needed to meet heavy demand. MCI (Maximum Contaminant level — In highest level of a contaminant there]. — In thighest level of a contaminant there MCLGs as leasible using the best available treatment technology. MCLG (Maximum Contaminant level God). — the

MCLG (Maximum Contaminant Level Goal) – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level) – a level of disinfectant added for water treatment that may not be exceeded at the consumer's tap without an unacceptable possibility of adverse health effects

MRDLG (Maximum Residual Disinfectant Level MRDLG (Maximum Resolutal Disnifectant Level Goal) - the maximum level of a disnet cartant for water treatment at which no known or antici-pated advises effect on the beath of persons would occur, and which allows an adequate margin of astlery MRDLGs are nonenforceable health goals and do not reflect the benefit of the addition of the chemical for control of waterborre microbial contaminants.

Microbial Substance – disease-causing organ-isms that may be harmful at certain levels. More information about *Cryptosporidium* and Giardia is supplied in this report

mrem/year (Millirems per year) - is a measure of

N (Norfolk System Results) - the highest level and range, if available, of the compounds detected in the finished water supplied by the City of Norfolk for Chesapeake customers

N/A - not available

ND - not detected, lab analysis indicates that the taminant is not present or was below the level of detection

NTU (Nephelometric Turbidity Unit) - a m of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

is just noticeable to the nerrapp person. NWR (Northwest River System Results) – The highest level and range, it available, of the compounds detected in the finished water processed at the Northwest River Water Treat-ment Plant [Entry Point #]], a combined surface and brackish well water source.

P (Portsmouth System Results) – the highest level and range, if available, of the compounds detected in the finished water supplied by the City of Portsmouth for Chesapeake customers.

pCi/L (Picocuries per Liter) - a measure of ivity

ppb (parts per billion) – One part per billion is the equivalent of one minute in 2,000 years; or one penny in \$10,000,000.

ppm (parts per million) - One part per million is the equivalent of one minute in 2 years, or one penny in \$10,000.

Plant Effluent - water leaving the plant after poing through the treatment process

Stage 2 D/DBPR (Disinfectants and Disinfection By-Product Rule) - rule developed to improve drinking water quality and provide additional monitoring of disinfection by-products

TOC (Total Organic Carbon) TT - This value repre-Tou (total urganic caroon 11 – his value repre-sents the waterwork's ability to meet TOC percent removal requirements based on an annual average of the monthly percent removal ratios. TOC percent removal requirements are met when the value is greater than or equal to 1.00.

 $\ensuremath{\text{TT}}$ (Treatment Technique) – a required process intended to reduce the level of a contaminant in drinking water.

TTHMs (Total Trihalomethanes) - compound formed during the disinfection of drinking water.

Drinking Water of the Highest Quality

We want you to know about your drinking water: where we get your water, how it is purified and what is in it. The federal Safe Drinking Water Act (SDWA) sets the standards and this annual water quality report is one of the provisions of those standards. Please take a few minutes to review this very important information and know that reliability, quality, and affordability are at the heart of our mission in Public Utilities.

In order to produce the approximately 16.7 million gallons per day for about 61,206 accounts, more than 195,125 analyses throughout the treatment process are performed annually for treatment of drinking water. Water quality sampling in approximately 480 homes and businesses around the city tells the story of how well we are doing.

Association with world class organizations helps Public Utilities remain on the cutting edge of technology and committed to continuous improvement. We are members of the **American Water Works Association** (AWWA) and its **Partnership for Safe Water** (PSW), an association of water utilities and government entities committed to drinking water quality that is superior to that required by federal regulations. We provide financial support to the **American Water Works Association Research Foundation** (AWWARF), which funds and publishes the results of many projects every year aimed at improving management and treatment of water and wastewater facilities. We belong to the **Association of Metropolitan Water Agencies** (AMWA), whose membership is limited to utilities with at least 50,000 customer accounts. We are also members of the **American Membrane Technology Association** (AMTA), and the **Water Environment Federation** (WEF).

.

ŝ

ý

Locally, the City provides financial and technical support to the regional **Hampton Roads Planning District Commission** (HRPDC), which coordinates many research, public education and information programs. Some of these programs are the Hampton Roads Water Efficiency Team (HR WET), Hampton Roads Stormwater (HR Storm), Hampton Roads Clean (HR Clean), the Groundwater Committee, the Water Supply Committee, and Help 2 Others (H2O). We are members of the Hampton Roads Utility and Heavy Contractors Association (HRUHCA) and the Virginia Cross-Connection Control Association (VCCCA)

The City of Chesapeake's "The City That Cares" motto is recognized by Public Utilities in meeting the needs of both external and internal customers. In cooperation with other City departments the Customer Contact Center began operations in July 2005. It provides a new, easier way for citizens to contact us with concerns and questions. Call 382-CITY (2489) or go on line at <u>www.CityOfChesapeake.net</u> and click on the C3 logo. For routine turn-on or turn-off services, Public Utilities' Customer Service section stands ready at 382-6352.

Reliability Comes from Many Sources

Chesapeake is fortunate to have two treatment plants and contracts to purchase treated water from the cities of Norfolk and Portsmouth. Additional water is available from an auxiliary well source that is used during peak demands. These sources are described below.



The City's Northwest River Water Treatment Plant, located at 3550 South Battlefield Boulevard, treats up to 10 million gallons a day (MGD) from the Northwest River. The plant also treats brackish ground water from four wells located along South Battlefield Boulevard. The plant's capabilities include both the conventional processes of coagulation, sedimentation, and filtration as well as reverse osmosis (RO) membrane treatment. This supply generally serves customers south of Military Highway, but is subject to periodic adjustment depending on consumption patterns.

In April 2006, the Lake Gaston Water Treatment Plant was dedicated. It provides 8 MGD of new water for the City. The plant is located west of the Hampton Roads Airport on Virginia Route 58. The plant is currently treating raw water purchased from Norfolk. Treatment is provided using ultrafiltration technology with low pressure. Upgrades to the Lake Gaston plant will allow treatment of the 1/6 portion of Lake Gaston raw water in the future. With this added source, we expect to meet our projected water demands to the year 2040. Customers in the Indian River and South Norfolk areas, north of Military Highway, receive treated water from the city of Norfolk. Water customers in Western Branch and Deep Creek, north of Military Highway, receive treated water from the city of Portsmouth. These sources are of excellent quality and also meet or exceed the SDWA standards.

The Western Branch Auxiliary Source is located near the Hampton Roads Airport. This source consists of groundwater from Wells #1 and #3 and the Aquifer Storage and Recovery (ASR) well. These wells serve a dual purpose. Fluoride occurs naturally in the native water; so the wells are used to provide natural fluoridation to the treated water. In addition, the Auxiliary Source is used to meet peak demand when necessary. When in use this water is blended with Lake Gaston treated water before entering the distribution system.

A private water company, Aqua Virginia, Inc., has a franchise area in the Norfolk Highlands neighborhood, which serves approximately 450 customers. The Aqua Virginia, Inc. customer service number is 1-800-537-4865.

Spotlight Water-Saving Tips — Help Yourself to Savings

Using our drinking water responsibly and in smart ways will lead to preserving supplies and possibly save you money. When you use less hot water you will save on the costs to heat the water. You may be surprised at the results of knowing how and where you use this precious natural resource. Here are some easy water-wise tips:

- Fix leaks
- · Wash only full loads of laundry and dishes
- Take shorter showers
- · Turn the water off while brushing teeth or shaving
- · Slow the flow to what you really need for the job
- Install water-saving aerators on faucets and tank dams on toilets
- Mulch around plants and shrubs
- Lawns need only 1" of water a week; if nature provides, turn off the sprinklers
- Water the lawn and garden in the early morning or evening

APPENDIX K Water Storage Requirement for Alternative 2

Community System Flows

| Per Diem Water Use | nes (ERC ¹) Gallons | 1 400 | 3 400 | 15 400 | 42 400 | 34 400 | 5 400 | 100 400 |
|--------------------|---------------------------------|----------|------------|-------------|--------|------------|------------------------|-----------|
| | # of Hon | Fentress | Blue Ridge | Centerville | Murray | Whittamore | Unaccounted Additional | Summation |

| | /day) typ | | | (Using Peak Factor of 3 00) | (Using Peak Factor of 3 00) | (Using Peak Factor of 6 00) | (Using Peak Factor of 6 00) | Using VDH equation (below) |
|---------------------------------|---------------------|---------|---------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|----------------------------|
| | (Gallons/connection | avg gpd | avg gpm | (max day) gpd | (max day) gpm | (peak hour) gpd | (peak hour) gpm | (peak hour) gpm |
| ŝ | 400 00 | 40,000 | 27 78 | 120,000 | 83 33 | 240,000 | 166 67 | 139 61 |
| Daily Pumpa | | | | | | | | |
| Service Connections Daily Pumpa | 100 | | | | | | | |





| page | avg gpd | (max day) gpd | (peak hour) gpd | |
|---------------------|---------|---------------|-----------------|--|
| Projected Daily Pum | 40,000 | 120,000 | 201,033 | |



 $= 11.4 \times N^{0.554}$





(sum of check marked entries)

000 gallons

Total Storage Required

¹ Equivalent Residential Connection

² The amount of emergency storage included within a particular water distribution system is an owner option based on an assessment of risk and the desired degree of system dependability. An assessment must be made of the type and nature of emergency conditions, including their frequency, intensity, and duration

APPENDIX L City of Chesapeake Public Utility Charges

Public Utilties Charges

A. Monthly Minimum Charges:

The minimum monthly charges includes 300 cubic feet (ccf)* of water.

| | | WATER | | | SEWER | | CO | MBINED | |
|------------|-----------------------|-----------------------|-----------------------|-----------------------|-----------------------|-----------------------|-----------------------|-----------------------|--------------------|
| meter size | Effective 1/1/2007 | Effective 7/1/2008 | Effective 7/1/2010 | Effective 1/1/2007 | Effective 1/1/2008 | Effective 1/1/2010 | Effective 1/1/2007 | Effective 1/1/2008 | Effectiv 1/1/20 |
| 5/8 | \$16.50 | \$17.50 | \$18.50 | \$6.95 | \$7.95 | \$8.95 | \$23.45 | \$25.45 | \$27.45 |
| 3/4 | \$18.15 | \$19.25 | \$20.35 | \$7.95 | \$8.75 | \$9.85 | \$26.10 | \$28.00 | \$30.20 |
| 1 | \$23.10 | \$24.50 | \$25.90 | \$9.73 | \$11.13 | \$12.53 | \$32.83 | \$35.63 | \$38.43 |
| 1 1/2 | \$29.70 | \$31.50 | \$33.30 | \$12.51 | \$14.31 | \$16.11 | \$42.21 | \$45.81 | \$49.41 |
| 2 | \$47.85 | \$50.75 | \$53.65 | \$20.16 | \$23.06 | \$25.96 | \$68.01 | \$73.81 | \$79.61 |
| 3 | \$181.50 | \$192.50 | \$203.50 | \$76.45 | \$87.45 | \$98.45 | \$257.95 | \$279.95 | \$301.95 |
| 4 | \$231.00 | \$245.00 | \$259.00 | \$97.30 | \$111.30 | \$125.30 | \$328.30 | \$356.30 | \$384.30 |
| 6 | \$346.50 | \$367.50 | \$388.50 | \$145.95 | \$166.95 | \$187.95 | \$492.45 | \$534.45 | \$576.45 |
| 8 | \$478.50 | \$507.50 | \$536.50 | \$201.55 | \$230.55 | \$259.55 | \$680.05 | \$738.05 | \$796.05 |
| 10 | \$627.00 | \$665.00 | \$703.00 | \$264.10 | \$302.10 | \$340.10 | \$891.10 | \$967.10 | \$1,043.10 |

B. Charges for usage over 300 ccf:

| \$3.578 | \$3.878 | \$4.178 | \$1.789 | \$2.554 | \$3.971 | \$5.367 | \$6.432 | \$8.149 |
|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | | | | | | | | |

* 100 ccf = 748 gallons

300 ccf = 2,244 gallons

C. How is the bill calculated?

RESIDENTIAL:

Most residential homes have a 5/8 inch water meter and are billed every two months.

Example 1

A customer uses 6 ccf. In two months

*46.90 - The combined minimum monthly bill for water and sewer services is \$23.45; multiply by 2 (the bill covers 2 months) = \$46.90
 - The minimum charge includes 3 ccf a month. A bill for two months would include 6 ccf.

Example 2

A customer uses 18 ccf. in two months

- \$46.90 The combined minimum monthly bill for water and sewer services is \$23.45; multiply by 2 = \$46.90
- <u>\$64.40</u> The minimum charge includes 3 ccf a month. A bill for two months would include 6ccf. The remaining 12 ccf (18ccf 6ccf) would be charged at \$5.367 per ccf.
- \$111.30

COMMERCIAL:

Many commercial customers have larger meters and are billed every month.

Example 1

4

The customer has a 2 inch meter and uses 18 ccf in one month

\$68.01 - The combined minimum monthly bill for water and sewer services for a 2 inch meter

\$80.51 - The minimum charge includes 3ccf a month. The remaining 15 ccf (18 ccf - 3 ccf) would be charged at \$5.367 per ccf. \$148.52

5/16/2007 MAM

APPENDIX M Reverse Osmosis for Community Water System

SIEMENS

January 21, 2009

Riordan Materials Corporation 8712 Inwood Road Baltimore, MD 21244

Attn: Mr. Thomas Rainier

 Reference:
 URS Confidential Client Reverse Osmosis/Nanofiltration Application

 Equipment:
 Vantage M84-024RO Vantage M83-006RO Pretreatment for Iron and Manganese

 Quote #:
 09PS4202GFM

Dear Mr. Rainier:

This letter includes budgetary pricing and information for the proposed application using reverse osmosis (RO) submitted by URS Engineers for a confidential client. Our recommendations are based on water quality data that we received from you via email.

We have attached computer models of the NF/RO system performance. Overall, this system would be very effective at removing dissolved contaminants with a recovery of approximately 92% for the primary and secondary RO.



Vantage M84 System

The following is the budgetary pricing and information offered regarding the above referenced project:

| Equipment | Capacity (permeate, gpm) | Budget Price |
|--|--------------------------|--------------|
| One (1) Vantage M84-024RO - Primary | 100 | \$137,600.00 |
| One (1) Vantage M83-006RO - Secondary | 24 | \$ 90,100.00 |

Estimated Delivery: 12-14 weeks after receipt of approval drawings

Siemens Water Technologies Corp.

100 Highpoint Drive, Suite 101 Chalfont, PA 18914 Tel: 215-712-7040 Fax: 215-996-1156

Equipment Furnished:

Vantage M units are pre-piped and skid mounted on a painted steel skid with the following with each system:

- Membrane elements as manufactured by DOW FILMTEC[™], either NF90-400 (primary) or LE400 (secondary). **MEMBRANE ELEMENTS ARE FIELD INSTALLED.**
- FRP membrane housings adequate for above membranes.
- Control panel with Siemens PLC controller and Siemens touch screen Human Machine Interface (HMI).
- Schedule 10 316L Stainless Steel high pressure piping.
- Schedule 80 PVC low pressure piping.
- Stainless steel pre-filter housing with first 2 sets of cartridge filters (about 1 month worth).
- Booster pump.
- Manual and automatic control valves.
- Instrumentation including flow meters/transmitters, pH and ORP meters, conductivity and pressure gauges.
- Product water divert line for wasting of below-quality water during startup.
- Reject flush line for flushing of system with raw water for shutdown.
- Raw water blend line including diaphragm valve and rotameter (on primary unit only).
- Air compressor with receiver and starter panel for automatic valve operation.
- Polyethylene CIP makeup tank with CIP hose kit (included with first skid only, additional skids will share the same tank and hose kit).
- Freight to the jobsite.
- Technical direction during plant installation, membrane loading, start-up and training. See table above for std. time.
- Antiscalant Feed System includes 16 gallon day tank, Grundfos DME series digital pump, rigid suction tubing with low level switch, priming aid, injection valve, alarm cable, communication cable and wall bracket for pump.

Refer to Equipment Lists for exact scope of supply.

Equipment Not Furnished:

Installation and field assembly, interconnecting piping, interconnecting wiring, backwash pumps, motor starters not specifically called out, and finished water storage.

Pretreatment for Iron and Manganese

The client also requested information on pretreatment options for iron and manganese. Per our correspondence, iron and manganese have been detected at 5.0 mg/L and 0.35 mg/L, respectively. Our recommendation for this application is our vertical pressure filter with oxidative media. We have provided pricing and information on a three-tank system. This provides redundancy and reduces the amount of backwash flow required on an instantaneous basis. Due to the relatively high levels of iron and manganese, we recommend running the filters at 2 gpm per square foot loading rate.

Budgetary pricing and information are as follows:

| Equipment | Capacity (gpm) | Budget Price | |
|--------------------------------------|----------------|--------------|--|
| Three (3) 84"-dia. vertical pressure | | | |
| filter vessels with Manganese | 135 | \$187,900.00 | |
| ANTHRA/SAND Media | | | |

Estimated Delivery: 12-14 weeks after receipt of approval drawings

Equipment Furnished:

Scope: (3) tanks, each includes 100 psi working pressure filter tank with supporting legs. Top side inlet connection with overdrain and bottom head effluent connection. Shop installed steel plate underdrain with gravel retaining strainers. Screwed air release connection. One 14" x 18" manhole in top head. One coat of interior and exterior primer, and one coat of interior finish paint. Sch. 40 steel filter face piping with exterior primer coat. Automatic backwash control panel, NEMA 12 rated. Pneumatically operated butterfly valves for inlet, backwash waste and effluent. Automatic air release valve and piping. Airwash grid and air blower. 10" of support gravel and 24" of 1.0-1.2 mm LO-d:C Manganese ANTHRA/SAND media. GFC #4879 loss of head gauge and #1639 backwash rate of flow indicator.

Equipment Not Furnished:

Installation, concrete slab work including waste sump, interconnecting piping, chemical feeds, and overall plant operation and controls.

Notes:

- · Prices include technical direction, commission and freight.
- Filter tank size is outside diameter. Straight side shell height is 5'-0".
- Unit capacity ranges based on 2 to 3 gpm/sq.ft. of filter area.

We look forward to working with you on this exciting project. Should you have any questions or require further information, please contact me at (215)712-7040.

Best Regards,

Richard Ross, P.E. Technical Sales Manager, East

Attachments: Equipment lists, sales drawings, brochure, ROSA projections, and specification.

cc: Dave Lucey, Siemens Water Technologies

| CI | | 5 |
|----|----|---|
| 31 | EN | |
| | | |

Vantage™ M83 Reverse Osmosis System Operating Cost Estimate

Note: This operating cost estimate is provided as a courtesy for Siemen Water Technologies customers and is an estimate only. No warrantees are expressed or implied.

| I ocation. | Confidential Virginia | | |
|---|---|--|--|
| Date: | January 21, 2009 | | |
| System Configuration | Water and the second | Operating Cost Summary | |
| Number of Vantage TM Skids: | 1 | PERMEATE PRODUCED | 13 140 000 gallons/vea |
| Vantage Model Number: Membrane Type: Array Configuration: Number of Pressure Vessels: Total Number of Elements: Number of Cartridge Filters: | M83-006 Reverse Osmosis 1:1 3M 2 per skid 6 per skid 4 - 30" per skid | Power Acid Feed Antiscalant Prefilters Membranes Classing | \$2453/year (\$0.187/kga \$0/year (\$0/kga \$4329/year (\$0.329/kga \$333/year (\$0.025/kga \$1495/year (\$0.114/kga |
| | | EST AMNUAL OF COST | \$1332/year (\$0.101/kga |
| System Flow Rates | | Estimated Operating Cests do not include labor, water az | ad sewer charges, CIP pumping costs, or disposal costs. |
| Feed Flow per Skid: | 33 GPM | | |
| Permeate Flow per Skid: | 25 GPM | | |
| Total Feed Flow: | 33 GPM | Operating C | ost Breakdown |
| Total Permeate Flow: | 25 GPM | 12 A | |
| RO System Recovery: | 75% | | |
| Acid Dose Rate: | 0 mg/l H2SO4 | | |
| Antiscalant Feed Rate: | 8 mg/l | Cleaning 13% | Power |
| Operating Times | E | | 25% |
| System Operating Time: | 24 hrs/day | Membranes | |
| Percent Online: | 100% | 15% | Acid Feed |
| Water Temperature: | 70 ºF | | 0% |
| CIP Interval: | 90 days | | |
| Cost Assumptions | | Prefilters 3% | |
| Power Cost: | \$0.06/kwhr | | |
| Acid Cost: | \$3.27/gallon | | |
| Antiscalant Cost: | \$3.22/gallon | | Antiscalant |
| Membrane Element Cost: | \$650/element | | 44% |
| Low pH Clean Solution: | \$39.00/gallon | | |
| | CAE 00/acilian | | |

SIEMENS

Feed Flow per Skid:

Total Feed Flow:

Acid Dose Rate:

Operating Times System Operating Time:

Percent Online:

CIP Interval:

Acid Cost:

Water Temperature:

Cost Assumptions Power Cost:

Antiscalant Cost:

Membrane Element Cost:

Low pH Clean Solution:

High pH Clean Solution:

Permeate Flow per Skid:

Total Permeate Flow:

RO System Recovery:

Antiscalant Feed Rate:

Vantage™ M84 Reverse Osmosis System Operating Cost Estimate

Note: This operating cost estimate is provided as a courtesy for Siemen Water Technologies customers and is an estimate only. No warrantees are expressed or implied.

| Project Name: | Confidential URS, VA | | | | | |
|---------------------------------------|------------------------|--|--|--|--|--|
| Location: | Confidential, Virginia | | | | | |
| Date: | January 21, 2009 | | | | | |
| System Configuration | | Operating Cost Summary | | | | |
| Number of Vantage [™] Skids: | 1 | PERMEATE PRODUCED | 52,560,000 gallons/year | | | |
| Vantage Model Number: | M84-024 | | | | | |
| Membrane Type: | Reverse Osmosis | Power | \$12264/year (\$0.233/kgal) | | | |
| Array Configuration: | 3:2:1 4M | Acid Feed | \$0/year (\$0/kgal) | | | |
| Number of Pressure Vessels: | 6 per skid | Antiscalant | \$4329/year (\$0.082/kgal) | | | |
| Total Number of Elements: | 24 per skid | Prefilters | \$1199/year (\$0.023/kgal) | | | |
| Number of Cartridge Filters: | 7 - 40" per skid | Membranes | \$5980/year (\$0.114/kgal) | | | |
| | | Cleaning | \$3996/year (\$0.076/kgal) | | | |
| | | EST ANNUAL OP COST | \$27768/year (\$0.528/kgal) | | | |
| System Flow Rates | | Estimated Operating Costs do not include labor, water an | d sower charges, CIP pumping costs, or disposal costs. | | | |



Reverse Osmosis System Analysis for FILMTEC[™] Membranes Project: Confidential URSV2 AFZ, Siemens Water Technologies

Project Information: Municipal groundwater source with high levels of Boron. URS would like projections done for a confidential client.

System Details

| Feed | Flow to Stage 1 | | | 34.00 gpn | n | Pass 1 Perme | ate Flow | 23.80 g | pm | Osmotic | Pressure: | | |
|-------|-----------------|-------|------|-------------------------|-------------------------|-------------------------|-----------------------|-------------------------|-----------------------|----------------------|-------------------------|--------------------------|-----------------------|
| Raw Y | Water Flow to S | yster | n | 34.00 gpn | a | Pass 1 Recover | ery | 70.00 9 | % | | Feed | 27.09 ps | ig |
| Feed | Pressure | | | 272.00 psig | s | Feed Tempera | ature | 62.6 H | 7 | 8 | Concentrate | 86.60 ps | ig |
| Fouli | ng Factor | | | 0.85 | | Feed TDS | | 3089.11 r | ng/l | | Average | 56.84 ps | ig |
| Chem | . Dose | | | None | | Number of El | ements | 6 | | Average | NDP | 208.95 ps | ig |
| Total | Active Area | | | 2400.00 ft ² | | Average Pass | 1 Flux | 14.28 g | fd | Power | | 5.03 kV | V |
| Water | Classification: | Well | Wate | r SDI < 3 | | | | | | Specific | Energy | 3.52 kV | Vh/kgal |
| Stage | Element | #PV | #Ele | Feed Flow (gpm) | Feed Press (psig) | Recirc Flow (gpm) | Conc Flow (gpm) | Conc Press (psig) | Perm Flow (gpm) | Avg Flux (gfd) | Perm Press (psig) | Boost Press (psig) | Perm TDS (mg/l) |
| 1 | BW30-400/34i | 1 | 3 | 34.00 | 267.00 | 0.00 | 19.16 | 262.43 | 14.84 | 17.80 | 0.00 | 0.00 | 17.64 |
| 2 | BW30-400/34i | 1 | 3 | 19.16 | 257.43 | 0.00 | 10.20 | 255.61 | 8.96 | 10.76 | 50.00 | 0.00 | 51.07 |

| | | | Pass Streams (mg/l as Ion) | | | | |
|-------|---------|----------------|-------------------------------|----------|----------|---------|-------|
| Norma | End | Advanted Freed | Conce | ntrate | Permeate | | |
| Name | Feed | Adjusted Feed | Stage 1 | Stage 2 | Stage 1 | Stage 2 | Total |
| NH4 | 3.30 | 3.30 | 5.83 | 10.88 | 0.03 | 0.08 | 0.05 |
| К | 58.40 | 58.40 | 103.32 | 193.14 | 0.37 | 1.10 | 0.64 |
| Na | 668.50 | 668.50 | 1182.73 | 2211.01 | 4.23 | 12,43 | 7.32 |
| Mg | 83.20 | 83.20 | 147.36 | 276.04 | 0.32 | 0.91 | 0.54 |
| Ca | 169.40 | 169.40 | 300.06 | 562.12 | 0.62 | 1.80 | 1.07 |
| Sr | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Ba | 0.10 | 0.10 | 0.18 | 0.33 | 0.00 | 0.00 | 0.00 |
| CO3 | 5.29 | 5.29 | 16.19 | 49.07 | 0.00 | 0.00 | 0.00 |
| HCO3 | 868.10 | 868.10 | 1521.48 | 2804.83 | 6.32 | 17.79 | 10.63 |
| NO3 | 0.20 | 0.20 | 0.34 | 0.58 | 0.02 | 0.06 | 0.04 |
| Cl | 1079.90 | 1080.71 | 1913.27 | 3580.68 | 5.24 | 15.55 | 9.12 |
| F | 0.80 | 0.80 | 1.41 | 2.64 | 0.01 | 0.02 | 0.01 |
| SO4 | 53.70 | 53.70 | 95.17 | 178.48 | 0.13 | 0.36 | 0.21 |
| SiO2 | 97.40 | 97.40 | 172.53 | 323.28 | 0.35 | 0.96 | 0.58 |
| Boron | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| CO2 | 20.11 | 20.11 | 24.38 | 35.84 | 20.95 | 26.85 | 23.18 |
| TDS | 3088.29 | 3089.11 | 5459.89 | 10193.09 | 17.64 | 51.07 | 30.22 |
| pН | 7.70 | 7.70 | 7.81 | 7.85 | 5.74 | 6.06 | 5.91 |

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume liability for results obtained or damages incurred from the application of this information. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Design Warnings

WARNING: Maximum element recovery has been exceeded. Please change your system design to reduce the element recoveries. (Product: BW30-400/34i, Limit: 19.00%)

CAUTION: The concentrate flow rate is less than the recommended minimum flow. Please change your system design to increase concentrate flow rates. (Product: BW30-400/34i, Limit: 13.00gpm)

Solubility Warnings

Langelier Saturation Index > 0 Stiff & Davis Stability Index > 0 BaSO4 (% Saturation) > 100% CaF2 (% Saturation) > 100% SiO2 (% Saturation) > 100% Antiscalants may be required. Consult your antiscalant manufacturer for dosing and maximum allowable system recovery.

Stage Details

| Stage 1 | Element | Recovery | Perm Flow (gpm) | Perm TDS (mg/l) | Feed Flow (gpm) | Feed TDS (mg/l) | Feed Press (psig) |
|---------|-------------------|--------------------------|---------------------------------|-----------------------------------|-----------------------------------|---------------------------------------|---------------------------------------|
| | 1 | 0.15 | 5.17 | 13.46 | 34.00 | 3089.11 | 267.00 |
| | 2 | 0.17 | 4.96 | 17.17 | 28.83 | 3640.06 | 265.04 |
| | 3 | 0.20 | 4.70 | 22.76 | 23.86 | 4392.09 | 263.54 |
| | | | | | | | |
| Stage 2 | Element | Recovery | Perm Flow (gpm) | Perm TDS (mg/l) | Feed Flow (gpm) | Feed TDS (mg/l) | Feed Press (psig) |
| Stage 2 | Element 1 | Recovery 0.18 | Perm Flow (gpm) 3.37 | Perm TDS (mg/l) 36.61 | Feed Flow (gpm) 19.16 | Feed TDS (mg/l) 5459.89 | Feed Press (psig) 257.43 |
| Stage 2 | Element 1 2 | Recovery 0.18 0.19 | Perm Flow (gpm) 3.37 3.02 | Perm TDS (mg/l) 36.61 49.85 | Feed Flow (gpm) 19.16 15.80 | Feed TDS (mg/l) 5459.89 6611.76 | Feed Press (psig) 257.43 256.63 |

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume liability for results obtained or damages incurred from the application of this information. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Scaling Calculations

| | Raw Water | Adjusted Feed | Concentrate |
|-------------------------------|-----------|---------------|-------------|
| pH | 7.70 | 7.70 | 7.85 |
| Langelier Saturation Index | 1.04 | 1.04 | 2.19 |
| Stiff & Davis Stability Index | 1.07 | 1.07 | 1.76 |
| Ionic Strength (Molal) | 0.05 | 0.05 | 0.18 |
| TDS (mg/l) | 3088.29 | 3089.11 | 10193.09 |
| HCO3 | 868.10 | 868.10 | 2804.83 |
| CO2 | 20.11 | 20.11 | 35.82 |
| CO3 | 5.29 | 5.29 | 49.07 |
| CaSO4 (% Saturation) | 1.19 | 1.19 | 5.57 |
| BaSO4 (% Saturation) | 80.00 | 80.00 | 260.06 |
| SrSO4 (% Saturation) | 0.00 | 0.00 | 0.00 |
| CaF2 (% Saturation) | 14.41 | 14.41 | 520.66 |
| SiO2 (% Saturation) | 89.36 | 89.36 | 297.86 |
| Mg(OH)2 (% Saturation) | 0.01 | 0.01 | 0.05 |

To balance: 0.81 mg/l Cl added to feed.

GENERAL FILTER THREE UNIT MANGANESE GREENSAND VERTICAL FILTER BATTERY STANDARD FLANGED PIPING





- NOTE: ON JOBS WHERE PRESSURE AERATION OCCURS BEFORE FILTRATION, THERE NEEDS TO BE A PROVISION MADE FOR AIR RELEASE IN THE HIGHEST POINT OF THE INLET PIPING.
- NOTE: FILTER PIPING SHOWN DASHED IS PROVIDED BY OTHERS UNLESS SPECIFICALLY QUOTED.

| NOTE | : CONFIGURA | TION SHOWN | IS STANDARD | REF. DATA | SHEET D- | 22.00A,B |
|--------------------|-------------------|-------------------|-------------------------|----------------|-------------------|----------------------------|
| FILTER DIAMETER | INFLUENT VALVE | EFFLUENT VALVE | BACKWASH WASTE VALVE | DRAIN VALVE | AIR WASH VALVE | BACKWASH RATE SET VALVE |
| 84" | 6" | 6" | 6" | 3" | 2.5" | 6" |



A-28512-2 REV. 1-3-07

ROSA Detailed Report

Reverse Osmosis System Analysis for FILMTEC[™] Membranes Project: Confidential URSV2 AFZ, Siemens Water Technologies

39.64

64.14

0.00

0.00

329.14

Project Information: Municipal groundwater source with high levels of Boron. URS would like projections done for a confidential client.

System Details

3

NF90-400

1 4

| Feed | Flow to Sta | ge 1 | | 133 | .33 gpm | Pass 1 F | ermeate Flo | w 100 |).01 gpm | Osm | notic Pressure | e: | | |
|--------|-------------|-------|--------|--------------------|----------------------|----------------------|--------------------|----------------------|--------------------|-------------------|----------------------|-----------------|--------------|-------------------|
| Raw V | Water Flow | to S | ystem | 133. | .33 gpm | Pass 1 F | Recovery | 75 | 5.01 % | | 1 | Feed 10. | 72 ps | sig |
| Feed I | Pressure | | | 105 | .22 psig | Feed Te | mperature | 6 | 52.6 F | | Concen | trate 38. | 82 ps | sig |
| Fouli | ng Factor | | | 0. | .85 | Feed TI | DS | 1188 | 8.35 mg/l | | Ave | rage 24. | 77 ps | ig |
| Chem | . Dose | | | No | one | Number | of Element | S | 24 | Ave | rage NDP | 58. | 91 ps | ig |
| Total | Active Are | a | | 9600. | .00 ft ² | Average | Pass 1 Flux | c 15 | 5.00 gfd | Pow | er | 7. | 53 k\ | N |
| Water | Classificat | tion: | Well V | Water SDI < | : 3 | | | | | Spec | cific Energy | 1. | 27 kN | Wh/kgal |
| Stage | Element | #PV | #Ele | Feed Flow (gpm) | Feed Press (psig) | Recirc Flow (gpm) | Conc Flow (gpm) | Conc Press (psig) | Perm Flow (gpm) | Avg Flux (gfd) | Perm Press (psig) | Boost Pr (ps | ess P ig) | erm TDS (mg/l) |
| 1 | NF90-400 | 3 | 4 | 133.33 | 100.22 | 0.00 | 66.98 | 85.06 | 66.35 | 19.90 | 0.00 | 0 | 00 | 48.13 |
| 2 | NF90-400 | 2 | 4 | 66.98 | 80.06 | 0.00 | 39.64 | 69.14 | 27.35 | 12.31 | 0.00 | 0 | 00 | 127.70 |

33.32

46.96

6.32

5.69

| | Pass Streams (mg/l as lon) | | | | | | | | | | | |
|-------|-------------------------------|-----------------|---------|-------------|---------|----------|---------|---------|-------|--|--|--|
| Name | Fred | A directed Good | (| Concentrate | | Permeate | | | | | | |
| Name | Name Feed | Adjusted Feed | Stage 1 | Stage 2 | Stage 3 | Stage 1 | Stage 2 | Stage 3 | Total | | | |
| NH4 | 1.30 | 1.30 | 2.49 | 4.04 | 4.70 | 0.10 | 0.24 | 0.58 | 0.17 | | | |
| K | 22.74 | 22.74 | 44.05 | 72.14 | 84.17 | 1.23 | 3.32 | 8.71 | 2.27 | | | |
| Na | 259.88 | 259.89 | 503.70 | 826.03 | 965.00 | 13.73 | 36.47 | 93.68 | 25.00 | | | |
| Mg | 31.40 | 31.40 | 61.84 | 103.27 | 122.00 | 0.67 | 1.78 | 4.56 | 1.22 | | | |
| Ca | 63.89 | 63.89 | 125.85 | 210.23 | 248.38 | 1.33 | 3.54 | 9.21 | 2.43 | | | |
| Sr | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | | | |
| Ba | 0.03 | 0.03 | 0.05 | 0.09 | 0.10 | 0.00 | 0.00 | 0.00 | 0.00 | | | |
| CO3 | 0.69 | 0.69 | 2.94 | 8.37 | 11.60 | 0.00 | 0.00 | 0.01 | 0.00 | | | |
| HCO3 | 331.00 | 331.00 | 648.43 | 1075.34 | 1266.37 | 7.40 | 19.59 | 51.22 | 13.48 | | | |
| NO3 | 0.11 | 0.11 | 0.14 | 0.16 | 0.17 | 0.08 | 0.11 | 0.14 | 0.09 | | | |
| Cl | 420.00 | 420.00 | 813.84 | 1334.34 | 1558.67 | 22.37 | 59.34 | 152.20 | 40.68 | | | |
| F | 0.30 | 0.30 | 0.58 | 0.93 | 1.09 | 0.02 | 0.06 | 0.14 | 0.04 | | | |
| SO4 | 20.00 | 20.00 | 39.66 | 66.73 | 79.19 | 0.15 | 0.41 | 1.07 | 0.28 | | | |
| SiO2 | 37.00 | 37.00 | 72.61 | 120.73 | 142.20 | 1.05 | 2.85 | 7.62 | 1.96 | | | |
| Boron | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | | | |
| CO2 | 17.70 | 17.70 | 18.65 | 20.81 | 21.98 | 17.82 | 19.12 | 20.92 | 18.38 | | | |
| TDS | 1188.34 | 1188.35 | 2316.16 | 3822.42 | 4483.65 | 48.13 | 127.70 | 329.14 | 87.63 | | | |
| pН | 7.40 | 7.40 | 7.63 | 7.76 | 7.79 | 5.86 | 6.23 | 6.58 | 6.09 | | | |

0.00

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume liability for results obtained or damages incurred from the application of this information. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

ROSA Detailed Report

Reverse Osmosis System Analysis for FILMTEC[™] Membranes Project: Confidential URSV2 AFZ, Siemens Water Technologies

Design Warnings

-None-

Solubility Warnings

Langelier Saturation Index > 0 Stiff & Davis Stability Index > 0 SiO2 (% Saturation) > 100%

Antiscalants may be required. Consult your antiscalant manufacturer for dosing and maximum allowable system recovery.

Stage Details

| Stage 1 | Element | Recovery | Perm Flow (gpm) | Perm TDS (mg/l) | Feed Flow (gpm) | Feed TDS (mg/l) | Feed Press (psig) |
|---------|---------|----------|-----------------|-----------------|-----------------|-----------------|-------------------|
| | 1 | 0.14 | 6.25 | 33.15 | 44.44 | 1188.35 | 100.22 |
| | 2 | 0.15 | 5.75 | 41.70 | 38.20 | 1377.09 | 95.02 |
| | 3 | 0.16 | 5.29 | 53.27 | 32.45 | 1613.62 | 90.85 |
| | 4 | 0.18 | 4.83 | 69.55 | 27.16 | 1917.13 | 87.58 |
| Stage 2 | Element | Recovery | Perm Flow (gpm) | Perm TDS (mg/l) | Feed Flow (gpm) | Feed TDS (mg/l) | Feed Press (psig) |
| | 1 | 0.12 | 4.10 | 89.86 | 33.49 | 2316.16 | 80.06 |
| | 2 | 0.12 | 3.64 | 113.14 | 29.39 | 2626.23 | 76.53 |
| | 3 | 0.12 | 3.19 | 143.84 | 25.76 | 2980.39 | 73.59 |
| | 4 | 0.12 | 2.75 | 184.71 | 22.57 | 3380.01 | 71.16 |
| Stage 3 | Element | Recovery | Perm Flow (gpm) | Perm TDS (mg/l) | Feed Flow (gpm) | Feed TDS (mg/l) | Feed Press (psig) |
| | 1 | 0.05 | 2.12 | 241.64 | 39.64 | 3822.42 | 64.14 |
| | 2 | 0.05 | 1.73 | 302.07 | 37.52 | 4024.37 | 59.41 |
| | 3 | 0.04 | 1.38 | 379.29 | 35.79 | 4203.52 | 55.02 |
| | 4 | 0.03 | 1.09 | 478.47 | 34.41 | 4356.98 | 50.89 |

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume liability for results obtained or damages incurred from the application of this information. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

ROSA Detailed Report

Scaling Calculations

| | Raw Water | Adjusted Feed | Concentrate |
|-------------------------------|-----------|---------------|-------------|
| pH | 7.40 | 7.40 | 7.79 |
| Langelier Saturation Index | -0.07 | -0.07 | 1.46 |
| Stiff & Davis Stability Index | 0.31 | 0.31 | 1.34 |
| Ionic Strength (Molal) | 0.02 | 0.02 | 0.08 |
| TDS (mg/l) | 1188.34 | 1188.35 | 4483.65 |
| HCO3 | 331.00 | 331.00 | 1266.37 |
| CO2 | 17.70 | 17.70 | 21.98 |
| CO3 | 0.69 | 0.69 | 11.60 |
| CaSO4 (% Saturation) | 0.26 | 0.26 | 2.03 |
| BaSO4 (% Saturation) | 17.14 | 17.14 | 80.78 |
| SrSO4 (% Saturation) | 0.00 | 0.00 | 0.00 |
| CaF2 (% Saturation) | 0.76 | 0.76 | 38.93 |
| SiO2 (% Saturation) | 33.94 | 33.94 | 130.46 |
| Mg(OH)2 (% Saturation) | 0.00 | 0.00 | 0.02 |

To balance: 0.01 mg/l Na added to feed.

÷

Vantage[™] M84 units are packaged single-pass 8-inch reverse osmosis units designed for a variety of applications requiring high quality equipment with a fast delivery and competitive price.These pre-engineered, pre-assembled and factory tested units minimize installation and start-up time. With simple utility connections and easy to set up controls, the unit is ready for quick on-line service.

The Vantage[™] M84 unit comes with a user friendly touch screen Human Machine Interface (HMI), Variable Frequency Drive (VFD) for flow control, built in Clean In Place (CIP) function, and pH/ORP monitoring.

The unit features an "On-Board" integrated cleaning system (CIP) initiated through the HMI. The CIP system includes plumbing to the on-skid RO cartridge filter housing and VFD controlled pump along with the factory supplied valves, hoses, and a polyethylene CIP tank (off-skid).

VANTAGE™ M84 UNIT BENEFITS:

- · Compact footprint saves valuable floor space
- · Quick equipment delivery keeps project moving fast
- Clean in place connections maximize system serviceability
 Comprehensive factory testing performed at our ISO9001 certified facility
- FilmTec's iLEC[®] interlocking endcaps, an innovative element coupling technology that significantly enhances the performance of RO systems

Water Technologies

Vantage[™] M84 Reverse Osmosis Units

The Clear Advantage In Membrane Systems

SIEMENS

STANDARD M84 UNIT FEATURES:

- Choice of brackish water or low energy TFC membranes (400 ft²) to ensure optimum water quality
- High pressure 316 stainless steel vertical multistage feed pump
- ASME Code FRP, RO pressure vessels with ASME pressure relief protection
- PVC low pressure feed, product and reject piping, 316L stainless steel high pressure piping
- Urethane coated carbon steel frame rated for Seismic Zone 4 anchorage
- Dry contacts are provided for chemical feed, pretreatment equipment, storage tank levels, and pressure switches
- All alarm and shut down conditions are indicated on the control interface


Specifications

| Model No** | Flow Ra GPM N | te Specific Nominal (n | cations n³/hr) | Vessel Staging | Membrane/ Vessel | Membrane Quantity | Custor | ner Con ecificati | nection ions | Utility Re High Voltage | High Voltage | Pump | Approx. Shipping Weight |
|---------------|------------------|---------------------------|-------------------|-------------------|---------------------|----------------------|--------|----------------------|-----------------|-------------------------------|-----------------|------|-------------------------------|
| | Product* | Feed | Reject | | | | Feed | Product | Reject | Service | FLA | HP | Ib (kg) |
| M84R024 | 100(22.7) | 134(30.4) | 34(7.7) | 3:2:1 | 4 | 24 | 3" | 3″ | 2* | 480 VAC 3 ph | 36 | 25 | 5400 (2449) |
| M84R036 | 150(34.1) | 200(45.4) | 50(11.4) | 4:3:2 | 4 | 36 | 4" | 4" | 2" | 480 VAC 3 ph | 67 | 50 | 5750 (2608) |
| M84R048 | 200(45,4) | 267(60.6) | 67(15.2) | 6:4:2 | 4 | 48 | 4* | 4" | 2" | 480 VAC 3 ph | 67 | 50 | 6100 (2767) |

*Product flow rates are based on a flux rate of 15 GFD and equipment design parameters listed below. Product flow rates may not be appropriate for other feed waters.
**The 8 designates 8* housing, the 4 designates 4 elements in length, and the -RXXX designates the number of membranes.
***Additional voltage options are available. Refer to equipment specifications.

Dimensions



Model Features

| Component | Description | | | | | |
|--------------------------------------|--|--|--|--|--|--|
| Controls | Siemens PLC | | | | | |
| HMI | 6" Color Touch Screen | | | | | |
| Inputs/Outputs | Discrete 24 point (14 input/ 10 output) | | | | | |
| I/O Expansion Capability | Yes | | | | | |
| Communication Port | PLC-RS485/HMI-Ethernet | | | | | |
| Remote Monitoring/Communications* | Optional Modules | | | | | |
| Flow Monitoring | Paddlewheel to PLC (feed/reject) | | | | | |
| Conductivity | Signet Multiparameter | | | | | |
| Auto-Flush (Standby) | Yes | | | | | |
| Visual/Audible Alarm | Yes | | | | | |
| Single Power Drop (460/575 VAC) | Yes | | | | | |
| 304LSS Pre-Filter Housing | Yes | | | | | |
| Product Divert Kit | Yes | | | | | |
| Variable Frequency Drive (VFD) Pump | Yes | | | | | |
| On-Board CIP (Tank off-skid) | Yes | | | | | |
| ORP/pH with alarms | Yes | | | | | |
| Product Blend Kit | Yes | | | | | |
| Low Energy Membranes (Cold Water) | Optional | | | | | |

*Additional communication modules and remote monitoring capabilities available upon request.

Design Parameters:

| Feed Water Source | Well or Pretreated |
|---|--|
| Maximum Turbidity | 1 NTU |
| Maximum Free Chlorine and/or chloramine | <0.1 PPM |
| Feed Water Fouling Index | Silt Density Index (SDI) <3 |
| Design Feed Water Temperature | 65*F (18.3*C) |
| Inlet Pressure Requirements | 30-60 PSIG |
| Product Pressure Available | 10 PSIG |
| System Recovery (Nominal) | 75% |
| Performance Basis | A specific computer projection must be run for each individual application. |

*Lower temperature may require larger booster pump or use of low energy membranes: If any of the feed water parameters are not within the limits given, contact Siemens Water Technologies Technical Support. The information provided in this brochure contains merely general descriptions or characteristics of performance which in actual case of use do not always apply as described or which may change as a result of further development of the products. An obligation to provide the respective characteristics shall only exist if expressly agreed in the terms of contract.

Vantage is a trademark of Siemens, its subsidiaries or affiliates. iLEC is a trademark of FilmTec Corporation, a wholly owned subsidiary of The Dow Chemical Company..

Siemens Water Technologies 600 Arrasmith Trail Arnes, IA 50010 Phone: 515-268-8400 Fax: 515-268-8500 www.siemens.com/water

EQUIPMENT LIST VANTAGE™ M84 REVERSE OSMOSIS SYSTEM

Confidential URS, VA

Equipment Supplied by Siemens Water Technologies

One (1) Vantage M84 Reverse Osmosis Membrane Skid: Model M84-024, rated for 100 GPM permeate. The skid would be in the 3:2:1 configuration using 8" diameter x 4 membrane long 4M FRP pressure vessels. The operating weight of the skid is approximately 7,200 lbs. The skid measures 18 feet 10 inches long by 4 feet 6 inches wide by 7 feet 9 inches high, outside dimensions. The skid is painted steel construction and has the following prepiped and installed on the skid:

<u>FRP Membrane Vessels</u>: Six (6) Protec model PRO-8-300 FRP membrane vessels arranged in a 3:2:1 configuration for housing the membrane elements. The vessels are rated for 300 psi, are ASME code stamped and are NSF 61 approved for contact with potable water. Connections to the vessels are stainless steel grooved side entry type for feed and concentrate connections.

<u>Piping</u>: High pressure skid piping will be constructed from welded, schedule 10 Type 316L stainless steel. Low pressure piping will be constructed from schedule 80 PVC.

<u>Prefilter Housing</u>: One (1) prefilter housing constructed of 304L stainless steel. The size of the prefilter shall be 7Rx4H.

<u>Booster Pump</u>: One (1) with stainless steel housing and 25 hp, 460V, 3ph, 60 Hz TEFC motor. The pump is a Grundfos CRN Series.

Automatic Control Valves:

Inlet Valve: One (1) per skid, butterfly type with pneumatic actuator.

Auto Flush Valve: One (1) per skid, ball type, 316 SS, with pneumatic actuator.

<u>Product Isolation Valve</u>: One (1) per skid, butterfly type, with fail-to-close pneumatic actuator.

<u>Product to Drain Valve</u>: One (1) per skid, butterfly type, with fail-to-open pneumatic actuator.

Manual Valves:

Pump Throttling Valve: One (1) per skid, ball type, 316 SS, with locking manual actuator.

Reject Throttling Valve: One (1) per skid, globe valve, 316 SS, with manual actuator.

<u>Blend Line Valve</u>: One (1) per skid, diaphragm type, PVC construction with manual handwheel actuator.

Miscellaneous Valves:

<u>Sample Valves</u>: One (1) set ¹/₄" PVC sample valves for feed water, product connections on each pressure vessel and a combined product sample.

Sample Valve: One (1) 1/4" 316 stainless steel plug valve for high pressure feed sampling.

<u>Pressure Relief</u>: One (1) per skid, relief valve with ASME certified carbon steel body with stainless steel trim and Viton soft seat.

Controls:

<u>Skid Control Panel</u>: One (1) skid mounted NEMA 12 enclosure per skid, with Siemens operator interface terminal, relays, lights, and switches controlled by a Siemens programmable controller. The panel will have discrete interlocks for integration with additional skids, chemical prefeed and external run and stop signals. An HMI will be provided consisting of a Siemens model TP177B with 6" diagonal color touch screen. In addition, the PLC will have an Ethernet connection module that will allow remote communication with the skid.

<u>Variable Frequency Drive (VFD)</u>: One (1) solid state variable frequency motor drive for the booster pump continuously adjustable over a range of 10 to 1. The VFD shall be mounted in the instrument control panel.

<u>Pressure Gauges</u>: Pressure gauges are 316 stainless steel bourdon tube and socket type with glycerin filled dial. Pressure gauges shall be provided for:

- cartridge prefilter inlet
- prefilter outlet
- booster pump discharge
- membrane housing inlet
- first stage permeate pressure prior to orifice plate
- concentrate outlet from each of stage 1, 2 and 3
- combined permeate

<u>Pressure Switches</u>: Two (2) per skid, one low pressure and one high pressure. The low pressure switch is adjustable between 4 and 50 psig. The high pressure switch is adjustable between 30 and 600 psig. Units have a BUNA N primary wetted diaphragm and a 1/4" 316 stainless steel wrought casing.

<u>Conductivity Sensor</u>: One (1) per skid, panel mounted in a NEMA 12 housing, monitor will be Signet 8900 Series Multi-parameter.

<u>Conductivity Probe</u>: Two (2) per skid, with 316 stainless steel electrodes, and PFM Orings, rated to 100 psig. Probes will be Signet 2850 Series.

<u>Flow Sensors</u>: Two (2) per skid, for feed and reject flow monitoring and control. The sensors are paddlewheel style, polypropylene construction, and mount in a T fitting in the process piping. The flow sensor is Signet 2536 series.

<u>Flow Indicating Rotameter</u>: One (1) per skid, for blend line flow determination. The rotameter will be acrylic construction and have 316 stainless steel end connections.

<u>pH and ORP Monitor</u>: One (1) per skid, panel mounted in a NEMA 12 housing. Monitor will be Signet 8900 Series Multi-parameter.

pH Probe: One (1) per skid, pH probe is Signet model 2774

ORP Probe: One (1) per skid, ORP probe is Signet model 2775.

The Following Items are Shipped Loose for Field Assembly:

<u>Twenty Four (24) – Membrane Elements</u>: Model LE-400 Reverse Osmosis membrane elements as manufactured by DOW FILMTEC[™].

<u>Fourteen (14) – Cartridge Prefilters</u>: 40" long for field installation in the prefilter housing. This quantity is sufficient for two complete sets of cartridge filters.

<u>One (1) – Chemical Clean-in-Place (CIP) Tank</u>: The CIP will be constructed of polyethylene and will be 36" diameter with a nominal capacity of 200 gallons. The tank will be supplied with four (4) PVC bulkhead fittings with PVC connections to allow flow into and out of the tank from the Vantage skid during cleaning. An additional bulkhead fitting and PVC ball valve will be supplied for tank draining.

<u>One (1) – CIP Hose and Recirculation Valve Kit</u>: for connection of above tank to the Vantage skid during CIP operation. The hoses shall be reinforced flexible hose with appropriate end connections for attachment to the skid.

One (1) – Set Antiscalant Feed Equipment: consisting of the following:

Chemical Feed Pump: One (1) per skid high-precision diaphragm type, on/off control by control panel with rate set from integral interface on pump. Pump will be Grundfos DME series with maximum capacity of 0.66 gph. Pump will be 120V, 1ph, 60 Hz service. Pump will be supplied with alarm wire and communication wire. Dose rate will be manually set from the pump, the pump will be turned on and off from skid control panel.

Chemical Day Storage Tank: One (1) 53 gallon Polyethylene Tank.

Suction Line: One (1) rigid suction tube with low level switch assembly.

Miscellaneous Hardware: Additional hardware consisting of pump wall mounting bracket, priming kit, inlet valve and pulsation dampener will be provided.

One (1) Air Compressor Pack: For Operation of the filter function valves consisting of two Quincy air compressors set for lead/lag, 4.4 CFM FAD @ 80 psig with ½ hp, 230 VAC, 3 ph, 60 Hz, 1750 rpm,

open drip proof drive motors, mounted on a common 30 gallon ASME code receiver (optional for additional cost: TEFC with NEMA 4 enclosure). Accessories include:

- V-belt drive
- enclosed belt guard
- inlet filter/silencer air filter with spare cartridge
- automatic adjustable pressure switches
- ASME safety relief valve on air receiver
- in-tank type check valve
- compressor vibration mounts
- manual tank drain
- 120V (mounted) electronic type automatic tank drain (contractor to provide wall outlet at proper location)
- 120V (mounted) refrigerated air dryer (contractor to provide wall outlet at proper location)
- compressed air filter with spare filter cartridge
- single-supply alternator/starter panel with control circuit transformer and test-off-auto selector switches in a NEMA 1 enclosure with IEC magnetic starters.
- vibration isolation pads
- manufacturer's standard paint system

(Note to Proposals Specialist: Additional items requiring an air supply, such as modulating valves, may require a larger compressor.)

<u>Owners Manuals</u>: six (6), with installation, operating, and maintenance instructions, drawings and manufacturers' bulletins. Information contained on CD's.

<u>Technical Direction</u>: Six (6) days, for installation supervision, plant start-up, and operator training in a total of three (3) trips to the jobsite.

NOTE: Availability of equipment components specified may dictate substitutions of equal quality at the discretion of Siemens Water Technologies. Interconnecting wiring and piping is <u>not</u> included in the equipment supplied. Chemicals for startup are <u>not</u> included.

Installation is by others.

Page 1 of 9 Rev. B Feb 2008

Equipment Specifications

Vantage™ M84 Series Reverse Osmosis Water Treatment System

Confidential URS, VA

Section 1 - GENERAL

1.01 WORK INCLUDED:

- A. This section of the specification covers the furnishing and installation of a Vantage M84 Series Reverse Osmosis treatment skid and appurtenances as shown on the drawings and as specified herein.
- B. The following items are a part of this section and shall be furnished by one manufacturer to ensure a properly designed and integrated water treatment system.
 - 1. Factory built structural carbon steel skid with urethane coating.
 - 2. Membrane elements in fiberglass pressure vessels, high pressure pump, prefilter housing, stainless steel high pressure piping, PVC low pressure piping, automatic process valves, and the system control panel all mounted on the above skid.
 - Cleaning solution tank and clean-in-place (CIP) hose kit.
 - 4. Instrumentation and control system designed to automatically control flow to the membranes based on a product flow setpoint input by the operator, automatically control CIP flow, prevent unacceptable water from being directed to downstream unit operations and to prevent damage to the membranes from over pressure or low reject flow rates.
 - 5. Raw water blend line built into the skid with rate set valve and flow meter.

1.02 QUALITY ASSURANCE:

A. The treatment system shall be furnished by a single manufacturer who shall comply with the following:

The manufacturer supplying equipment for this specification shall furnish proof of a minimum of 100 installations and 10 years of manufacturing treatment systems similar to the specified system.

In addition to normal start-up service, the systems detailed above shall be fully operational including the demonstration of a fully automated control sequence for the flush of the system and prevention of over-pressure of the membranes.

Membrane elements, housings and piping of the packaged treatment system shall be certified to NSF[®] Standard 61.

1.03 SUBSTITUTIONS:

- A. Manufacturers other than that which is specified and/or not meeting EVERY provision of the specification shall be required to submit a complete and detailed PRE-QUALIFICATION PACKAGE to the engineer at least fifteen (15) days prior to the bid. Any PRE-QUALIFICATION PACKAGE must contain as a minimum:
 - 1 Detailed Layout Drawings.
 - 2. Detailed component specifications and catalog cut sheets.
 - 3. Process P&ID Drawing.
 - 4. Detailed list of variations required from original design, referencing appropriate sections of the specifications and locations on the drawings.
 - 5. History of the process offered, including pilot data and experience.
 - 6. Installation list including actual scale-up data from pilot testing to full scale plant operation, also including plant contact names and telephone numbers.
 - 7. All other data as required in Quality Assurance section above.
 - 8. A detailed System Performance Guarantee with appropriate remedies for non-performance.
- B. Manufacturers qualifying will be recognized by addendum a minimum of five (5) days prior to the bid. Contractors shall include all costs associated with any redesign required with their bid.
- C. Manufacturers not meeting this specification in EVERY WAY or are not PRE-QUALIFIED and approved by the engineer as outlined above will not be considered for use on this project.

Section 2 - PRODUCTS

2.01 GENERAL

A. All component parts and equipment utilized in the pre-engineered water treatment system shall be furnished as a complete integrated system by one manufacturer. This specification describes a Vantage Series M84 Water Treatment System as manufactured by Siemens Water Technologies.

Furnish and install one (1) identical skid capable of producing 100 GPM* permeate. Total plant design flow rate is 100 GPM. The pre-engineered treatment system shall be Vantage Model M84-024.

* This is based on a nominal design flux of 15 gfd, which is typical for well water or pretreated surface water with an SDI of less than 5.

2.02 REVERSE OSMOSIS SKID

A. The configuration of the system shall be multi-stage, single pass, with a design system recovery of 75%. The skid shall be staged in a 3:2:1 configuration and shall utilize 4M vessels.

1

- B. Influent temperature shall be greater than 50°F, have an SDI less than 5 and have undetectable free chlorine and/or chloramines.
- C. Skid Fabrication

The Vantage Series Reverse Osmosis System shall be mounted on a rectangular steel skid. Major components shall be of the size and configuration shown on the drawings and fabricated of ASTM A36 structural carbon steel and ASTM A500 structural carbon steel tubing. Surface shall be prepared using an SSPC SP-6 commercial blast and coated with 6-9 mils DFT urethane. The skid frame shall extend to the full footprint of the skid.

All external connections shall be provided as flanged connections as shown in the drawings.

- 1. High pressure piping on the skid (greater than 90 psi) shall be welded Schedule 10, 316L stainless steel.
- Low pressure piping shall be Schedule 80 PVC conforming to ASTM-D-1784, socket welded and flanged (threaded for instrumentation).
- 3. Gaskets shall be 1/8" thick EPDM, ring or full face.
- D. Membrane and Pressure Vessels
 - 1. Membranes shall be thin film composite, 8" spiral wound and shall come in a standard 40" length. The membranes shall be DOW FILMTEC[™] LE-400.
 - 2. Each membrane element shall have an active surface area of 400 ft².
 - 3. The system shall be designed for a flux of 15 gallons/ft²/day (GFD).
 - 4. Membrane elements shall be housed in a fiberglass reinforced plastic (FRP) pressure vessel rated to 300 psig. Each housing shall be 8" diameter, and have grooved 1 ½" side entry connections. Housings shall be ASME code stamped. Membrane housings shall be Protec[™] Pro-8-300 Series. Pressure relief must also be provided, as per ASME and the code stamped housing.
- E. Booster Pump
 - 1. A multistage centrifugal pump shall be mounted on each skid for pressurizing the water to the RO system. Each pump will be designed to provide 133 gpm of water at a pressure of 250 psig.
 - 2. Pump housing shall be constructed of 316 stainless steel. Pump impellers shall be 316 stainless steel.
 - 3. Pump motor shall be 25 hp, TEFC, 460 volt, 3 phase, 60 hz. Motor shall have Class F insulation, be UL recognized, and have a service factor of 1.15.

- 4. Pump shall be Grundfos CRN series.
- F. Plant Process Valves

The treatment plant manufacturer shall provide all process control valves in sizes shown on the drawings.

 There shall be automatic control valves with pneumatic actuators for the skid including:

One inlet valve, wafer butterfly style, with EPDM seats.

One auto flush valve, which shall be a ball valve with 316 stainless steel body, ball and stem.

One product isolation valve, wafer butterfly style, with EPDM seats. Actuator shall be fail-to-close.

One product to drain valve, wafer butterfly style, with EPDM seats. Actuator shall be fail-to-open.

2. There shall be adequate manual valves on the skid as follows:

One pump throttling valve, which shall be a ball valve with 316 stainless steel body, ball and stem and locking manual actuator.

One reject throttling valve, which shall be a 316 stainless steel globe valve with manual actuator.

One lot 1/4" PVC sample valves for feed water, product connections on each pressure vessel and a combined product sample.

One ¼" 316 stainless steel plug valve for high pressure feed sampling.

One 1/4" PVC valve for low pressure feed sampling

3. There shall be a pressure relief valve with ASME certified carbon steel body with stainless steel trim and Viton soft seat on the skid on both the feed to the membrane housings and on the product piping.

Gauges shall be isolated from the process stream by 1/4" stainless steel threaded plug valves.

G. System Prefilters

- 1. The skid shall be provided with one multi-element prefilter for removal of suspended solids in the influent water.
- 2. The filter elements shall be non-shedding polypropylene with a nominal opening of 5 microns.

- 3. The filter housing shall be 304L stainless steel and shall have a 150 psig non-code pressure rating. The housing shall be sized for no more than 5 gpm per 10" filter equivalent.
- H. Blend Line
 - 1. Each membrane skid shall be equipped with a raw water blend line that allows a portion of raw water to be blended with the membrane permeate to reach a desired finished water quality goal.
 - 2. The blend line shall consist of a diaphragm valve, check valve and rotameter to allow the operator to manually adjust the desired raw water bypass rate.

2.03 CLEAN-IN-PLACE SYSTEM

- A. The cleaning system pump, filter and controls will be fully integrated into the Reverse Osmosis skid. The only additional CIP components that shall be required will consist of a chemical makeup tank and a hose kit.
 - 1. The CIP Chemical Makeup Tank shall have a capacity of 200 gallons and shall be 36" diameter. The tank will be installed by the contractor near the membrane skid as shown on the project plans. It shall be polyethylene construction and use PVC bulkhead fittings for the connection points.
 - A hose kit shall be provided by the manufacturer with sufficient hoses and connection hardware to make the CIP system operational when required. The hose kit shall also be supplied with a bypass valve for mixing of CIP solution.

2.04 AIR COMPRESSOR

Manufacturer shall furnish one compressor pack consisting of two (2) single A. stage automatic air compressors with one ASME code, 30 gallon horizontal receiver, motor, load-less starting, pressure gauge, safety valve, crankcase drain, intake air filter, pressure switch, manual and automatic receiver blowdown, continuously running refrigeration type air dryer, dryer moisture trap with manual and automatic blowdown, shut off valve and compressed air filter with spare cartridge. Compressor pack to be completely shop assembled with dryer. Refrigeration dryer shall be 120 volt single phase, contractor to provide wall outlet at proper location for dryer. Compressors shall have a piston displacement of 4.4 cfm FAD and driven by 1/2 hp, 230 volt, 3 phase, 60 Hz drive motors. Compressors shall be alternating with lead compressor switch setting 70 - 90 psig, lag compressor switch setting 60 - 80 psig. Capacity of a single compressor shall be sufficient for normal operation of pneumatic valves. An IEC specific purpose motor starter assembly is to be provided as part of the compressor pack and is to be installed by the contractor.

2.05 ANTISCALANT FEED SYSTEM

- A. Manufacturer shall furnish chemical dosing equipment for the introduction of antiscalant to the system feedwater. It shall consist of a metering pump, calibration column, tubing and injection quill.
 - The pump will be field mounted by others on the chemical storage container for the antiscalant. The pump will be Grundfos DME series, capable of a maximum of 0.66 gph, with a turndown capability of 1000:1. The pump rate shall be manually set by the operator, but pump run status will be controlled by the skid control system.

Section 3 - PLANT CONTROL

3.01 PLANT CONTROL - GENERAL

A PLC based control panel shall be supplied to monitor and control the Vantage Series System. The PLC based system shall be capable of operating in an automatic mode completely autonomously. The control panel shall provide automatic starting and stopping of the Treatment System, based on clearwell level or device failure.

A. The control system shall be supplied complete including all necessary equipment to provide a complete and functioning system. The components shall include PLC, human machine interface (HMI), control relays, push-buttons & selector switches, indicating lights, power supplies, fuses and terminal strips. The PLC shall have an Ethernet[™] port, enabling interface to a SCADA System or, Master Control Panel or to other membrane skids.

3.02 TREATMENT SYSTEM CONTROL PANEL

- A. The treatment system controls shall consist of Local Control Panel (LCP) on the skid. The control panel shall be supplied in a NEMA 4/12 steel enclosure suitable for indoor use. The front panel of the cabinet shall contain all push buttons, and Human Machine Interface as detailed within this specification. The internal portion of the cabinet shall contain all rail-mounted PLC equipment, power supply, processor, and interface cards. Relays and terminals shall also be contained within the cabinet. The PLC subsystem shall be Siemens S7/200 model CPU224XP. Terminal strips for all field wiring shall be furnished within the panel.
- B. Fuses and simplex outlet shall be provided within the panel.
- C. All digital outputs shall be provided with relay contacts.

3.03 VARIABLE FREQUENCY DRIVE (VFD)

- A. The drive for the booster pump shall consist of an adjustable frequency AC motor controller.
- B. The VFD shall provide continuously adjustable settings over a range of not less than 10 to 1. The controller shall be solid state.

C. The VFD shall be mounted in the instrument control panel.

3.04 DEVICES FOR OPERATOR INTERFACE

External face mounted devices for operator interface shall be as follows:

A. Human Machine Interface

The HMI shall be touch screen type with 6 in. diagonal full color display. The HMI shall be fully programmed with shall allow the operator to view and modify system variables within the PLC. It shall allow the operator to set process flow rate, run status and CIP operation through the use of virtual switches/pushbuttons. The HMI shall have an Ethernet port to allow interfacing with other membrane skids, pretreatment devices or other control devices. The HMI shall be Siemens model TP177B DP/PN with Ethernet.

- B. Pushbuttons
 - 1. Pushbuttons shall be Siemens. Panel Mounted Pushbuttons shall be provided to perform the following functionality:
 - a. Emergency Stop

3.05 PROCESS CONTROL SYSTEM FUNCTIONS

- A. The LCP shall automatically control the treatment process.
- B. The HMI shall provide operator adjustable set points for the following parameters:
 - 1. RO selector Man/Auto
 - 2. RO selector Start/Stop
 - 3. Permeate Flow Rate Setpoint
 - 4. Auto flush selector On/Off
 - 5. Alarm silence
 - 6. Alarm reset
 - 7. CIP Start/Stop
 - 8. CIP Flow rate set
- C. The PLC shall, via the HMI, provide the following status indicators at a minimum:
 - 1. Feed flow, reject flow, product flow, % recovery
 - 2. Total run time
 - 3. RO operating mode
 - 4. Pump status
 - 5. Inlet, reject, product to tank, product to drain valve status
 - 6. Pretreatment lockout
 - 7. Storage tank full (Standby no call for water)

- D. The following alarm conditions shall be monitored by LCP. All alarms shall be visible via the HMI Display.
 - 1. Low quality product
 - 2. Low feed pressure
 - 3. Low reject flow
 - 4. High product flow
 - 5. Low feed flow
 - 6. High pump discharge pressure
 - 7. High feed water temperature
 - 8. ORP alarm
 - 9. Emergency Stop
 - 10. VFD fault
 - 11. CIP low flow
- E. The following additional features shall be provided in the LCP.
 - 1. Alarm horn and alarm pilot light
 - 2. Chemical injection pump terminals
 - 3. Auxiliary contacts for pump running & fault

3.06 INSTRUMENTS

- A. Pressure Sensors and Gauges
 - 1. Pressure gauges shall be 316 stainless steel bourdon tube and socket with a 63mm glycerin filled dial. Pressure gauges shall be Ashcroft series 1009.
 - 2. Pressure switches shall be provided for low feed pressure and high discharge pressure. The pressure switches shall have a 15 amp switching power at 120 volts. The low pressure switch shall have an adjustable range between 4 and 50 psig. The high pressure switch shall have an adjustable range between 30 and 600 psig. Units shall have a BUNA N primary wetted diaphragm and a 1/8" 316 stainless steel wrought casing.
- B. Conductivity Sensors
 - Conductivity shall be continuously monitored by the control system. The monitor shall be NEMA 4 and be panel mounted. Conductivity monitors shall be Signet 8900 Series Multi-parameter.
 - Conductivity probes shall have 316 stainless steel electrodes, 316 stainless steel body, and FPM O-rings. Units shall thread into a ³⁄₄" NPT connection and be rated to 100 psig. Probes shall be Signet 2850 Series.
- C. Flow Sensors/Indicators
 - Each skid will be equipped with two flow sensors for feed and reject flow monitoring and control. The sensors shall be paddlewheel style and shall be polypropylene and mount in a T fitting in the process piping. The flow sensor will be Signet 2536 series.

- 2. Each skid shall have an acrylic rotameter for flow determination in the product blend line. The rotameter shall have 316 stainless steel end connections. The rotameter shall be manufactured by King Products.
- D. PH/ORP Sensors
 - PH and ORP of the raw water shall be continuously monitored by the control system. A sample shall be taken from a high pressure point, fed to the sensors, and returned to a low pressure point so that no waste stream is generated from the sampling. The monitor shall be NEMA 4 and be panel mounted. The monitor shall be Signet 8900 Series Multi-parameter.
 - 2. PH probe shall be Signet model 2774 and ORP probe shall be Signet model 2775.

Section 4 - Execution

4.01 DELIVERY OF EQUIPMENT

- A. The membrane skids shall be shipped to site as a complete unit with the exception of the blend line and membrane elements, which will be installed on-site by the contractor.
- B. The CIP tank and hose kit shall be shipped loose for placement and field installation by others.

4.02 INSTALLATION AND TRAINING

The Vantage Series Reverse Osmosis System shall be installed as shown on the Contract Drawings and specified herein.

The Manufacturer shall inspect the installation of all equipment in this section prior to start-up in order to verify that the equipment has been properly installed and operates properly as a system and individually.

After the equipment has been properly installed, the Manufacturer shall calibrate the equipment with the Owner's operator present.

The Manufacturer shall furnish the service of a competent technical service representative after Contractor's start-up to instruct the Owner's personnel in the operation and maintenance of the equipment.

The Manufacturer's representative shall be present for six (6) days in three (3) trips total to provide services described above.







.

Vantage[™] M83 units are packaged single-pass 8-inch reverse osmosis units are designed for a variety of applications requiring high quality equipment with a fast delivery and competitive price. These pre-engineered, pre-assembled and factory tested units minimize installation and start-up time. With simple utility connections and easy to set up controls, the unit is ready for quick on-line service.

The Vantage[™] M83 unit comes with a user friendly touch screen Human Machine Interface (HMI), Variable Frequency Drive (VFD) for flow control, built in Clean In Place (CIP) function, and pH/ORP monitoring.

The system features an "On-Board" integrated cleaning system (CIP) initiated through the HMI. The CIP system includes plumbing to the on-skid RO cartridge filter housing and VFD controlled pump along with the factory supplied valves, hoses, and a polyethylene CIP tank (off-skid).

VANTAGE[™] M83 UNIT BENEFITS:

- Compact footprint saves valuable floor space
- Quick equipment delivery keeps project moving fast
- · Clean in place connections maximize system serviceability
- Comprehensive factory testing performed at our ISO9001 certified facility
- Optional Filmtec's iLEC® interlocking endcaps, an innovative element coupling technology that significantly enhances the performance of RO systems

Water Technologies

Vantage[™] M83 Reverse Osmosis Units

The Clear Advantage In Membrane Systems

SIEMENS

STANDARD M83 UNIT FEATURES:

- Choice of brackish water, low energy TFC, or nanofilteration membranes (400 ft²) to ensure optimum water quality
- High pressure 316 stainless steel vertical multistage feed pump
- ASME Code FRP, RO pressure vessels with pressure relief protection
- PVC low pressure feed, product and reject piping, 316L stainless steel high pressure piping
- Urethane coated carbon steel frame rated for Seismic Zone 4 anchorage
- Dry contacts are provided for chemical feed, pretreatment equipment, storage tank levels, and pressure switches
- All alarm and shut down conditions are indicated on the control interface



Specifications

| Model | Flow | A Rate Spo M Nomin | ecificati al (m³/h | ons ir) | Vessel | Membrane/ | Membrane | Custo | omer Con pecificat | nection ions | Utility Re High | High | nts*** | Approx. Shipping |
|---------|----------|-----------------------|-----------------------|------------|---------|-----------|----------|-------|-----------------------|-----------------|--------------------|------|--------|---------------------|
| 140. | Product* | Feed | Reject | Recycle | Staging | vesser | quantity | Feed | Product | Reject | Service | FLA | HP | Ib (kg) |
| M83R006 | 25(5,7) | 33(7.5) | 8(1.8) | 10(2.3) | 1:1 | 3 | 6 | 2" | 1,5" | 1.5″ | 480 VAC 3ph | 16 | 10 | 2900 (1315) |
| M83R009 | 37(8.4) | 49(11.1) | 12(2.7) | 5(1.1) | 1:1:1 | 3 | 9 | 2″ | 1.5" | 1.5″ | 480 VAC 3ph | 29 | 20 | 3175 (1440) |
| M83R012 | 50(11.4) | 67(15.2) | 17(3.9) | 5(1.1) | 2:1:1 | 3 | 12 | 2" | 2* | 1.5″ | 480 VAC 3ph | 36 | 20 | 3450 (1565) |
| M83R015 | 62(14.1) | 83(18.9) | 21(4.8) | 3(0.7) | 2:2:1 | 3 | 15 | 3" | 2" | 1.5″ | 480 VAC 3ph | 36 | 25 | 3725 (1690) |
| M83R018 | 75(17.0) | 100(27.7) | 25(5.7) | 3(0.7) | 3:2:1 | 3 | 18 | 3" | 3" | 1.5" | 480 VAC 3ph | 42 | 30 | 4000 (1814) |

*Product flow rates are based on equipment design parameters listed below. Product flow rates may not be appropriate for other feed waters. **The 8 designates 8* housing, the 3 designates 3 elements in length, and the R0XX designates the nominal design product flow rate at 65°F (18.3°C). ***Additional voltage options are available. Refer to equipment specifications.

Dimensions



Model Features

| Component | Description | | | | | | |
|-------------------------------------|--|--|--|--|--|--|--|
| Controls | Siemens PLC & HMI | | | | | | |
| inputs/Outputs | Discrete 24 point (14 input/ 10 output) | | | | | | |
| I/O Expansion Capability | Yes | | | | | | |
| Communication Port | R\$485 | | | | | | |
| Remote Monitoring/Communications* | Optional Modules | | | | | | |
| Flow Monitoring | Paddlewheel (feed/reject) Rotometer (recycle) | | | | | | |
| Conductivity | Signet Multiparameter | | | | | | |
| Auto-Flush (Standby) | Yes | | | | | | |
| Visual/Audible Alarm | Yes | | | | | | |
| Single Power Drop (480 VAC) | Yes | | | | | | |
| 304LSS Pre-Filter Housing | Yes | | | | | | |
| Variable Frequency Drive (VFD) Pump | Yes | | | | | | |
| On-Board CIP (Tank off-skid) | Yes | | | | | | |
| ORP/pH with alarms | Yes | | | | | | |
| Low Energy Membranes (Cold Water) | Optional | | | | | | |
| Product Divert Kit | Optional | | | | | | |

*Additional communication modules and remote monitoring capabilities available upon request.

Design Parameters:

| Feed Water Source | Well or pretreated | | | | | |
|---|---|--|--|--|--|--|
| Maximum Turbidity | 1 NTU | | | | | |
| Maximum Free Chlorine and/or chloramine | <0.1 PPM | | | | | |
| Feed Water Fouling Index | Silt Density Index (SDI) <3 | | | | | |
| Design Feed Water Temperature | 65°F (18.3°C) | | | | | |
| Inlet Pressure Requirements | 30-60 PSIG | | | | | |
| Product Pressure Available | 10 PSIG | | | | | |
| System Recovery (Nominal) | 75% | | | | | |
| Performance Basis | A specific computer projection must be run for each individual application | | | | | |

*Lower temperature may require larger booster pump or use of low energy membranes. If any of the feed water parameters are not within the limits given, contact Siemens Water Technologies Technical Support. The information provided in this brochure contains merely general descriptions or characteristics of performance which in actual case of use do not always apply as described or which may change as a result of further development of the products. An obligation to provide the respective characteristics shall only exist if expressly agreed in the terms of contract.

Vantage is a trademark of Siemens, its subsidiaries or affiliates. ILEC is a trademark of FilmTec Corporation, a wholly owned subsidiary of The Dow Chemical Company.

Siemens Water Technologies 600 Arrasmith Trail Arnes, IA 50010 Phone: 515-268-8500 Fax: 515-268-8500 www.siemens.com/water







EQUIPMENT LIST VANTAGE™ M83 REVERSE OSMOSIS SYSTEM

Confidential URS, VA Secondary System

Equipment Supplied by Siemens Water Technologies

One (1) <u>Vantage M83 Reverse Osmosis Membrane Skid</u>: Model M83-006, rated for 25 GPM permeate. The skid would be in the 1:1 configuration using 8" diameter x 3 membrane long 3M FRP pressure vessels. The operating weight of the skid is approximately 4,400 lbs. The skid measures 14 feet 0 inches long by 2 feet 8 inches wide by 6 feet 5 inches high, outside dimensions. The skid is painted steel construction and has the following prepiped and installed on the skid:

<u>FRP Membrane Vessels</u>: Two (2) Protec model PRO-8-300 FRP membrane vessels arranged in a 1:1 configuration for housing the membrane elements. The vessels are rated for 300 psi, are ASME code stamped and are NSF 61 approved for contact with potable water. Connections to the vessels are stainless steel grooved side entry type for feed and concentrate connections.

<u>Piping</u>: High pressure skid piping will be constructed from welded, schedule 10 Type 316L stainless steel. Low pressure piping will be constructed from schedule 80 PVC.

<u>Prefilter Housing</u>: One (1) prefilter housing constructed of 304L stainless steel. The size of the prefilter shall be 4Rx3H.

Booster Pump: One (1) with stainless steel housing and 10 hp, 460V, 3ph, 60 Hz TEFC motor. The pump is a Grundfos CRN Series.

Automatic Control Valves:

Inlet Valve: One (1) per skid, butterfly type with pneumatic actuator.

Auto Flush Valve: One (1) per skid, ball type, 316 SS, with pneumatic actuator.

<u>Product Isolation Valve</u>: One (1) per skid, butterfly type, with fail-to-close pneumatic actuator.

<u>Product to Drain Valve</u>: One (1) per skid, butterfly type, with fail-to-open pneumatic actuator.

Manual Valves:

Pump Throttling Valve: One (1) per skid, ball type, 316 SS, with locking manual actuator.

Reject Throttling Valve: One (1) per skid, globe valve, 316 SS, with manual actuator.

Reject Recycle Valve: One (1) per skid, globe type, 316 SS, with manual actuator.

Miscellaneous Valves:

<u>Sample Valves</u>: One (1) set ¹/₄" PVC sample valves for feed water, product connections on each pressure vessel and a combined product sample.

Sample Valve: One (1) 1/4" 316 stainless steel plug valve for high pressure feed sampling.

<u>Pressure Relief</u>: One (1) per skid, relief valve with ASME certified carbon steel body with stainless steel trim and Viton soft seat.

Controls:

<u>Skid Control Panel</u>: One (1) skid mounted NEMA 12 enclosure per skid, with Siemens operator interface terminal, relays, lights, and switches controlled by a Siemens programmable controller. The panel will have discrete interlocks for integration with additional skids, chemical prefeed and external run and stop signals. An HMI will be provided consisting of a Siemens model TP177A with 6" diagonal touch screen.

<u>Variable Frequency Drive (VFD)</u>: One (1) solid state variable frequency motor drive for the booster pump continuously adjustable over a range of 10 to 1. The VFD shall be mounted in the instrument control panel.

<u>Pressure Gauges</u>: Pressure gauges are 316 stainless steel bourdon tube and socket type with glycerin filled dial. Pressure gauges shall be provided for:

- cartridge prefilter inlet
- prefilter outlet
- booster pump discharge
- membrane housing inlet
- first stage permeate pressure prior to orifice plate
- concentrate outlet from each of stage 1, 2 and 3
- combined permeate

<u>Pressure Switches</u>: Two (2) per skid, one low pressure and one high pressure. The low pressure switch is adjustable between 4 and 50 psig. The high pressure switch is adjustable between 30 and 600 psig. Units have a BUNA N primary wetted diaphragm and a 1/4" 316 stainless steel wrought casing.

<u>Conductivity Sensor</u>: One (1) per skid, panel mounted in a NEMA 12 housing, monitor will be Signet 8900 Series Multi-parameter.

<u>Conductivity Probe</u>: Two (2) per skid, with 316 stainless steel electrodes, and PFM Orings, rated to 100 psig. Probes will be Signet 2850 Series.

<u>Flow Sensors</u>: Two (2) per skid, for feed and reject flow monitoring and control. The sensors are paddlewheel style, polypropylene construction, and mount in a T fitting in the process piping. The flow sensor is Signet 2536 series.

<u>pH and ORP Monitor</u>: One (1) per skid, panel mounted in a NEMA 12 housing. Monitor will be Signet 8900 Series Multi-parameter.

pH Probe: One (1) per skid, pH probe is Signet model 2774

ORP Probe: One (1) per skid, ORP probe is Signet model 2775.

The Following Items are Shipped Loose for Field Assembly:

<u>Seventy Two (72) – Membrane Elements</u>: Model BW30-400/34i Reverse Osmosis membrane elements as manufactured by DOW FILMTEC™.

<u>Eight (8) – Cartridge Prefilters</u>: 30" long for field installation in the prefilter housing. This quantity is sufficient for two complete sets of cartridge filters.

<u>One (1) – Chemical Clean-in-Place (CIP) Tank</u>: The CIP will be constructed of polyethylene and will be 36" diameter with a nominal capacity of 200 gallons. The tank will be supplied with four (4) PVC bulkhead fittings with PVC connections to allow flow into and out of the tank from the Vantage skid during cleaning. An additional bulkhead fitting and PVC ball valve will be supplied for tank draining.

<u>One (1) – CIP Hose and Recirculation Valve Kit</u>: for connection of above tank to the Vantage skid during CIP operation. The hoses shall be reinforced flexible hose with appropriate end connections for attachment to the skid.

One (1) – Set Antiscalant Feed Equipment: consisting of the following:

Chemical Feed Pump: One (1) per skid high-precision diaphragm type, on/off control by control panel with rate set from integral interface on pump. Pump will be Grundfos DME series with maximum capacity of 0.66 gph. Pump will be 120V, 1ph, 60 Hz service. Pump will be supplied with alarm wire and communication wire. Dose rate will be manually set from the pump, the pump will be turned on and off from skid control panel.

Chemical Day Storage Tank: One (1) 53 gallon Polyethylene Tank.

Suction Line: One (1) rigid suction tube with low level switch assembly.

Miscellaneous Hardware: Additional hardware consisting of pump wall mounting bracket, priming kit, inlet valve and pulsation dampener will be provided.

<u>One (1) Air Compressor Pack</u>: For Operation of the filter function valves consisting of two Quincy air compressors set for lead/lag, 4.4 CFM FAD @ 80 psig with ½ hp, 230 VAC, 3 ph, 60 Hz, 1750 rpm, open drip proof drive motors, mounted on a common 30 gallon ASME code receiver (optional for additional cost: TEFC with NEMA 4 enclosure).

Accessories include:

- V-belt drive
- enclosed belt guard
- inlet filter/silencer air filter with spare cartridge

- automatic adjustable pressure switches
- ASME safety relief valve on air receiver
- in-tank type check valve
- compressor vibration mounts
- manual tank drain
- 120V (mounted) electronic type automatic tank drain (contractor to provide wall outlet at proper location)
- 120V (mounted) refrigerated air dryer (contractor to provide wall outlet at proper location)
- · compressed air filter with spare filter cartridge
- single-supply alternator/starter panel with control circuit transformer and test-off-auto selector switches in a NEMA 1 enclosure with IEC magnetic starters.
- vibration isolation pads
- manufacturer's standard paint system

(Note to Proposals Specialist: Additional items requiring an air supply, such as modulating valves, may require a larger compressor.)

<u>Owners Manuals</u>: six (6), with installation, operating, and maintenance instructions, drawings and manufacturers' bulletins. Information contained on CD's.

<u>Technical Direction</u>: Six (6) days, for installation supervision, plant start-up, and operator training in a total of three (3) trips to the jobsite.

NOTE: Availability of equipment components specified may dictate substitutions of equal quality at the discretion of Siemens Water Technologies. Interconnecting wiring and piping is <u>not</u> included in the equipment supplied. Chemicals for startup are <u>not</u> included.

Installation is by others.

Page 1 of 9 Rev. B Feb 2008

Equipment Specifications

Vantage[™] M83 Series Reverse Osmosis Water Treatment System

Confidential URS, VA Secondary System

Section 1 - GENERAL

1.01 WORK INCLUDED:

- A. This section of the specification covers the furnishing and installation of a Vantage M83 Series Reverse Osmosis treatment skid and appurtenances as shown on the drawings and as specified herein.
- B. The following items are a part of this section and shall be furnished by one manufacturer to ensure a properly designed and integrated water treatment system.
 - 1. Factory built structural carbon steel skid with urethane coating.
 - Membrane elements in fiberglass pressure vessels, high pressure pump, prefilter housing, stainless steel high pressure piping, PVC low pressure piping, automatic process valves, and the system control panel all mounted on the above skid.
 - Cleaning solution tank and clean-in-place (CIP) hose kit.
 - 4. Instrumentation and control system designed to automatically control flow to the membranes based on a product flow setpoint input by the operator, automatically control CIP flow, prevent unacceptable water from being directed to downstream unit operations and to prevent damage to the membranes from over pressure or low reject flow rates.

1.02 QUALITY ASSURANCE:

A. The treatment system shall be furnished by a single manufacturer who shall comply with the following:

The manufacturer supplying equipment for this specification shall furnish proof of a minimum of 100 installations and 10 years of manufacturing treatment systems similar to the specified system.

In addition to normal start-up service, the systems detailed above shall be fully operational including the demonstration of a fully automated control sequence for the flush of the system and prevention of over-pressure of the membranes.

Membrane elements, housings and piping of the packaged treatment system shall be certified to NSF[®] Standard 61.

1.03 SUBSTITUTIONS:

- A. Manufacturers other than that which is specified and/or not meeting EVERY provision of the specification shall be required to submit a complete and detailed PRE-QUALIFICATION PACKAGE to the engineer at least fifteen (15) days prior to the bid. Any PRE-QUALIFICATION PACKAGE must contain as a minimum:
 - 1 Detailed Layout Drawings.
 - 2. Detailed component specifications and catalog cut sheets.
 - 3. Process P&ID Drawing.
 - Detailed list of variations required from original design, referencing appropriate sections of the specifications and locations on the drawings.
 - 5. History of the process offered, including pilot data and experience.
 - Installation list including actual scale-up data from pilot testing to full scale plant operation, also including plant contact names and telephone numbers.
 - 7. All other data as required in Quality Assurance section above.
 - 8. A detailed System Performance Guarantee with appropriate remedies for non-performance.
- B. Manufacturers qualifying will be recognized by addendum a minimum of five (5) days prior to the bid. Contractors shall include all costs associated with any redesign required with their bid.
- C. Manufacturers not meeting this specification in EVERY WAY or are not PRE-QUALIFIED and approved by the engineer as outlined above will not be considered for use on this project.

Section 2 - PRODUCTS

2.01 GENERAL

A. All component parts and equipment utilized in the pre-engineered water treatment system shall be furnished as a complete integrated system by one manufacturer. This specification describes a Vantage Series M83 Water Treatment System as manufactured by Siemens Water Technologies.

Furnish and install one (1) identical skid capable of producing 25 GPM* permeate. Total plant design flow rate is 25 GPM. The pre-engineered treatment system shall be Vantage Model M83-006.

* This is based on a nominal design flux of 15 gfd, which is typical for well water or pretreated surface water with an SDI of less than 5.

2.02 REVERSE OSMOSIS SKID

A. The configuration of the system shall be multi-stage, single pass, with a design system recovery of 75%. The skid shall be staged in a 1:1 configuration and shall utilize 3M vessels.

- B. Influent temperature shall be greater than 70°F, have an SDI less than 5 and have undetectable free chlorine and/or chloramines.
- C. Skid Fabrication

The Vantage Series Reverse Osmosis System shall be mounted on a rectangular steel skid. Major components shall be of the size and configuration shown on the drawings and fabricated of ASTM A36 structural carbon steel and ASTM A500 structural carbon steel tubing. Surface shall be prepared using an SSPC SP-6 commercial blast and coated with 6-9 mils DFT urethane. The skid frame shall extend to the full footprint of the skid.

All external connections shall be provided as flanged connections as shown in the drawings.

- 1. High pressure piping on the skid (greater than 90 psi) shall be welded Schedule 10, 316L stainless steel.
- Low pressure piping shall be Schedule 80 PVC conforming to ASTM-D-1784, socket welded and flanged (threaded for instrumentation).
- 3. Gaskets shall be 1/8" thick EPDM, ring or full face.
- D. Membrane and Pressure Vessels
 - Membranes shall be thin film composite, 8" spiral wound and shall come in a standard 40" length. The membranes shall be DOW FILMTEC[™] BW30-400/34i.
 - 2. Each membrane element shall have an active surface area of 400 ft².
 - 3. The system shall be designed for a flux of 15 gallons/ft²/day (GFD).
 - 4. Membrane elements shall be housed in a fiberglass reinforced plastic (FRP) pressure vessel rated to 300 psig. Each housing shall be 8" diameter, and have grooved 1 ½" side entry connections. Housings shall be ASME code stamped. Membrane housings shall be ProtecTM Pro-8-300 Series. Pressure relief must also be provided, as per ASME and the code stamped housing.
- E. Booster Pump
 - A multistage centrifugal pump shall be mounted on each skid for pressurizing the water to the RO system. Each pump will be designed to provide 33 gpm of water at a pressure of 200 psig.
 - 2. Pump housing shall be constructed of 316 stainless steel. Pump impellers shall be 316 stainless steel.
 - 3. Pump motor shall be 10 hp, TEFC, 460 volt, 3 phase, 60 hz. Motor shall have Class F insulation, be UL recognized, and have a service factor of 1.15.

- 4. Pump shall be Grundfos CRN series.
- F. Plant Process Valves

1

- The treatment plant manufacturer shall provide all process control valves in sizes shown on the drawings.
 - There shall be automatic control valves with pneumatic actuators for the skid including:

One inlet valve, wafer butterfly style, with EPDM seats.

One auto flush valve, which shall be a ball valve with 316 stainless steel body, ball and stem.

One product isolation valve, wafer butterfly style, with EPDM seats. Actuator shall be fail-to-close.

One product to drain valve, wafer butterfly style, with EPDM seats. Actuator shall be fail-to-open.

2. There shall be adequate manual valves on the skid as follows:

One pump throttling valve, which shall be a ball valve with 316 stainless steel body, ball and stem and locking manual actuator.

One reject throttling valve, which shall be a 316 stainless steel globe valve with manual actuator.

One lot 1/4" PVC sample valves for feed water, product connections on each pressure vessel and a combined product sample.

One ¼" 316 stainless steel plug valve for high pressure feed sampling.

One 1/4" PVC valve for low pressure feed sampling

There shall be a pressure relief valve with ASME certified carbon steel body with stainless steel trim and Viton soft seat on the skid on both the feed to the membrane housings and on the product piping.

Gauges shall be isolated from the process stream by ¼" stainless steel threaded plug valves.

G. System Prefilters

- The skid shall be provided with one multi-element prefilter for removal of suspended solids in the influent water.
- The filter elements shall be non-shedding polypropylene with a nominal opening of 5 microns.

 The filter housing shall be 304L stainless steel and shall have a 150 psig non-code pressure rating. The housing shall be sized for no more than 5 gpm per 10" filter equivalent.

2.03 CLEAN-IN-PLACE SYSTEM

- A. The cleaning system pump, filter and controls will be fully integrated into the Reverse Osmosis skid. The only additional CIP components that shall be required will consist of a chemical makeup tank and a hose kit.
 - 1. The CIP Chemical Makeup Tank shall have a capacity of 200 gallons and shall be 36" diameter. The tank will be installed by the contractor near the membrane skid as shown on the project plans. It shall be polyethylene construction and use PVC bulkhead fittings for the connection points.
 - A hose kit shall be provided by the manufacturer with sufficient hoses and connection hardware to make the CIP system operational when required. The hose kit shall also be supplied with a bypass valve for mixing of CIP solution.

2.04 AIR COMPRESSOR

A. Manufacturer shall furnish one compressor pack consisting of two (2) single stage automatic air compressors with one ASME code, 30 gallon horizontal receiver, motor, load-less starting, pressure gauge, safety valve, crankcase drain, intake air filter, pressure switch, manual and automatic receiver blowdown, continuously running refrigeration type air dryer, dryer moisture trap with manual and automatic blowdown, shut off valve and compressed air filter with spare cartridge. Compressor pack to be completely shop assembled with dryer. Refrigeration dryer shall be 120 volt single phase, contractor to provide wall outlet at proper location for dryer. Compressors shall have a piston displacement of 4.4 cfm FAD and driven by 1/2 hp, 230 volt, 3 phase, 60 Hz drive motors. Compressors shall be alternating with lead compressor switch setting 70 - 90 psig, lag compressor switch setting 60 - 80 psig. Capacity of a single compressor shall be sufficient for normal operation of pneumatic valves. An IEC specific purpose motor starter assembly is to be provided as part of the compressor pack and is to be installed by the contractor.

2.05 ANTISCALANT FEED SYSTEM

- A. Manufacturer shall furnish chemical dosing equipment for the introduction of antiscalant to the system feedwater. It shall consist of a metering pump, calibration column, tubing and injection quill.
 - The pump will be field mounted by others on the chemical storage container for the antiscalant. The pump will be Grundfos DME series, capable of a maximum of 0.66 gph, with a turndown capability of 1000:1. The pump rate shall be manually set by the operator, but pump run status will be controlled by the skid control system.

Section 3 - PLANT CONTROL

3.01 PLANT CONTROL - GENERAL

A PLC based control panel shall be supplied to monitor and control the Vantage Series System. The PLC based system shall be capable of operating in an automatic mode completely autonomously. The control panel shall provide automatic starting and stopping of the Treatment System, based on clearwell level or device failure.

A. The control system shall be supplied complete including all necessary equipment to provide a complete and functioning system. The components shall include PLC, human machine interface (HMI), control relays, push-buttons & selector switches, indicating lights, power supplies, fuses and terminal strips. The PLC shall have an Ethernet[™] port, enabling interface to a SCADA System or, Master Control Panel or to other membrane skids.

3.02 TREATMENT SYSTEM CONTROL PANEL

- A. The treatment system controls shall consist of Local Control Panel (LCP) on the skid. The control panel shall be supplied in a NEMA 4/12 steel enclosure suitable for indoor use. The front panel of the cabinet shall contain all push buttons, and Human Machine Interface as detailed within this specification. The internal portion of the cabinet shall contain all rail-mounted PLC equipment, power supply, processor, and interface cards. Relays and terminals shall also be contained within the cabinet. The PLC subsystem shall be Siemens S7/200 model CPU224XP. Terminal strips for all field wiring shall be furnished within the panel.
- B. Fuses and simplex outlet shall be provided within the panel.
- C. All digital outputs shall be provided with relay contacts.

3.03 VARIABLE FREQUENCY DRIVE (VFD)

- A. The drive for the booster pump shall consist of an adjustable frequency AC motor controller.
- B. The VFD shall provide continuously adjustable settings over a range of not less than 10 to 1. The controller shall be solid state.
- C. The VFD shall be mounted in the instrument control panel.

3.04 DEVICES FOR OPERATOR INTERFACE

External face mounted devices for operator interface shall be as follows:

A. Human Machine Interface

The HMI shall be touch screen type with 6 in. diagonal monochrome display. The HMI shall be fully programmed with shall allow the operator to view and modify system variables within the PLC. It shall allow the operator to set process flow rate, run status and CIP operation through the use of virtual switches/pushbuttons. The HMI shall be Siemens model TP177A.

- B. Pushbuttons
 - 1. Pushbuttons shall be Siemens. Panel Mounted Pushbuttons shall be provided to perform the following functionality:
 - a. Emergency Stop

3.05 PROCESS CONTROL SYSTEM FUNCTIONS

- A. The LCP shall automatically control the treatment process.
- B. The HMI shall provide operator adjustable set points for the following parameters:
 - 1. RO selector Man/Auto
 - 2. RO selector Start/Stop
 - 3. Permeate Flow Rate Setpoint
 - 4. Auto flush selector On/Off
 - 5. Alarm silence
 - 6. Alarm reset
 - 7. CIP Start/Stop
 - 8. CIP Flow rate set
- C. The PLC shall, via the HMI, provide the following status indicators at a minimum:
 - 1. Feed flow, reject flow, product flow, % recovery
 - 2. Total run time
 - 3. RO operating mode
 - 4. Pump status
 - 5. Inlet, reject, product to tank, product to drain valve status
 - 6. Pretreatment lockout
 - 7. Storage tank full (Standby no call for water)
- D. The following alarm conditions shall be monitored by LCP. All alarms shall be visible via the HMI Display.
 - 1. Low quality product
 - 2. Low feed pressure
 - 3. Low reject flow
 - 4. High product flow
 - 5. Low feed flow
 - 6. High pump discharge pressure
 - 7. High feed water temperature
 - 8. ORP alarm
 - 9. Emergency Stop
 - 10. VFD fault
 - 11. CIP low flow

- E. The following additional features shall be provided in the LCP.
 - 1. Alarm horn and alarm pilot light
 - 2. Chemical injection pump terminals
 - 3. Auxiliary contacts for pump running & fault

3.06 INSTRUMENTS

- A. Pressure Sensors and Gauges
 - 1. Pressure gauges shall be 316 stainless steel bourdon tube and socket with a 63mm glycerin filled dial. Pressure gauges shall be Ashcroft series 1009.
 - 2. Pressure switches shall be provided for low feed pressure and high discharge pressure. The pressure switches shall have a 15 amp switching power at 120 volts. The low pressure switch shall have an adjustable range between 4 and 50 psig. The high pressure switch shall have an adjustable range between 30 and 600 psig. Units shall have a BUNA N primary wetted diaphragm and a 1/8" 316 stainless steel wrought casing.
- B. Conductivity Sensors
 - 1. Conductivity shall be continuously monitored by the control system. The monitor shall be NEMA 4 and be panel mounted. Conductivity monitors shall be Signet 8900 Series Multi-parameter.
 - Conductivity probes shall have 316 stainless steel electrodes, 316 stainless steel body, and FPM O-rings. Units shall thread into a ¾" NPT connection and be rated to 100 psig. Probes shall be Signet 2850 Series.
- C. Flow Sensors/Indicators
 - Each skid will be equipped with two flow sensors for feed and reject flow monitoring and control. The sensors shall be paddlewheel style and shall be polypropylene and mount in a T fitting in the process piping. The flow sensor will be Signet 2536 series.
 - 2. Each skid shall have an acrylic rotameter for flow determination in the product blend line. The rotameter shall have 316 stainless steel end connections. The rotameter shall be manufactured by King Products.
- D. PH/ORP Sensors
 - PH and ORP of the raw water shall be continuously monitored by the control system. A sample shall be taken from a high pressure point, fed to the sensors, and returned to a low pressure point so that no waste stream is generated from the sampling. The monitor shall be NEMA 4 and be panel mounted. The monitor shall be Signet 8900 Series Multi-parameter.

2. PH probe shall be Signet model 2774 and ORP probe shall be Signet model 2775.

Section 4 - Execution

4.01 DELIVERY OF EQUIPMENT

- A. The membrane skids shall be shipped to site as a complete unit with the exception of the blend line and membrane elements, which will be installed on-site by the contractor.
- B. The CIP tank and hose kit shall be shipped loose for placement and field installation by others.

4.02 INSTALLATION AND TRAINING

The Vantage Series Reverse Osmosis System shall be installed as shown on the Contract Drawings and specified herein.

The Manufacturer shall inspect the installation of all equipment in this section prior to start-up in order to verify that the equipment has been properly installed and operates properly as a system and individually.

After the equipment has been properly installed, the Manufacturer shall calibrate the equipment with the Owner's operator present.

The Manufacturer shall furnish the service of a competent technical service representative after Contractor's start-up to instruct the Owner's personnel in the operation and maintenance of the equipment.

The Manufacturer's representative shall be present for six (6) days in three (3) trips total to provide services described above.

APPENDIX N Point of Entry Reverse Osmosis System
SERIES AA - 350 TO 1,000 GPD SYSTEMS

STANDARD EQUIPMENT

- Thin Film Composite Membranes
- Stainless Steel Pressure Vessels
- Rotary Vane Brass Pump
- Motor
- 5 Micron Pre-Filter (1)
- 10 Micron Carbon Filters (2)
- Polypropylene Filter Housings (3)
- Automatic inlet feed solenoid valve

- Heavy duty powder coated frame
- Liquid Filled System Pressure Gauges
- Low Pressure Switch
- System control valve
- Recycle control valve
- Polyethylene High Pressure Tubing
- Product Tank Pressure Control (Required to turn system on/off with pressurized tank - tank sold separately)

OPTIONAL EQUIPMENT

Stainless Steel Pump

- * Pressurized Product Water Storage Tank 40 or 88 Gallon Size
- *Pre-treatment equipment: Softener Carbon filter Multi-media filter

*Recommended Minimum Options

| | Capacity | | Elements* | | Line Sizes (In/Cm) | | | Dim | Approx Shipping | | |
|--------------|----------|--------|-----------|-------------------|--------------------|--------|--------|--------|-----------------|--------|---------|
| Model | GPD | m³/day | Qty. | Length (In/cm) | Inlet | Perm. | Conc. | Length | Width | Height | (lb/kg) |
| AA-12521-116 | 350 | 1.3 | 1 | 21/54 | .375/1 | .375/1 | 0.25/1 | 14/36 | 26/66 | 20/51 | 60/26 |
| AA-22521-116 | 700 | 2.7 | 2 | 21/54 | .375/1 | .375/1 | 0.25/1 | 14/36 | 26/66 | 20/51 | 70/30 |
| AA-32521-116 | 1000 | 3.8 | 3 | 21/54 | .375/1 | .375/1 | 0.25/1 | 14/36 | 26/66 | 20/51 | 65/21 |

*Elements are 2.5" (6.4 cm) Diameter

NOTES

- All dimensions and weights are approximate.
- System must operate with a pressurized storage tank to turn system on/off (quoted separately).
- Systems rated at 77°F (25°C) using 1000 ppm sodium chloride solution and 200 psi pressure. System capacity changes significantly with water temperature. For higher TDS, a water analysis must be supplied and could result in modifications to the system.
- Chlorine must be removed prior to RO system if present in the feed water.
- Water must be pretreated by a softener or antiscalant to avoid scaling the membranes.
- Standard packaging is boxed, crating optional.

ORDERING INFORMATION

Please add our voltage codes to the end of the model number when ordering. Example: AA-12521-116 = 110v / 1 ph / 60 hz.

Voltage 116 = 110v/ 1ph/ 60hz Codes: 215 = 220/230v, 1ph, 50hz

Three Phase Not Available

are trademarks of APPLIED MEMBRANES, INC. © 2007 Applied Membranes, Inc



Series AA Systems



Designed to produce low dissolved solids water from tap or well water, these Reverse Osmosis RO systems use high efficiency reverse osmosis membranes. The product water is used in applications such as restaurants, aquariums, small manufacturing, and a wide variety of other applications.

Series AA RO systems offer a compact design. These economically priced systems are simple to install and operate. When combined with a water softener as pretreatment, they offer a reliable water purification solution.

Key Features:

- Over 20 years of experience is reflected in our quality
- Compact, Heavy Duty, Powder Coated Frame
- Proven components used throughout the system
- Conservatively engineered for reliable long term performance
- Factory tested to ensure trouble-free operation

STANDARD EQUIPMENT AA RO Systems

- Thin Film Composite Membranes
- Stainless Steel Pressure Vessels
- Rotary Vane Brass Pump
- Motor
- 5 Micron Pre-Filter (1)
- 10 Micron Carbon Filters (2)
- Polypropylene Filter Housings (3)
- Brass Auto Feed Shut-Off

OPTIONAL EQUIPMENT

- Stainless Steel Pump
- Stainless Steel Back Pressure Regulator
- Pressurized Product Water Storage Tank*

Tank Level Control for Atmospheric Tank Softener*

Low Pressure Switch

Brass Pressure Regulator

Heavy duty powder coated frame

Liquid Filled System Pressure Gauges

Polyethylene High Pressure Tubing

Backwashable Pretreatment* - Carbon or Media

http://www.appliedmembranes.com/deleted%20pages/aasys.html



Scroll to the bottom for additional photographs

Product Tank Pressure Control (turns system off with pressurized tank - tank sold separately)

Page 1 of 4

Series AA Systems

in 10, 30, 40 or 88 Gallon Size

Recycle Loop with Brass Valve

*Recommended Minimum Options

Three Phase Not Available

Page 2 of 4

| Model | Capacity | | Elements (2.5" Dia) | | Line sizes (in/cm) | | | D | Approx Weight | | |
|----------|----------|--------|---------------------|-------------------|--------------------|--------|--------|--------|---------------|--------|---------|
| | GPD | m3/day | Qty | Length (in/cm) | Iniet | Perm | Conc | Length | Width | Height | (lb/kg) |
| AA-12514 | 220 | 0.8 | 1 | 14/36 | .375/1 | .375/1 | 0.25/1 | 14/36 | 26/66 | 20/51 | 55/24 |
| AA-12521 | 350 | 1.3 | 1 | 21/54 | .375/1 | .375/1 | 0.25/1 | 14/36 | 26/66 | 20/51 | 60/26 |
| AA-32514 | 525 | 2.0 | 3 | 14/36 | .375/1 | .375/1 | 0.25/1 | 14/36 | 26/66 | 20/51 | 6521 |
| AA-22521 | 700 | 2.7 | 2 | 21/54 | .375/1 | .375/1 | 0.25/1 | 14/36 | 26/66 | 20/51 | 70/30 |

NOTES

- All dimensions and weights are approximate.
- System must operate with a pressurized storage tank to turn system on/off (quoted separately).
- Systems rated at 77°F (25°C) using 1000 ppm sodium chloride solution and 200 psi pressure. System capacity changes significantly with water temperature. For higher TDS, a water analysis must be supplied and could result in modifications to the system.
- Chlorine must be removed prior to RO system if present in the feed water.
- Water must be pretreated by a Water Softener or antiscalant to avoid scaling the membranes.
- Standard packaging is boxed, crating optional.

ORDERING INFORMATION

Please add our voltage codes to the end of the model number when ordering. Example: AA-12521-116 = 110V/1 ph/ 60 hz

Voltage Codes:

215 = 220/230, 1 ph, 50 Hz

216 = 220/230, 1 ph, 60 hz

116 = 110v/1 ph/60 hz

Replacement Parts and Consumables for AA Reverse Osmosis Systems

Click here for replacement Reverse Osmosis Membranes

- Click here for replacement Membrane Pressure Vessels
- Click here for replacement Sediment filters
- Click here for replacement Carbon Filters
- Click here for replacement Filter Housings
- Click here for replacement Components
- Click here for Membrane Cleaning Cartridges

PHOTOGRAPHS of AA Series RO Systems



'This page was last updated 06/30/08

For prompt, courteous and reliable service, contact us today!



Copyright © 2009 Applied Membranes, Inc. All Rights Reserved.

[Contact Us] [How to Purchase our Products] [Download Catalog] [Download Manuals] [Download Forms & Product Literature] [Track an Order] [Membranes] [RO Systems] [Seawater Desailnation Systems] [Water Treatment Systems] [Metain Systems] [Membrane Systems] [Water Treatment Systems] [Membranes] [Inon Filters] [Iron Filters] [Filters & Housings] [Membrane Housings/Pressure Vessels] [Residential Components] [Pumps] [Membrane Chemicals] [Ultraviolet] [Ozone] [Water Quality Test Equipment] [About Applied Membranes]

PPLED[®] FILTERS PYROLOX FILTERS FOR IRON REMOVAL

About Pyrolox:

A mined ore, Pyrolox effectively reduces iron, sulfur and manganese from problem water.

A Naturally mined ore, Pyrolox is a mineral form of manganese dioxide which has been used in water treatment for more than 75 years. Pyrolox is a granular filtration media for hydrogen sulfide, iron and manganese reduction. Pyrolox functions as a catalyst, but itself remains relatively unchanged. Pyrolox works on a principle whereby the hydrogen sulfide, iron and manganese are oxidized and trapped on the media while simple backwashing cleans the bed. No chemical regeneration is required, nothing is imparted into the drinking water and Pyrolox has a high capacity for low contaminant concentrations. Pyrolox can be used in conjunction with aeration, chlorination, ozone or other pretreatment methods for difficult applications. Chlorine or other oxidants accelerate the catalytic reaction.

Advantages of Pyrolox:

- Effective reduction of iron, sulfur and manganese
- Durable material with long service life and low annual attrition of bed
- No chemical regeneration required, only periodic backwashing

Conditions for Operation:

Iron Filters (Pyrolox)

- pH: 6.5 9.0
- Because of its heavy weight, it is very important that Pyrolox filters are backwashed properly to insure adequate bed expansion and continued service life.



With SS Jacket***

With No Jacket

| Model No.* | Media (Cu.Ft.) | Service Flow Rate** (GPM) | Backwash** (GPM) | Fleck Valve Head | Tank Size (Dia." × H.") | Pipe Size (in.) | Approx. Ship. Wt. (Ibs) | |
|------------|-------------------|------------------------------|---------------------|------------------------|----------------------------|--------------------|-------------------------------|--------|
| W-MFI744P | 0.3 | 1.3 | 7 | 5600 | 7 × 44 | 3/4 | 75 | |
| W-MFI844P | 0.5 | 1.7 | 7 | 2510 | 8 × 44 | 1 | 95 | |
| W-MFI940P | 0.6 | 2.2 | 12 | 2510 | 9 × 40 | 1 | 100 | |
| W-MFI1040P | 1.0 | 2.7 | 15 | 2510 | 10 × 40 | 1 | 155 | |
| W-MFI1054P | 1.0 | 2.7 | 15 | 2510 | 10 × 54 | 1 | 165 | |
| W-MFI1252P | 1.5 | 3.9 | 15 | 2510 | 12 × 52 | 1 | 245 | |
| W-MFI1354P | 2.0 | 4.6 | 25 | 2750 | 13 × 54 | 1 | 285 | |
| W-MFI1465P | 2.5 | 5.3 | 25 | 2750 | 14 × 65 | 1 | 435 | |
| W-MFI1665P | 3.0 | 7.0 | 30 | 2850 | 16 × 65 | 1.5 | 465 | |
| W-MFI2162P | 4.0 | 12.0 | 49 | 2850 | 21 × 62 | 1.5 | 635 | Syste |
| W-MFI2472P | 6.0 | 15.7 | 60 | 3150 | 24 × 72 | 2 | 905 | SKIA N |

System Shown with Optional

0

System Shown with Optional Skid Mounting & Control Panel

Notes:

* Please add the appropriate voltage code to the end of the model no. when ordering.

110v/60Hz = 116, 220v/60Hz = 216, 220v/50Hz = 215 *Example: W-MFI744P-116*

** 5 gpm per sq. ft. of media is the best design condition for filtration. Backwash flow rate based on 25 psi pressure drop.

*** Stainless Steel Jacket available for 9-16" Diameter as an additional option.

Specifications

- Vessel is rated at 150 psi maximum operating pressure, 120°F maximum operating temperature.
- All Systems Automatic
- Fleck Control Valve
- Standard Valve Configuration Below. Metered Valve, Electronic Valve, or change to 7/12-Day timer are available as options.
 7"-14" Diameter: 7-Day Timer.
 16"-48" Diameter: 12-Day Timer.

are trademarks of APPLIED MEMBRANES, INC. © 2006 Applied Membranes, Inc



CARBON FILTERS – GRANULAR ACTIVATED (GAC)

About Carbon Filters:

These filters are used to reduce chlorine, organics, color, tannin, and objectionable tastes and odors from water. Automatic backwashing system removes the trapped contaminants within the filter bed and washes them down the drain. Our Household Carbon Filters (10"-12" Diameter) use NSF approved coconut shell based carbon.

Advantages of Carbon Filtration:

- Significantly reduce the following contaminants:
 Chlorine
 - Chlorine By-Products such as Trihalomethanes (THMs)
 - Bad Tastes and Odors
 - Turbidity
 - Herbicides, Pesticides & Insecticides
 - Volatile Organic Chemicals (VOCs)





With SS Jacket***

With No Jacket

| Model No.* | Volume of | Flow Rate | e (GPM)** | Backwash Flow | Fleck Valve | Tank Size | In/Out Conn. | Approx. Ship. |
|------------------|----------------|-----------------------|------------|---------------|-------------|----------------|--------------|---------------|
| - Love of Downie | Media (Cu.Ft.) | 5gpm/ft. ² | 15gpm/ft.2 | (GPM)** | Head | (Dia"×H") | (in.) | Wt. (lbs) |
| W-G744 | 0.4 | 1 | 4 | 2 | 5600 | 7 × 44 | 3/4 | 60 |
| W-G844 | 0.5 | 2 | 5 | 3 | 5600 | 8 × 44 | 3/4 | 62 |
| W-G940 | 0.7 | 2 | 6 | 3.5 | 5600 | 9 × 40 | 3/4 | 65 |
| W-G1040 | 1.0 | 2 | 7 | 4 | 5600 | 10×40 | 3/4 | 70 |
| W-G1054 | 1.4 | 2 | 7 | 4 | 5600 | 10×54 | 3/4 | 80 |
| W-G1252 | 1.9 | 4 | 12 | 6 | 2510 | 12 × 52 | 1 | 100 |
| W-G1354 | 2.4 | 4 | 14 | 7 | 2510 | 13 × 54 | 1 | 135 |
| W-G1465 | 3.0 | 5 | 16 | 7 | 2510 | 14 × 65 | 1 | 185 |
| W-G1665 | 4.0 | 7 | 21 | 15 | 2510 | 16×65 | 1 | 235 |
| W-G2162 | 8.0 | 13 | 36 | 25 | 2850 | 21 × 62 | 1.5 | 335 |
| W-G2472 | 10.0 | 15 | 47 | 40 | 2850 | 24 × 72 | 1.5 | 410 |
| W-G3072 | 15.0 | 24 | 74 | 55 | 3150 | 30 × 72 | 2 | 485 |
| W-G3672 | 20.0 | 35 | 106 | 75 | 3150 | 36 × 72 | 2 | 785 |
| W-G4272 | 30.0 | 48 | 144 | 100 | 3900 | 42 × 72 | 3 | 935 |
| W-G4872 | 40.0 | 60 | 188 | 100 | 3900 | 48 × 72 | 3 | 1,535 |

Notes:

* Please add the appropriate voltage code to the end of the model no. when ordering.

110v/60Hz = 116, 220v/60Hz = 216, 220v/50Hz = 215 Example: W-G744-116

** 5 gpm per sq. ft. of media is the best design condition for filtration. For relatively clean water, you may go up to design criteria of 15 gpm per sq. ft. Backwash flow rate based on 25 psi pressure drop.

*** Stainless Steel Jacket available for 9-16" Diameter as an additional option.

Specifications

- Vessel rated at 150 psi max. operating pressure, 120°F max. operating temp.
- All Systems Automatic
- Fleck Control Valve
- Standard Valve Configuration Below. Metered Valve, Electronic Valve, or change to 7/12-Day timer are available as options.
 - 7"-14" Diameter: 7-Day Timer. 16"-48" Diameter: 12-Day Timer.



Systems Shown with Optional Skid Mounting and Control Panel

are trademarks of APPLIED MEMBRANES, INC. © 2006 Applied Membranes, Inc



APPENDIX O Present Worth Comparison of Alternative Evaluation

Battlefield Golf Club Water Project PRESENT WORTH OPINION OF COST EVALUATIONS

| | A | Iternative 1 | Α | Iternative 2 | Alternative 3 | | А | lternative 4 |
|---------------------------|----|--------------|----|--------------|---------------|-----------|----|--------------|
| Expected System Life (yr) | | 30 | | 30 | 30 | | 30 | |
| Capital Cost | \$ | 7,221,756 | \$ | 8,411,704 | \$ | 2,770,149 | \$ | 803,000 |
| O&M Costs/yr | \$ | 3,000 | \$ | 187,227 | \$ | 460,879 | \$ | 10,000 |
| Present Worth Costs | \$ | 7,267,873 | \$ | 11,289,844 | \$ | 9,854,989 | \$ | 956,725 |

Alternative 1 Provide City Of Chesapeake Water via a Water Main Extension

Alternative 2 Installation of Community System

Alternative 3 Installation of Point of Entry (POE) Treatment Systems on Existing Private W

Alternative 4 Development and Installation of New Individual Home Owner Supply Wells

Assumptions

Cost Opinions do not consider Engineering Time required for alternatives

Cost Opinions do not consider Permitting Time and Constraints

Cost Opinions make assumptions for market value of land acquistion

Cost Opinions are not actual determinations of project costs and are strictly for comparison

Cost Opinions do not consider cost of brine disposal

Battlefield Golf Club Water Project Centerville Turnpike Water Main - Alternative 1

| ITEM NO. | ITEM DESCRIPTION | UNIT | QTY | UNIT COST | LINE ITEM COST |
|----------|--|-----------|-------|-------------------|--------------------|
| 1 | Mobilization | LS | 1 | \$92,000.00 | \$100,000.00 |
| 2 | 16" Water Main - Ductile Iron Pipe | LF | 8439 | \$108.25 | \$913,521.75 |
| 3 | 10" Water Main - Ductile Iron Pipe | LF | 384 | \$74.66 | \$28,669.44 |
| 4 | 6" Water Main - Ductile Iron Pipe | LF | 160 | \$58.00 | \$9,280.00 |
| | Water Main Undercut Excavation & Replacement | | | | |
| 5 | with Bedding Stone | CY | 1009 | \$32.00 | \$32,288.00 |
| 6 | Select Backfill , CBR 15 - Pipe | CY | 3844 | \$20.00 | \$76,880.00 |
| 7 | Pipe Bedding | CY | 570 | \$54.00 | \$30,780.00 |
| 8 | Course Aggregate | TON | 1976 | \$50.00 | \$98,800.00 |
| 9 | 16" Cross | EA | 1 | \$2,000.00 | \$2,000.00 |
| 10 | 16" x 10"Tee | EA | 2 | \$1,836.00 | \$3,672.00 |
| 11 | 16" x 6"Tee | EA | 16 | \$1,661.00 | \$26,576.00 |
| 12 | 16" 45° Bend - Ductile Iron Pipe | EA | 28 | \$1,177.00 | \$32,956.00 |
| 13 | 16" 22-1/2" Bend - Ductile Iron Pipe | EA | 24 | \$1,193.00 | \$28,632.00 |
| 14 | 16" Butterfly valve - Ductile Iron Pipe | EA | 11 | \$4,500.00 | \$49,500.00 |
| 15 | Fire Hydrant Assembly | EA | 200 | \$3,000.00 | \$51,000.00 |
| 10 | Connect to Existing Water Main | TON | 299 | \$25.00 | \$7,475.00 |
| 17 | Service Connections | | 2 | \$3,500.00 | \$7,000.00 |
| 10 | Utility Tranch Davament Datching | | 1410 | \$2,500.00 | \$75,000.00 |
| 19 | 2" SM-24 | Ton | 1410 | \$90.00 | \$11,700,00 |
| 20 | 7" BM-2 | Ton | 455 | \$90.00 | \$40,950,00 |
| 20 | 10" Aggregate Base | Ton | 630 | \$35.00 | \$22,050,00 |
| 22 | Traffic Control | LS | 1 | \$5,000,00 | \$5,000,00 |
| 23 | Erosion and Sediment Control Pipe line | LS | 1 | \$25,000.00 | \$25,000.00 |
| 24 | Curb and Gutter Replacement | LF | 60 | \$45.00 | \$2,700.00 |
| 25 | Storm Drain Pipe - 15" RCP | LF | 330 | \$44.00 | \$14,520.00 |
| 26 | Storm Drain Pipe - 18" RCP | LF | 50 | \$62.00 | \$3,100.00 |
| 27 | Storm Drain Pipe - 24" RCP | LF | 442 | \$77.00 | \$34,034.00 |
| 28 | Storm Drain Pipe - 30" RCP | LF | 20 | \$160.00 | \$3,200.00 |
| 29 | Flared End Section - 15" RCP | EA | 19 | \$750.00 | \$14,250.00 |
| 30 | Flared End Section - 18" RCP | EA | 2 | \$780.00 | \$1,560.00 |
| 31 | Flared End Section - 24" RCP | EA | 17 | \$800.00 | \$13,600.00 |
| 32 | Flared End Section - 30" RCP | EA | 2 | \$1,000.00 | \$2,000.00 |
| 33 | Drop Inlet | EA | 1 | \$5,000.00 | \$5,000.00 |
| 34 | Manhole | EA | 2 | \$4,000.00 | \$8,000.00 |
| 35 | Connect to Existing Storm Struct. | EA | 2 | \$1,000.00 | \$2,000.00 |
| 36 | Select Tree Removal | EA | 10 | \$585.00 | \$5,850.00 |
| 37 | Seeding, Fertilizing and Lime | LS | 1 | \$10,000.00 | \$10,000.00 |
| 38 | Sawcut and Remove Pavement | LF | 1410 | \$3.85 | \$5,428.50 |
| 20 | Pavement Milling & Overlay for Utility Patch | 017 | 2506 | ¢1,5,00 | *52 5 00 00 |
| 39 | 2° Mill | SY | 3506 | \$15.00 | \$52,590.00 |
| 40 | Asphalt Overlay | Ion | 385 | \$125.00 | \$48,125.00 |
| 41 | I ramic Control | LS | l | \$5,000.00 | \$5,000.00 |
| 42 | Pavement Repair Along Centerville Tpk. | cv | 10441 | \$15.00 | ¢156 615 00 |
| 42 | 2 -Mill 12 wide A 7851 long | 51 Ton | 10441 | \$13.00 | \$150,015.00 |
| 45 | Traffia Control | | 1/22 | \$90.00 | \$134,980.00 |
| 44 | Isolated Davement Pengir | LS CV | 1000 | \$9,000.00 | \$9,000.00 |
| 4J 46 | VDOT EC-1 For Ditch Stabalization | SI SV | 12220 | \$00.00 \$2.25 | \$27 515 25 |
| 40 | Excavation For Ditch | CY | 12229 | \$2.23 \$5.45 | \$27,515.25 |
| 48 | Tonsoil | CY | | \$25 M | \$55 800 00 |
| 49 | Select Borrow, CBR 15 - Ditch fill Only | CY | 3707 | \$20.00 | \$74 140 00 |
| 50 | Fine Grade Shoulder | SY | 9166 | \$1.50 | \$13 749 00 |
| 51 | Concrete Driveway Replacement | EA | 3 | \$2,800.00 | \$8,400.00 |
| 52 | Asphalt Driveway Replacement | EA | 4 | \$3.000.00 | \$12.000.00 |
| 53 | Gravel Driveway Replacement | EA | 4 | \$1,000.00 | \$4,000.00 |

Battlefield Golf Club Water Project Centerville Turnpike Water Main - Alternative 1

| ITEM NO. | ITEM DESCRIPTION | UNIT | QTY | UNIT COST | LINE ITEM COST |
|----------|---------------------------------------|------|-------|-------------|----------------|
| 54 | Traffic Control Non paving operations | LS | 1 | \$40,000.00 | \$40,000.00 |
| | | | | | |
| | Subtotal | | | | \$2,570,351.99 |
| | Contengency 10% | | | | \$257,035.20 |
| | Easement Acquisition | | | | |
| 55 | Business | SF | 10500 | \$ 15.00 | \$157,500.00 |
| 56 | Other | SF | 55380 | \$ 8.00 | \$443,040.00 |
| | | | | | |
| | TOTAL | | | | \$3,427,927.19 |

| ITEM NO. | ITEM DESCRIPTION | UNIT | OTY | U | NIT COST | LII | NE ITEM COST |
|----------|---|-------------|--------------|--------|---------------|--------|----------------|
| | | | ~ | _ | | | |
| 1 | Mobilization | LS | 1 | \$ | 100.000.00 | \$ | 150.000.00 |
| | Whittamore Road | | | | , | - | , |
| 2 | 10" DI Pipe | LF | 2250 | \$ | 68.00 | \$ | 153.000.00 |
| 3 | 8" DI Pine | LF | 5685 | \$ | 58.00 | \$ | 329,730.00 |
| 4 | 6" DI Pine | LF | 370 | \$ | 50.00 | \$ | 18 500 00 |
| 5 | Hydrants & Appurtenances | FA | 17 | \$ | 3,000,00 | \$ | 51,000,00 |
| 6 | 10" Gate Valve & Box | ΕΛ | 2 | \$ | 2 500 00 | \$ | 5 000 00 |
| 7 | 8" Gate Valve & Box | ΕΛ | 5 | \$ | 1 300 00 | \$ | 6 500 00 |
| 8 | 6" Gate Valve & Box | EA EA | 17 | ф ¢ | 031.00 | ф С | 15 827 00 |
| 0 | Connect to avisting Water Main | | 1/ | ¢ | 3 500 00 | ¢ | 3 500 00 |
| 10 | Sorvice Connections | EA | 20 | ¢ | 1,600,00 | ¢ | 48,000,00 |
| 10 | Water Main Undercut Excavation & Replacement with | LA LE/6" | 30 | ¢ | 1,000.00 | φ | 48,000.00 |
| 11 | Bedding Stone | denth | 4000 | ¢ | 7 43 | ¢ | 20 720 00 |
| 11 | Select Backfill CBP 15 Dipa Install | CV | 7164 | ф ¢ | 20.00 | ф ¢ | 143 280 00 |
| 12 | Temperature Development Detab Water Main | CI CV | 7104 5272 | ф ф | 20.00 | ¢ | 145,280.00 |
| 15 | Concert Decement Patch water Main | 51 | 35/5 | \$ | 27.00 | ¢ | 145,071.00 |
| 14 | Sawcut Pavement | | 16120 | \$ | 10,000,00 | \$ | 16,120.00 |
| 15 | Erosion and Sed. Control | LS | 1 | \$ | 10,000.00 | \$ | 10,000.00 |
| 16 | Storm Drain Pipe-24" RCP | LF | 376 | \$ | 130.00 | \$ | 48,880.00 |
| 17 | Flared End Section 24" RCP | EA | 47 | \$ | 2,350.00 | \$ | 110,450.00 |
| 18 | Crusher Run Fill at Culverts | CY | 47 | \$ | 50.00 | \$ | 2,350.00 |
| 19 | Traffic Control | LS | 1 | \$ | 15,000.00 | \$ | 15,000.00 |
| | Water Line Sub Total | | | | | \$ | 1,151,928.00 |
| | Rebuild Entire Roadway | | | | | | |
| 20 | Demolition and removal of pavement and subgrade. Haul off | CY | 12935 | \$ | 20.00 | \$ | 258,700.00 |
| 21 | 24" Select Material, CBR=15, Sand Blanket | CY | 11940 | \$ | 19.00 | \$ | 226,860.00 |
| 22 | Grade/compact Subgrade | SY | 17911 | \$ | 1.50 | \$ | 26,866.50 |
| 23 | Subgrade Undercut & replacement W/ select material | CY | 1000 | \$ | 40.00 | \$ | 40,000.00 |
| 24 | 8" Aggregate Base Material | Ton | 7630 | | \$35.00 | | \$267,050.00 |
| 25 | Grade Aggregate Base Material | 51 | 1/911 | | \$2.00 | | \$35,822.00 |
| 26 | 2 Surface & 4 Binder Aspnait | Ton | 0180 | | \$90.00 | | \$556,200.00 |
| 27 | Troffic Control for Boody ov Construction | 51 | 1/911 | ¢ | <u>\$2.30</u> | | \$44,777.30 |
| 20 | Subtotal Pabuild Poadway | LS | 1 | ¢ | 20,000.00 | | \$20,000.00 |
| | Subiotal Rebuild Roadway | | | | | | \$1,470,270.00 |
| | Sub Total Whittamore | | | | | | \$2 628 204 00 |
| | Sub Total Williamole | | | | | | φ2,020,204.00 |
| | Murray Drive | | | | | | |
| 29 | 10" DI Pine | LF | 2127 | \$ | 68.00 | \$ | 144 636 00 |
| 30 | 8" DI Pine | LF | 4936 | \$ | 58.00 | \$ | 286,288,00 |
| 31 | 6" DI Pine | LF | 162 | \$ | 50.00 | \$ | 8,100.00 |
| 32 | Hydrants & Appurtenances | EA | 16 | \$ | 3.000.00 | \$ | 48,000.00 |
| 33 | 10" Gate Valve & Box | EA | 1 | \$ | 2,500.00 | \$ | 2,500.00 |
| 34 | 8" Gate Valve & Box | EA | 2 | \$ | 1.300.00 | \$ | 2,600.00 |
| 35 | 6" Gate Valve & Box | EA | 16 | \$ | 931.00 | \$ | 14,896.00 |
| 36 | Connect to existing Water Main | LA | 1 | \$ | 3,500.00 | \$ | 3,500.00 |
| 37 | Service Connections | EA | 41 | \$ | 1,600.00 | \$ | 65,600.00 |
| 38 | Select Borrow, CBR 15 - Pipe Install Only (Backfill) | CY | 37 | \$ | 40.00 | \$ | 1,480.00 |
| 39 | Sawcut Pavement | LF | 170 | \$ | 10.00 | \$ | 1,700.00 |
| 40 | Curb and Gutter Replacement | LF | 50 | \$ | 45.00 | \$ | 2,250.00 |
| 41 | Erosion and Sed. Control | LS | 1 | \$ | 4,000.00 | \$ | 4,000.00 |
| 42 | Traffic Control | LS | 1 | \$ | 2,000.00 | \$ | 2,000.00 |
| | Pavement Repair | | | | | | |
| 43 | 1.5" SM-2A | TON | 4 | \$ | 1.000.00 | \$ | 4,000,00 |

Battlefield Golf Club Water Project Murray Drive & Whittamore Road Water Main - Alternative 1

| Battlefield Golf Club Water Project |
|---|
| Murray Drive & Whittamore Road Water Main - Alternative 1 |

| ITEM NO. | ITEM DESCRIPTION | UNIT | QTY | U | NIT COST | LIN | E ITEM COST |
|----------|---|------|------|----|-----------|-----|----------------|
| 44 | 4" BM-2 | TON | 9 | \$ | 1,000.00 | \$ | 9,000.00 |
| 45 | Aggregate Base Mat. | TON | 12 | \$ | 50.00 | \$ | 600.00 |
| 46 | Grading | SY | 7850 | \$ | 1.50 | \$ | 11,775.00 |
| 47 | 2" Topsoil | AC | 1.62 | \$ | 26,000.00 | \$ | 42,120.00 |
| 48 | Seeding | AC | 1.62 | \$ | 2,500.00 | \$ | 4,050.00 |
| | Sub Total Murray Drive | | | | | | \$659,095.00 |
| | | | | | | | |
| | Total Murray, Whittamore and Mobilization | | | | | | \$3,437,299.00 |
| | 10% Contigency | | | | | | \$343,729.90 |
| | Easement Acquisition * | | | | | | |
| 48 | Residential (FH and Water Meters) | SF | 1600 | \$ | 8.00 | \$ | 12,800.00 |
| | Total | | | | | \$ | 3,793,828.90 |
| | • | | • | | | | |

| ITEM NO. | ITEM DESCRIPTION | UNIT | QTY | UNIT COST | LINE ITEM COST |
|----------|---|-------|-------|--------------|----------------|
| | | | | | |
| 1 | Mobilization | LS | 1 | \$100,000.00 | \$150,000.00 |
| | Whittamore Road | | | | |
| 2 | 8" DI Pipe | LF | 7935 | \$58.00 | \$460,230.00 |
| 3 | 6" DI Pipe | LF | 370 | \$50.00 | \$18,500.00 |
| 4 | Hydrants & Appurtenances | EA | 17 | \$3,000.00 | \$51,000.00 |
| 5 | 10" Gate Valve & Box | EA | 2 | \$2,500.00 | \$5,000.00 |
| 6 | 8" Gate Valve & Box | EA | 5 | \$1,300.00 | \$6,500.00 |
| 7 | 6" Gate Valve & Box | EA | 17 | \$931.00 | \$15,827.00 |
| 8 | Service Connections | EA | 30 | \$1,600.00 | \$48,000.00 |
| | Water Main Undercut Excavation & Replacement with | LF/6" | | | |
| 9 | Bedding Stone | depth | 4000 | \$7.43 | \$29,720.00 |
| 10 | Select Backfill, CBR 15 - Pipe Install | CY | 7164 | \$20.00 | \$143,280.00 |
| 11 | Temporary Pavement Patch Water Main | SY | 5373 | \$27.00 | \$145,071.00 |
| 12 | Sawcut Pavement | LF | 16120 | \$1.00 | \$16,120.00 |
| 13 | Erosion and Sed. Control | LS | 1 | \$10.000.00 | \$10.000.00 |
| 14 | Storm Drain Pipe-24" RCP | LF | 376 | \$130.00 | \$48,880.00 |
| 15 | Flared End Section 24" RCP | EA | 47 | \$2,350.00 | \$110.450.00 |
| 16 | Crusher Run Fill at Culverts | CY | 47 | \$50.00 | \$2,350.00 |
| 17 | Traffic Control | LS | 1 | \$15.000.00 | \$15.000.00 |
| | Water Line Sub Total | | | | \$1,125,928.00 |
| | Rebuild Entire Roadway-Whittamore | | | | 1 7 - 7 |
| | Demolition and removal of pavement and subgrade. Haul | | | | |
| 18 | off-site | CY | 12935 | \$20.00 | \$258,700.00 |
| 19 | 24" Select Material, CBR=15, Sand Blanket | CY | 11940 | \$19.00 | \$226,860.00 |
| 20 | Grade/compact Subgrade | SY | 17911 | \$1.50 | \$26,866.50 |
| 21 | Subgrade Undercut & replacement W/ select material | CY | 1000 | \$40.00 | \$40,000.00 |
| 22 | 8" Aggregate Base Material | Ton | 7630 | \$35.00 | \$267,050.00 |
| 23 | Grade Aggregate Base Material | SY | 17911 | \$2.00 | \$35,822.00 |
| 24 | 2" Surface & 4" Binder Asphalt | Ton | 6180 | \$90.00 | \$556,200.00 |
| 25 | Geotextile Fabric Under Aggregate | SY | 17911 | \$2.50 | \$44,777.50 |
| 26 | Traffic Control for Roadway Construction | LS | 1 | \$20,000.00 | \$20,000.00 |
| | Subtotal Rebuild Roadway | | | | \$1,476,276.00 |
| | | | | | ¢2 <02 204 00 |
| | Sub Total Whittamore | | | | \$2,602,204.00 |
| | Murray Drive | | | | |
| 27 | 8" DI Pine | IF | 7063 | \$58.00 | \$409 654 00 |
| 28 | 6" DI Pine | LI | 162 | \$50.00 | \$8,100,00 |
| 28 | Hydrants & Appurtenances | EA | 16 | \$3,000,00 | \$48,000,00 |
| 30 | 10" Gate Valve & Box | EA | 1 | \$2,500.00 | \$2,500.00 |
| 31 | 8" Gate Valve & Box | EA | 2 | \$1.300.00 | \$2,600.00 |
| 32 | 6" Gate Valve & Box | EA | 16 | \$931.00 | \$14,896.00 |
| 33 | Service Connections | EA | 41 | \$1,600.00 | \$65,600.00 |
| 34 | Select Borrow, CBR 15 - Pipe Install Only (Backfill) | CY | 37 | \$40.00 | \$1,480.00 |
| 35 | Sawcut Pavement | LF | 170 | \$10.00 | \$1,700.00 |
| 36 | Curb and Gutter Replacement | LF | 50 | \$45.00 | \$2,250.00 |
| 37 | Erosion and Sed. Control | LS | 1 | \$4,000.00 | \$4,000.00 |
| 38 | Traffic Control | LS | 1 | \$2,000.00 | \$2,000.00 |
| | Pavement Repair | | | | |
| 39 | 1.5" SM-2A | TON | 4 | \$1,000.00 | \$4,000.00 |
| 40 | 4" BM-2 | TON | 9 | \$1,000.00 | \$9,000.00 |
| 41 | Aggregate Base Mat. | TON | 12 | \$50.00 | \$600.00 |
| 42 | Grading | SY | 7850 | \$1.50 | \$11,775.00 |

Battlefield Golf Club Water Project Community Supply Water Distribution System - Alternative 2

| ITEM NO. | ITEM DESCRIPTION | UNIT | QTY | UNIT COST | LINE ITEM COST |
|----------|---|------|------|-------------|----------------|
| 43 | 2" Topsoil | AC | 1.62 | \$26,000.00 | \$42,120.00 |
| 44 | Seeding | AC | 1.62 | \$2,500.00 | \$4,050.00 |
| | Sub Total Murray Drive | | | | \$634,325.00 |
| | | | | | |
| | Centerville | | | | |
| 45 | 8" Water Main - Ductile Iron Pipe | LF | 3102 | \$58.00 | \$179,916.00 |
| | Water Main Undercut Excavation & Replacement with | | | | |
| 46 | Bedding Stone | CY | 355 | \$32.00 | \$11,360.00 |
| 47 | Select Backfill, CBR 15 - Pipe | CY | 1355 | \$20.00 | \$27,100.00 |
| 48 | Pipe Bedding | CY | 200 | \$54.00 | \$10,800.00 |
| 49 | Course Aggregate | TON | 670 | \$50.00 | \$33,500.00 |
| 50 | 8" Gate Valve Valve | EA | 3 | \$4,500.00 | \$13,500.00 |
| 51 | Fire Hydrant Assembly | EA | 3 | \$3,000.00 | \$9,000.00 |
| 52 | Crusher Run - Fire Hydrant Only | TON | 105 | \$25.00 | \$2,625.00 |
| 53 | Service Connections | EA | 5 | \$2,500.00 | \$12,500.00 |
| | Utility Trench Pavement Patching | LF | 497 | | |
| 54 | 2" SM-2A | Ton | 15 | \$90.00 | \$1,350.00 |
| 55 | 7" BM-2 | Ton | 160 | \$90.00 | \$14,400.00 |
| 56 | 10" Aggregate Base | Ton | 222 | \$35.00 | \$7,770.00 |
| 57 | Traffic Control | LS | 1 | \$3,000.00 | \$3,000.00 |
| 58 | Erosion and Sediment Control Pipe line | LS | 1 | \$5,000.00 | \$5,000.00 |
| 59 | Curb and Gutter Replacement | LF | 20 | \$45.00 | \$900.00 |
| 60 | Seeding, Fertilizing and Lime | LS | 1 | \$2,500.00 | \$2,500.00 |
| 61 | Sawcut and Remove Pavement | LF | 730 | \$3.85 | \$2,810.50 |
| 62 | Storm Drain Pipe - 15" RCP | LF | 69 | \$44.00 | \$3,036.00 |
| 63 | Storm Drain Pipe - 18" RCP | LF | 52 | \$62.00 | \$3,224.00 |
| 64 | Storm Drain Pipe - 24" RCP | LF | 145 | \$77.00 | \$11,165.00 |
| 65 | Flared End Section - 15" RCP | EA | 3 | \$750.00 | \$2,250.00 |
| 66 | Flared End Section - 18" RCP | EA | 6 | \$780.00 | \$4,680.00 |
| 67 | Flared End Section - 24" RCP | EA | 4 | \$800.00 | \$3,200.00 |
| 68 | Drop Inlet | EA | 1 | \$5,000.00 | \$5,000.00 |
| 69 | Manhole | EA | 1 | \$4,000.00 | \$4,000.00 |
| 70 | Pavement Milling & Overlay for Utility Patch | | | | |
| 71 | 2" Mill | SY | 1500 | \$15.00 | \$22,500.00 |
| 72 | Asphalt Overlay | Ton | 240 | \$125.00 | \$30,000.00 |
| 73 | Traffic Control | LS | 1 | \$3,000.00 | \$3,000.00 |
| 74 | Pavement Repair Along Centerville Tpk. | | | | |
| 75 | 2"-Mill 12'wide X 3300' long | SY | 4400 | \$15.00 | \$66,000.00 |
| 76 | Asphalt Overlay | Ton | 484 | \$90.00 | \$43,560.00 |
| 77 | Isolated Pavement Repair | SY | 100 | \$80.00 | \$8,000.00 |
| 78 | VDOT EC-1 For Ditch Stabalization | SY | 433 | \$2.25 | \$974.25 |
| 79 | Excavation For Ditch | CY | 1500 | \$5.45 | \$8,175.00 |
| 80 | Topsoil | CY | 786 | \$25.00 | \$19,650.00 |
| 81 | Select Borrow, CBR 15 - Ditch fill Only | CY | 1300 | \$20.00 | \$26,000.00 |
| 82 | Fine Grade Shoulder | SY | 3231 | \$1.50 | \$4,846.50 |
| 83 | Concrete Driveway Replacement | EA | 1 | \$2,800.00 | \$2,800.00 |
| 84 | Gravel Driveway Replacement | EA | 1 | \$1,000.00 | \$1,000.00 |
| | | | | | |
| | Subtotal Centerville Turnpike | | | | \$611,092.25 |
| | | | | | |
| | Total of Construction | | | | \$3,847,621.25 |
| | 10% Contigency | | | | \$384,762.13 |
| | | | | | |
| | | | | | |
| | | | | | |

Battlefield Golf Club Water Project Community Supply Water Distribution System - Alternative 2

Battlefield Golf Club Water Project Community Supply Water Distribution System - Alternative 2

| ITEM NO. | ITEM DESCRIPTION | UNIT | QTY | UNIT COST | LINE ITEM COST |
|----------|----------------------|------|-------|-----------|----------------|
| | | | | | |
| | Easement Acquisition | | | | |
| | Centerville Turnpike | | | | |
| 85 | Residential | SF | 23930 | \$8.00 | \$191,440.00 |
| | | | | | |
| | Murry Drive | | | | |
| 86 | Residential | SF | 1600 | \$8.00 | \$12,800.00 |
| | | | | | |
| | | | | | |
| | Total Estimate | | | | \$4,436,623.38 |
| | | | | | |

| Item | Quantity | Unit Cost | Unit | Total Cost |
|--|----------|-----------|------------|------------|
| | | | | |
| Item 1 - Mobilization/Demobilization | | | | |
| | | | | |
| Setup Charge Trailer | 1 | \$920 | EA | \$920 |
| Trailer/Furniture | 6 | \$2,875 | Month | \$17,250 |
| Port-a-john | 180 | \$6 | Days | \$1,035 |
| Water | 180 | \$6 | Days | \$1,035 |
| Mobilization | 1 | \$80,500 | LS | \$80,500 |
| Site Cleanup | 1 | \$5,750 | LS | \$5,750 |
| | | | | |
| Item 2 - Erosion and Sediment | | | | |
| | | | | |
| Stabilized construction entrance | 1 | \$5,750 | EA | \$5,750 |
| Silt fence | 200 | \$2 | LF | \$460 |
| LOD Fence | 2,000 | \$2 | LF | \$4,600 |
| R-3 / R4 riprap pad | 2 | \$2,300 | EA | \$4,600 |
| Dirtbag Dirtbag discharge area (Pad) | 400 | \$1,000 | EA SF | \$1,000 |
| | 400 | φŪ | 51 | \$2,500 |
| Item 3 - Farthwork | | | | |
| | | | | |
| Grading | 1 | \$29.000 | LS | \$29.000 |
| Borrow | 1 | \$2,500 | LS | \$2,500 |
| | | | | |
| Item 4 - Groundwater Withdrawal Permit | | | | |
| | | | | |
| Engineering Support preparing plan, hydrogeologic information, etc | 1 | \$75,000 | LS | \$75,000 |
| Permit Fee | 1 | \$6,000 | LS | \$6,000 |
| | | | | |
| Item 5 - Well Field | | | | |
| | | | | |
| Property Acquisition for Siting of Wells | 3 | \$75,000 | EA | \$225,000 |
| Well Construction | 3 | \$40,000 | EA | \$120,000 |
| Well Pipe, Well Pumps, Motors, Pitless Adapter, Wiring Etc | 3 | \$40,000 | EA | \$120,000 |
| | | | | , |
| Item 6 - Raw Water Transmission Mains | | | | |
| | | | | |
| 4" SDR 21 | 3,000 | \$58 | LF | \$174,000 |
| | | | | |
| Item 7 - Paving and Surfacing | | | | |
| | | | | |
| Paving | 1 | \$3,000 | LS | \$3,000 |
| Gravel road | 1 | \$2,500 | LS | \$2,500 |
| | | | | |
| Item 8 -Exterior Piping | | | | 1 |
| | | | | 1 |
| Exterior DIP Piping Fittings and Valves | 1 | \$85,000 | LS | \$85,000 |
| Misc Fittings / Thrust Blocks | 1 | \$10,000 | LS | \$10,000 |
| | | | | |
| Item 9 - Landscaping and Site Improvements | | | | |
| | | | | |
| Landscaping and Site Improvements (incl fencing) | 1 | \$20,000 | LS | \$20,000 |
| Itom 10 Concento | | | | |
| item 10 - Concrete | | | | |
| Tank foundation, Footers, Slab, Door Landing Slabs | 9 | \$518 | CY | \$30,000 |
| | | | | |
| Item 11 - Water Treatment Plant Structure and Finishings | | ļ | | <u> </u> |
| The CMIL David France | 000 | #150 | 6 7 | #100.000 |
| 1 russes, UNU, Doors, Etc Fixtures and furniture | 800 | \$150 | SF TS | \$120,000 |
| Emergency Generator | 1 | \$80.000 | LS | \$80.000 |
| | | +=3,000 | | |
| Item 12 - Fe and Mn Pressure Filters Unit Process Equipment | | 1 | | 1 |
| | | 1 | | 1 |
| Manganese Greensand Filters | 1 | \$187,900 | LS | \$187,900 |
| | 1 | | | 1 |
| Item 13 - RO Unit Process Equipment | 1 | 1 | İ | 1 |
| | | 1 | | 1 |
| | | | - | - |

Battlefield Golf Club Water Project Community Water Supply and Treatment System - Alternative 2

| Vantage M84-024RO | 1 | \$137,600 | LS | \$137,600 |
|--|-----|--------------|------|-------------------------|
| Vantage M83-006RO | 1 | \$90,100 | LS | \$90,100 |
| | | | | |
| Item 14 - Equipment and Mechanical Work | | | | |
| Interior Process Piping and Fittings | 1 | \$60,000 | LS | \$60,000 |
| Disinfection and hydrostatic pressure testing | 1 | \$11,500 | LS | \$11,500 |
| Fittings and Supports | 1 | \$11,500 | LS | \$11,500 |
| Controls | 1 | \$25,000 | LS | \$25,000 |
| Chlorination System | 1 | \$5,000 | EA | \$5,000 |
| Chlorine/Fluoride Residual Analyzer | 1 | \$5,000 | EA | \$5,000 |
| Fluroidation System | 1 | \$5,000 | EA | \$5,000 |
| Dehumidifiers (3) | 1 | \$6,000 | LS | \$6,000 |
| Exhaust Fan w/ Louvers | 1 | \$4,500 | LS | \$4,500 |
| Gas Service Pipe | 1 | \$11,500 | LS | \$11,500 |
| Water heater | 1 | \$1,150 | LS | \$1,150 |
| | | | | |
| Item 15 - Raw Water "Reservior", Backwash/Brine Holding Tank, Pump Station | | | | |
| | | | | |
| 20,000 gal Tank for Raw Water for Chemical Pre-treatment | 1 | \$50,000 | LS | \$50,000 |
| 50,000 gal Tank includes excavation, foundation, handrails, etc | 1 | \$200,000 | LS | \$200,000 |
| | | | | |
| | | | | |
| Item 16 - Community Water Distribution System | | | | |
| | | | | |
| From URS Virginia Beach | 1 | \$ 4,436,623 | LS | \$4,436,623 |
| | | | | |
| | | | | |
| Item 17 - Ground Level Water Storage Tank | | | | |
| | | | | |
| High Service Fire Pump | 1 | \$10,000 | EA | \$10,000 |
| VFD service pumps (one for redundancy) | 2 | \$10,000 | EA | \$20,000 |
| Property Acquisition for Siting of Tank | 1 | \$75,000 | EA | \$75,000 |
| 120,000 gal Tank includes foundation, painting, etc | 1 | \$144.000 | LS | \$144.000 |
| | _ | +, | | +, |
| Item 18 - Electrical | | | | |
| | | | | |
| Service Meter/Entrance | 1 | \$4.000 | LS | \$4.000 |
| Panelboard (1) - 120/240V. 24 Ckt | 1 | \$5,000 | LS | \$5,000 |
| Service & Equipment Grounding | 1 | \$3,000 | IS | \$3,000 |
| Emergency Lights (2) | 1 | \$1,500 | LS | \$1,500 |
| Lighting (11) | 1 | \$5,500 | IS | \$5,500 |
| Recentacles (10) | 1 | \$3,000 | IS | \$3,000 |
| Miss Wiring Unit Htre Exh Fane | 1 | \$4,000 | IS | \$4,000 |
| Alarm Banal (2) & Wiring | 1 | \$4,000 | LS | \$4,000 |
| Alarm/Intile Wiring to Treatment Pldg | 1 | \$0,000 | IS | \$0,000 |
| Flam Switch Dreamer Switch Flanded Flam Samer ata | 1 | \$10,000 | LS | \$10,000 |
| Flow Switch, Flessure Switch, Flooded Floor Sensor, etc | 1 | \$4,000 | LS | \$4,000 |
| Plant Hait Harter FKW (00W 2 DH (2)) | 1 | \$1,200 | LS | \$1,200 |
| Elect Unit Heater, SK w 480V, 3 PH (2) | 1 | \$3,500 | LS | \$3,500 |
| Weil Starter Replacement (5) | 5 | \$5,000 | EA | \$25,000 |
| riogrammable Logic Controller | 1 | \$15,000 | EA | \$15,000 |
| Well Feeder Line | 1 | \$100,000 | LS | \$100,000 |
| Electric Work for Reverse Osmosis System | 1 | \$150,000 | LS | \$150,000 |
| | | | | |
| Item 19 - HVAC/Plumbing | | 4 | | |
| Ventilation | 1 | \$7,260 | LS | \$7,260 |
| Plumbing | 1 | \$27,720 | LS | \$27,720 |
| Controls | 1 | \$10,000 | LS | \$10,000 |
| Water heater | 2 | \$2,500 | LS | \$5,000 |
| | | | | |
| Item 20 - Indirects | | | | |
| | | | | |
| Survey | 64 | \$144 | HR | \$9,200 |
| Project Manager | 120 | \$863 | Days | \$103,500 |
| Superintendant | 180 | \$748 | Days | \$134,550 |
| Administrative | 100 | \$518 | Days | \$51,750 |
| Insurance | 1 | \$106,375 | LS | \$106,375 |
| Bonds | 1 | \$106,375 | LS | \$106,375 |
| | | | | |
| Subtotal | | | | \$7,647,003 |
| Contingency (10%) | | | | \$764,700 |
| Total | | | | \$8 411 704 |
| 10(81 | | | | φ0, 4 11,704 |

Battlefield Golf Club Water Project Community Water Supply System O & M Cost Comparison - Alternative 2

| Combined Wells | 180 | gpm |
|--------------------------|----------|-----|
| Pumping Duration per Day | 3.70 | hr |
| Q= | 0.040 | MGD |
| Q= | 40,000.0 | gpd |

| Oxidation NaOC(1025%) 12 5% chlorine (lbs/gal) 126 s/gal Dose (mg/L) 3 50 Cost (\$'yr) \$ Disinfection 12 5% chlorine (lbs/gal) 12 6 s/gal 0.85 100 \$ 287 50 Disinfection NaOC(1025%) 12 6 s/gal 0.85 100 \$ 6cst (\$'yr) 82 14 Proordation NaP Dose (mg/L) \$ Cost (\$'yr) 82 14 Adjustness NaP Dose (mg/L) \$ Cost (\$'yr) 82 14 Adjustness NaP Dose (mg/L) \$ Cost (\$'yr) 82 14 Adjustness \$ 9.0 4.00 \$ 307 33 Adjustness \$ 9.0 4.00 \$ 307 33 Pumps Energy Costs Cost (\$'yr) \$ 1.005 74 Pumps Energy Costs Cost per kW-Hr(\$/kw Hr) \$ Cost (\$'yr) kW-hr/year 50403.7 0.12 \$ 6.048 45 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 3.024 22 | Ocidation NeOCI (125%) 12 5% chlorine (lb/gal) Dose (mg/L) 3 50 Cost (%/yr) 5 (287 50 Disinfection NeOCI (125%) 12 5% chlorine (lb/gal) 1.2 6 5/gal = Dose (mg/L) 12 5% chlorine (lb/gal) 2.6 (25%) 1.0 8 2.87 50 Pluoridation NaF Dose (mg/L) 5/gal = 0.85 1.00 \$ 2.87 50 Albalanity and pH NaF Dose (mg/L) 5 (1.0 400 \$ Cost (%/yr) 5 (1.0 5 / 4.0 00 \$ 3.07 53 Albalanity and pH Na ₂ CO ₃ Dose (mg/L) 4 00 \$ Cost (%/yr) 5 (1.00 5 / 4.0 00 \$ 3.07 53 Pumps Energy Costs \$ 1.005 74 Pumps Energy Costs \$ 1.005 74 Pumps Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Hours pumping / day 3.7 k of Wells Operationing 2 Kilowatt (kW) 18 6425 Hours pumping / day 3.7 k W-hrs/year 25.201 9 Cost per kW-Hr(5/kw Hr) 0.12 Cost (%/yr) 3.024 22 Supermatant Recycle Horsepower (HP) 75 Kilowatt (kW) 18 6425 Hours pumping / day 3.7 kW-hrs/year 25.201 9 Cost per kW-Hr(5/kw Hr) 0.12 Cost (%/yr) 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3.7 kW-hrs/year 25.201 9 Cost per kW-H | Treatment Process | | Chemical Costs | | | | |
|---|---|--------------------------------|---------------------------------|---------------------|---------------------------|----|--------------|--|
| 12 5% chlorine (lbs/ga) 1 26 Dose (mg/L) \$ 287 50 Disinfection NaOCI (12.5%) 12 5% chlorine (lbs/gal) 1 26 Dose (mg/L) \$ Cost (\$%y) It 5 % chlorine (lbs/gal) 1 26 Dose (mg/L) \$ Cost (\$%y) \$ S 214 Fluoridation NaF Dose (mg/L) \$ Cost (\$%y) \$ \$ 307 53 Atlatinity and pH Ns+CO_S Dose (mg/L) \$ Cost (\$%y) \$ 307 53 Atlatinity and pH Ns+CO_S Dose (mg/L) \$ Cost (\$%y) \$ 3105 74 Pumps Energy Costs Forduction Wells Horsepower (HP) per well 25 \$ \$ 0.000 \$ \$ </th <th>12 5% chlorine (ble/ga) 12 6 Dose (mg/L) S 287 50 Disinfection NaOCI (125%) 12 6 Dose (mg/L) Cost (\$/y7) 8 214 Phonoidation NaP 0.85 100 S 8214 Phonoidation NaP Dose (mg/L) S Cost (\$/y7) 307 53 Attailinity and pif NaCO NaSCO Dose (mg/L) S Cost (\$/y7) Attailinity and pif NaCO NaCO Dose (mg/L) S Cost (\$/y7) Attailinity and pif NaCO Energy Costs Dose (mg/L) S Cost (\$/y7) Pumps Energy Costs Energy Costs</th> <th>Oxidation</th> <th>NaOCl (12.5</th> <th>5%)</th> <th></th> <th></th> <th>Cost (\$/y1)</th> | 12 5% chlorine (ble/ga) 12 6 Dose (mg/L) S 287 50 Disinfection NaOCI (125%) 12 6 Dose (mg/L) Cost (\$/y7) 8 214 Phonoidation NaP 0.85 100 S 8214 Phonoidation NaP Dose (mg/L) S Cost (\$/y7) 307 53 Attailinity and pif NaCO NaSCO Dose (mg/L) S Cost (\$/y7) Attailinity and pif NaCO NaCO Dose (mg/L) S Cost (\$/y7) Attailinity and pif NaCO Energy Costs Dose (mg/L) S Cost (\$/y7) Pumps Energy Costs | Oxidation | NaOCl (12.5 | 5%) | | | Cost (\$/y1) | |
| Sigal – 0.85 3.50 \$ 287 50 Distanfection NeGC (12.5%) 12.5% chlorine (Dsgal) 1.26 Dose (mg/L) \$ 6.214 Huocidation NeF Dose (mg/L) \$ Cost (\$/yr) \$ 307 53 Attatinity and pff NaF Dose (mg/L) \$ Cost (\$/yr) \$ 307 53 Adjustment \$/gal – 0.90 \$ Cost (\$/yr) \$ 328 57 Pumps Energy Costs \$ 1.005 74 \$ 328 57 \$ 288 70 Pumps Energy Costs \$ 1.005 74 \$ \$ 308 425 Hours pumping / day 3 7 \$ Cost per kW-Hr(\$/kw Hr) \$ Cost (\$/yr) kW-hrx/year 52.01 9 0.12 \$ \$ \$ \$ Booster Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) \$ Cost (\$/yr) \$ \$ Buop Horsepower (HP) 7 Cost per kW-Hr(\$/kw Hr) \$ \$ | Sigl - 0.85 3.50 \$ 287 50 Disinfeccion NeGC (12.5%) 12.5% chlorine (b/sgla) 1.26 Dose (mg/L) \$ 6.214 Buordation NeF Dose (mg/L) \$ Gost (\$/yr) 3.07 53 Allatinity and plf NaF Dose (mg/L) \$ Cost (\$/yr) 3.07 53 Adjustment \$/gal = 0.90 4.00 \$ 3.02 83 3.00 53 Adjustment \$/gal = 0.90 4.00 \$ 3.02 83 3.00 53 Pumps Energy Costs 5 1.000 5 \$ 3.08 85 3.08 85 Poduction Wells Horsepower (HP) per well 25 Cost per kW-Hr (\$/kw Hr) \$ | | 12 5% chlorine (lbs/gal) | 1 26 | Dose (mg/L) | | | |
| Distinification NaCQ (12.5%) (12.5% chlorine (lbs/gal) 126 (10) Cost (\$/yr) (\$ & 82.14 Huoridation NaF Dose (mg/L) (10) Cost (\$/yr) (\$ & 307.53 Alkelinity and pt/ Adjustment Na ₂ CO ₃ (\$ gal = Dose (mg/L) (10) Cost (\$/yr) (\$ & 307.53 Alkelinity and pt/ Adjustment Na ₂ CO ₃ (\$ gal = Dose (mg/L) (\$ & 307.53 Cost (\$/yr) (\$ & 307.53 Pumps Energy Costs Dose (mg/L) (\$ & 307.53 Cost (\$/yr) (\$ & 328.57 Pumps Energy Costs Cost (\$/yr) (\$ & 1005.74 Pumps Energy Costs Cost (\$/yr) (\$ & 1000.74 Pothous Pumping / day * of Wells Overationing * of Wells (WW) 25 (Cost per kW-Hr(\$/kw Hr) 0.12 Cost (\$/yr) (\$ & 3.024.22 Booster Pumps Horsepower (HP) * S 75 (Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) 0.12 Cost (\$/yr) \$.024.22 Supermatant Recycle Pump Hours Pumping / day Kilowatt (kW) 18 6425 (Cost per kW-Hr(\$/kw Hr) 0.12 Cost (\$/yr) \$.024.22 Pump Station Pumps House Pumping / day Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) 0.12 Cost (\$/yr) \$.024.22 Pump Station Pumps House Pumping / day Kilowatt (kW) 6.425 Cost (\$/yr) \$.024.22 | Distrifection NAOCI (025%) [12 5% chlorine (Bs/gal) 1 26 (0.85) Dose (mg/L) (0.05) Cost (\$/y7) (\$ 307 53 Planoidation NaP Dose (mg/L) (0.05) Cost (\$/y7) (\$ 307 53 Cost (\$/y7) (\$ 307 53 Atkatinity and pft Ns ₂ CO ₃ (\$ 1,005 74 Dose (mg/L) (\$ 000 \$ Cost (\$/y7) (\$ 307 53 Atkatinity and pft Ns ₂ CO ₃ (\$ 1,005 74 Dose (mg/L) (\$ 000 \$ Cost (\$/y7) (\$ 307 53 Pumps Energy Costs (\$ 1,005 74 Dose (mg/L) (\$ 000 \$ Cost (\$/y7) (\$ 000 \$ Cost (\$/y7) (\$ 000 \$ Poduction Walls Horsepower (HP) per well 25 (\$ 1005 74 25 (\$ 000 \$ Cost per kW-Hr(\$/kw Hr) 25 (\$ 000 \$ Cost (\$/y7) (\$ 000 \$ Cost (\$/y7) (\$ 000 \$ Cost (\$/y7) (\$ 000 \$ Cost (\$/y7) 2 0 12 Cost (\$/y7) 2 0 0 12 <thcost (\$="" y7)<br="">2 0 0 12<td></td><td>\$/gal =</td><td>0 85</td><td>3 50</td><td>\$</td><td>287 50</td></thcost> | | \$/gal = | 0 85 | 3 50 | \$ | 287 50 | |
| 12 5% chlorine (lbs/gal) 1 26 \$/gal = Dose (mg/L) 100 Cost (\$/yr) 8 2 14 Huoridation NaF Dose (mg/L) 100 Cost (\$/yr) 8 307 33 Alkalinity and pH Na ₂ CO ₃ Dose (mg/L) 100 Cost (\$/yr) 8 307 33 Alkalinity and pH Na ₂ CO ₃ Dose (mg/L) 400 Cost (\$/yr) 8 32 857 Pumps Energy Costs S 1.005 74 Pumps Energy Costs Cost (\$/yr) 8 1.005 74 Cost (\$/yr) 8 0.004 37 Cost (\$/yr) 0 12 Cost (\$/yr) 8 0.048 45 Booster Pumps Horsepower (HP) per well kW-hrs/year 50403 7 Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) 8 0.048 45 Booster Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) 8 0.024 22 Supermanan Recycle Pump Station Pumps Horsepower (HP) 75 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) 8 0.024 22 Pump Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) 8 0.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) 8 0.024 22 Pump Station Pumping / day 8 0 7 Gost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) 8 0. | 12 5% chlorine (lbs'gal) 1 26 S'gal = Dose (mg/L) 100 Cost (\$/yr) 8 2 14 Buoridation NaF Dose (mg/L) 100 Cost (\$/yr) 8 307 53 Allalinity and pH Adjuatment NapCO ₃ Dose (mg/L) 100 Cost (\$/yr) 8 307 53 Mage Dose (mg/L) 100 Cost (\$/yr) 8 307 53 Pumps Energy Costs Production Wells Horsepower (HP) per well 400 25 5 Cost (\$/yr) 8 0048 45 Poduction Wells Horsepower (HP) per well 400 \$ 37 \$ of Wells Operationing 8 00484 7 Cost per kW-Hr(\$/kw Hr) 5 Cost (\$/yr) 8 012 Cost (\$/yr) 8 0,048 45 Booster Pumps Horsepower (HP) 8 00497 25 012 Cost (\$/yr) 9 012 Cost (\$/yr) 8 0,048 45 Buors Pumping / day 9 012 37 012 Cost (\$/yr) 8 0,048 45 Cost (\$/yr) 9 012 Cost (\$/yr) 8 0,042 42 Pump Horsepower (HP) 7 5 7 5 20 012 2 02 8 02 42 20 012 2 02 8 02 42 Pump Station Pumps Horsepower (HP) 7 6 7 5 20 012 2 02 8 02 42 2 02 8 02 42 Pump Station Pumps Horsepower (HP) 8 010 400 37 8 0,024 22 2 012 3 0,024 22 8 0,024 02 | Disinfection | NaOCl (12.5 | 5%) | | | | |
| Sigal = 0.85 1.00 \$ 82.14 Ruoridation NaF Dose (mg/L) \$ Cost (\$/yr) Alkalinity and pH Na ₂ CO ₃ Dose (mg/L) \$ Cost (\$/yr) Alkalinity and pH Na ₂ CO ₃ Dose (mg/L) \$ Cost (\$/yr) Alkalinity and pH Na ₂ CO ₃ Dose (mg/L) \$ Cost (\$/yr) Alkalinity and pH Na ₂ CO ₃ Dose (mg/L) \$ Cost (\$/yr) Adjustment S/gal = 0.90 4.00 \$ 328.57 Pumps Energy Costs S 1.005.74 Podiccion Wells Horsepower (HP) per well 25 Kilowatt (kW) 26 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Socoster Pumps Horsepower (HP) 25 Gost (\$/yr) \$ 3.024.22 Booster Pumps Horsepower (HP) 75 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/skw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 25 Silowatt (\$W) 18 6425 Socost (\$/yr) \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 Silowatt (\$W) 18 6425 | Sigal = 0.85 1.00 \$ 82.14 Pinocidation NaF Dose (mg/L) Cost (\$/yr) Alkalinity and pH Na_CO3 Dose (mg/L) Cost (\$/yr) Alkalinity and pH Na_CO3 Dose (mg/L) Cost (\$/yr) Adjustment S/gal = 0.90 4.00 \$ 328.57 Pumps Energy Costs 10.005.74 \$ 1.005.74 Poduction Wells Horsepower (HP) per well 25 Kilowatt (kW) 26 Cost (\$/yr) \$ 6.048.45 Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 0.12 \$ 3.024.22 Booster Pumps Horsepower (HP) 75 Cost (\$/yr) \$ 3.024.22 \$ 3.024.22 Supermatant Recycle Horsepower (HP) 75 Cost (\$/yr) \$ 3.024.22 \$ 3.024.22 Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024.22 Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 Cost (\$/yr) \$ 3.0 | | 12 5% chlorine (lbs/gal) | 1 26 | Dose (mg/L) | | Cost (\$/yr) | |
| Pluoridation NaF Dose (mg/L) Cost (%yr) Alkalinity and pH NaCOs 000 \$ 307 53 Adjustment \$/gal = 0.90 4.00 \$ 328 57 Adjustment \$/gal = 0.90 4.00 \$ 328 57 Pumps Energy Costs \$ 1.005 74 Poduction Wells Horsepower (HP) per well 25 \$ 6.048 45 Hours Pumping / day 3.7 \$ 6.048 45 \$ 6.048 45 Hours Pumping / day 3.7 \$ 6.048 45 \$ 6.048 45 Bootter Pumps Horsepower (HP) 25 \$ 6.048 45 Hours Pumping / day 3.7 \$ 6.048 45 \$ 3.024 22 Supernatiant Recycle Horsepower (HP) 25 \$ 3.024 22 Pump Kilowatt (kW) 18 6425 \$ 0.12 \$ 3.024 22 Pump Horsepower (HP) 7.5 \$ 3.024 22 \$ 3.024 22 Pump Hours Pumping / day 0.4 Cost per kW-Hr (\$/kw Hr) \$ Cost (\$/yr) kW-hrs/year 2.5.01.9 0.12 \$ 3.024 22 | Placeidation NaF Dose (mg/L) Cost (\$/yr) Alkelinity and pH Na ₂ CO ₃ Dose (mg/L) 100 \$ 307 53 Alkelinity and pH Na ₂ CO ₃ Dose (mg/L) Cost (\$/yr) Sigs = 1 0.90 4.00 \$ 307 53 Adjustment \$/ggl = 0.90 4.00 \$ 328 57 \$ 1.005 74 Pumps Energy Costs \$ 1.005 74 \$ 5.005 74 Poincion Wells Horsepower (HP) per well 25 Cost per kW-Hr(\$/kw Hr) \$ Cost (\$/yr) # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) \$ Cost (\$/yr) Booster Pumps Horsepower (HP) 25 \$ \$ 3.02 42 Booster Pumps Horsepower (HP) 25 \$ \$ 3.02 42 Supernatean Recycle Horsepower (HP) 25 \$ \$ 3.02 42 Pump Kilowatt (kW) 18 6425 \$ \$ 3.02 42 Pump Station Pumps Horsepower (HP) < | | \$/gal = | 0 85 | 1 00 | \$ | 82 14 | |
| S/Ib = 1.12 1.00 \$ 30733 Mike/CO3 Nis2CO3 Dose (mg/L) Cost (\$yr) S 328 57 Adjustment Sigal = 0.90 4.00 \$ 328 57 Pumps Energy Costs \$ 1.005 74 Pumps Energy Costs Cost (\$yr) # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$yr) # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$yr) Booter Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$yr) Kilowatt (kW) 18 6425 0.12 \$ 6.048 45 Booter Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 7.5 Kilowatt (kW) 18 6425 Hours Pumping / day 0.4 0.4 2.02.0.2 0.12 \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 0.12 \$ 3.024 22 </td <td>S/Ib = 112 100 \$ 30733 Alkalinity and pH Adjustment Na₂CO₃ Dose (mg/L) Cose (\$/yr) S 28 57 Alkalinity and pH Adjustment Na₂CO₃ 0.90 400 \$ 28 57 Pumps Energy Costs \$ 1.00574 \$ 1.00574 Pumps Energy Costs Cost (\$/yr) \$ 6.04845 Booseer Pumps Horsepower (HP) per well kW-hrs/year 25 504037 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booseer Pumps Horsepower (HP) 25 Kilowatt (kW) Cost (\$/yr) \$ 6.04845 Booseer Pumps Horsepower (HP) 25 Kilowatt (kW) Cost (\$/yr) Cost (\$/yr) \$ 3.024 22 Supermatant Recycle Pump Station Pumps Horsepower (HP) 75 Kilowatt (kW) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Reverse Osmosis Process Equipment Costs S 3.024 22 S 3.024 22 S 3.024 22 Vantage M83 RO System Vender Supplied Information \$ 6 3.024 22 S 3.024 22 S 3.024 22 S 3.024</td> <td>Fluoridation</td> <td>NaF</td> <td></td> <td>Dose (mg/L)</td> <td></td> <td>Cost (\$/yr)</td> | S/Ib = 112 100 \$ 30733 Alkalinity and pH Adjustment Na ₂ CO ₃ Dose (mg/L) Cose (\$/yr) S 28 57 Alkalinity and pH Adjustment Na ₂ CO ₃ 0.90 400 \$ 28 57 Pumps Energy Costs \$ 1.00574 \$ 1.00574 Pumps Energy Costs Cost (\$/yr) \$ 6.04845 Booseer Pumps Horsepower (HP) per well kW-hrs/year 25 504037 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booseer Pumps Horsepower (HP) 25 Kilowatt (kW) Cost (\$/yr) \$ 6.04845 Booseer Pumps Horsepower (HP) 25 Kilowatt (kW) Cost (\$/yr) Cost (\$/yr) \$ 3.024 22 Supermatant Recycle Pump Station Pumps Horsepower (HP) 75 Kilowatt (kW) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Reverse Osmosis Process Equipment Costs S 3.024 22 S 3.024 22 S 3.024 22 Vantage M83 RO System Vender Supplied Information \$ 6 3.024 22 S 3.024 22 S 3.024 22 S 3.024 | Fluoridation | NaF | | Dose (mg/L) | | Cost (\$/yr) | |
| Alkalinity and pH Adjustment Na ₂ CO ₅ Dose (mg/L) 4 00 Cost (\$'yr) \$ 328 57 Pumps Energy Costs Production Wells Horsepower (HP) per well # of Wells Operationing # of Wells Operators Kilowatt (kW) 18 6425 Hours Pumping / day 0 4 Cost (\$'yr) 0 12 Cost (\$'yr) \$ 3,024 22 Supermatant Recycle Pump Horsepower (HP) Kilowatt (kW) 18 6425 Hours Pumping / day 0 4 Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$'yr) \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$'yr) \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$'yr) \$ 3,024 22 Vender Supplied Information Vantage M83 RO System Vender Supplied Information Vender Supplied Information | Alkalinity and pH Adjustment Na ₂ CO ₅ Dose (mg/L) 4 00 Cost (%yr) 5 328 57 Pumps Energy Costs Production Wells Horsepower (HP) per well Kilowatt (kW) 25 Kilowatt (kW) Cost (%yr) 18 6425 Hours Pumping / day 3 7 * of Wells Operationing 2 Cost per kW-Hr(%/kw Hr) Cost (%yr) 5 .0048 45 Booster Pumps Horsepower (HP) 25 Kilowatt (kW) Cost (%yr) Cost (%yr) Booster Pumps Horsepower (HP) 25 Kilowatt (kW) Cost (%yr) Cost (%yr) Booster Pumps Horsepower (HP) 25 Kilowatt (kW) Cost (%yr) Cost (%yr) Bours Pumping / day 37 Kilowatt (kW) Cost (%yr) Cost (%yr) S 3.024 22 Supermistant Recycle Horsepower (HP) 25 Kilowatt (kW) Cost (%yr) S 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(%/kw Hr) Cost (%/yr) Reverse Osmosis Process Equipment Costs Cost (%/yr) S 3.024 22 Vender Supplied Information Vender Supplied Information S 3.452 1 S 3.024 22 S 1.509 99 Vender Supplied Information Vender Supplied Information S 3.15.020 07 </td <td></td> <td>\$/lb =</td> <td>1 12</td> <td>1 00</td> <td>\$</td> <td>307 53</td> | | \$/lb = | 1 12 | 1 00 | \$ | 307 53 | |
| Adjustment \$/gal = 0 90 4 00 \$ 328 57 Reverse Osmosis Energy Costs S 1.005 74 Pumps Energy Costs Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) # of Wells Horsepower (HP) per well 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) S 6.048 45 Booster Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) S 6.048 45 Booster Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) S 6.048 45 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) S 3.024 22 Supernatant Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) S 3.024 22 Pump Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) S 3.024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) S 3.024 22 S 3.024 22 S <td>Adjustment S/gal = 0 90 4 00 \$ 328 57 k 1,005 74 Pumps Energy Costs Production Wells Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 6.048 45 Booster Pumps Horsepower (HP) 25 6.048 45 Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ Supernature Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Horsepower (HP) 25 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Hay 3.7 Cost per kW-Hr(\$/kw Hr) \$ 3.024 22 Pump Kation Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 3.024 22 \$ <</td> <td>Alkalinity and pH</td> <td>Na₂CO₃</td> <td>i</td> <td>Dose (mg/L)</td> <td></td> <td>Cost (\$/yr)</td> | Adjustment S/gal = 0 90 4 00 \$ 328 57 k 1,005 74 Pumps Energy Costs Production Wells Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 6.048 45 Booster Pumps Horsepower (HP) 25 6.048 45 Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ Supernature Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Horsepower (HP) 25 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Hay 3.7 Cost per kW-Hr(\$/kw Hr) \$ 3.024 22 Pump Kation Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 3.024 22 \$ < | Alkalinity and pH | Na ₂ CO ₃ | i | Dose (mg/L) | | Cost (\$/yr) | |
| § 1,005 74 Pumps Energy Costs Production Wells Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 * of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supermatant Recycle Horsepower (HP) 75 Pump Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supermatant Recycle Horsepower (HP) 25 Hours Pumping / day 04 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 kilowatt (kW) Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Reverse Osmosis Process Equipment Costs 12.399 32 Vantage M83 RO System Vender Supplied Information Vender Supplied Information \$ 3.024 22 \$ 1.1569 90 \$ 15.022 07 WTP Operations Watter Treatment Plant Personnel 15.022 07 WTP Operations Hours/Week/Operator 2 4 00 0 Payrate (\$/hr) S 34.000 00 \$ 15.020 00 <td>§ 1,00574 Pumps Energy Costs Production Wells Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 ef of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 75 Kilowatt (kW) 18 6425 Hours Pumping / day 04 Kilowatt (kW) 18 6425 Hours Pumping / day 04 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Yearcege M83 RO System Vantage M83 RO System Vender Supplied Information Vender Supplied Information Vender Supplied Information Vender Supplied Information Vender Supplied Information Vender Supplied Information Suppling/Water Quality Analysis Cost (\$/yr) \$ 15.022 07 WTP Operators Number of Operators 24 Hours/Week/Operator Payrate (\$/hr) S 124,800 00 \$ 12,800 00 Sampling/Water Quality Analysis # of Analyses Cost P Test 1,000 00 Ad</td> <td>Adjustment</td> <td>\$/gal =</td> <td>0 90</td> <td>4 00</td> <td>\$</td> <td>328 57</td> | § 1,00574 Pumps Energy Costs Production Wells Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 ef of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 75 Kilowatt (kW) 18 6425 Hours Pumping / day 04 Kilowatt (kW) 18 6425 Hours Pumping / day 04 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Yearcege M83 RO System Vantage M83 RO System Vender Supplied Information Vender Supplied Information Vender Supplied Information Vender Supplied Information Vender Supplied Information Vender Supplied Information Suppling/Water Quality Analysis Cost (\$/yr) \$ 15.022 07 WTP Operators Number of Operators 24 Hours/Week/Operator Payrate (\$/hr) S 124,800 00 \$ 12,800 00 Sampling/Water Quality Analysis # of Analyses Cost P Test 1,000 00 Ad | Adjustment | \$/gal = | 0 90 | 4 00 | \$ | 328 57 | |
| PumpsEnergy CostsProduction WellsHorsepower (HP) per well25 Kilowatt (KW)18 6425 Hours Pumping / day37 0 12Cost per kW-Hr(\$/kw Hr) \$ \$ 6,048 45Booster PumpsHorsepower (HP)25 Kilowatt (kW)18 6425 Hours Pumping / day0 12\$ 6,048 45Booster PumpsHorsepower (HP)25 Kilowatt (kW)18 6425 Hours Pumping / day37 Cost per kW-Hr(\$/kw Hr)Cost (\$/yr) \$ 3,024 22Supernatant RecycleHorsepower (HP)75 Kilowatt (kW)18 6425 Hours Pumping / day04 Cost per kW-Hr(\$/kw Hr)Cost (\$/yr) \$ 3,024 22Supernatant RecycleHorsepower (HP)25 Kilowatt (kW)18 6425 Hours Pumping / day04 Soft er kW-Hr(\$/kw Hr)Cost (\$/yr) \$ 302 42Pump Station PumpsHorsepower (HP)25 Kilowatt (kW)18 6425 Hours Pumping / day37 Soft er kW-Hr(\$/kw Hr)Cost (\$/yr) \$ 302 42Pump Station PumpsHorsepower (HP)25 Kilowatt (kW)18 6425 Hours Pumping / day37 Soft er kW-Hr(\$/kw Hr)Cost (\$/yr) \$ 3,024 22Pump Station PumpsHorsepower (HP)25 Kilowatt (kW)18 6425 Soft er kW-Hr(\$/kw Hr)\$ 3,024 22Pump Station PumpsHorsepower (HP)25 Kilowatt (kW)18 6425 Soft er kW-Hr(\$/kw Hr)\$ 3,024 22Pump Station PumpsHorsepower (HP)25 Kilowatt (kW)18 6425 Soft er kW-Hr(\$/kw Hr)\$ 1,239 32Vartage M83 RO SystemVender Supplied Information Vender Supplied Information\$ 3,452 1 S 11,550 20WTP OperationsNum | Pumps Energy Costs Production Wells Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) 8 Cost (\$/yr) \$ Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) \$ Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) 0 12 Cost (\$/yr) \$ Supernatant Recycle Horsepower (HP) 75 Pump Cost per kW-Hr(\$/kw Hr) KW-hrs/year Cost (\$/yr) \$ Pump Station Pumps Hours Pumping / day 04 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Cost (\$/yr) \$ Reverse Osmosis Process Equipment Costs 23.024 22 Vantage MB3 R0 System Vender Supplied Information Vender Supplied Information 2 \$ 3.452 1 WTP Operations Watter Treatment Plant Personnel 3 11.569 99 WTP Operations Watter Cost per Test Additional Miscellaneous 24 Additional Miscellaneous 3 34.000 00 | | | | | \$ | 1,005 74 | |
| Production Wells Horsepower (HP) per well 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 0 12 \$ 6,048 45 Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 0 12 \$ 0,044 45 Booster Pumps Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supermatant Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Hours Pumping / day 0 4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) 302 42 Pump Station Pumps Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Wurs Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) 3.024 42 Wartage M83 RO System Vender Supplied Information \$ 11,569 99 </td <td>Production Wells Horsepower (HP) per well 25 Kilowatt (KW) Cost Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) 0.12 \$ 6.048.45 Booter Pumps Horsepower (HP) 25 0.12 \$ 6.048.45 Booter Pumps Horsepower (HP) 25 \$ 6.048.45 Booter Pumps Horsepower (HP) 75 \$ 3.024.22 Supernatant Recycle Horsepower (HP) 75 \$ 3.024.22 Pump Kilowatt (kW) 18.6425 \$ 3.024.22 Pump Kilowatt (kW) 18.6425 \$ \$ 3.024.22 Pump Horsepower (HP) 75 \$ \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 \$ \$ 3.024.22 Nums Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 \$ \$ \$ 3.024.22</td> <td>Pumps</td> <td></td> <td>Ener</td> <td>rgy Costs</td> <td></td> <td></td> | Production Wells Horsepower (HP) per well 25 Kilowatt (KW) Cost Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) 0.12 \$ 6.048.45 Booter Pumps Horsepower (HP) 25 0.12 \$ 6.048.45 Booter Pumps Horsepower (HP) 25 \$ 6.048.45 Booter Pumps Horsepower (HP) 75 \$ 3.024.22 Supernatant Recycle Horsepower (HP) 75 \$ 3.024.22 Pump Kilowatt (kW) 18.6425 \$ 3.024.22 Pump Kilowatt (kW) 18.6425 \$ \$ 3.024.22 Pump Horsepower (HP) 75 \$ \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 \$ \$ 3.024.22 Nums Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 \$ \$ \$ 3.024.22 | Pumps | | Ener | rgy Costs | | | |
| Kilowatt (kW) 18 6425 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) \$ 6.048 45 Booster Pumps Horsepower (HP) 25 6.048 45 Hours Pumping / day 37 0.12 \$ 6.048 45 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) \$ 6.048 45 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) \$ 6.048 45 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) \$ 6.0425 Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) \$ 0.302 422 Supernatiant Recycle Horsepower (HP) 7.5 Cost per kW-Hr(\$/kw Hr) \$ 0.024 22 Pump Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) \$ 0.024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) \$ 0.024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) \$ 0.024 22 Yeantage M83 RO System WorkerSupplied Information \$ 0.12 \$ 3.024 22 Vantage M84 RO System Vender Supplied | Kilowatt (kW) 18 6425 Hours Pumping / day 37 # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Boonter Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Boonter Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) 5 Gost (\$/yr) Boonter Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) 5 Gost (\$/yr) Supernatant Recycle Horsepower (HP) 7.5 Cost per kW-Hr(\$/kw Hr) 3.024 22 Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Gost (\$/yr) 3.024 22 Pump Station Pumps Horsepower (HP) 7.5 Cost per kW-Hr(\$/kw Hr) 6.048 45 Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) 0.2 3.024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) 6.048 (\$/yr) Kilowatt (kW) 18 6425 Dia 3.024 22 \$ 3.024 22 Pump Station Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) 2.023 93 22 \$ | Production Wells | Horsepower (HP) per well | 25 | | | | |
| Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) 0.12 \$ 6,048.45 Booster Pumps Horsepower (HP) 25 0.12 \$ 6,048.45 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 6,048.45 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 3,024.22 Superastant Recycle Horsepower (HP) 7.5 \$ \$ 3,024.22 Pump Kilowatt (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) \$ \$ 3,024.22 Pump Kilowatt (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) \$ \$ 3,024.22 Pump Station Pumps Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) \$ \$ 3,024.22 Pump Station Pumps Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ \$ 3,024.22 Vantage M83 RO System Vender Supplied Information \$ Cost (\$/yr) \$ \$ 3,024.22< | Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) # of Wells Operationing 2 0.12 \$ 6,048.45 Booster Pumps Horsepower (HP) 25 0.12 \$ 6,048.45 Booster Pumps Horsepower (HP) 25 0.12 \$ 6,048.45 Booster Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024.22 Supernatiant Recycle Horsepower (HP) 7.5 Cost per kW-Hr(\$/kw Hr) \$ 3,024.22 Pump Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) \$ 3,024.42 Pump Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) \$ 3,024.42 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) \$ 3,024.22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) \$ 3,024.22 Vantage M83 RO System Vender Supplied Information \$ \$ 3,024.22 \$ 3,024.22 \$ 3,024 | | Kilowatt (kW) | 18 6425 | | | | |
| # of Wells Operationing 2 Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) Booster Pumps Horsepower (HP) 25 0 0 12 \$ 6.048 45 Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Superatant Recycle Horsepower (HP) 75 Cost per kW-Hrt(\$/kw Hr) \$ 3.024 22 Pump Kilowatt (kW) 18 6425 Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Hours Pumping / day 0.4 Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Horsepower (HP) 25 E Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Pump Station Pumps Hours Pumping / day 3.7 Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Vantage M83 RO System Vender Supplied Info | # of Wells Operationing 2 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kooster Pumps Horsepower (HP) 25 5 6.048.45 Mosepower (MP) 25 Kilowati (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) 5 3.024.22 Supernatiant Recycle Horsepower (HP) 7.5 Kilowati (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) \$ 3.024.22 Supernatiant Recycle Horsepower (HP) 7.5 Kilowati (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024.22 Pump Kilowati (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024.42 Pump Station Pumps Horsepower (HP) 25 Kilowati (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowati (kW) 18.6425 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024.42 Pump Station Pumps Horsepower (HP) 25 Kilowati (kW) 18.6425 Cost (\$/yr) \$ Cost (\$/yr) \$ S.024.22 \$ <t< td=""><td></td><td>Hours Pumping / day</td><td>37</td><td></td><td></td><td></td></t<> | | Hours Pumping / day | 37 | | | | |
| kW-hrs/year 50403 7 0 12 \$ 6,048 45 Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Cost (\$/yr) Cost (\$/yr) S 3,024 22 Supernatant Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) \$ 3,024 22 Supernatant Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) \$ 3,024 22 Supernatant Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) \$ 3,024 22 Pump Horsepower (HP) 25 Cost (\$/yr) \$ 3,024 22 Pump Station Pumps Horsepower (HP) 25 Cost (\$/yr) \$ 3,024 22 Pump Station Pumps Horsepower (HP) 25 Cost (\$/yr) \$ 3,024 22 Wenhrs/year 25,201 9 0 12 \$ 3,024 22 \$ 3,024 22 Wump Station Pumps Horsepower (HP) 25 Cost (\$/yr) \$ \$ 3,024 22 \$ Vantage M83 | kW-hrs/year 50403 7 0 12 \$ 6.048 45 Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(§/kw Hr) Cost (\$/yr) \$ 3.024 22 Supernatant Recycle Horsepower (HP) 7 5 Cost per kW-Hr(§/kw Hr) S 3.024 22 Supernatant Recycle Horsepower (HP) 7 5 Cost per kW-Hr(§/kw Hr) Cost (\$/yr) S 3.024 22 Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(§/kw Hr) Cost (\$/yr) S 3.024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(§/kw Hr) Cost (\$/yr) S 3.024 22 Pump Station Pumps Hours Pumping / day 3 7 Cost per kW-Hr(§/kw Hr) Cost (\$/yr) S 3.024 22 Pump Station Pumps Hours Pumping / day 3 7 Cost per kW-Hr(§/kw Hr) Cost (\$/yr) S 3.024 22 Vantage M83 RO System Vender Supplied Information S 3.024 22 S 3.024 22 S 3.042 12 S | | # of Wells Operationing | 2 | Cost per kW-Hr(\$/kw Hr) | | Cost (\$/yr) | |
| Booster Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 75 s 3.024 22 Supernatant Recycle Horsepower (HP) 75 s s 3.024 22 Pump Kilowatt (kW) 18 6425 o s 3.024 22 Pump Kilowatt (kW) 18 6425 o s 3.024 22 Pump Station Pumps Horsepower (HP) 25 s 3.024 22 Fung Station Pumps Horsepower (HP) 25 s 3.024 22 Kilowatt (kW) 18 6425 s 3.024 22 \$ 3.024 22 Fung Station Pumps Horsepower (HP) 25 s 3.024 22 \$ 3.024 22 Kilowatt (kW) 18 6425 Iours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3.024 22 Kurage M83 RO System Vender Supplied Information \$ 3.452 1 \$ 1.15692 | Booster Pumps Horsepower (HP) 25 Kilowatt (kW) Cost per kW-Hrt(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 75 Kilowatt (kW) 18 6425 0 12 \$ 3,024 22 Supernatant Recycle Horsepower (HP) 75 Kilowatt (kW) 18 6425 0 12 \$ 3,024 22 Pump Kilowatt (kW) 18 6425 0 12 \$ 3,024 22 Pump Kilowatt (kW) 18 6425 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Vantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 1,00000 \$ 124,800 00 \$ | | kW-hrs/year | 50403 7 | 0 12 | \$ | 6,048 45 | |
| Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatiant Recycle Horsepower (HP) 7 0 12 \$ 3,024 22 Supernatiant Recycle Horsepower (HP) 75 0 12 \$ 3,024 22 Pump Kilowatt (kW) 18 6425 0 12 \$ 3,024 22 Hours Pumping / day 0 4 Cost per kW-Hr(\$/kw Hr) \$ 3,024 22 Pump Station Pumps Horsepower (HP) 25 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kulowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kulowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Yantage M83 RO System Vender Supplied Information \$ 11,569 99 \$ 11,56 | Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 75 3,024 22 Bump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Supernatant Recycle Horsepower (HP) 75 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Pump Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Pump Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 302 42 Pump Station Pumps Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 302 42 Wantage M83 RO System Vender Supplied Information \$ 3,452 1 \$ 3,452 1 \$ 3,452 1 \$ 11,569 39 \$ 11,569 30 \$ 11,569 30 \$ 3,452 0 \$ 11,569 30 | Booster Pumps | Horsepower (HP) | 25 | | | | |
| Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 7.5 0.12 \$ 3,024.22 Pump Kilowatt (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Cost (\$/yr) Pump Horsepower (HP) 7.5 0.12 \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 0.12 \$ 3.024.22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) 3.024.22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) 3.024.22 Number of Numping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 3.024.22 Vantage M83 RO System Vender Supplied Information \$ 12.399.32 Vantage M84 RO System Vender Supplied Information \$ 3.452.1 Vantage M84 RO System Vender Supplied Information \$ 11.569.99 Sampling/Water Quality Analysis # of Analyses Cost per Test </td <td>Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 7.5 0.12 \$ 3,024 22 Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Cost (\$/yr) Pump Station Pumps Horsepower (HP) 25 0.12 \$ 3024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 0.12 \$ 3024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 0.12 \$ 3024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Wares Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 12,399 32 \$ 12,399 32 Wantage M83 RO System Vender Supplied Information \$ 3,452 1 \$ 11,569 99 \$ 11,569 99 Vantage M84 RO</td> <td></td> <td>Kilowatt (kW)</td> <td>18 6425</td> <td></td> <td></td> <td></td> | Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Supernatant Recycle Horsepower (HP) 7.5 0.12 \$ 3,024 22 Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Cost (\$/yr) Pump Station Pumps Horsepower (HP) 25 0.12 \$ 3024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 0.12 \$ 3024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 0.12 \$ 3024 22 Pump Station Pumps Horsepower (HP) 25 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Kilowatt (kW) 18 6425 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Wares Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) \$ 12,399 32 \$ 12,399 32 Wantage M83 RO System Vender Supplied Information \$ 3,452 1 \$ 11,569 99 \$ 11,569 99 Vantage M84 RO | | Kilowatt (kW) | 18 6425 | | | | |
| kW-hrs/year 25,201 9 0 12 \$ 3,024 22 Supernatant Recycle Pump Horsepower (HP) 7 5 Kilowatt (kW) 18 6425 14 04 0 4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Pump Horsepower (HP) 25 Kilowatt (kW) 0 12 \$ 3024 22 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 0 12 \$ 302 42 Pump Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 3,024 22 \$ 3,024 22 Vantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ Cost (\$/yr) \$ 3,452 1 WTP Operations Water Treatment Plant Personnel \$ 11,569 99 \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 \$ 34,52 1 WTP Operator< | kW-hrs/year 25,201 9 0 12 \$ 3,024 22 Supernatiant Recycle Pump Horsepower (HP) 7 5 Kilowatt (kW) 0 4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Numps Horsepower (HP) 25 Kilowatt (kW) 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 0 4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) KW-hrs/year 25,201 9 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) KW-hrs/year 25,201 9 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs Cost (\$/yr) \$ 3,024 22 Vantage M83 RO System Vender Supplied Information \$ Gost (\$/yr) \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 \$ 34,000 00 \$ <th< td=""><td></td><td>Hours Pumping / day</td><td>37</td><td>Cost per kW-Hr(\$/kw Hr)</td><td></td><td>Cost (\$/yr)</td></th<> | | Hours Pumping / day | 37 | Cost per kW-Hr(\$/kw Hr) | | Cost (\$/yr) | |
| Supernatiant Recycle Pump Horsepower (HP) 7 5 Kilowatt (kW) 18 6425 Hours Pumping / day 0 4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kW-hrs/year 2,520 2 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 0 12 \$ 302 42 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Wenders Supplied Information \$ 12,399 32 \$ 12,399 32 Reverse Osmosis Process Equipment Costs \$ 3,024 22 Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 15,609 9 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 \$ 15,022 07 \$ 30 \$ 124,800 00 < | Supernatiant Recycle Pump Horsepower (HP) 7.5 Kilowatt (kW) Ost per kW-Hr(\$/kw Hr) Cost (\$/yr) Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) \$ 302.42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 0.12 \$ 302.42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18.6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) KW-hrs/year 25,201.9 0.12 \$ 3,024.22 \$ 12,399.32 Reverse Osmosis Process Equipment Costs \$ 12,399.32 Vantage M83 RO System Vender Supplied Information \$ 3,452.1 Vantage M84 RO System Vender Supplied Information \$ 11,569.99 WTP Operations Watter Treatment Plant Personnel \$ 15,022.07 WTP Operator 2 40.00 30 \$ 124,800.00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800.00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800.00 | | kW-hrs/year | 25,201 9 | 0 12 | \$ | 3,024 22 | |
| Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Hours Pumping / day 0 4 Cost per kW-Hr(\$/kw Hr) 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 0 12 \$ 302 42 Fump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 12,399 32 Reverse Osmosis Process Equipment Costs \$ 12,399 32 \$ 12,399 32 Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M83 RO System Vender Supplied Information \$ 11,569 99 Vantage M84 RO System Vender Supplied Information \$ 15,022 07 WTP Operations Water Treatment Plant Personnel \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 124,800 00 | Pump Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Hours Pumping / day 0 4 Cost per kW-Hr(\$/kw Hr) 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 6 6 6 Kilowatt (kW) 18 6425 Kilowatt (kW) 18 6425 6 6 6 302 42 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Kilowatt (kW) 18 6425 6 12 \$ 3,024 22 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 12,399 32 Reverse Osmosis Process Equipment Costs \$ 12,399 32 \$ 12,399 32 Vantage M83 RO System Vender Supplied Information \$ \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ \$ \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ | Supernatant Recycle | Horsepower (HP) | 75 | | | | |
| Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kW-hrs/year 2,520.2 0.12 \$ 302.42 Pump Station Pumps Horsepower (HP) 25 0.12 \$ 302.42 Kilowatt (kW) 18.6425 Kilowatt (kW) 18.6425 0.12 \$ 3,024.22 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024.22 KW-hrs/year 25,201.9 0.12 \$ 3,024.22 \$ 12,399.32 Reverse Osmosis Process Equipment Costs \$ 12,399.32 \$ 12,399.32 Vantage M83 RO System Vantage M83 RO System Vender Supplied Information Vender Supplied Information \$ 3,452.1 \$ 11,569.99 \$ 11,569.99 WTP Operations Water Treatment Plant Personnel \$ 15,022.07 \$ 15,022.07 WTP Operator 2 40.00 30 \$ 124,800.00 \$ 124,800.00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000.00 \$ 34,000.00 \$ 158,800.00 | Hours Pumping / day 0.4 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kW-hrs/year 2,520.2 0.12 \$ 302.42 Pump Station Pumps Horsepower (HP) 25 0.12 \$ 302.42 Kilowatt (kW) 18.6425 Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kW-hrs/year 25,201.9 0.12 \$ 3,024.22 \$ 12,399.32 Reverse Osmosis Process Equipment Costs \$ 12,399.32 Vantage M83 RO System Vender Supplied Information \$ 3,452.1 Vantage M84 RO System Vender Supplied Information \$ 11,569.99 Vartage M84 RO System Vender Supplied Information \$ 15,022.07 WTP Operations Water Treatment Plant Personnel \$ 15,022.07 WTP Operator 2 40.00 30 \$ 124,800.00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 1,000.00 \$ 10,000.00 \$ 158,800.00 \$ 158,800.00 | Pump | Kilowatt (kW) | 18 6425 | | | | |
| kW-hrs/year 2,520 2 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 \$ 12,399 32 Vantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ 3,452 1 \$ 3,452 1 WTP Operations Water Treatment Plant Personnel \$ 11,569 99 \$ 15,022 07 WTP Operator Quality Analysis # of Analyses Cost per Kest Additional Miscellaneous \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 | kW-hrs/year 2,520 2 0 12 \$ 302 42 Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 \$ 12,399 32 Vantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ 012 \$ 3,452 1 WTP Operations Water Treatment Plant Personnel \$ 11,569 99 \$ 15,022 07 WTP Operator Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 | | Hours Pumping / day | 04 | Cost per kW-Hr(\$/kw Hr) | | Cost (\$/yr) | |
| Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) \$ 3,024 22 KW-hrs/year 25,201 9 0 12 \$ 3,024 22 \$ 12,399 32 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Vantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ 3,452 1 \$ 3,452 1 WTP Operations Water Treatment Plant Personnel \$ 11,569 99 \$ 15,022 07 WTP Operator Number of Operators Hours/Week/Operator Payrate (\$/hr) Cost (\$/yr) WTP Operator 2 40 00 30 \$ 124,800 00 \$ 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 24 1,000 00 \$ 10,000 00 \$ 158,800 00 \$ 158,800 00 | Pump Station Pumps Horsepower (HP) 25 Kilowatt (kW) 18 6425 Hours Pumping / day 37 Cost per kW-Hr(\$/kw Hr) \$ 3,024 22 kW-hrs/year 25,201 9 0 12 \$ 3,024 22 \$ 12,399 32 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Vantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ 3,452 1 \$ 3,452 1 WTP Operations Water Treatment Plant Personnel \$ 11,569 99 \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 | | kW-hrs/year | 2,520 2 | 0 12 | \$ | 302 42 | |
| Kilowatt (kW) 18 6425 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) Hours Pumping / day 3 7 Cost per kW-Hr(\$/kw Hr) \$ 3,024 22 kW-hrs/year 25,201 9 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Wantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 | Kilowatt (kW) 18 6425 Hours Pumping / day Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kW-hrs/year 37 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Wantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ 0 12 \$ 3,452 1 Watter Burge M84 RO System Vender Supplied Information \$ 0 12 \$ 3,452 1 WTP Operations Water Treatment Plant Personnel \$ 0 12 \$ 11,569 99 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800 00 | Pump Station Pumps | Horsepower (HP) | 25 | | | | |
| Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kW-hrs/year 25,201 9 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Wantage M83 RO System Vender Supplied Information Vender Supplied Information Cost (\$/yr) \$ 3,452 1 Wantage M84 RO System Vender Supplied Information \$ 11,569 99 \$ 15,022 07 WTP Operations Water Treatment Plant Personnel Cost (\$/yr) \$ 24,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 | Hours Pumping / day 3.7 Cost per kW-Hr(\$/kw Hr) Cost (\$/yr) kW-hrs/year 25,201 9 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Wantage M83 RO System Vender Supplied Information Cost (\$/yr) \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 \$ 15,022 07 WTP Operations Water Treatment Plant Personnel Cost (\$/yr) \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 1,000 00 \$ 158,800 00 \$ 158,800 00 | | Kilowatt (kW) | 18 6425 | | | | |
| kW-hrs/year 25,201 9 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs \$ 12,399 32 Wantage M83 RO System Vender Supplied Information Vender Supplied Information Cost (\$/yr) \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 3,452 1 \$ 11,569 99 \$ 11,569 99 \$ 15,022 07 WTP Operations Water Treatment Plant Personnel \$ 000 \$ \$ 124,800 00 \$ 240 00 \$ 30 \$ 24,800 00 \$ 34,000 00 \$ 34, | kW-hrs/year 25,201 9 0 12 \$ 3,024 22 Reverse Osmosis Process Equipment Costs Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 3,452 1 Wartage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800 00 | | Hours Pumping / day | 37 | Cost per kW-Hr(\$/kw Hr) | | Cost (\$/yr) | |
| s 12,399 32 Reverse Osmosis Process Equipment Costs Vantage M83 RO System Vender Supplied Information Cost (\$/yr) Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800 00 | s 12,399 32 Reverse Osmosis Process Equipment Costs Vantage M83 RO System Vender Supplied Information Cost (\$/yr) Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel \$ 15,022 07 WTP Operator Number of Operators Hours/Week/Operator Payrate (\$/hr) \$ 24,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800 00 | | kW-hrs/year | 25,201 9 | 0 12 | \$ | 3,024 22 | |
| Vantage M83 RO System Vender Supplied Information Cost (\$/yr) Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations ¥ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 158,800 00 \$ 158,800 00 | Vantage M83 RO System Vender Supplied Information Cost (\$/yr) Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Watter Treatment Plant Personnel WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 158,800 00 \$ 158,800 00 | Reverse Ormorie | I | Process Fo | winment Costs | \$ | 12,399 32 | |
| Vantage M83 RO System Vender Supplied Information \$ 3,452 1 Vantage M84 RO System Vender Supplied Information \$ 3,452 1 Wantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 34,000 00 Sampling Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800 00 | Vantage M83 RO System Vantage M84 RO System Vender Supplied Information Vender Supplied Information \$ 3,452 1 Wantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel \$ 15,022 07 WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 10,000 00 \$ 158,800 00 | 210.0100 0000000 | | 1100000 119 | | | Cost (\$/vr) | |
| Wantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 34,000 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous \$ 158,800 00 | Wantage M84 RO System Vender Supplied Information \$ 11,569 99 WTP Operations Water Treatment Plant Personnel WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 158,800 00 | Vantage M83 RO System | Vender | Supplied Informatio | n | \$ | 3.452.1 | |
| WTP Operations Water Treatment Plant Personnel WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 158,800 00 | WTP Operations Water Treatment Plant Personnel WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 158,800 00 | Vantage M84 RO System | Vender | Supplied Informatio | on | \$ | 11,569 99 | |
| WTP Operations Water Treatment Plant Personnel WTP Operator Number of Operators Hours/Week/Operator Payrate (\$/hr) Cost (\$/yr) WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$10,000 00 \$ 158,800 00 | WTP Operations Water Treatment Plant Personnel WTP Operator Number of Operators Hours/Week/Operator Payrate (\$/hr) Cost (\$/yr) WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 34,000 00 \$ 1,000 00 \$10,000 00 \$ 158,800 00 | 0 , ' | | | | \$ | 15,022 07 | |
| WTP Operator Number of Operators Hours/Week/Operator Payrate (\$/hr) Cost (\$/yr) Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 158,800 00 | WTP Operator Number of Operators Hours/Week/Operator Payrate (\$/hr) Cost (\$/yr) WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 34,000 00 \$ 158,800 00 | WTP Operations | T | Vater Treatma | ent Plant Personnel | | | |
| WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 34,000 00 \$ 34,000 00 \$ 34,000 00 \$ 158,800 00 \$ 158,800 00 \$ 158,800 00 \$ \$ 158,800 00 | WTP Operator 2 40 00 30 \$ 124,800 00 Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 34,000 00 \$ 158,800 00 \$ 158,800 00 | ,, II Operations | Number of Operators H | Hours/Week/Operato | r Payrate (\$/hr) | | Cost (\$/yr) | |
| Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 10,000 00 \$ 34,000 00 \$ 158,800 00 \$ 158,800 00 | Sampling/Water Quality Analysis # of Analyses Cost per Test Additional Miscellaneous 24 \$ 1,000 00 \$ 10,000 00 \$ 34,000 00 \$ 158,800 00 \$ 158,800 00 | WTP Operator | 2 | 40 00 | 30 | \$ | 124,800 00 | |
| 24 \$ 1,000 00 \$10,000 00 \$ 34,000 00 \$ 1,000 00 \$ 158,800 00 \$ 158,800 00 | 24 \$ 1,000 00 \$ 34,000 00 \$ 34,000 00 \$ 158,800 00 <td>ampling/Water Quality Analysis</td> <td># of Analyses</td> <td>Cost per Test</td> <td>Additional Miscellaneous</td> <td></td> <td></td> | ampling/Water Quality Analysis | # of Analyses | Cost per Test | Additional Miscellaneous | | | |
| \$ 158,800 00 | \$ 158,800 00 | / / | 24 \$ | 1,000 00 | \$10,000 00 | \$ | 34,000 00 | |
| | | | | | | \$ | 158,800 00 | |
| | | | | | | | | |

| Item | Quantity | Unit Cost | Unit | Total Cost |
|--|----------|-------------|------|------------------|
| | | | | |
| Item 1 - Individual RO System with booster pumps, tanks, etc. | 100 | \$ 4,813.17 | EA | \$481,317 |
| | | | | |
| | | | | |
| Item 2 - RO System Housing | | | | |
| Building Shed | 100 | \$5.000 | EA | \$500.000 |
| | | 40,000 | | +, |
| | | | | |
| Item 3 - Piping, Mechanical, and Electrical Work | | | | |
| Piping from well and to home | 100 | \$5,000 | EA | \$500,000 |
| Control System for RO | 100 | \$2,500 | EA | \$250,000 |
| Mechanical/Electrical work in RO Building | 100 | \$3,500 | EA | \$350,000 |
| Item 4: Indirects | | | | |
| Survey | 64 | \$144 | HR | \$9,200 |
| Project Manager | 120 | \$863 | Days | \$103,500 |
| Superintendant | 180 | \$748 | Days | \$134,550 |
| Administrative | 100 | \$518 | Days | \$51,750 |
| Insurance | 1 | \$69,000 | LS | \$69,000 |
| Bonds | 1 | \$69,000 | LS | \$69,000 |
| Subtotal | | | | \$2,518,317 |
| Contingency (10%) | | | | \$251.832 |
| Total | | | | \$2 770 149 |
| 10(a) | | | | $\psi 2,770,149$ |

Battlefield Golf Club Water Project Residential RO Systems - Point of Entry - Alternative 3

Battlefield Golf Club Water Project Residential Point of Entry O & M Cost Comparison - Alternative 3

| Number of Homes (ERCs) | 100 | |
|------------------------|----------|-----|
| Daily Water | 400 | gpd |
| RO Efficiency | 40 | % |
| Waste Water | 1000.000 | gpd |

| | | Energy Costs | | | | | | |
|---------------------------------|---------------------|----------------------------|---------------------------|----|--------------|--|--|--|
| Heating and Electric for Shed | | | Cost per kW-Hr(\$/kw Hr) | | Cost (\$/yr) | | | |
| | kW-hrs/yea | r 1,500 0 | 0 12 | \$ | 180 00 | | | |
| Booster Pumps | Watts (W |) 1120 | | | | | | |
| | Horsepower (HP |) 1 50 | | | | | | |
| | Kilowatt (kW |) 112 | | | | | | |
| | Hours Pumping / day | y 67 | Cost per kW-Hr(\$/kw Hr) | | Cost (\$/yr) | | | |
| | kW-hrs/yea | r 2,725 3 | 0 12 | \$ | 327 04 | | | |
| | | | | \$ | 50,704 00 | | | |
| Reverse Osmosis | | Process Equ | upment Costs | | | | | |
| | | | Per Invidual Unit | | Cost (\$/yr) | | | |
| Individual RO System | Rep | lacement Filter Cartridges | 1380 | \$ | 138,000 00 | | | |
| Individual RO System | I | Replacement Membrances | 143 75 | \$ | 14,375 00 | | | |
| Individual RO System | Me | mbrane Cleaning Supplies | 230 | \$ | 23,000 00 | | | |
| | | | | \$ | 175,375 00 | | | |
| Operations | | City of Chesa | peake Personnel | | | | | |
| | Number of Operators | Hours/Week/Operator | Payrate (\$/hr) | | Cost (\$/yr) | | | |
| WTP Operator | 2 | 40 00 | 30 | \$ | 124,800 00 | | | |
| Sampling/Water Quality Analysis | # of Analyses | Cost per Test | Additional Miscellaneous | | | | | |
| | 100 | \$ 1,000 00 | \$10,000 00 | \$ | 110,000 00 | | | |
| | | | • | \$ | 234,800 00 | | | |

| Item | Quantity | Unit Cost | Unit | Total Cost |
|---|----------|-------------|------|------------|
| | | | | |
| Item 1 | | | | |
| Abandon Existing Well | 100 | \$ 1,500.00 | EA | \$150,000 |
| | | | | |
| Item 2 - New Wells | | | | |
| Permitting | 100 | \$100 | ΕA | \$10,000 |
| Drilling and Well Installation Cost (incl. pump and wiring) | 100 | \$3,000 | EA | \$300,000 |
| Disinfection | 100 | \$200 | EA | \$20,000 |
| Water Quality Testing | 100 | \$1,000 | EA | \$100,000 |
| | | | | |
| Item 3 - Home Water System | | | | |
| Pressure Tank and Water Conditioner | 100 | \$1,000 | EA | \$100,000 |
| Plumbing | 100 | \$500 | EA | \$50,000 |
| Subtotal | | | | \$730,000 |
| Contingency (10%) | | | | \$73,000 |
| Total | | | | \$803,000 |

Battlefield Golf Club Water Project New Private Wells into the Yorktown Eastover Aquifer - Alternative 4

Battlefield Golf Club Water Project New Private Wells (O & M) - Alternative 4

| Item C | | Unit Cost | Unit | Total Cost |
|--|-----|-----------|------|------------|
| | | | | |
| Item 1 | | | | |
| Filter Replacement, electricity, repairs, new pump replacement | 100 | \$ 100.00 | EA | \$10,000 |
| ten years, etx. | | | | |
| Total | | | | \$10,000 |

APPENDIX P Alternative Evaluation Matrix

URS

Alternatives Evaluation Matrix

| Alternatives Evaluation | | Alternatives | | | | | | | |
|--|--------------------|--------------|------|----------|-----|----------|-----|-------|------|
| | | Optio | on 1 | Option 2 | | Option 3 | | Optic | on 4 |
| Categories and Criteria | Relative Weight | AR | WR | AR | WR | AR | WR | AR | WR |
| | | | | | | | | | |
| Regulatory Compliance - Water Quality | 20% | | | | | | | | |
| - Meets VA Drinking Water Standards | 10 | 5 | 50 | 5 | 50 | 4 | 40 | 3 | 30 |
| - Long Term Compliance | 10 | 5 | 50 | 5 | 50 | 4 | 40 | 1 | 10 |
| Property Owner Impact | 16% | | | | | | | | |
| -Affects Property Value | 8 | 5 | 40 | 4 | 32 | 2 | 16 | 3 | 24 |
| -Homeowner responsibilities / increased burdens / Safety | 8 | 3 | 24 | 3 | 24 | 1 | 8 | 5 | 40 |
| Operational Requirements | 16% | | | | | | | | |
| - Sustainability (waste gen/resources/conserve energy) | 8 | 5 | 40 | 0 | 0 | 0 | 0 | 5 | 40 |
| - Reliability | 8 | 5 | 40 | 4 | 32 | 4 | 32 | 2 | 16 |
| Technical Feasibility | 14% | | | | | | | | |
| - Time for Implementation | 8 | 4 | 32 | 0 | 0 | 3 | 24 | 5 | 40 |
| - Constructability | 6 | 3 | 18 | 2 | 12 | 2 | 12 | 5 | 30 |
| Present Worth | 20% | | | | | | | | |
| - Capital costs | 10 | 2 | 20 | 0 | 0 | 3 | 30 | 5 | 50 |
| - O & M costs | 10 | 5 | 50 | 1 | 10 | 0 | 0 | 5 | 50 |
| Permitting / Administrative Burdens | 14% | | | | | | | | |
| - Permitting | 8 | 3 | 24 | 0 | 0 | 1 | 8 | 3 | 24 |
| - Level of effort | 6 | 4 | 24 | 0 | 0 | 1 | 6 | 2 | 12 |
| m . 1 . 1 . 1 | 100 | | 410 | | 010 | | 014 | | 0.11 |
| 1 otal weighted alternative rating | 100 | | 412 | | 210 | | 216 | | 366 |

Relative weight - relative importance of criteria as compared to other criteria; scale 0 - 10; no importance rated 0, most important rated 10

AR - Alternative rating. Rates the alternatives according to their anticipated performance with respect to the various criteria;

scale 0 to 5; least favorable rated 0, most favorable rated 5.

| AR Scale | | | |
|----------|---------------------------|--|--|
| 0 | Exceptionally Unfavorable | | |
| 1 | Very Unfavorable | | |
| 2 | Somewhat Unfavorable | | |
| 3 | Somewhat Favorable | | |
| 4 | Very Favorable | | |
| 5 | Exceptionally Favorable | | |

WR - Weighted rating. Relative weight for each criteria multiplied by alternative rating.

Total weighted alternative rating -Sum of weighted ratings for each alternative

Option Description

- 1 Provide City Water via a Water Main Extension.
- 2 Install a Community Groundwater Supply, Treatment, Storage and Distribution System.
- 3 Install POE Treatment Systems on Existing Private Wells
- 4 Install New Private Wells