

US EPA ARCHIVE DOCUMENT

60-Day Inspection Results for Impressed Current Cathodic Protection Systems

FACILITY NAME: _____

AMP RANGE RECOMMENDED: _____

VOLTAGE RANGE RECOMMENDED: _____

Date	Your Name	Voltage Reading	Amp Reading	Is Your System Running Properly? (Yes/No)

- If the rectifier voltage and/or amperage output(s) are outside the recommended operating levels, contact a cathodic protection expert to address the problem.
- Never turn off your rectifier.
- KEEP THIS RECORD FOR AT LEAST 6 MONTHS AFTER THE DATE OF THE LAST READING