

US EPA ARCHIVE DOCUMENT

EPA Water Supply System Sampling November 2008

Asterisk Number	Municipal Plant	Sample Type	PFOA	PFOS
13	Moulton Turkey Creek	Raw	Below Quantitation Limit	Below Quantitation Limit
12	Moulton Sinking Creek	Raw	Below Quantitation Limit	Below Quantitation Limit
12	Moulton Sinking Creek	Finished	Below Quantitation Limit	Below Quantitation Limit
16	West Morgan East Lawrence	Raw	28	26
16	West Morgan East Lawrence	Finished	25	21
16	West Morgan East Lawrence	Finished	26	Below Quantitation Limit
14	Decatur	Raw	Below Quantitation Limit	Below Quantitation Limit
14	Decatur	Finished	Below Quantitation Limit	Below Quantitation Limit

Sample values are reported in parts per trillion.