

Statement of Basis

Greenhouse Gas Prevention of Significant Deterioration Preconstruction Permit for the Calpine Corporation, Deer Park Energy Center (DPEC), LLC

Permit Number: PSD-TX-979-GHG

August 2012

This document serves as the Statement of Basis required by 40 CFR 124.7. This document sets forth the legal and factual basis for the draft permit conditions and provides references to the statutory or regulatory provisions, including provisions under 40 CFR 52.21, that would apply if the permit is finalized. This document is intended for use by all parties interested in the permit.

I. Executive Summary

On September 1, 2011, the Calpine Corporation, Deer Park Energy Center (DPEC), LLC, submitted to EPA Region 6 a Prevention of Significant Deterioration (PSD) permit application for Greenhouse Gas (GHG) emissions from proposed construction of a natural gas-fired combined-cycle combustion turbine generator (CTG) at the existing DPEC facility. In connection with the same proposed project, Calpine Corporation submitted a PSD permit application for non-GHG pollutants to the Texas Commission on Environmental Quality (TCEQ) on September 1, 2011. On December 11, 2011, February 7, 2012, April 2, 2012, April 30, 2012 and June 22, 2012, Calpine submitted additional information to amend their permit applications to both EPA and TCEQ, revising the permit applications to incorporate a multiphase construction of the proposed CTG. The revised project at the DPEC plant proposes phased construction of the natural gas-fired combined-cycle CTG with a generating capacity of approximately 180 megawatts that will be completed in two stages of construction. In the initial phase, Calpine intends to construct a Siemens Model FD2 combustion turbine that will be subsequently be upgraded in performance as a FD3-series combustion turbine in the second stage of construction. Modification of the FD2 combustion turbine to the FD3-series would commence within eighteen (18) months of completion of construction or beginning of commercial operation of the initial project. After reviewing the application, EPA Region 6 has prepared the following Statement of Basis (SOB) and draft air permit to authorize phased construction of air emission sources at DPEC.

This SOB documents the information and analysis EPA used to support the decisions EPA made in drafting the air permit. It includes a description of the proposed facility, the applicable air permit requirements, and an analysis showing how the applicant complied with the requirements.

EPA Region 6 concludes that Calpine's application is complete and provides the necessary information to demonstrate that the proposed project meets the applicable air permit regulations. EPA's conclusions rely upon information provided in the permit application, supplemental information EPA requested and provided by Calpine Corporation, and EPA's own technical analysis. EPA is making all this information available as part of the public record.

II. Applicant

Calpine Corporation 717 Texas, Suite 1000 Houston, TX 77002

Physical Address: 5665 Highway 225 Deer Park, TX 77536

Contact: Patrick Blanchard Director of Environmental, Health and Services Deer Park Energy Center LLC 717 Texas, Suite 1000 Houston, TX 77002

III. Permitting Authority

On May 3, 2011, EPA published a federal implementation plan that makes EPA Region 6 the PSD permitting authority for the pollutant GHGs. 75 FR 25178 (promulgating 40 CFR § 52.2305). Texas still retains approval of its plan and PSD program for pollutants that were subject to regulation before January 2, 2011, i.e., regulated NSR pollutants other than GHGs.

The GHG PSD Permitting Authority for the State of Texas is:

EPA, Region 6 1445 Ross Avenue Dallas, TX 75202

The EPA, Region 6 Permit Writer is: Alfred C. Dumaual, Ph.D. Air Permitting Section (6PD-R) (214) 665-6613

The Non-GHG PSD Permitting Authority for the State of Texas is:

Air Permits Division (MC-163) TCEQ P.O. Box 13087 Austin, TX 78711-3087

IV. Facility Location

The Calpine Corporation, DPEC plant is located in Harris County, Texas, and this area is currently considered to be in attainment for all NAAQS with the exception of the 8 hour Ozone standard, for which it is classified as a marginal non-attainment area as of April 2012. The geographic coordinates for this facility are as follows:

| Latitude: | 29° 42' 43.6" | North | (29.712111) |
|------------|---------------|-------|--------------|
| Longitude: | 95° 08' 7.8" | West | (-95.135511) |

The figures below illustrate the facility location for this draft permit in city of Deer Park, Harris County, Texas.



V. Applicability of Prevention of Significant Deterioration (PSD) Regulations

EPA concludes Calpine's proposed modification is subject to PSD review for the pollutant GHG, because the project would lead to an emissions increase of GHGs for a facility as described at 40 CFR §§ 52.21(b)(23) and (49)(iv). Under the project, GHG emissions are calculated to increase over zero tons per year (tpy) on a mass basis and well exceed the applicability threshold of 75,000 tpy CO₂e. (EPA calculates CO₂e emissions of 1,045,635 tpy in the initial phase of construction which is increased to 1,060,783 tpy after the final phase of construction). EPA Region 6 implements a GHG PSD FIP for Texas under the provisions of 40 CFR § 52.21 (except paragraph (a)(1)). See 40 CFR § 52.2305.

As the permitting authority for regulated NSR pollutants other than GHGs, TCEQ has determined the modification is subject to PSD review for non-GHG pollutants. Accordingly, under the circumstances of this project, the State will issue the non-GHG portion of the permit and EPA will issue the GHG portion.¹

EPA Region 6 applies the policies and practices reflected in the EPA document entitled "PSD and Title V Permitting Guidance for Greenhouse Gases" (March 2011). Consistent with that guidance, we have not required the applicant to model or conduct ambient monitoring for GHGs, and EPA Region 6 has not required any assessment of impacts of GHGs in the context of the additional impacts analysis or Class I area provisions. Instead, EPA has determined that compliance with the BACT analysis is the best technique that can be employed at present to satisfy the additional impacts analysis and Class I area requirements of the rules related to GHGs. We note again, however, that the project has triggered review for regulated NSR pollutants that are non-GHG pollutants under the PSD permit sought from TCEQ.

VI. Project Description

The proposed GHG PSD permit, if finalized, will allow DPEC to initiate a multiphase construction of a new 180 MW natural gas-fired Siemens 501 F-series combined-cycle combustion turbine generator, identified as CTG5, with a plant-wide generating capacity of 1230-1300 MW, depending on ambient conditions. The phased construction for this project will be carried out in two stages. In the initial stage, Calpine proposes to construct a 168 MW natural gas-fired Siemens Model 501 FD2 combined-cycle combustion turbine as described above upon issuance of the PSD GHG permit. In the final stage, the FD2 combustion turbine will be upgraded to a 180 MW FD3 combustion turbine, this involves replacement of a limited number of internal components of the turbine which will be accomplished in the timeframe of a routine outage. The modification includes improvements to the turbine blades, vanes and improved compressors seals that allow the turbine to regain generation capacity that is lost in the summer months due to hot ambient conditions. Calpine plans to install the turbine using the FD2 configuration to ensure the project is online and available to supply needed power to the Electric Reliability Council of Texas (ERCOT) grid for the summer of 2014 peak season. Additional time may be required to install the parts required for an FD3 configuration, and hence a two-

¹ U.S. Environmental Protection Agency, *Question and Answer Document: Issuing Permits for Sources with Dual PSD Permitting Authorities*, April 19, 2011,< <u>http://www.epa.gov/nsr/ghgdocs/ghgissuedualpermitting.pdf</u>> (April 2011).

phased construction period is required to avoid compromising the scheduled construction and installation of the combustion turbine.

Calpine intends to begin the upgrade of the Siemens 501 FD2-series engine to the FD3-series within an eighteen (18) month period following commercial operation of the FD2 series unit. Completion of construction of the initial project will occur the date that commercial operation of the FD2 phase of the project begins, or no later than eighteen (18) months after initial testing is completed in order to account for any additional work that may take place during the "shakedown period" that immediately follows first fire of the proposed turbine. The increased changes in CO₂ emissions due to this modification are presented in the calculations of the original application as submitted on September 1, 2011. It is calculated that the proposed combustion turbine is an FD3-series engine will generate more CO₂ emissions than the FD2series; however, the heat rate (in Btu/kWh) for the combined cycle process is about the same for both configurations. Some or all of the steam produced from the new combustion turbine will either exhaust to a dedicated Heat Recovery Steam Generator (HRSG) to produce steam or be sold to a neighboring facility. The steam produced from the HRSG is then routed to an existing shared 200 MW steam turbine unit to produce electricity for sale to the ERCOT power grid. Listed in the table below is a summary of the emissions for this project, a detailed analysis of the calculations can be found in the Appendix, Tables 1 through 8:

| Total GHG Potential Emissions – Phase 1 of Construction (FD2) | | | | | | |
|---|--|-------------------------|---|--|--|--|
| | Potential Emissions (Mass Basis) TPY | | CO ₂ e Potential Emissions TPY | | | |
| | | | | | | |
| CO ₂ | 1,044,629 | CO ₂ | 1,044,629 | | | |
| CH ₄ | 19.34 | CH ₄ | 406 | | | |
| N ₂ O | 1.93 | N ₂ O | 599 | | | |
| SF ₆ | 0.00018 | SF ₆ | 4.3 | | | |
| Total Potential Emissions | | | | | | |
| (Mass Basis) | 1,044,651 | Total CO ₂ e | 1,045,635 | | | |
| Total G | HG Potential Emission | s – Phase 2 of Co | onstruction (FD3) | | | |
| | Potential Emissions (Mass Basis) TPY | | CO ₂ e Potential Emissions TPY | | | |
| | | | | | | |
| CO ₂ | 1,062,627 | CO ₂ | 1,062,627 | | | |
| CH ₄ | 19.67 | CH ₄ | 413 | | | |
| N ₂ O | 1.97 | N ₂ O | 610 | | | |
| SF ₆ | 0.00018 | SF ₆ | 4.3 | | | |
| Total Potential Emissions | | | | | | |

VII. General Format of the BACT Analysis

The BACT analyses was conducted in accordance with the "*Top-Down*" *Best Available Control Technology Guidance Document* outlined in the 1990 draft U.S. EPA *New Source Review Workshop Manual*, which outlines the steps for conducting a top-down BACT analysis. Those steps are listed below.

- (1) Identify all potentially available control options;
- (2) Eliminate technically infeasible control options;
- (3) Rank remaining control technologies;
- (4) Evaluate the most effective controls and document the results; and
- (5) Select BACT.

Also in accordance with the top-down BACT guidance, the BACT analyses also takes into account the energy, environmental, and economic impacts of the control options during step 4. Emission reductions may be determined through the application of available control techniques, process design, and/or operational limitations. Such reductions are necessary to demonstrate that the emissions remaining after application of BACT will not cause adverse environmental effects to public health and the environment.

Each of the emission unit submitted in the PSD GHG application was evaluated separately in the top-down 5-step BACT analysis.

VIII. Applicable Emission Units Subject to BACT

The following devices are subject to this GHG PSD permit:

- Natural Gas-Fired Combined-cycle Combustion Turbine Generator (CTG5) and Heat Recovery Steam Generator (HRSG5)
- Fugitive Natural Gas emissions from piping components (NG-FUG)
- SF₆ Insulated Electrical Equipment (SF6-FUG)

IX. GHG BACT for the Natural-Gas Fired Combined-Cycle Combustion Turbine Generator (CTG5) and Heat Recovery System Generator (HRG5)

The new combined-cycle combustion turbine generator (CTG) is proposed to be as efficient, but with improved environmental controls compared to the other four existing CTG at the site. If approved, initially, a Siemens 501 FD2-series combined-cycle combustion generator with a electrical generating capacity of approximately 168 MW will be constructed and will be upgraded to a FD3-series with a electrical generating capacity of 180 MW within an 18-month period under terms of conditions of the permit. The FD3 upgrade includes improvements to the turbine blades and vanes and improved compressor seals to allow the turbine to regain generation capacity that is lost during the summer months due to hot ambient conditions. The FD3-series combustion turbine will generate more CO_2 emissions than the FD2-series; however the efficiency, in terms of heat rate (in Btu/kWh), is the same for both on a combined cycle basis. The CTG/HRSG unit will be fired exclusively with pipeline-quality natural gas with a fuel sulfur content of up to 5 grains of sulfur per 100 dry standard cubic feet (gr S/100 dscf). For purposes of BACT, CTG5 and HRSG5 are treated as one emission unit.

EPA has reviewed Calpine's BACT analysis for the two-phase construction of a natural gas-fired combined-cycle combustion turbine generator and finds it sufficient in setting forth this proposed permit, as summarized below.

Step One: Identify All Potentially Available Control Technologies

As part of the PSD review, Calpine provides in the GHG permit application a 5-step top-down BACT analysis for the new combustion turbine emission unit. In this analysis, the following technologies are identified in the BACT analysis:

- (A) the use of carbon capture and storage (CCS) including CO₂ capture/compression, CO₂ transport and CO₂ storage;
- (B) Inherently lower-emitting processes, practices, and designs which are further subdivided into:
 - (1) Combustion turbine energy efficiency processes, practices and designs;
 - (2) Heat recovery steam generator energy efficiency process, practices and designs; and
 - (3) Plant-wide energy efficiency processes, practices, and designs;
- (A) Carbon Capture and Storage

For purposes of the BACT analysis, CCS is classified as an add-on pollution control technology for "facilities emitting CO₂ in large concentrations, including fossil fuel-fired power plants, and for industrial facilities with high-purity CO₂ streams (e.g., hydrogen production, ammonia production, natural gas processing, ethanol production, ethylene oxide production, cement production, and iron and steel manufacturing)."² CCS involves the separation and capture of CO₂ from the combustion process flue gas, the pressurizing of the captured CO₂ and then the transportation of the compressed CO₂ by pipeline or other means of transportation, if necessary, where it is injected into a long-term geological location.

²U.S. Environmental Protection Agency, Office of Air Quality Planning and Standards, *PSD and Title V Permitting Guidance for Greenhouse Gases*, March 2011, <<u>http://www.epa.gov/nsr/ghgdocs/ghgpermittingguidance.pdf</u>> (March 2011)

Several technologies are in various stages of development and are being considered for CO_2 separation and capture.

| CCS Component | CCS Technology | | |
|---|--|--|--|
| | Post-combustion | | |
| | Pre-combustion | | |
| Capture | Oxy-fuel combustion | | |
| | Industrial separation (natural gas processing, ammonia production) | | |
| Trongetetion | Pipeline | | |
| Iransportation | Shipping | | |
| | Enhanced Oil Recovery (EOR) | | |
| Geological Storage | Gas or oil fields | | |
| Geological Stolage | Saline formations | | |
| | Enhanced Coal Bed Methane Recovery (ECBM) | | |
| Ocean Storage | Direct injection (dissolution type) | | |
| Ocean Storage | Direct injection (lake type) | | |
| Mineral carbonation | Natural silicate minerals | | |
| | Waste minerals | | |
| CO ₂ Utilization/Application | Industrial Uses of CO ₂ (e.g. carbonated products) | | |

As it stands currently, CCS technology and its components can be summarized in the table³ below adopted from IPCC's *Carbon Dioxide Capture and Storage* report:

For large, point sources, there are three types of capture configurations – pre-combustion capture, post-combustion capture, and oxy-combustion capture:

- 1) Pre-combustion capture implies as named, the capture of CO_2 prior to combustion. It is a technological option available to integrated coal gasification combined-cycle (IGCC) plants. In these plants, coal is gasified to form synthesis gas (syngas with key components of carbon monoxide and hydrogen). Carbon monoxide (CO) is reacted with steam to form CO_2 which is then removed and the hydrogen is then diluted with nitrogen and fed into the gas turbine combined-cycle.
- 2) Post-combustion capture involves extracting CO₂ in a purified form from the flue gas following combustion of the fuel. Primarily for coal-fired power plants and electric generating units (EGU), other industries can benefit. Currently, all commercial post-combustion capture is via chemical absorption process using monoethanolamine (MEA)-based solvents.⁴

³ Intergovernmental Panel on Climate Change (IPCC) Special Report, Bert Metz, Ogunlade Davidson, Heleen de Coninck, Manuela Loos and Leo Meyer (Eds.), *Carbon Dioxide Capture and Storage* (New York: Cambridge University Press, 2005), Table SPM.2, 8. <<u>http://www.ipcc.ch/pdf/special-reports/srccs/srccs_wholereport.pdf</u>>

⁴ Wes Hermann et al. An Assessment of Carbon Capture Technology and Research Opportunities - GCEP Energy Assessment Analysis, Spring 2005. <<u>http://gcep.stanford.edu/pdfs/assessments/carbon_capture_assessment.pdf</u>>

3) Oxy-combustion technology is primarily applied to coal-burning power plants where the capture of CO₂ is obtained from a pulverized coal oxy-fuel combustion in which fossil fuels are burned in a mixture of recirculated flue gas and oxygen rather than air. The remainder of the flue gas, that is not recirculated, is rich in carbon dioxide and water vapor, which is treated by condensation of the water vapor to capture the CO₂.⁵ When combusting coal with air (which is done in nearly all existing coal-burning power plants), nitrogen is formed as byproduct of the combustion and is present in high concentrations in the flue gas. Post-combustion capture of CO₂ is essentially the separation of nitrogen and carbon dioxide, which can be done but at a high cost. However if there were no nitrogen present as in the case of oxy-combustion, then CO₂ capture from flue gas would be greatly simplified⁶. It is implied that an optimized oxy-combustion power plant will have ultra-low CO₂ emissions as a result.

Once CO_2 is captured from the flue gas, CO_2 is compressed to 100 atmospheres (atm) or higher for ease of transport (usually by pipeline) into a storage area, in most cases, a geological storage area. It is also possible that CO_2 can be stored and shipped via all different modes of transportation via land, air and sea.

Geological storage of CO_2 involves the injection of compressed CO_2 into deep geologic formations (injection zones) overlain by competent sealing formations and geologic traps that will prevent the CO_2 from escaping, there are five types of geologic formations that are considered: clastic formations; carbonate formations; deep, unmineable coal seams; organic-rich shales; and basalt interflow zones. There is a large body of ongoing research and field studies focused on developing better understanding of the science and technologies for CO_2 storage.⁷

(B) Inherently lower-emitting processes, practices, and designs

Methods techniques and systems to increase energy efficiency is the key GHG reducing direction that falls under "lower polluting processes/practices." Use of inherently loweremitting technologies, including energy efficiency measures, represents an opportunity for GHG reductions in these types of BACT reviews. In some cases, a more energy efficient process or project design may be used effectively alone; where in other cases, energy efficient measure may be used effectively in tandem with end-of-stack controls to achieve additional control criteria pollutants. Applying the most energy efficient technologies at a source should in most cases translate into fewer overall emissions of all air pollutants per unit of energy produced. Selecting technologies, measures and options that are energy efficient translates not only in the reduction of emissions of the particular regulated NSR air pollutant undergoing BACT review, but it also may achieve collateral reductions of emissions of other pollutants, as well as GHGs.

<http://www.netl.doe.gov/technologies/carbon_seq/refshelf/2011_Sequestration_Program_Plan.pdf>

⁵ U.S. Department of Energy, Office of Fossil Energy, National Energy Technology Laboratory, "Oxy-Fuel Combustion", August 2008. < <u>http://www.netl.doe.gov/publications/factsheets/rd/R&D127.pdf</u>>

⁶ Herzog et al., page 4-5

⁷ U.S. Department of Energy, Office of Fossil Energy, National Energy Technology Laboratory *Carbon Sequestration Program: Technology Program Plan*, , February 2011

Inherently lowering emitting processes, practices, and designs is divided into two basic categories. The first category of energy efficient improvement options includes improvement options or processes that maximize the energy efficiency of the individual emissions unit. The second category of energy efficiency improvements includes options that could reduce emissions is more appropriate for new Greenfield facilities that includes equipment or processes that have the effect of lowering emissions by improving the utilization of thermal energy and electricity that is generated and used on the site.

(1) In the case of combustion turbine energy efficiency processes, practices and designs, one of the current efficient ways of generating electricity from a natural gas fuel source is through a combined-cycle design. For fossil fuel technologies, efficiency ranges from 30 to 50 percent higher heating value (HHV). A typical coal-fired Rankine cycle power plant has a base load efficiency of approximately 30% HHV while a modern F-Class natural gas fired combined-cycle turbine generator operating under optimal conditions has a baseload efficiency of approximately 50% HHV.

The combined-cycle unit operates based on a combination of two thermodynamic cycles: the Brayton and Rankine cycles. The combustion turbine operates on the Brayton cycle while the HRSG and steam turbine operate on the Rankine cycle. The combination of both of these cycles contributes to the higher efficiency of the combined-cycle power plants.

While there are number of modifications to a combustion turbine generator that exist, Calpine has identified the following additional processes, practices and designs that are applicable for the combined combustion turbine generator:

- (a) *Periodic Burner Tuning*: The modern F-Class combustion turbines have a regularly scheduled maintenance program for optimal efficiency of the turbine. Three basic maintenance levels exist: combustion inspections, hot gas path inspections, and major overhauls with combustion inspections being the most common. As a part of the maintenance activity, combustors are tuned to restore the highly efficient low-emission operation.
- (b) Reduction in Heat Loss: Use of insulation blankets help minimize heat loss at cooler temperatures, as well as protect personnel and nearby auxiliary equipment, insulation blankets will be deployed around the combustion turbine casing. Uses of the blankets immediately minimize any heat loss from the combustion turbine shell and increase the overall efficiency of the machine.
- (c) *Instrumentation and Controls*: Operation of the combustion turbine is all under automatic control via the distributed control system (DCS). DCS oversees all aspects of the operation including fuel feed and burner operations to achieve efficient low-NOx combustion. The control system monitors the operational parameters of the unit and modulates the fuel flow and turbine

operations to achieve optimal high-efficiency low-emission performance for full-load and part-load conditions.

Calpine proposed the use of a new combined-cycle combustion turbine, which is more energy efficient compared with the emissions from a simple-cycle gas turbine in table below.

| GHG Control Technologies | Emission Rate (lb CO ₂ /MWh) |
|-----------------------------|--|
| New combined-cycle gas CTG | 774 |
| Existing combined-cycle CTG | 824-996 |
| Simple cycle CT | ~1,319 |

Calpine has elected to construct the Siemens 501F CTG/HRSG with a CTG rated at 180 MW nominal and a duct burner-fired heat recovery steam generator (HRSG). The maximum design rated capacity of the duct burners will be 725 million British thermal units per hour (MMBtu/hr). The CTG will be fired exclusively with pipelinequality natural gas. The Siemens 501F turbine was chosen for DPEC because it has the appropriate size needed for this facility, DPEC is already equipped with four (4) operating Siemens 501F turbines, and several Siemens 501F turbines are ready for use in Calpine's fleet. In comparison with other turbines, EPA has identified the several high energy efficient models commercially available around the 180 MW range. For a CTG, efficiency can be determined by the heat rate, which can be expressed as Btu of the fuel combusted divided by kWh of electricity produced (Btu/kWh). The lower the overall numbers, the less heat needed to produce a unit of electricity. Using data provided by the manufacturer for CTG under ISO test conditions, EPA identified the following models:

| Manufacturer | Model | Net Plant Output (kW) ⁸ | LHV ⁹ ISO Heat Rate (Btu/kWh) | %Net ISO Plant Efficiency (ISO) |
|--------------|-----------------------------|--|---|--|
| Rolls-Royce | 2 x Trent 60 DLE | 149 | 7,129 | 45.5 |
| Rolls-Royce | 2 x Trent 60 WLE ISI | 153 | 7,281 | 44.5 |
| Mitsubishi | MPCP1 (M501) | 167 | 7,000 | 46.3 |
| Siemens | SCC6-2000F 1x1 (FD2/FD3) | 171 | 7,007 | 46.2 |
| Hitachi | 206FA | 215 | 6,800 | 47.7 |

As listed in the table above, the Siemens 501F-series turbine has a calculated efficiency of 46.2% which is as efficient as or more efficient than the other listed natural gas-fired combined-cycle combustion turbines (efficiencies tend to range from 40% to 60% with larger kW-producing turbines typically having the highest

⁸ Net plant output is calculated using specific design (i.e., ISO) test criteria

⁹ Lower heat rate is determined by subtracting the heat of vaporization of water from the higher heating value.

efficiencies)¹⁰. Since age and ambient and operating conditions will affect efficiency, the heat rate numbers presented above are used to compare efficiency between turbine models and do not translate directly into permit limitations.

- (2) For the heat recovery steam generator, energy efficient processes, practices and design include:
 - a. *Heat Exchanger Design*: Heat exchanger design is optimized to provide maximum heat exchange transfer from the waste heat of the combustion turbine exhaust using multiple thin-walled tubes filled with fluid and at the same time minimizing the overall size of the HRSG.
 - b. *Insulation*: Similar to the combustion turbine practice, use of insulation to minimize heat loss to the surroundings is used to help improve the overall efficiency of the HRSG. Insulation is applied to the HRSG panels that make up the shell of the unit, to the high-temperature steam and water lines, and typically to the bottom portion of the stack.
 - c. *Minimizing Fouling of Heat Exchange Surfaces*: Since HRSGs are made up of numerous tubes within the shell of the unit are used to generate steam from the combustion turbine, the tubes and their extended surfaces must be kept as clean as possible to maximize heat transfer. Fouling occurs from the constituents within the exhaust gas stream. To minimize fouling, filtration of the inlet air to the combustion turbine is performed. Additionally, cleaning of the tubes is performed during periodic outages.
 - d. *Minimized Vented Steam and Repair of Steam Leaks*: Routine maintenance checks will include inspection of valves and pipes for steam leaks and reducting steam escaping which would result in large losses in efficiency in power generation.
- (3) Plant-wide energy efficient processes include fuel gas preheating, drain operation, multiple combustion/HRSG trains and boiler feed pump fluid drivers.
 - a. *Fuel gas preheating*: The overall efficiency is increased with increased fuel inlet temperatures. For the F-class combustion turbine, the fuel gas is heated with high temperature water from the HRSG.
 - b. *Drain operation*: Drains are required to allow for draining the equipment for maintenance (maintenance drains) and allow condensate to be removed from the steam piping and drains for operation (operation drains) and prevent loss of energy from the cycle.

¹⁰ United States Environmental Protection Agency, Combined Heat and Power Partnership, *Technology Characterization: Steam Turbines*, December 2008, p.8-9 http://www.epa.gov/chp/documents/catalog chptech steam turbines.pdf>

- c. *Multiple combustion turbine/HRSG trains*: Multiple combustion turbine/HRSG trains help with part-load operation and allow for higher overall plant part-load efficiency by shutting down trains operating at less efficiency part-load conditions and ramping up the remaining train(s) to high-efficiency full-load operations.
- d. *Boiler feed pump fluid drivers*: Boiler feed pumps are used as a means to impart high pressure on the working fluid. The pumps require considerable power and to minimize the power consumption at part-loads, fluid drives are being used to minimize power consumption at part-load at part-load, improving the facility's overall efficiency.

Step Two: Eliminate Technically Infeasible Control Options

Based on the information reviewed for this BACT analysis, while there are some portions of CCS that are technically infeasible, EPA has determined that overall Carbon Capture and Storage (CCS) technology is technologically feasible at this source. Listed below is a summary of those CCS components that are technically feasible and those CCS components that are not technically feasible for DPEC.

| CCS Component | CCS Technology | Technical Feasibility |
|-----------------------------|--------------------------------|------------------------------|
| | Post-combustion | Y |
| | Pre-combustion | Ν |
| Capture | Oxy-fuel combustion | Ν |
| | Industrial separation (natural | Ν |
| | gas processing, ammonia | |
| | production) | |
| Transportation | Pipeline | Y |
| Transportation | Shipping | Y |
| | Enhanced Oil Recovery | Y |
| | (EOR) | |
| Caslagias Stars | Gas or oil fields | N* |
| Geological Storage | Saline formations | N* |
| | Enhanced Coal Bed Methane | N* |
| | Recovery (ECBM) | |
| | Direct injection (dissolution | N* |
| Ocean Storage | type) | |
| | Direct injection (lake type) | N* |
| Minaral authonation | Natural silicate minerals | N* |
| | Waste minerals | N* |
| Large scale CO ₂ | | N* |
| Utilization/Application | | |

Step Two Summary for CCS for Calpine DPEC

* Both geologic storage and large scale CO₂ utilization technologies are in the research and development phase in the United States and currently commercially unavailable.¹¹

Step Three: Rank Remaining Control Technologies by Control Effectiveness

The remaining technically feasible options for controlling CO_2 emissions from the combustion turbine operation are as follows (listed in descending order of the most technically feasible):

1) Carbon Capture and Storage (CCS)

CCS could enable large (> 85%) reduction of CO_2 emissions from fossil fuel combustion in power generation, industrial processes and synthetic fuel production¹² and is the best known method of reducing CO_2 e emissions into the atmosphere.

- 2) Inherently lower-emitting processes, practices, and designs which are further subdivided into:
 - a. Combustion turbine energy efficiency processes, practices and designs;
 - b. Heat recovery steam generator energy efficiency process, practices and designs; and
 - c. Plant-wide energy efficiency processes, practices, and designs;

To date, other similar facilities with a GHG BACT limit are summarized in the table below:

| Company / Location | Process Description | Control Device | BACT Emission Limit / Requirements | Year Issued | Reference |
|--|---|---|--|----------------|---------------------|
| Lower Colorado River Authority (LCRA), Thomas C. Ferguson Plant Horseshoe Bay, TX | combined- cycle combustion turbine and heat recovery steam generator | Energy Efficiency/ Good Design & Combustion Practices | Combustion turbine annual net heat rate limited to 7,720 Btu/kWh (HHV) GHG BACT limit of 0.459 tons CO ₂ /MWh (net) 365-day average, rolling daily for the combustion turbine unit Fugitive methane emissions and SF6 emissions are monitored and maintained using | 2011 | PSD-TX-1244- GHG |

¹¹ U.S. Department of Energy, Carbon Sequestration Program: Technology Program Plan, page 20-23

¹² IEA Energy Technology Essentials, "CO2 Capture and Storage," December 2006 <<u>http://www.iea.org/techno/essentials1.pdf</u>> (December 2006)

| | | | best practice standards. | | |
|--|---|---|---|------|--------------------------|
| | | | Combustion turbine annual net heat rate limited to 7,319 Btu/kWh (HHV) | | |
| Palmdale Hybrid Power Plant Project | combined- cycle combustion turbine and heat recovery steam generator, plus a 50 MW solar array* | Energy Efficiency/ Good Design & Combustion Practices, and use of the solar array | GHG BACT limit of 0.387 tons CO ₂ /MWh (net) 365-day average, rolling daily for the combustion turbine unit Auxiliary boiler and heater heat input limit of 110 | 2011 | SE 09-01 |
| Palmdale, CA | | | MMBtu/hr and 500 hours operation on 365-day rolling total SF6 Circuit Breakers BACT limit of 9.56 tpy CO ₂ e | | |
| Calpine Russell City Energy | 600 MW combined- cycle power plant | Energy Efficiency/ Good Design & Combustion Practices | Combustion turbine Operational limit of 2,038.6 MMBtu/kWh Fire Pump Diesel Engine GHG BACT limit of 7.6 tpy CO ₂ e | 2011 | 15487 |
| Hayward, CA | | | SF6 Circuit Breaker annual limit of 39.3 tpy CO ₂ e | | |
| PacifiCorp Energy Lakeside, UT | combined- cycle turbine | Energy Efficiency/ Good Design & Combustion Practices | Combustion turbine BACT limit of 950 lb CO ₂ e/MWh | 2011 | DAQE- IN0130310010-11 |

| Kennecott Utah Copper- Repowering | 275 MW combined | Energy Efficiency/ Good Design & | Combustion turbine BACT limit of 1,162,552 tpy CO ₂ e | 2011 | DAQE- IN105720026-11 |
|---|--------------------|--|--|------|-------------------------|
| South Jordan, UT | combustion | Combustion Practices | rolling 12-month period | | 11103720020-11 |

*Palmdale is unique as the applicant proposed to include, and thus the BACT analysis and eventual limit included, use of a solar component that includes up to 50 MW of potential solar thermal power generation, which represents an inherently lower-emitting technology for that proposed facility.

Step Four: Evaluate Top Control Alternatives - Economic, Energy, and Environmental Impacts

EPA Region 6 reviewed Calpine's CCS cost estimate and believes the overall cost estimation is financially prohibitive due to the overall cost of GHG control strategies. CCS costs include installation and operation of carbon capture controls and construction of a new pipeline to transport the CO_2 approximately 15 miles¹³ (24 kilometers) to the closest site with recognized potential for geological storage of CO_2 , which is the enhanced oil recovery (EOR) operations located at the Hastings oil field, southwest of Houston, Texas.

The bulk of the cost for CCS is attributable to the post-combustion capture and compression system, and the additional operating cost estimates are listed in detail in Table 9 of the Appendix. As it stands, the estimated cost to construct and install a CCS system to the turbine is approximately \$113 million¹⁴, around 50% of the cost of the of a typical gas-fired combined cycle turbine without CCS. Additionally Calpine, using EPA guidance documents, has provided an estimation that the overall average operating costs for the entire CCS system could add approximately \$80 million annually (See Appendix, Table 9). While Calpine has provided information suggesting that annual operating costs for CCS could increase overall costs by as little as 20%¹⁵, EPA notes that Calpine arrives at this figure by including the lowest estimated cost for each and every step of the CCS process. Calpine's analysis also included an estimate of the annual operating costs for CCS if the highest costs were needed for each and every step of the CCS process, and estimated the annual operating cost increase to be approximately 58%. Since it is unlikely that either the lowest costs or the highest costs could be achieved for each and every step of the process, EPA has instead relied upon the average costs and determined that the average combined costs of installation and operation of a CCS system still makes CCS economically infeasible for this project.

In addition, EPA notes that implementing CCS would result in energy penalty simply because the CCS process will use energy produced by the plant. This may, in turn, potentially increases the natural gas fuel use of the plant, with resulting increases in emissions of non-GHG pollutants, to overcome these efficiency losses, or would result in less energy being produced for use on the

¹³University of Texas at Austin, Bureau of Economic Geology, Gulf Coast Carbon Center, <<u>http://www.beg.utexas.edu/gccc/miocene/></u>

¹⁴ Natural Gas Combined-Cycle Plants With and Without Carbon Capture & Sequestration, DOE <<u>http://www.netl.doe.gov/energy-analyses/pubs/deskreference/B_NGCC_051507.pdf</u>>

¹⁵ The minimum cost factor found for implementation/operation of the CO2 capture systems within the cost-related information reviewed for CCS technology was found from the "Properties" section of the Greenhouse Gas Mitigation Strategies Database (last accessed April 2010) (<<u>http://ghg.ie.unc.edu:8080/GHGMDB/#data</u>>), which was obtained through the EPA GHG web site (<<u>http://www.epa.gov/nsr/ghgpermitting.html</u>>).

grid. The *Report of the Interagency Task Force on Carbon Capture and Storage* has estimated that an energy penalty of as much as 15% would result from inclusion of CO_2 capture (Reference 4, page A-14) and an overall loss of energy efficiency of approximately 7%¹⁶. It was concluded in the same report¹⁷ that while CCS is technically feasible at this time, the costs for the capture and compression of CO_2 remains the biggest barrier to widespread commercialization of CCS.

Therefore, CCS has been eliminated as BACT for this particular project based upon research and analysis showing that there is a significant negative economic impact due to the additional projected capital costs of implementing and operating CCS as the control technology at the proposed combustion turbine. In addition, the potential negative environmental and energy impacts of increased non-GHG pollutant emissions, the overall loss in energy efficiency, and/or decreased energy produced for use on the grid also provide a basis for excluding CCS as BACT for this facility.

Step Five: Select BACT

Calpine intends to initially construct and install an FD2-series combustion turbine with plans to modify it within an eighteen (18) month period to the FD3-series combustion turbine. The proposed BACT limits are in terms of efficiency measured in units of Btu of fuel energy consumed in order to generate a kilowatt of electric energy (Btu/kWh). Since CCS has been eliminated as BACT for CTG5, then BACT for the new combined-cycle combustion turbine is the high efficiency processes, practices and designs which are made enforceable by output-based and annual BACT limits. The average heat rate in terms of Btu/kWh (HHV) will be the same for the FD2 configuration as the FD3 configuration when in continuous operation, since the FD2-series and FD3-series combustion turbines have the same efficiency. However, the FD3 configuration provides greater output at high ambient temperatures during base load periods. Therefore, for the FD3, the potential annual electric generation (MWh) and fuel usage, as well as corresponding GHG emissions, will be higher on an annual basis, maximum CO₂e potential emissions will increase by only two percent (2%) from 1,045,635 tons for the FD2-series to 1,063,650 tons of CO₂e for the FD3-series combustion turbine (see Appendix Calculations, Tables 1 and 2).

a) Degradation Consideration for combined-cycle combustion turbine generator efficiency

To establish an enforceable BACT condition that can be achieved over the life of the facility, it is important that the permit limit accounts for the anticipated degradation of the equipment over time between regular maintenance cycles. A 48,000-operating-hour degradation curve provided by the manufacturer, Siemens, reflects anticipated recoverable and non-recoverable degradation in heat rate between major maintenance overhauls of approximately five percent (5%). The results of the degradation curves differentiate between "recoverable" and "non-recoverable" degradation. Components of the turbine and combustion system subject to high thermal and mechanical stress are designed for periodic refurbishment or replacement. The turbine components most affected by the combustion process include combustion liners, fuel nozzle assemblies, transition pieces, turbine nozzles, stationary shrouds, and turbine buckets. These components are often referred to as "hot gas path" components. "Recoverable" degradation is

¹⁶_IPCC Special Report of the Interagency Task Force on *Carbon Capture and Storage* (August 2010)

¹⁷ <u>Ibid.</u>, p. 33-51

mostly attributable to turbine blade fouling due to impurities in intake air and fuel. This type of degradation can be mitigated through inspection programs, on-line turbine water washes, instrument calibration, and other maintenance activities. "Non-recoverable" degradation is mainly attributed to blade surface roughness, erosion and blade tip rubs and cannot be restored upon a maintenance overhaul.

The manufacturer's degradation results only account for the anticipated degradation within the first 48,000 hours of the gas turbine's useful life; they do not reflect any potential increase in this rate of degradation which might be expected after the first major overhaul and/or as the equipment approaches the end of its useful life. Further, the projected 5% degradation rate represents the average, and not the maximum or guaranteed rate of degradation for the turbines. Therefore, Calpine DPEC proposes that, for the purposes of deriving an enforceable BACT limit on the proposed facility's heat rate, gas turbine degradation may be reasonably be estimated at six percent (6%) of the facility's heat rate.

Finally, in addition to the heat rate degradation from normal wear and tear on the turbines, DPEC also suggested a compliance margin based on potential degradation in other elements of the combined-cycle plant that would cause the overall plant heat rate to rise (i.e., cause efficiency to fall). DPEC proposed a 3% degradation rate to account for these factors. The other elements of the combined-cycle plant include the following:

- Degradation in Turbine Exhaust Flow: The gas turbine manufacturer's degradation curves predict potential recoverable and non-recoverable degradation in gas turbine exhaust flow over the 48,000-maintenance cycle. This degradation in exhaust flow could result in a direct reduction in the ability of the steam turbine to generate power, which could further degrade the plant's overall efficiency. While degradation in the exhaust flow is expected to be partially offset by degradation in exhaust temperature (which raises over the maintenance cycle), this offset is not expected to make up for anticipated degradation in the reduction in steam turbine power as a result of reduced exhaust flow.
- Degradation in Performance of Steam Turbine and Other Equipment: Degradation in the performance of the heat recovery steam generator, steam turbine, heat transfer, cooling tower, and ancillary equipment such as pumps and motors is also expected to occur over the course of a major maintenance cycle.

b) BACT Limit:

By establishing the energy efficiency for the combined-cycle turbine as BACT, permit conditions must be developed to ensure that Calpine DPEC installs and operate an energy efficient turbine in an energy efficient manner.

EPA has developed an emission limit in tons of GHG per MWh produced that must be met during the initial and periodic stack testing. Since ambient conditions can affect the efficiency during a stack test and cannot be predicted at this time, the emission limit is being set using International Organization for Standardization (ISO) conditions. ISO 3977-2 is corrected for the following conditions:

- Ambient Dry Bulb Temperature: 59°F
- Ambient Relative Humidity: 60%
- Barometric Pressure: 14.69 psia
- Fuel Lower Heating Value: 20,647 Btu/lb
- Fuel HHV/LHV Ratio: 1.1086

1) BACT Limit for the Combined-Cycle Combustion Turbine Generator

To ensure Calpine DPEC operates its facility to minimize greenhouse gases, EPA proposes to establish an CO₂ emission limit/MWh. To determine an appropriate heat rate limit for continuous operations, the baseline annual average heat rate (HHV) of 6,852 Btu/kWh is used with the 3.3% design margin taken into account followed by a six percent (6%) performance margin reflecting efficiency losses due to equipment degradation prior to maintenance overhauls, and then a three percent (3%) degradation margin reflecting the variability in operation in auxiliary plant equipment due to use over time, resulting in the annual average heat rate (HHV) of 7,728 Btu/kWh (See Appendix, Table 4). Additionally, to determine the heat input limit for this facility, the heat rate is calculated assuming that all steam generated in the heat recovery steam generator is used to generate electricity in the existing on-site steam turbine even though there are periods when some or all of the generated steam is sold to a neighboring facility rather than sent to the on-site steam turbine.

The proposed GHG PSD permit, if approved, requires an output-based BACT limit of **0.460 tons CO₂/MWh (net) for both the FD2 and FD3 engines** on a 30-day rolling average and an annual GHG BACT limit of **1,045,635 tons CO₂e per year for the FD2 series engine** and **1,063,650 tons of CO₂e per year for the FD3 series engine** on a 365-day rolling average. This is with the understanding that the FD2 series will be upgraded to the FD3 series within a statutory timeframe of 18 months under the conditions of this permit. In establishing an enforceable BACT limit over the lifetime of the turbine, Calpine accounted for the anticipated degradation of the equipment over time between regular maintenance cycles, as discussed in this section. (See Appendix, Table 4 for calculations)

c) Operating Conditions

Listed below are the operating conditions and work practice for the heat recovery steam generator and the plant-wide operations that ensure that CTG5 is operating at the highest possible efficiency.

1) HRSG5 Unit Operating Conditions

The Heat Recovery Steam Generator (HRSG5) energy efficiency processes, practices and designs considered include:

- i. Energy efficient heat exchanger design. In this design, each pressure level incorporates an economizer section(s), evaporator section, and superheater section(s);
- ii. Addition of insulation to the HRSG5 panels, high-temperature steam and water lines and to the bottom portion of the stack;

- iii. Filtration of the inlet air to the combustion turbine and periodic cleaning of the tubes (performed at least every 18 months) is performed to minimize fouling; and
- iv. Minimization of steam vents and repairs of steam leaks.

2) Plant Wide Operating Conditions

Within the combined-cycle power plant, several plant-wide, overall energy efficiency processes, practices and designs are included as BACT requirements because the additional operating conditions/practices help maintain the efficiency of the turbine. The requirements include:

- i. Fuel gas preheating. For the F-class combustion turbine based combined-cycle, the fuel gas is pre-heated to temperature of approximately 300°F with high temperature water from the HRSG;
- ii. Drain operation. Operation drains are controlled to minimize the loss of energy from the cycle but closing the drains as soon as the appropriate steam conditions are achieved;
- Multiple combustion turbine/HRSG trains. Multiple combustion turbine/HRSH trains help with part-load operation. A higher overall plant part-load efficiency is achieved by shutting down trains operating at less efficient part-load conditions and ramping up the remaining train(s) to high-efficiency full-load operation;
- iv. Boiler feed pump fluid drives. To minimize the power consumption at part-loads, the use of fluid drives or variable-frequency drives are used to minimize the power consumption at part-load conditions;

d) BACT Compliance:

For both the FD2 and FD3-series, the combined-cycle combustion turbine unit is designed with a number of features to improve the overall efficiency. The additional combustion turbine design features include:

1. Inlet evaporative cooling to utilize water to cool the inlet air and thereby increasing the turbine's efficiency;

2. Periodic burner tuning as part of a regularly scheduled maintenance program to help ensure a more reliable operation of the unit and maintain optimal efficiency;

3. Insulation blankets are utilized to minimize the heat loss through the combustion turbine shell and help improve the overall efficiency of the machine; and

4. Hydrogen will be used to cool the generators resulting in a lower electrical loss and higher unit efficiency.

Calpine DPEC's proposed method to demonstrate compliance with the CO₂ emission limit of 0.421 tons of CO2 per MWh (net)¹⁸ established as BACT by using fuel flow meters to monitor the quantity of fuel combusted in the electric generating unit and performing periodic scheduled fuel sampling pursuant to 40 CFR 75.10(3)(ii) and the procedures listed in 40 CFR 75, Appendix G. Results of the fuel sampling will be used to calculate a site-specific Fc factor, and that factor will be used in the equation below to calculated CO₂ mass emissions. In conjunction with the flow meter methodology, Calpine will determine the CO₂ hourly emission rate and CO₂ mass emissions using an O₂ monitor pursuant to 40 CFR Subpart 75 and appendix F of 40 CFR Subpart 75. The proposed permit also includes an alternative compliance demonstration method in which Calpine DPEC may install, calibrate, and operate a CO₂ CEMS and volumetric stack gas flow monitoring system with an automated data acquisition and handling system for measuring and recording CO₂ emissions. To demonstrate compliance with the CO₂ BACT limit of 0.460 tons of CO₂ per MWh (net) using CO₂ CEMS, the measured hourly CO₂ emissions are divided by the net hourly energy output and averaged daily.

Currently, the four existing natural gas-fired turbines at Deer Park utilize fuel flow meters and monthly GCV (Gross Calorific Value) sampling in order to comply with the Acid Rain quality assurance and monitoring requirements of 40 CFR 75, Appendix D and G. The proposed natural gas-fired turbine identified as CTG5/HRSG5 will also comply with the fuel flow metering and GCV sampling requirements listed in Appendix D. Calpine DPEC proposes to determine a site-specific Fc factor using the ultimate analysis and GCV in equation F-7b of 40 CFR 75, Appendix F. The site-specific Fc factor will be re-determined annually in according to 40 CFR 75, Appendix F, §3.3.6.

The equation for estimating CO₂ emissions as specified in 40 CFR 75.10(3)(ii) is as follows:

 $W_{CO_2} = (Fc \times H \times Uf \times MW_{CO_2})/2000$

Where:

 $W_{CO2} = CO_2$ emitted from combustion, tons/hour

 MW_{CO2} = molecular weight of CO₂, 44.0 lbs/mole

Fc = Carbon-based Fc-Factor, 1040 scf/MMBtu for natural gas or site-specific Fc factor

H = hourly heat input in MMBtu, as calculated using the procedure in 40 CFR 75, Appendix F, $5 Uf = 1/385 \text{ scf } CO_2/lb$ -mole at 14.7 psia and $68^{\circ}F$

Calpine DPEC is subject to all applicable requirements for fuel flow monitoring and quality assurance pursuant to 40 CFR 75, Appendix D, which includes:

- Fuel flow meter- meets an accuracy of 2.0%, required to be tested once each calendar quarter pursuant to 40 CFR 75, Appendix D, §2.1.5 and §2.1.6(a))
- Gross Calorific Value (GCV)- determine the GCV of pipeline natural gas at least once per calendar month pursuant to 40 CFR 75, Appendix D, §2.3.4.1

Additionally, this approach is consistent with the CO_2 reporting requirements of 40 CFR 98, Subpart D- GHG Mandatory Reporting Rule for Electricity Generation. Furthermore, Calpine DPEC proposed CO_2 monitoring method is consistent with the recently proposed New Source

¹⁸ Output-based limits will be based on ton of CO_2 versus ton of CO_2 e because all emissions determined by monitoring methodology in accordance to 40 CFR Part 75 are done in lbs of CO_2 as opposed to lbs of CO_2 e.

Performance Standards, Subpart TTTT- Standards of Performance for Greenhouse Gas Emissions for Electric Utility Generating Units (40 CFR 60.5535(c)) which allows for electric generating units firing gaseous fuel to determine CO_2 mass emissions by monitoring fuel combusted in the affected electric generating unit and using a site specific Fc factor determined in accordance to 40 CFR 75, Appendix F.

The calculated hourly CO_2 concentration result for emission point, CTG5/HRSG5, is required to be compared to the measured hourly CO_2 concentration from the CO_2 emission monitor. If the mean difference between the calculated and measured CO_2 concentration result is greater than 10%, Calpine shall review the emission units and monitoring instrumentation operational performance. This comparison is generally similar to the Relative Accuracy Test Audit (RATA) trial run standards provided in 40 CFR Part 75(E)(2). From this review, any corrective measures taken are to be identified, recorded, including the reason for the CO_2 emissions difference and corrective measures completed within 48 hours of the corrective measures being taken. If Calpine DPEC chooses to install and operate the CO_2 CEMS equipped with a volumetric stack gas monitoring system, the CO_2 concentration calculation and mean difference comparison is no longer a requirement and the applicant shall rely on the data from the CO_2 CEMS for compliance purposes.

The emission limits associated with CH_4 and N_2O are calculated based on emission factors provided in 40 CFR Part 98, Table C-2 and the actual heat input (HHV). Comparatively, the emissions from CO_2 contribute the most (greater than 99%) to the overall emissions from the CTGs and; therefore, additional analysis is not required for CH_4 and N_2O . To calculate the CO_2e emissions, the draft permit requires calculation of the emissions based on the procedures and Global Warming Potentials (GWP) contained in the Greenhouse Gas Regulations, 40 CFR Part 98, Subpart A, Table A-1. Records of the calculations would be required to be kept to demonstrate compliance with the emission limits on a 365-day average, rolling daily.

An initial stack test demonstration will be required for CO_2 emissions from emission unit. An initial stack test demonstration for CH_4 and N_2O emissions are not required because the CH_4 and N_2O emission are approximately 0.09% of the total CO_2e emissions from the CTGs and are considered a *de minimis* level in comparison to the CO_2 emissions.

For startup and shutdown operating scenarios for the proposed CTG, BACT will be achieved by minimizing the duration of the start-up and shutdown events, consistent with market demands, and by engaging the pollution control equipment (e.g., the SCR system in combined-cycle) as soon as practicable, based on vendor recommendations and guarantees. During periods of startup and shutdown, the permittee must record the time, date, fuel heat input (HHV) in MMBtu/hr and the duration of each startup and shutdown event. All emissions during startup and shutdown are minimized by limiting the duration of operation. The estimated 70 tons/hour (See calculations in Table 5 of the Appendix) illustrate that startup and shutdown emissions are lower than "normal" emissions and are accounted for in the Annual Facility Emissions (Table 1 of Appendix). To demonstrate compliance with the startup and shutdown emissions, Calpine shall record the time, date, fuel heat input and duration of each startup and shutdown event. The duration of operation during startup and shutdown are defined as follows:

- 1. A startup of CTG5 is defined as the period that begins when there is measureable fuel flow to the CTG5 and ends when the CTG5 load reaches 60 percent. A startup for each CTG5 is limited to 480 minutes.
- 2. A shutdown of each CTG5 is defined as the period that begins when CTG5 load falls below 60 percent and ends when there is no longer measureable fuel flow to CTG5. A shutdown for CTG5 is limited to 180 minutes.

Under draft terms, records of all emissions calculations for startup and shutdown events shall be kept on-site for a period of 5-years. After review of the submitted materials, EPA agrees with and adopts Calpine's BACT analysis for the natural gas-fired combined-cycle combustion turbines.

X. GHG BACT for the Fugitive Emission Sources (NG-FUG)

Step One: Identify All Potentially Available Control Technologies

The control technology for process fugitive emissions of GHGs are:

- Leakless Technology
- Instrument Leak detection and repair (LDAR) programs
- Remote Sensing
- Auditory, Visual, and Olfactory (AVO) Monitoring

Step Two: Eliminate Technically Infeasible Control Options

- *Leakless Technology* Leakless technology valves may be incorporated in situations where highly toxic or otherwise hazardous materials are present. Likewise, some technologies, such as bellows valves, cannot be repaired without a unit shutdown. Because natural gas is not considered highly toxic nor a hazardous material, this gas does not warrant the risk of unit shutdown for repair, and therefore leakless valve technology for fuel lines is considered technically impracticable.
- Instrument LDAR Programs Is considered technically feasible.
- *Remote Sensing* Is considered technically feasible.
- AVO Monitoring Is considered technically feasible.

Step Three: Rank Remaining Control Technologies by Control Effectiveness

Instrument LDAR programs and the alternative work practice of remote sensing using an infrared camera have been determined by EPA to be equivalent methods of piping fugitive controls.¹⁹ The most stringent LDAR program, 28LAER, provides for 97% control credit for valves, flanges, and connectors.

As-observed AVO methods are generally somewhat less effective than instrument LDAR and remote sensing, since they are not conducted at specific intervals. However, since pipeline natural gas is odorized with very small quantities of mercaptan, as-observed olfactory observation is a very effective method for identifying and correcting leaks in natural gas systems.

¹⁹ 73 FR 78199-78219, December 22, 2008.

Due to the pressure and other physical properties of plant fuel gas, as-observed audio and visual observations of potential fugitive leaks are likewise moderately effective.

Step Four: Evaluate Top Control Alternatives

Although instrument LDAR and/or remote sensing of piping fugitive emissions in natural gas lines may be somewhat more effective than as-observed AVO methods, these methods are not economically practicable for GHG control from components in fuel gas service. The incremental GHGs controlled by implementation of the 28LAER or a comparable remote sensing program is less than 60 tons CO_2e per year, or less than 0.0001% of the total project's proposed CO_2e emissions.

Step Five: Select BACT

EPA has reviewed and Calpine's Fugitive Emission Sources top-down BACT analysis. Based on the economic impracticability of instrument monitoring and remote sensing for fuel gas piping components, EPA proposes to incorporate as-observed AVO as BACT for the piping components in new combustion turbine generator and heat recovery steam generator and proposes an annual BACT emission limit of **60 tons per year CO₂e**. Calpine also identified and adopted the use of dry compressor seals, use of rod packing for reciprocating compressors, and the use of low-bleed gas-driven pneumatic controllers or air-driven pneumatic controllers as BACT for fugitives. EPA determines that the AVO program for fugitives for control of CH₄ emissions is BACT.

XI. GHG BACT for the SF6 Insulated Electrical Equipment (SF6-FUG)

<u>Step One: Identify All Potentially Available Control Technologies</u> Several control options can be used to help minimize GHG emissions for the SF6 circuit breakers which include:

- Use of dielectric oil or compressed air circuit breakers these types of circuit breakers do not contain any GHG pollutants and serve as a substitute for SF6 circuit breakers. Potential alternatives to SF6 circuit breakers are addressed in the National Institute of Standards and Technology (NTIS) Technical Note 1425, *Gases for Electrical Insulation and Arc Interruption: Possible Present and Future Alternatives to Pure SF6²⁰*
- Totally enclosed SF6 circuit breakers with leak detection system Modern SF6 circuit breakers, as opposed to the older SF6 circuit breakers, are designed as a totally enclosed-pressure system which reduces the potential for SF6 emissions. These systems are equipped with a density alarm that provides a warning when 10% of the SF6 (by weight) has escaped. This identifies potential leak problems before the bulk of the SF6 can escape

²⁰Christophorous, L.G., J.K. Olthoff, and D.S. Green, *Gases for Electrical Insulation and Arc Interruption: Possible Present and Future Alternatives to Pure SF6*, NIST Technical Note 1425, Nov. 1997, <<u>http://www.epa.gov/electricpower-sf6/documents/new report final.pdf</u>>

Step Two: Eliminate Technically Infeasible Control Options

At this time, sulfur hexafluoride (SF6)-containing circuit breakers are the only commercially available circuit breakers. While there are other potential dielectric, non-greenhouse gas substances such as oil and air that could be used, these types of circuit breakers are all in the research stage and thus are not technically feasible for use at the DPEC.²¹

Step Three: Rank Remaining Control Technologies by Control Effectiveness

The only remaining technically feasible options for insulating electrical equipment associated with the combustion turbine process are totally enclosed SF6 circuit breakers with a leak detection system.

Step Four: Evaluate Top Control Alternatives

There no other control alternatives available at this time as stated in Step 2, therefore SF6 circuit breakers will only be considered.

Step Five: Select BACT

Based on Calpine's top-down BACT analysis for fugitive emissions, Calpine concludes that using state-of-the-art enclosed-pressure SF₆ circuit breakers with leak detection is the appropriate BACT control technology option. The proposed GHG PSD permit, if approved, is comprised of a 72 pound SF₆ insulated circuit breaker. Calpine will monitor the SF₆ emissions annually in accordance with the requirements of the Mandatory Greenhouse Gas Reporting rules for Electrical Transmission and Distribution Equipment Use. The annual SF₆ emissions will be calculated according to the mass balance approach in Equation DD-1 of Subpart DD. EPA concurs with and adopts Calpine's best work practice standards for control of SF₆ emissions and the state-of-the-art enclosed-pressure SF₆ circuit breakers with leak detection for fugitive SF₆ emissions as BACT.

XII. Threatened and Endangered Species

Pursuant to Section 7(a)(2) of the Endangered Species Act (ESA) (16 U.S.C. 1536) and its implementing regulations at 50 CFR Part 402, EPA is required to insure that any action authorized, funded, or carried out by EPA is not likely to jeopardize the continued existence of any federally-listed endangered or threatened species or result in the destruction or adverse modification of such species' designated critical habitat.

To meet the requirements of Section 7, EPA is relying on a Biological Assessment (BA) prepared by the applicant and reviewed by EPA. Further, EPA designated Calpine as its non-federal representative for purposes of preparation of the BA and for conducting informal consultation.

A draft BA has identified twelve (12) species as federally endangered or threatened in Harris County by the U.S. Fish and Wildlife Service (USFWS), National Marine Fisheries Service (NMFS) and the Texas Parks and Wildlife Department (TPWD).

²¹ Christophorous, L.G. et al., pp. 28-29

EPA has determined that issuance of the proposed permit to Calpine for construction of the combustion turbine generator/heat recovery steam generator will have no effect on five (5) of these listed species, specifically the smalltooth sawfish (*Pristis pectinata*), the red-cockaded woodpecker (*Picoides borealis*), the whooping crane (*Grus americana*), the Louisiana black bear (*Ursus americanus luteolus*), and the red wolf (*Canis rufus*). These species are either thought to be extirpated from the county or Texas or are not present in the action area.

The remaining seven (7) species identified are species that may be present in the action area in certain circumstances. As a result of this potential occurrence and based on the information provided in the draft BA, the issuance of the permit may affect, but is not likely to adversely affect the following species. As a result, EPA will submit the final draft BA to the Southwest Region, Clear Lake, Texas Ecological Services Field Office of the USFWS for its concurrence that issuance of the permit may affect, but is not likely to adversely affect the following species:

- Houston toad (*Bufo houstonensis*).
- Texas prairie dawn-flower (Hymenoxys texana).

EPA will also submit the final draft BA to the NOAA Southeast Regional Office, Protected Resources Division of NMFS for its concurrence that issuance of the permit may affect, but is not likely to adversely affect the following species:

- leatherback sea turtle (*Dermochelys coriacea*)
- green sea turtle (*Chelonia mydas*)
- Kemp's ridley sea turtle (*Lepidochelys kempii*)
- loggerhead sea turtle (*Caretta caretta*)
- West Indian manatee (*Trichechus manatus*)

Any interested party is welcome to bring particular concerns or information to our attention regarding this project's potential effect on endangered species. The final draft biological assessment can be found at EPA's Region 6 Air Permits website at <u>http://yosemite.epa.gov/r6/Apermit.nsf/AirP</u>.

XIII. Magnusson-Stevens Act

The 1996 Essential Fish Habitat (EFH) amendments to the Magnuson-Stevens Fishery Conservation and Management Act (Magnuson-Stevens Act) set forth a mandate for NOAA's National Marine Fisheries Service (NMFS), regional fishery management councils (FMC), and other federal agencies to identify and protect important marine and anadromous fish habitat.

To meet the requirements of the Magnuson-Stevens Act, EPA is relying on an EFH Assessment prepared by the applicant and reviewed by EPA.

The action area of the project site affects tidally influenced portions of the Buffalo Bayou (Houston Ship Channel) which connects to Upper Galveston Bay. These tidally influenced portions have been identified as potential habitats of postlarval, juvenile, and subadult red drum

(*Sciaenops ocellatus*), Spanish mackerel (*Scomberomorus maculatus*), pink shrimp (*Penaeus duorarum*), white shrimp (*Penaeus setiferus*) and brown shrimp (*Farfantepenaeus aztecus*). The EFH Amendment information was obtained from the Gulf of Mexico Fishery Management Council (<u>http://www.gulfcouncil.org/</u>).

Based on the information provided in the EFH Assessment, EPA concludes that the proposed PSD permit allowing Calpine DPEC to construct the combustion turbine generator/heat recovery generator, identified as CTG5/HRSG5, will have no adverse impacts on EFH.

XIV. National Historic Preservation Act (NHPA)

Section 106 of the NHPA requires EPA to consider the effects of this permit action on properties eligible for inclusion in the National Register of Historic Places. To make this determination, EPA relied on a cultural resource report prepared by Blanton and Associates, Inc. ("Blanton"), Calpine's consultant, submitted on May 4, 2012.

Blanton conducted an a cultural resource survey within a 1,000-meter radius of the construction site which included a review of the Texas Historical Commission's online Texas Archaeological Site Atlas (TASA) and a pedestrian survey. Based on the information provided in the cultural resources report, no archaeological resources or historic structures were found. The site is located in a modern industrial facility in a highly developed, industrialized zone surrounded by oil and gas refineries.

Upon receipt of the report, EPA sent letters to Indian tribes identified by the Texas Historical Commission as having historical interests in Texas to inquire if any of the tribes have historical interest in the particular location of the project and to inquire whether any of the tribes wished to consult with EPA in the Section 106 process. EPA received no tribal requests for participation as a consulting party or comments about the project.

After considering a report submitted by the applicant, EPA Region 6 determines that because the report indicated that no archaeological resources or historic properties are located within the construction area of the project and that a potential for the location of archaeological resources is low, issuance of the permit to Calpine will not affect properties potentially eligible for listing on the National Register.

EPA will provide a copy of this report to the State Historic Preservation Officer for consultation and concurrence with this determination. Any interested party is welcome to bring particular concerns or information to our attention regarding this project's potential effect on historic properties.

XV. Environmental Justice (EJ)

Executive Order (EO) 12898 (59 FR 7629 (Feb. 16, 1994)) establishes federal executive branch policy on environmental justice. Based on this Executive Order, the EPA's Environmental Appeals Board (EAB) has held that environmental justice issues must be considered in connection with the issuance of federal Prevention of Significant Deterioration (PSD) permits issued by EPA Regional Offices [See, e.g., In re Prairie State Generating Company, 13 E.A.D. 1, 123 (EAB 2006); In re Knauf Fiber Glass, Gmbh, 8 E.A.D. 121, 174-75 (EAB 1999)]. This permitting action, if finalized, authorizes emissions of GHG, controlled by what we have determined is the Best Available Control Technology for those emissions. It does not select environmental controls for any other pollutants. Unlike the criteria pollutants for which EPA has historically issued PSD permits, there is no National Ambient Air Quality Standard (NAAOS) for GHG emissions. The global climate-change inducing effects of GHG emissions, according to the "Endangerment and Cause or Contribute Finding", are far-reaching and multi-dimensional (75 FR 66497). Climate change modeling and evaluations of risks and impacts are typically conducted for changes in emissions that are orders of magnitude larger than the emissions from individual projects that might be analyzed in PSD permit reviews. Quantifying the exact impacts attributable to a specific GHG source obtaining a permit in specific places and points would not be possible [PSD and Title V Permitting Guidance for GHGS at 48]. Thus, we conclude it would not be meaningful to evaluate impacts of GHG emissions on a local community in the context of a single permit. Accordingly, we have determined an environmental justice analysis is not necessary for the permitting record.

XVI. Conclusion and Proposed Action

Based on the information supplied by Calpine, our review of the analyses contained the TCEQ PSD Permit Application and the GHG PSD Permit Application, and our independent evaluation of the information contained in our Administrative Record, it is our determination that the proposed facility would employ BACT for GHGs under the terms contained in the draft permit. Therefore, EPA is proposing to issue Calpine a PSD permit for GHGs for the facility, subject to the PSD permit conditions specified therein. This permit is subject to review and comments. A final decision on issuance of the permit will be made by EPA after considering comments received during the public comment period.

Statement of Basis

Appendix

for

Calpine Corporation, Deer Park Energy Center (DPEC), LLC Greenhouse Gas Prevention of Significant Deterioration Preconstruction Permit

Permit Number: PSD-TX-979-GHG

Table 1. Annual Facility Emissions

Output-based emissions limit, in tons per megawatt-hour (tons/MWh) on a 30-day rolling average, and annual emissions, in tons per year (TPY) on a 365-day rolling average basis shall not exceed the following:

| Phase 1 of Construction | | | | | | | |
|--------------------------|---|------------------------------------|--|---|--|--|--|
| | | GH | G Mass Basis | | ВАСТ | | |
| Emission Unit | Description | | GHG Potential Emissions (TPY) ^{2,3} | | Output-based BACT CO ₂ Limit ¹ | Tons per year CO ₂ e ^{2,3} | Annual BACT Limit (TPY CO ₂ e ^{2,3}) |
| CTG5 (FD2) / HRSG5 | CTG5/HRSG5 Annual Emissions | CO ₂ CH ₄ | 1,044,629 | CO ₂ CH ₄ | 0.460 tons/MWh 7,730 Btu/KWh | 1,044,629 406 | 1,045,635 |
| NG- FUG | Fugitive Natural Gas emissions from piping components (including valves & flanges) | CO ₂ | 0.11 | CO ₂ CH ₄ ⁴ | | 0.11 | 60 |
| SF6- FUG | SF ₆ Insulated Electrical Equipment | SF ₆ | 0.00018 | SF ₆ | | 4.3 | 4.3 |

1. Compliance with the output-based emission limits (on a per hour basis) is based on a 30-day rolling average.

2. Compliance with the annual emission limits (tons per year) is based on a 365-day rolling average.

3. The tpy emission limits specified in this table are not to be exceeded for this facility and includes emissions only from the facility during normal operations and startup and shutdown activities.

4. Because the emissions from this unit are calculated to be 96% methane (CH_4) , the remaining pollutant emission (CO_2) is not presented in the table.

5. Because the emissions from this unit are calculated to be over 99.9% carbon dioxide (CO₂), the remaining pollutant emissions (CH₄ and N₂O) are not presented in the table.

| | Phase 2 of Construction | | | | | | | |
|--------------------------|---|---|--|--|--|--|--|--|
| | | GH | G Mass Basis | ВАСТ | | | | |
| Emission Unit | Description | | GHG Potential Emissions (TPY) ^{2,3} | | Output-based BACT CO ₂ Limit ¹ | Tons per year CO ₂ e ^{2,3} | Annual BACT Limit (TPY CO ₂ e ^{2,3}) | |
| CTG5 (FD2) / HRSG5 | CTG5/HRSG 5 Annual Emissions | CO ₂ CH ₄ | 1,062, 627 19.67 1.97 | CO ₂ CH ₄ N ₂ O | 0.460 tons/MWh 7,730 Btu/KWh | 1,062, 627 413 610 | 1,063,650 | |
| NG- FUG | Fugitive Natural Gas emissions from piping components (including valves & flanges) | CO ₂ CH ₄ ⁴ | 0.11 | CO ₂ CH ₄ ⁴ | | 0.11 59.69 | 60 | |
| SF6- FUG | SF ₆ Insulated Electrical Equipment | SF ₆ | 0.00018 | SF ₆ | | 4.3 | 4.3 | |

1. Compliance with the output-based emission limits (on a per hour basis) is based on a 30-day rolling average.

2. Compliance with the annual emission limits (tons per year) is based on a 365-day rolling average.

3. The tpy emission limits specified in this table are not to be exceeded for this facility and includes emissions only from the facility during normal operations and startup and shutdown activities.

4. Because the emissions from this unit are calculated to be 96% methane (CH_4), the remaining pollutant emission (CO_2) is not presented in the table.

5. Because the emissions from this unit are calculated to be over 99.9% carbon dioxide (CO_2), the remaining pollutant emissions (CH_4 and N_2O) are not presented in the table.

| Phase 1 of Construction | | | | | | |
|--|--|-----------|--------------|----------|--|--|
| Total Heat Input Capacity (MMBtu/yr) ¹ = 17,577,900 | | | Greenhouse (| Gas | | |
| | | CO_2 | CH_4 | N_2O | | |
| Emission Factor ² (kg/MMBtu) | | | 1.00E-03 | 1.00E-04 | | |
| Global Warming Potential ³ (GWP) | | 1 | 21 | 310 | | |
| GHG Potential Emissions ^{4,5} (tpy) | | 1,044,629 | 19.34 | 1.93 | | |
| Total GHG Potential Emissions (tpy) | | | 1,044,651 | | | |
| CO_2e^6 (tpy) | | 1,044,629 | 406 | 599 | | |
| Total CO_2e^7 (tpy) | | | 1,045,635 | | | |

Table 2: Annual Emissions for the FD2 Combined-cycle Combustion Turbine and Steam Generator (CTG5/HRSG5) -

Methodologies and Assumptions

1 Total Heat Input Capacity was determined from the projected annual firing rate information provided by Calpine and reviewed by the EPA

| | Annual | | Duct Burner | Total Hourly | |
|--|----------------------------|----------------------------------|--------------------------|--------------------------|---------------------------------------|
| Operating Mode | Operating Hours (hr/yr) | Turbine Heat Input (MMBtu/hr) | Heat Input (MMBtu/hr) | Heat Input (MMBtu/hr) | Total Annual Heat Input (MMBtu/hr) |
| Base Load, 70°F Ambient, Avg Duct Burner Firing | 6,760 | 1,827.5 | 110 | 1937.5 | 13,097,500 |
| Base Load, 90°F Ambient, Peak Duct Burner Firing | 1,500 | 1602.8 | 595 | 2,197.8 | 3,296,700 |
| Base Load, 90°F Ambient, Peak Duct Firing, Power Augmentation | 500 | 1,712.4 | 655 | 2,367.4 | 1,183,700 |
| | 8,760 | | | | 17,577,900 |

 2 CH4 and N2O GHG factors are based on Table C-2 of 40 CFR 98

³ Greenhouse Warming Potentials (GWP) are from Table A-1 of 40 CFR Part 98, Subpart A. Mandatory Greenhouse Gas Reporting

⁴ CO₂ emissions is based on Equation G-4, Appendix G, 40 CFR Part 75, Appendix G where the yearly emission was calculated instead of hourly

 $W_{CO2} = (Fc x H x Uf x MW_{CO2})/2000$

where: $WCO_2 = CO_2$ emitted (tons/yr) H = Heat Input (MMBtu/yr)

 $MW_{CO2} =$ Molecular Weight of $CO_2 = 44.0$ lbs/mole

Fc = Carbon-base F factor, 1040 scf/MMBtu $Uf = 1/385 scf CO_2/lb-mole$

⁵ Greenhouse Warming Potentials (GWP) are from Table A-1 of 40 CFR Part 98, Subpart A and GHG Potential Emissions (tons/year) = Throughput (MMBtu/yr) x Emission Factor (kg/MMBtu) x (2.2 lbs/kg) x (1 ton/2000 lbs)

 6 CO₂e (tpy) = GHG Potential Emissions x GWP for each pollutant

⁷ Total CO₂e (tpy) = (CO₂ Potential Emissions x CO₂ GWP) + CH₄ Potential Emissions x CH₄ GWP) + (N₂O Potential Emissions x N₂O GWP)

| Phase 2 of Construction | | | | | | | | | | | |
|---|------------|--|-------------------|----------------|----------|--|--|--|--|--|--|
| Total Heat Input Capacity (MMBtu/yr) ¹ | 17,880,750 | | | Greenhouse Gas | 8 | | | | | | |
| | | | CO_2 | CH_4 | N_2O | | | | | | |
| Emission Factor ² (kg/MMBtu) | | | | 1.00E-03 | 1.00E-04 | | | | | | |
| Global Warming Potential ³ (GWP) | | | 1 | 21 | 310 | | | | | | |
| GHG Potential Emissions ^b (tpy) | | | 1,062,627 | 19.67 | 1.97 | | | | | | |
| Total GHG Potential Emissions (tpy) | | | | 1,080,728 | | | | | | | |
| CO_2e^6 (tpy) | | | 1,062,627 413 610 | | | | | | | | |
| Total $CO_2 e^7$ (tpy) 1,063,650 | | | | | | | | | | | |

Table 3: Annual Emissions for the FD3 Combined-Cycle Combustion Turbine and Steam Generator (CTG5/HRSG5)

Methodologies and Assumptions

¹ Total Heat Input Capacity was determined from the projected annual firing rate information provided by Calpine and reviewed by the EPA

| Operating Mode | Annual Operating Hours (hr/yr) | Turbine Heat Input (MMBtu/hr) | Duct Burner Heat Input (MMBtu/hr) | Total Hourly Heat Input (MMBtu/hr) | Total Annual Heat Input (MMBtu/hr) |
|--|-----------------------------------|----------------------------------|---|---------------------------------------|---------------------------------------|
| Base Load, 70°F Ambient, Avg Duct Burner Firing | 6,760 | 1,873 | 110 | 1,983 | 13,097,500 |
| Base Load, 90°F Ambient, Peak Duct Burner Firing | 1,500 | 1,752 | 595 | 2,347 | 3,520,050 |
| Base Load, 90°F Ambient, Peak Duct Firing, Power Augmentation | 500 | 1,871 | 655 | 2,526 | 1,263,200 |
| | 8,760 | | | | 17,880,750 |

² CH₄ and N₂O GHG factors are based on Table C-2 of 40 CFR 98

³ Greenhouse Warming Potentials (GWP) are from Table A-1 of 40 CFR Part 98, Subpart A. Mandatory Greenhouse Gas Reporting

⁴ CO2 emissions is based on Equation G-4, Appendix G, 40 CFR Part 75, Appendix G where the yearly emission was calculated instead of hourly

 $W_{CO2} = (Fc x H x Uf x MW_{CO2})/2000$

where: $W_{CO2} = CO_2$ emitted (tons/yr) H = Heat Input (MMBtu/yr)

 $MW_{CO2} =$ Molecular Weight of $CO_2 = 44.0$ lbs/mole

Fc = Carbon-base F factor. 1040 scf/MMBtu

Uf = 1/385 scf CO2/lb-mole⁵ Greenhouse Warming Potentials (GWP) are from Table A-1 of 40 CFR Part 98, Subpart A and GHG Potential Emissions (tons/year) = Throughput (MMBtu/yr) x Emission Factor (kg/MMBtu) x (2.2 lbs/kg) x (1 ton/2000 lbs)

⁶ CO₂e (tpy) = GHG Potential Emissions x GWP for each pollutant

⁷ Total CO₂e (tpy) = (CO₂ Potential Emissions x CO₂ GWP) + CH₄ Potential Emissions x CH₄ GWP) + (N₂O Potential Emissions x N₂O GWP)

Table 4: Output-Based BACT Limits for FD2 and FD3 Combined-Cycle Combustion Turbine and Steam Generator (CTG5/HRSG5)



Calculation of Output-Based BACT Limit (ton CO2/MWh) for CTG5/HRSG5⁵

| EPN | Base Heat Rate (Btu/kWh) ⁶ | Heat Input Required to Produce 1 MW (MMBtu/h) ² | tons CO2e per year ³ | Total Heat Input Capacity (MMBtu/yr) ³ | tons CO2e/MWh ⁴ | |
|----------------|---|--|---------------------------------------|--|-------------------------------|--|
| CTG5/ HRSG5 | 7727.9 | 7.73 | 1,063,650 | 17,880,750 | 0.460 | |

¹Base Heat Rate was calculated accounting for a 3.3% margin of error in design and construction of the new turbine

²Heat Input was calculated by dividing the Base Heat Rate by a factor of 1000

³Values obtained from Table 2 for the FD2 series and Table 3 for the FD3 series of the SOB Appendix ⁴tons CO₂e/MWh = ((tons CO₂e per year)/(total heat input capacity/Heat Input Required to produce 1 MW)). Output-based limits will be based on CO2 versus CO2e because all emissions determined by monitoring methodology in accordance to 40 CFR Part 75 are in lbs of CO₂ as opposed to lbs of CO₂e.

⁵Ongoing Output-based BACT limit averaged over each 30-day consecutive period

⁶Base Heat Rate was calculated accounting for 3.3% design margin, 6.0% performance margin and a 3.0% degradation margin (See SOB, Step 5 discussion of GHG BACT for the Combined-cycle Combustion Turbine Generator)

| Table | 5. | Startup and | Shutdown | Hourly | Emissions | Calculations |
|-------|----|-------------|----------|--------|-----------|--------------|
|-------|----|-------------|----------|--------|-----------|--------------|

| Total Heat Input Capacity (MMBtu/hr) ¹ | 1,164 | | | | |
|--|--------------|----------|----------|---------------|----------|
| | | | G | reenhouse Gas | |
| | | | CO_2 | CH_4 | N_2O |
| Emission Factor ² (kg/MMBtu) | | | | 1.00E-03 | 1.00E-04 |
| Global Warming Potential ³ (GV | WP) | | 1 | 21 | 310 |
| GHG Potential Emissions ^{4,5} (to | ns per hour) | | 69 | 1.28E-03 | 1.28E-04 |
| Total GHG Potential Emissions | | 69 | | | |
| $\rm CO_2 e^6$ (tons per hour) | 69 | 2.69E-02 | 3.97E-02 | | |
| Total CO_2e^b (tons per hour) | | 69 | | | |

Methodologies and Assumptions

¹ Total Heat Input Capacity was determined from the hourly firing rate information provided by Calpine and reviewed by the EPA. *Startup Emission Basis* –A startup period begins when an initial flame detection signal is recorded in the plant's Data Acquisition and Handling System (DAHS) and ends when combustion tubine output reaches 60% load. Since GHG emissions are proportional to fuel consumption, high GHG emissions during a startup occurs at the point of highest fuel consumption (approximately 60% load).

| | | Turbine | Duct Burner | Total Hourly |
|---|---|------------|-------------|--------------|
| | | Heat Input | Heat Input | Heat Input |
| | Operating Mode | (MMBtu/hr) | (MMBtu/hr) | (MMBtu/hr) |
| Maximum Hourly Heat Input | Base Load, 20°F Ambient, Max Duct Burner Firing | 2,017 | 452 | 2,469 |
| Maximum Hourly Heat Input during Startup | 60% Load, 90°F Ambient, no Duct Burner Firing | 1,164 | 0 | 1,164 |

² CH4 and N2O GHG factors are based on Table C-2 of 40 CFR 98

³ Greenhouse Warming Potentials (GWP) are from Table A-1 of 40 CFR Part 98, Subpart A. Mandatory Greenhouse Gas Reporting

 4 CO₂ emissions is based on Equation G-4, Appendix G, 40 CFR Part 75, Appendix G where the yearly emission was calculated instead of hourly

 $W_{CO2} = (Fc x H x Uf x MW_{CO2})/2000$

where: $W_{CO2} = CO_2$ emitted (tons/yr) H = Heat Input (MMBtu/yr) $MW_{CO2} =$ Molecular Weight of $CO_2 = 44.0$ lbs/mole Fc = Carbon-base F factor, 1040

Uf = 1/385 scf CO2/lb-mole

⁵ Greenhouse Warming Potentials (GWP) are from Table A-1 of 40 CFR Part 98, Subpart A and GHG Potential Emissions (tons/year) = Throughput (MMBtu/yr) x Emission Factor (kg/MMBtu) x (2.2 lbs/kg) x (1 ton/2000 lbs)

⁶ CO₂e (tpy) = GHG Potential Emissions x GWP for each pollutant

⁷ Total CO_2e (tpy) = (CO_2 Potential Emissions x CO_2 GWP) + CH_4 Potential Emissions x CH_4 GWP) + (N_2O Potential Emissions x N_2O GWP)

| | Source | Source Fluid State Count | | Emission Easter ¹ | Greenhouse Gas | | |
|-------------------------------------|---------------------------|--------------------------|-------|---------------------------------|----------------|------------|--|
| | Types | Fluid State | Count | (scf/hr/comp) | CO_2^2 | CH_4^{3} | |
| | Valves | Gas/vapor | 60 | 0.123 | 0.05 | 1.27 | |
| | Flanges | Gas/vapor | 240 | 0.017 | 0.03 | 0.70 | |
| NG-FUG | Relief Valves | Gas/vapor | 8 | 0.196 | 0.01 | 0.27 | |
| | Sampling Collections | Gas/vapor | 18 | 0.123 | 0.01 | 0.38 | |
| Global Warming P | otential ³ (GV | WP) | | | 1 | 21 | |
| GHG Potential Em | issions ⁴ (tpy |) | | | 0.10 | 2.62 | |
| Total GHG Potential Emissions (tpy) | | | | | 2.72 | 2 | |
| CO_2e^5 (tpy) | | | | | 0.10 | 54.95 | |
| Annual CO ₂ e BAC | T Limit (tpy | | | | 55.0 | 5 | |

Methodologies and Assumptions

¹ Emission factors from Table W-1A of 40 CFR 98 Mandatory Greenhouse Gas Reporting

 2 CO₂ emissions based on vol% of CO₂ in natural gas (1.33% from Natural Gas Analysis)

³ CH₄ emissions based on vol% of CH₄ in natural gas (94.44% from natural gas analysis)

⁴ Greenhouse Warming Potentials (GWP) are from Table A-1 of 40 CFR Part 98, Subpart A

⁵ CO_2e (tpy) = GHG Potential Emissions x GWP for each pollutant

⁶ Total CO₂e (tpy) = (CO₂ Potential Emissions x CO₂ GWP) + CH₄ Potential Emissions x CH₄ GWP) + (N₂O Potential Emissions x N₂O GWP)

sample calc

| | | %CO ₂ | | | | |
|-----------|-----------|------------------|-----------|--------------------------|---------|---------|
| 60 valves | 0.123 scf | 0.0133 | lb-mole | 44.01 lb CO ₂ | 8760 hr | ton |
| | hr*valve | | 385.5 scf | lb-mole | yr | 2000 lb |

| | Initial Conditions | | | Final conditions | | | CO_2^3 | CH4 ⁴ | |
|--|-------------------------------|-----------------|-----------|--------------------|--------------|------------------------------|-----------------|------------------|-------------|
| Location | Volume ¹ (ft) | Pressure (psig) | Temp (°F) | Pressure (psig) | Temp (°F) | Volume ² (scf) | Annual (tpy) | Annual (tpy) | Total (tpy) |
| Turbine Fuel Line Shutdown/Maintenance | 955 | 50 | 50 | 0 | 68 | 4397 | 0.0033 | 0.0861 | |
| Small Equipment/Fugitive Component Repair/Replacement | 6.7 | 50 | 50 | 0 | 68 | 31 | 0.00002 | 0.0006 | |
| | Total GHG Potential Emissions | | | | | | | | |
| Global Warming Potential 1 21 | | | | | | | | | |
| | | | | | С | O ₂ e Emissions | 0.0034 | 1.8216 | 1.8250 |

Table 7. Miscellaneous Fugitive Emissions from Small Equipment & Component Repair/Replacement

1. Initial volume was calculated by multiplying the cross sectional area by the length of the pipe using the following formula: $V_i = {\pi * [(diameter(inches)/12)/2]^2 * length(ft)}$

2. Final volume was calculated using ideal gas law: $[((PV)/(ZT))_i=((PV)/(ZT))_f]$. $V_f = [V_i^*(P_i/P_f)^*(T_{f'}T_i)^*(Z_{f'}/Z_i)]$, where the compressibility factor, Z, is estimated as the following equation: $Z_n = 0.9994 - 0.0002P_n + 3e-08P_n^2$

3. CO_2 emissions is based on % volume of CO_2 in Natural gas = 1.33% from natural gas analysis

4. CH_4 emissions is based on % volume of CH_4 in natural gas = 94.4% from natural gas analysis

5. Global Warming Potential factors are based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting

Example Calculation:

| 4,397 scf Nat Gas | 0.0133 scf CO ₂ | lbmole | 44.01 lb CO ₂ | ton | 0.0022 | tons CO ₂ |
|-------------------|----------------------------|-----------|--------------------------|---------|------------|----------------------|
| year | scf Nat Gas | 385.5 scf | lbmole | 2000 lb | 0.0033 | yr |

Table 8. Fugitive Emissions from Electrical Equipment Insulated with SF₆

| Assumptions: | ns: New insulated circuit breaker SF6 capacity | | lbs | |
|--------------|--|---------|-----------|--|
| | Estimated annual SF6 leak rate | 0.50% | weight | |
| | Estimated annual SF6 mass emission rate | 0.00018 | tons/year | |
| | Global Warming Potential | 23,900 | | |
| | Estimated annual CO ₂ e emission rate | 4.302 | ton/year | |
| | | | | |

1. Global Warming Potential factors based on Table A-1 of 40 CFR 98 Mandatory Greenhouse Gas Reporting

2. Estimated annual CO2e emissions was calculated using the following equation:

| | 72 lbs | 0.005 (%weight) | ton | (GWP) 23,900 | = | 4.3 |
|---|--------|-----------------|----------|-----------------|---|-----------|
| _ | | year | 2000 lbs | | | Tons/year |

Table 9. Financial Assessment for Implementation of a Carbon Capture and Storage System at the Calpine DPEC Facility

| Carbon Capture and Storage (CCS) Components | Annual System CO ₂ Throughput (tons of CO ₂ captured, transported, and stored) | Pipeline Length for CO_2 Transport System (km) ⁵ | Range of Approximate Annual Costs for CCS System (in USD) ⁶ | | | | | |
|---|---|---|---|--|--|--|--|--|
| Post-Combustion CO2 Capture and Compression System ¹ | | | | | | | | |
| Average Cost ^{2,3,4} | 956,349 | | \$70,544,632 | | | | | |
| CO2 Transport System | | | | | | | | |
| Average Cost ^{2,3,4} | 956,349 | 24 | \$419,123 | | | | | |
| CO2 Storage System | | | | | | | | |
| Average Cost ^{2,3,4} | 956,349 | | \$8,918,776 | | | | | |
| Total Annual Costs for CO2 Capture, Transport and Storage Systems | | | | | | | | |
| Average Cost ^{2,3,4} | 956,349 | | \$79,882,531 | | | | | |

Assumptions:

- 1. Assume that the capture systems is able to capture 90% of the total CO2 emissions generated by the power plant's gas turbines
- 2. The minimum cost factor found for implementation/operation of the CO2 capture systems within the cost-related information reviewed for CCS technology is found from the "Properties" section of the Greenhouse Gas Mitigation Strategies Database (last accessed April 2010) (http:/ghg.ie.unc.edu:8080/GHGMDB/#data), which was obtained through the EPA GHG web site (http://www.epa.gov/nsr/ghgpermitting.html). The factor is based on the increased cost of electricity (COE; in \$/MW-h) resulting from the implementation and operation at a CO2 capture system on a natural gas-fired combined-cycle power plant. The factor accounts for annualized capital costs, fixed operating costs, variable operating costs, and fuel costs.
- 3. Maximum costs are from the Report of the Interagency Task Force on Carbon Capture and Storage, pp 33, 34, 37 and 44 (August 2010) (http://www.epa.gov/climatechange/policy/ccs task force.html). The factors from the report are in dollars (USD) per tonne of CO2 processed, transported or stored and have been converted to dollars per ton. Per the report, the factors are based on the increased cost of electricity (COE; in \$/kW-h) of an "energy-generating system, including all the costs over its lifetime; initial investment, operations, and maintenance, cost of fuel and cost of capital."
- 4. The average costs factors were calculated as the arithmetic mean of the minimum and maximum factors for each of the CCS component system and for all
- 5. The length of the pipeline was the assumed distance to the closest potential geologic storage site, as identified by the University of Texas at Austin, Bureau of Economic Geology, Gulf Coast Carbon Center, available at <<u>http://www.beg.utexas.edu/gccc/miocene/</u>>.
- 6. Cost estimates (for geologic storage of CO2) are limited to capital and operational costs, and do not include potential costs associated with long-term liability from Intergovernmental Panel on Climate Change (IPCC) Special Report, *Carbon Dioxide Capture and Storage* (New York: Cambridge University Press, 2005), p.44
 http://www.ipcc.ch/pdf/special-reports/srccs/srccs wholereport.pdf>