

US EPA ARCHIVE DOCUMENT

From: [Andrew Chartrand](#)
To: [Wilson, Aimee](#)
Subject: RE: Sinton Compressor Station
Date: Tuesday, September 17, 2013 3:58:55 PM
Attachments: [EPA Responses Sinton_09 10 13.docx](#)

See attached for responses to your questions on the Sinton Compressor Station application. Thank you.

Andrew J. Chartrand
Cheniere Energy, Inc.
700 Milam St., Suite 800
Houston, TX 77002
Phone: (713) 375-5429
Fax: (713) 375-6429
Cell: (832) 358-5535

From: Wilson, Aimee [mailto:Wilson.Aimee@epa.gov]
Sent: Friday, August 09, 2013 2:56 PM
To: Andrew Chartrand
Subject: Sinton Compressor Station

Andrew,

I left you a message earlier on CCS infeasibility for simple cycle turbines. I realized after we spoke, that this came up from OAQPS review of the Sinton permit. I have comments from OAQPS, but not OGC. I don't think OGC will comment at this point. There are a few items that OAQPS would like to have addressed.

If we eliminate CCS as being technically infeasible for simple cycle turbines, we have to show that combined cycle were not feasible for the project. Can you provide an analysis to show why combined cycle turbines were not feasible? Also, OAQPS wants to know if you can provide an output based limit as BACT on the turbines. Since you are not producing electricity, it could be a lb of CO₂/ hp-hr. OAQPS is also concerned that the most efficient turbines may not be selected. You propose a minimum thermal efficiency of 36%, but Copano's turbines which also are used for compression, but have a WHRU – have a 40% thermal efficiency. Can Cheniere install turbines with a 40% thermal efficiency? The addition of an output based limit would help to ensure a highly efficient turbine is selected. They also want to see what operating and maintenance practices will be implemented to ensure efficient operation.

Also, on the liquefaction plant you provided supporting information on why electric driven compressors could not be used. Please provide something similar for the Sinton Compressor Station. This is of concern due to the fact we have some facilities permitted that did install electric driven compression engines.

On the fugitive emissions, is there anything additional we can say on why leakless technologies are not selected? All we have from the application is that they are not universally adopted. We really need a more solid reason why they cannot be selected.

If you can provide me this additional information, I can probably get the draft permit to you by the

end of next week. Please call me if you have any questions.

Thanks,
Aimee

This e-mail and any attachments are for the sole use of the intended recipient(s) and may contain information that is legally privileged and/or confidential information. If you are not the intended recipient(s) and have received this e-mail in error, please immediately notify the sender by return e-mail and delete this e-mail from your computer. Any distribution, disclosure or the taking of any other action by anyone other than the named recipient is strictly prohibited.



Memorandum

To: Environmental Protection Agency, Region 6 – Aimee Wilson

From: Lisa Swanson, Providence

CC: Rance Jett, Providence; Andrew Chartrand, Cheniere Energy, Inc.

Re: Request for Additional Information Regarding the Greenhouse Gas (GHG)
Permit for the Sinton Compressor Station – San Patricio County

In response to EPA's August 12, 2013, additional information request for the Sinton Compressor Station's GHG Permit, Cheniere Corpus Christi Pipeline, L.P. (CCPL) is providing the following responses:

Comment 1

If we eliminate CCS as being technically infeasible for simple cycle turbines, we have to show that combined cycle were not feasible for the project. Can you provide an analysis to show why combined cycle turbines were not feasible?

Response

Combined cycle turbines are not feasible for the Sinton Compressor Station due to the fact that combined cycle operation implies waste heat recovery (WHRU) which is used to generate electricity or supply other heat-related uses such as thermal regeneration of dehydration towers. The Sinton Compressor Station has no need for the excess heat or power generated. In addition, combined cycle operations require stable operation to be cost effective. Combined cycle operation takes time to bring on-line as the heat recovery loop must be heat saturated before any power can be derived. The potential transient loading of the turbines combined with considerable capital costs make combined cycle a non-viable alternative.

Comment 2

Also, OAQPS wants to know if you can provide an output based limit as BACT on the turbines. Since you are not producing electricity, it could be a lb of CO₂/ hp-hr. OAQPS

is also concerned that the most efficient turbines may not be selected. You propose a minimum thermal efficiency of 36%, but Copano's turbines which also are used for compression, but have a WHRU – have a 40% thermal efficiency. Can Cheniere install turbines with a 40% thermal efficiency? The addition of an output based limit would help to ensure a highly efficient turbine is selected. They also want to see what operating and maintenance practices will be implemented to ensure efficient operation.

Response

See response to Comment 1. CCPL is proposing Solar turbines that are similar to the Copano turbines although they are different models. Copano achieves the 40% thermal efficiency through the use of WHRU. CCPL's proposal is consistent with gas pipeline applications and has high thermal efficiency found for this application. CCPL is proposing an output-based limit of 0.91 lb CO₂/hp-hr for each of the two turbines. This limit is based on a higher heating value (HHV) of 1,045 Btu/scf.

Comment 3

Also, on the liquefaction plant you provided supporting information on why electric driven compressors could not be used. Please provide something similar for the Sinton Compressor Station. This is of concern due to the fact we have some facilities permitted that did install electric driven compression engines.

Response

Use of electric motors to drive the refrigerant compressors would “redefine the source,” because the use of gas turbines is part of the basic design of the proposed compressor station. As EPA noted in its March 2011 guidance document, PSD and Title V Permitting Guidance for Greenhouse Gases (“GHG Permitting Guidance”), Step 1 of the top-down BACT analysis need not include inherently lower-polluting processes that would fundamentally redefine the nature of the source proposed by the permit application. GHG Permitting Guidance at p.26. Permitting authorities can look at whether design elements can be changed to achieve emission reductions “without disrupting the applicant’s basic business purpose for the proposed facility.” Id. As detailed below, the substitution of electric motors for the proposed gas turbines in this case would interfere with the plant’s basic design.

Additionally, CCPL is concerned that the electric generation capacity in Texas is limited. The uncertainty of the electric capacity and prices highlights the economic risk and also presents potential operational risk for the proposed compressor station.

Comment 4

On the fugitive emissions, is there anything additional we can say on why leakless technologies are not selected? All we have from the application is that they are not universally adopted. We really need a more solid reason why they cannot be selected.

Response

While not classified as “leakless technology”, valves, seals, and piping utilized will be state-of-the-art for current industry practices and will be designed to be as fully pressure containing as possible. Examples include installing valves that are equipped with lubrication/sealant ports around stem packing, ensuring correct flange alignment during construction and use of spiral wound gaskets in flanges, and use of dry gas seals for centrifugal compressors. In addition, the Solar turbines that are proposed for the Sinton Compressor Station use tandem dry gas seals. CCPL has elaborated the on the BACT analysis for the Fugitive Emissions at the facility, and this revised BACT analysis is included as **Attachment A** to this letter.

ATTACHMENT A
REVISED FUGITIVE EMISSIONS BACT ANALYSIS

B.4.3.3 CH₄ BACT for Fugitive Emissions

There will be less than 10 tpy of CH₄ from the fugitive components at the site. This is a negligible contribution to the facility's total GHG emissions; however, for completeness, they are addressed in this BACT analysis. CCPL is proposing to incorporate an annual infrared sensing plan to comply with the requirements of 40 CFR 60 Part 98.

Identification of Potential CH₄ Control Technologies (Step 1)

Based on the previously identified sources, four methods were identified and were all carried to Step 2 in the process.

GHG Emission Reduction Measure	Description
Leakless Technology Components	Replacement of traditional components with components designed for leakless operation
Leak Detection and Repair Program	Leak inspection programs that comply with state and federal regulations
Audio, Visual and Olfactory Programs	Supplemental inspection programs based on AVO sensing
Alternative Monitoring Programs	Remote Sensing such as infrared camera monitoring

Eliminate Technically Infeasible Options (Step 2)

Leakless Technology Components

Emissions from pumps and valves can be reduced through the use of leakless valves and sealless pumps. Common leakless valves include bellow valves and diaphragm valves, and common sealless pumps are diaphragm pumps, canned motor pumps and magnetic drive pumps. Leaks from pumps and compressors can also be reduced by using dual seals with or without barrier fluids.

Leakless valves and sealless pumps are effective at minimizing or eliminating leaks, but their use may be limited by materials of construction considerations and process operating conditions. Additionally, elevated service temperatures can have a negative effect on leakless components. For example, the tensile strength of bellow valves is degraded at higher process temperatures, which reduces the component life-cycle. Installing leakless and sealless equipment components is generally reserved for individual, chronic leaking components and specialized services. Additionally, leakless valves are primarily used where highly toxic materials are in service. Leakless technology components have not been

widely adopted as BACT/LAER, and are not considered technically feasible on a facility-wide basis for the Sinton Compressor Station.

Leak Detection and Repair (LDAR) Programs

LDAR programs have been traditionally developed for control of VOC emissions. LDAR programs vary in stringency as needed for control of VOC emissions; however, due to the negligible amount of GHG emissions from fugitives, LDAR programs would not be considered for control of GHG emissions alone.

The fundamental elements for all LDAR programs include: identification of components to be included in the program, conducting routine instrument monitoring of identified components, repair of leaking components and reporting of the monitoring results. Monitoring direct emissions of CH₄ with traditional portable hydrocarbon monitoring equipment is technically feasible.

Audio/Visual/Olfactory (AVO) Monitoring Program

AVO monitoring can be used to detect leaking fugitive components. Natural gas leaks are expected to have discernible odors that are detectable by olfactory means. Large leaks can be detected by sound and sight. The visual detection can be direct, or a secondary indicator such as condensation around a leaking source due to the cooling of an expanding gas as it leaves the leak interface.

Alternative Monitoring Program

Alternative monitoring programs such as remote sensing technologies have been proven effective in leak detection and repair. The use of sensitive infrared camera technology has become widely accepted as a cost effective means for identifying leaks of hydrocarbons.

Rank of Remaining Control Technologies (Step 3)

In the third step of the top-down BACT analysis, the remaining options for process fugitives BACT are ranked. Based on TCEQ air permit guidance documentation, an LDAR program represents the top level BACT. The control efficiencies for the various accepted TCEQ LDAR programs are provided in the following table.

Control Efficiencies for TCEQ Leak Detection and Repair Programs¹

Equipment / Service	28M	28RCT	28VHP	28MID	28LAER	Audio/Visual/Olfactory ¹
Valves						
Gas/Vapor	75%	97%	97%	97%	97%	97%
Light Liquid	75%	97%	97%	97%	97%	97%
Heavy Liquid ²	0% ³	0% ⁴	0% ⁴	0% ⁴	0% ⁴	97%
Pumps						
Light Liquid	75%	75%	85%	93%	93%	93%
Heavy Liquid ²	0% ³	0% ³	0% ⁵	0% ⁶	0% ⁶	93%
Flanges / Connectors						
Gas/ Vapor ⁷	30%	30%	30%	30%	97%	97%
Light Liquid ⁷	30%	30%	30%	30%	97%	97%
Heavy Liquid	30%	30%	30%	30%	30%	97%
Compressors	75%	75%	85%	95%	95%	95%
Relief Valves (Gas/Vapor)	75%	97%	97%	97%	97%	97%
Open-ended Lines ⁸	75%	97%	97%	97%	97%	97%
Sampling Connections	75%	97%	97%	97%	97%	97%

1. Audio, visual, and olfactory walk-through inspections are applicable for inorganic/odorous and low vapor pressure compounds such as chlorine, ammonia, hydrogen sulfide, hydrogen fluoride, and hydrogen cyanide.
2. Monitoring components in heavy liquid service is not required by any of the 28 Series LDAR programs. If monitored with an instrument, the applicant must demonstrate that the VOC being monitored has sufficient vapor pressure to allow reduction.
3. No credit may be taken if the concentration at saturation is below the leak definition of the monitoring program (i.e. $(0.044 \text{ psia}/14.7 \text{ psia}) \times 106 = 2,993 \text{ ppmv}$ versus leak definition = 10,000 ppmv).
4. Valves in heavy liquid service may be given a 97% reduction credit if monitored at 500 ppmv by permit condition provided that the concentration at saturation is greater than 500 ppmv.
5. Pumps in heavy liquid service may be given an 85% reduction credit if monitored at 2,000 ppmv by permit condition provided that the concentration at saturation is greater than 2,000 ppmv.
6. Pumps in heavy liquid service may be given a 93% reduction credit if monitored at 500 ppmv by permit condition provided that the concentration at saturation is greater than 500 ppmv.

¹ TCEQ Air Permit Division. Control Efficiency for TCEQ Leak Detection and Repair Programs. Revised (July, 2011). (APDG 6129v2).

7. *If the applicant decides to monitor connectors using an organic vapor analyzer (OVA) at the same leak definition as valves, then the applicable valve reduction credit may be used instead of the 30% reduction credit. If this option is chosen, the applicant shall continue to perform the weekly physical inspections in addition to the quarterly OVA monitoring.*
8. *The 28 Series quarterly LDAR programs require open-ended lines to be equipped with an appropriately sized cap, blind flange, plug, or a second valve. If so equipped, open-ended lines may be given a 100% control credit.*

Based on the control efficiency table for typical LDAR programs, the control efficiency ranges for individual components are 75-95% for valves, 75-93% for pumps, 30-97% for flanges and connectors, 75-95% for compressors, and 75-97% for all other component types. These higher efficiency LDAR programs are intended for VOC controls in nonattainment areas and for facilities with project emissions that exceed the significant emission rate (SER) for VOCs and require state and/or federal BACT review.

Remote sensing using infrared imaging has proven effective for identification of leaks. The process has been the subject of EPA rulemaking as an alternative method to EPA's Method 21. Effectiveness is likely comparable to EPA Method 21.

AVO walk-through inspections are generally applicable for inorganic/odorous and low vapor pressure compounds such as chlorine, ammonia, hydrogen sulfide, and hydrogen cyanide. The effectiveness of an AVO monitoring program is dependent upon the frequency of observation opportunities, such as during routine inspections. This method generally cannot identify leaks at a low leak rate as instrumented readings can identify. Due to the typical frequency of observation, this method of observation is effective for identification of larger leaks, and is typically intended as a supplement to an instrumented LDAR program. In addition, an AVO inspection program may only be applied to inorganic compounds that cannot be monitored by instruments, and in limited instances, AVO inspection programs have been allowed to be applied to extremely odorous organic compounds such as mercaptans.²

Evaluation of Most Stringent Controls (Step 4)

No significant adverse energy or environmental impacts (that would influence the GHG BACT selection process) are associated with the three technically feasible control options. ***Selection of CH₄ BACT (Step 5)***
CH₄ BACT for the fugitive sources is the proposed remote sensing program using infrared imaging. Although it is technically feasible to

² TCEQ. Technical Supplement 3: Equipment Leak Fugitives (RG-360). Revised (January, 2006).

use an LDAR program, or an AVO program to supplement an instrumented LDAR program, to control the negligible amount of GHG emissions that may occur from process fugitives at the Sinton Compressor Station, an LDAR program represents the Lowest Achievable Emission Rate (LAER) control option for emissions of VOC. While a top-down BACT analysis also requires that LAER control candidates are included in the control candidate review, they are not strictly required in areas that demonstrate attainment. Currently, San Patricio County is classified as an attainment or unclassifiable area for all pollutants. In addition, the proposed project emissions for VOCs are less than the SER for PSD review; therefore, BACT review of VOC emissions is not required.

The primary purpose of implementing an LDAR program as BACT/LAER is to control fugitive emissions of VOCs to the atmosphere. TCEQ guidance suggests that an LDAR program is not necessary to satisfy BACT when uncontrolled fugitive emissions are less than 10 tpy. Because the fugitive VOC emissions from the proposed project would not meet the 10 tpy threshold, the TCEQ would not require CCPL to implement LDAR for VOC control. Moreover, methane is not considered a VOC, so LDAR is not required for streams containing a high content of methane. Therefore, CCPL has eliminated LDAR, and a supplementary AVO monitoring program, from further BACT considerations.

CCPL proposes to conduct annual GHG surveys using remote sensing with infrared imaging in compliance with 40 CFR 60 Part 98 for stand-alone compression stations.