

US EPA ARCHIVE DOCUMENT

# Occidental Chemical Corporation – Ingleside Ethylene Plant

## Average Cost Effectiveness Calculations

9/18/13

### Emissions Assuming Natural Gas Fired Boilers for new Amine Regenerator

### Thermal Oxidizers CCS Average Cost Effectiveness

<b>Capital Cost</b>	
Pipeline	\$167,000,000
Pipeline Pumps	\$62,500,000
Amine Contactor, Amine Stripper, Reclaimer, Boiler	\$100,000,000
Stack Blowers	\$20,500,000
Total	\$350,000,000
<b>Annual Costs</b>	
Pipeline pumps electricity	\$6,000,000
Pipeline operating expense	\$9,200,000
Fuel for CCS	\$5,000,000
Straight Line Annualized Capital Cost for 25 Years	\$14,000,000
Estimated Annual Revenue	-\$3,843,729
Annual Cost	\$30,356,271
CO2 Emissions Reduction from Thermal Oxidizers (100% Load)	107,879
CO2 Emission Increase from boilers for Regenerator	96,012
Net CO2 Emissions Reduction tons/yr	11,867
<b>Average Cost Effectiveness \$/ton</b>	<b>\$2,558</b>

Assume maximum firing for maximum CO2 capture  
 Max CO2 emissions from Thermal Oxidizers (100% load) 12,315 lb/hr per thermal oxidizer  
 CO2 Capture (assuming 100% recovery) - 2 Thermal Oxidizers 107,879 ton/year  
 Total CO2 capture 24,630 lb/hr

Use gas processing data on amine absorber-strippers from Campbell Gas Processing Books  
 From J.M. Campbell & Co Gas Processing Handbook (Table 4.10))  
 Energy Required per lb of CO2 for Regeneration 72000 Btu/hr per gpm of DEA  
 Solvent SG 1.1  
 Factor per lb Solvent 130.8 Btu/lb of solvent  
 Solvent Concentration (Aqueous DEA) 25%  
 Factor per lb of DEA 523 Btu/lb of DEA  
 Moles CO2/Mole DEA 0.2  
 Energy Required per lb of CO2 absorbed 6242.9 Btu/lb CO2

Additional Steam Energy Required for Amine Regenerator 153.8 MMBtu/hr  
 Boiler Efficiency 0.82  
 Fuel Required 187.5 MMBtu/hr  
 CO2 Factor 116.9 lb/MMbtu/hr  
 CO2 Produced 21,921 lb/hr  
 CO2 Produced from boilers for regenerator 96,012 ton/year

### Furnaces CCS Average Cost Effectiveness

<b>Capital Cost</b>	
Pipeline	\$167,000,000
Pipeline Pumps	\$62,500,000
Amine Contactor, Amine Stripper, Reclaimer, Boiler	\$200,000,000
Stack Blowers	\$20,500,000
Total	\$450,000,000
<b>Annual Costs</b>	
Pipeline pumps electricity	\$6,000,000
Pipeline operating expense	\$9,200,000
Fuel for CCS	\$15,000,000
Straight Line Annualized Capital Cost for 25 Years	\$18,000,000
Estimated Annual Revenue	-\$10,396,513
Annual Cost	\$37,803,487
CO2 Emissions Reduction from Furnaces (100% Load)	291,791
CO2 Emission Increase from boilers for Regenerator	-259,692
Net CO2 Emissions Reduction tons/yr	32,099
<b>Average Cost Effectiveness \$/ton</b>	<b>\$1,178</b>

Assume maximum firing for maximum CO2 capture  
 Max CO2 emissions from Furnaces (100% load) 13,324 lb/hr per furnace  
 CO2 Capture (assuming 100% recovery) - 5 furnaces 291,791 ton/year  
 Total CO2 capture 66,619 lb/hr

Use gas processing data on amine absorber-strippers from Campbell Gas Processing Books  
 From J.M. Campbell & Co Gas Processing Handbook (Table 4.10))  
 Energy Required per lb of CO2 for Regeneration 72000 Btu/hr per gpm of DEA  
 Solvent SG 1.1  
 Factor per lb Solvent 130.8 Btu/lb of solvent  
 Solvent Concentration (Aqueous DEA) 25%  
 Factor per lb of DEA 523 Btu/lb of DEA  
 Moles CO2/Mole DEA 0.2  
 Energy Required per lb of CO2 absorbed 6242.9 Btu/lb CO2

Additional Steam Energy Required for Amine Regenerator 415.9 MMBtu/hr  
 Boiler Efficiency 0.82  
 Fuel Required 507.2 MMBtu/hr  
 CO2 Factor 116.9 lb/MMbtu/hr  
 CO2 Produced 59,290 lb/hr  
 CO2 Produced from boilers for regenerator 259,692 ton/year