

US EPA ARCHIVE DOCUMENT

**CHAPTER 4**  
**EPA/NSF ETV**  
**EQUIPMENT VERIFICATION TESTING PLAN**  
**BAG FILTERS AND CARTRIDGE FILTERS FOR THE REMOVAL OF**  
**MICROBIOLOGICAL AND PARTICULATE CONTAMINANTS**

Prepared by:  
NSF International  
789 Dixboro Road  
Ann Arbor, MI 48105

Copyright 2002 NSF International 40CFR35.6450.

Permission is hereby granted to reproduce all or part of this work, subject to the limitation that users may not sell all or any part of the work and may not create any derivative work therefrom. Contact ETV Drinking Water Systems Center Manager at (800) NSF-MARK with any questions regarding authorized or unauthorized uses of this work.

TABLE OF CONTENTS

	<u>Page</u>
<b>1.0 APPLICATION OF THIS VERIFICATION TESTING PLAN .....</b>	<b>4-5</b>
<b>2.0 INTRODUCTION .....</b>	<b>4-5</b>
<b>3.0 GENERAL APPROACH.....</b>	<b>4-5</b>
<b>4.0 OVERVIEW OF TASKS.....</b>	<b>4-6</b>
4.1 Task A: Characterization of Feed Water .....	4-6
4.2 Task B: Initial Tests Runs .....	4-6
4.3 Task 1: Verification Testing Runs .....	4-6
4.4 Task 2: Feed Water and Finished Water Quality.....	4-6
4.5 Task 3: Operating Conditions and Treatment Equipment Performance.....	4-6
4.6 Task 4: Microbiological Contaminant Removal.....	4-6
4.7 Task 5: Data Management .....	4-7
4.8 Task 6: QA/QC.....	4-7
<b>5.0 TESTING PERIODS.....</b>	<b>4-7</b>
<b>6.0 DEFINITIONS.....</b>	<b>4-7</b>
6.1 Bag Filter.....	4-7
6.2 Cartridge Filter .....	4-8
6.3 Filtration .....	4-8
6.4 Predisinfection.....	4-8
6.5 Prefiltration.....	4-8
<b>7.0 TASK A: CHARACTERIZATION OF FEED WATER.....</b>	<b>4-8</b>
7.1 Introduction .....	4-8
7.2 Objectives.....	4-8
7.3 Work Plan.....	4-9
7.4 Analytical Schedule.....	4-9
7.5 Evaluation Criteria.....	4-9
<b>8.0 TASK B: INITIAL TEST RUNS .....</b>	<b>4-10</b>
8.1 Introduction .....	4-10
8.2 Objectives.....	4-10
8.3 Work Plan.....	4-10
8.4 Analytical Schedule.....	4-11
8.5 Evaluation Criteria.....	4-11

**TABLE OF CONTENTS (continued)**

		<u>Page</u>
<b>9.0</b>	<b>TASK 1: VERIFICATION TESTING RUNS AND ROUTINE EQUIPMENT OPERATION</b> .....	4-12
9.1	Introduction .....	4-12
9.2	Experimental Objectives .....	4-12
9.3	Work Plan .....	4-12
	9.3.1 Verification Testing Runs .....	4-12
	9.3.2 Routine Equipment Operation .....	4-13
9.4	Schedule .....	4-13
9.5	Evaluation Criteria.....	4-13
<b>10.0</b>	<b>TASK 2: TEST RUNS FOR FEEDWATER AND FINISHED WATER QUALITY</b> .....	4-13
10.1	Introduction .....	4-13
10.2	Experimental Objectives .....	4-14
10.3	Work Plan.....	4-14
	10.3.1 Water Quality Sample Collection .....	4-14
10.4	Analytical Schedule.....	4-15
10.5	Evaluation Criteria.....	4-16
<b>11.0</b>	<b>TASK 3: DOCUMENTATION OF OPERATING CONDITIONS AND TREATMENT EQUIPMENT PERFORMANCE</b> .....	4-16
11.1	Introduction .....	4-16
11.2	Objectives .....	4-16
11.3	Work Plan.....	4-17
11.4	Schedule .....	4-17
11.5	Evaluation Criteria.....	4-18
<b>12.0</b>	<b>TASK 4: MICROBIOLOGICAL CONTAMINANT REMOVAL</b> .....	4-18
12.1	Introduction .....	4-18
12.2	Experimental Objectives .....	4-19
12.3	Work Plan.....	4-19
	12.3.1 Seeding Technique.....	4-19
	12.3.2 Electronic Particle Counting .....	4-19
	12.3.3 Microspheres.....	4-20
	12.3.4 Organisms Employed for Challenge Tests.....	4-21
12.4	Analytical Schedule.....	4-22
	12.4.1 Particle Counting .....	4-22
	12.4.2 Microsphere Samples.....	4-22
	12.4.3 Microbiological Samples .....	4-23
12.5	Evaluation Criteria.....	4-24

**TABLE OF CONTENTS (continued)**

	<u>Page</u>
<b>13.0 TASK 5: DATA MANAGEMENT</b> .....	4-24
13.1 Introduction .....	4-24
13.2 Experimental Objectives .....	4-24
13.3 Work Plan.....	4-25
13.3.1 Data Management .....	4-25
13.3.2 Statistical Analysis.....	4-26
<b>14.0 TASK 6: QA/QC</b> .....	4-26
14.1 Introduction .....	4-26
14.2 Experimental Objectives .....	4-26
14.3 Work Plan.....	4-26
14.4 Daily QA/QC Verifications .....	4-27
14.5 QA/QC Verifications Performed Every Two Weeks .....	4-27
14.6 QA/QC Verifications for Each Test Period.....	4-27
14.7 On-Site Analytical Methods .....	4-27
14.7.1 pH.....	4-27
14.7.2 Temperature .....	4-27
14.7.3 Color (Optional Parameter).....	4-28
14.7.4 Turbidity Analysis .....	4-28
14.7.4.1 Bench-Top Turbidimeters .....	4-28
14.7.4.2 In-Line Turbidimeters .....	4-29
14.7.5 Particle Counting .....	4-29
14.7.5.1 Bench-Top Particle Counters .....	4-29
14.7.5.2 In-Line Particle Counter.....	4-31
14.8 Chemical and Biological Samples Shipped Off-Site for Analyses .....	4-32
14.8.1 Organic Parameter: Total Organic Carbon and UV <sub>254</sub> (UV is an Optional Parameter).....	4-32
14.8.2 Microbial Parameters: Total Coliform (Optional) and Algae.....	4-32
14.8.3 Inorganic Samples .....	4-32
14.9 Microspheres .....	4-33
<b>15.0 OPERATION &amp; MAINTENANCE</b> .....	4-33
15.1. Maintenance .....	4-33
15.2 Operation.....	4-34
<b>16.0 REFERENCES</b> .....	4-35

**LIST OF TABLES**

Table 1. Generic Schedule for Verification Testing .....	4-36
Table 2. Water Quality Sampling and Measurement Schedule .....	4-37
Table 3. Analytical Methods.....	4-38
Table 4. Cartridge Filtration and Bag Filtration Equipment Operating Data .....	4-39

## 1.0 APPLICATION OF THIS VERIFICATION TESTING PLAN

This document is the ETV Testing Plan for evaluation of water treatment equipment utilizing bag filters or cartridge filters. This Testing Plan is to be used as a guide in the development of the Product-Specific Test Plan for testing bag filtration or cartridge filtration equipment, within the structure provided by the document, "EPA/NSF ETV Protocol For Equipment Verification Testing For Physical Removal of Microbiological And Particulate Contaminants: Requirements For All Studies."

In order to participate in the equipment verification process for bag or cartridge filtration, the equipment Manufacturer shall employ the procedures and methods described in this test plan and in the referenced ETV Protocol Document as guidelines for the development of the Product-Specific Test Plan. The procedures and methods shall generally follow those Tasks related to Verification Testing that are outlined herein, with changes and modifications made for adaptations to specific bag filtration or cartridge filtration equipment. At a minimum, the format of the procedures written for each Task should consist of the following sections:

- Introduction;
- Objectives;
- Work Plan;
- Analytical Schedule;
- Evaluation Criteria.

Each Product-Specific Test Plan shall include Tasks 1 through 6 as described later in this document.

## 2.0 INTRODUCTION

This Equipment Verification Testing Plan is applicable to the testing of water treatment equipment utilizing bag filtration equipment or cartridge filtration equipment. Two phases of testing are discussed. The first phase is Initial Operations, which consists of a series of tests that will be used by the Manufacturer to determine the optimum treatment scheme and most appropriate testing schedule at the specific geographical location or locations where testing is carried out. The second phase is Verification Testing, which will evaluate performance of the equipment under different raw water quality conditions. Verification Testing will be done during time periods when the source water or feed water quality is appropriate for testing the full range of water quality conditions that need to be evaluated. Development and execution of well-documented testing covering a wide range of water quality has a better chance of minimizing subsequent on-site testing which states may require before approving use of the equipment at specific locations.

## 3.0 GENERAL APPROACH

Testing of equipment covered by this Verification Testing Plan will be conducted by an NSF-qualified Testing Organization that is selected by the Manufacturer. Water quality analytical work to be carried out as a part of this Verification Testing Plan will be contracted with a state-certified or third party- or EPA-accredited analytical laboratory.

## 4.0 OVERVIEW OF TASKS

The following section provides a brief overview of the recommended tasks that may be included in Initial Operations and of the required and optional tasks to be included in the bag filtration and cartridge filtration Verification Testing program. Tasks A and B are sequential tasks done before Verification Testing. Tasks 1 through 6 are to be done during Verification Testing and have overlapping time frames.

### 4.1 Task A: Characterization of Feed Water

The objective of this Initial Operations task is to obtain a chemical, biological and physical characterization of the feed water. A brief description of the watershed that provides the feedwater shall be provided, to aid in interpretation of feedwater characterization.

### 4.2 Task B: Initial Tests Runs

During Initial Operations, a Manufacturer may choose to evaluate equipment operation and determine the treatment conditions that result in effective treatment of the feed water. During this task, an inspection of field operations and analytical procedures will be carried out. Following the inspection, testing for variability in performance of bags or cartridges shall be undertaken.

### 4.3 Task 1: Verification Testing Runs

Water treatment equipment shall be operated for a minimum of 30-days during each of one or more testing periods to collect data on equipment performance and water quality for purposes of performance verification.

### 4.4 Task 2: Feed Water and Finished Water Quality

During each day of Verification Testing, feed water and treated water samples shall be collected, and appropriate sample analysis shall be undertaken. If pre-filtration clarification equipment is used, its effect on water quality shall be documented.

### 4.5 Task 3: Operating Conditions and Treatment Equipment Performance

During each day of Verification Testing, operating conditions and performance of the water treatment equipment shall be documented including filtration rate and rate of filter head loss gain. If pre-filtration equipment is used, the equipment shall be described, and the operating conditions shall be documented.

### 4.6 Task 4: Microbiological Contaminant Removal

The objective of this task is to evaluate removal of microbiological contaminants or surrogates during Verification Testing by measuring removal of *Cryptosporidium* oocysts or of protozoan-sized particles seeded in the feed water, or by undertaking a combination of the above techniques.

#### 4.7 Task 5: Data Management

The objectives of this task are to establish an effective field protocol for data management at the field operations site and for data transmission between the Testing Organization and the NSF for data obtained during the Verification Testing and to develop statistical analysis of certain test data.

#### 4.8 Task 6: QA/QC

An important aspect of Verification Testing is the protocol developed for quality assurance and quality control. The objective of this task is to assure accurate measurement of operational and water quality parameters during bag filtration or cartridge filtration equipment Verification Testing.

### 5.0 TESTING PERIODS

The required tasks in the Verification Testing Plan (Tasks 1 through 6) are designed to be carried out over one or more 30-day periods, not including mobilization, start-up, and Initial Operations. Additional verification testing periods may be necessary to verify the manufacturer's objectives, such as in the treatment of surface water where additional testing during each season may assist in verifying an objective. For systems treating solely groundwater or surface waters of consistent quality due to pre-treatment, one verification testing period may be sufficient. If one verification testing period is selected, the feed water should represent the worst-case concentrations of contaminants which can verify the manufacturer's objectives. For example, a good challenge for a bag filter or cartridge filter would be a testing period during which the feedwater exhibits the highest turbidity the equipment is capable of handling and/or algal blooms. Although one testing period satisfies the minimum requirement of the ETV Program, manufacturers are encouraged to use additional testing periods to cover a wider range of water quality conditions.

Verification testing periods consist of continued evaluation of the treatment system using the pertinent treatment parameters defined in Initial Operations. Performance and reliability of the equipment shall be tested during verification testing periods at a minimum of 30 days. The purpose of the 30 day minimum test period is to operate the equipment and evaluate the performance under a range of circumstances including installation of new bags or cartridges and attainment of terminal headloss.

A schedule describing the duration and initiation of each of the above tasks is provided in Table 1.

### 6.0 DEFINITIONS

Definitions that apply for bag filtration and cartridge filtration processes include:

**6.1 Bag Filter:** A non-rigid, disposable, fabric filter in which flow generally is from the inside of bag to the outside. One or more filter bags are contained within a pressure vessel designed to facilitate rapid change of the filter bags when the filtration capacity has been used up. Bag filters generally do not employ any chemical coagulation, if pretreatment is employed. For these filters, pretreatment is likely to consist of prefiltration or predisinfection. The pore sizes in the filter bags designed for protozoa removal generally are small enough to remove protozoan cysts and oocysts but large enough that bacteria, viruses and fine colloidal clays would pass through.



**6.2 Cartridge Filter:** A rigid or semi-rigid, disposable, self-supporting filter element in which flow generally is from the outside of the cartridge to the inside. One or more filter cartridges are contained within a pressure vessel designed to facilitate rapid change of the cartridges when the filtration capacity has been used up. Cartridge filters generally do not employ any chemical coagulation, if pretreatment is employed. For these filters, pretreatment is likely to consist of prefiltration or predisinfection. The pore sizes in the filter cartridges designed for protozoa removal generally are small enough to remove protozoan cysts and oocysts but large enough that viruses and fine, sub-micron colloidal clays would pass through.

**6.3 Filtration:** A process for removing particulate matter from water by passage through porous media.

**6.4 Predisinfection:** Disinfection done at the beginning of treatment. Some regulatory agencies may require predisinfection to retard microbial growth on the bag or cartridge filters.

**6.5 Prefiltration:** A first-stage filtration process sometimes used ahead of bag filters or cartridge filters. Prefilters generally do not employ chemical pretreatment, but are instead intended to remove coarser particulate matter, thus prolonging the life of the bag filter or cartridge filter being used to remove protozoan cysts or oocysts.

## 7.0 TASK A: CHARACTERIZATION OF FEED WATER

### 7.1 Introduction

This Initial Operations task is needed to determine if the chemical, biological and physical characteristics of the feed water are appropriate for the bag filtration or cartridge filtration equipment to be tested. This task should be undertaken with great care, because of the limited capability of bag filters and cartridge filters to remove fine colloidal clays that cause turbidity in many surface waters and because feed waters having high concentrations of particulate matter such as algae, particles consisting of plant material, or sediment can rapidly clog bag filters and cartridge filters, necessitating replacement of the clogged filters.

If the source water used as feed water for the testing program has an excessive amount of the fine turbidity-causing particles, the bag filtration or cartridge filtration equipment may not be able to attain sufficient turbidity removal. Because bag filters and cartridge filters do not remove viruses, the entire burden of virus control falls on the disinfection process when these filters are used for water treatment. Excessive turbidity in filtered water could present problems in attaining effective disinfection and would be a likely cause for rejection of bag filters or cartridge filters by drinking water regulators.

If the source water used as feed water consistently has a very low turbidity and very low concentration of algae and other particulate matter, drinking water regulators may be reluctant to approve cartridge filters or bag filters for applications in which the source water turbidity or particulate matter concentration is higher (Alaska Department of Environmental Conservation, 1994). The feedwater quality chosen for Verification Testing can influence both performance of the filtration equipment and the potential for acceptance of testing results by state regulatory agencies.

## 7.2 Objectives

The objective of this task is to obtain data from one or more years for the chemical, biological, and physical characterization of the source water or the feed water that will be entering the treatment system being tested. Factors of particular interest include conditions that affect bag filter and cartridge filter cycle lengths, such as turbidity in runoff events following heavy rainfall or snowmelt, or algae blooms.

## 7.3 Work Plan

This task can be accomplished by compiling data obtained from third party sources (i.e. USGS, USEPA, State Laboratories, Municipal Laboratories). The specific parameters needed to characterize the water will depend on the equipment being tested but information on the following characteristics should be compiled:

- Turbidity, Algae, Temperature, and pH
- Total Coliform, Total Alkalinity, Hardness, and True Color
- TSS

Sufficient information shall be obtained to illustrate the timing and degree of variations expected to occur in these parameters that will be measured during Verification Testing. This information will be compiled and shared with NSF so NSF and the Testing Organization can determine the adequacy of the data for use as the basis to make decisions on the testing schedule. Failure to adequately characterize the feed water (source water) could result in testing at a site later deemed inappropriate, so the initial characterization will be important to the success of the testing program.

A brief description of the watershed that provides the feedwater shall be provided, to aid in interpretation of feedwater characterization. The watershed description should include a statement of the approximate size of the watershed, a description of the topography (i.e. flat, gently rolling, hilly, mountainous) and a description of the kinds of human activities that take place (i.e. mining, manufacturing, cities or towns, farming) or animal activities with special attention to potential sources of pollution that might influence feed water quality. The nature of the water source, such as stream, river, lake, or man-made reservoir, should be described as well.

## 7.4 Analytical Schedule

In many cases, sufficient water quality data may already exist to permit making a determination of the suitability of a source water for use as feed water in a bag filtration and cartridge filtration Verification Testing program.

## 7.5 Evaluation Criteria

Feed water quality will be evaluated in the context of the Manufacturer's statement of performance objectives. If the turbidity of the feed water is substantially greater than 1 nephelometric turbidity unit (ntu) and periodically exceeds 5 ntu, producing filtered water with an acceptable turbidity may be difficult. The feed water should challenge the capabilities of the equipment but should not be beyond the range of water quality suitable for treatment by the equipment in question.

## **8.0 TASK B: INITIAL TEST RUNS**

### **8.1 Introduction**

During Initial Operations, a Manufacturer may choose to evaluate equipment operation and determine the treatment conditions that result in effective treatment of the feed water. This is a recommended portion of the Initial Operations task and may occur during each of the periods in which Verification Testing is to be done. Initial test runs are required before the start of the first period of Verification Testing so an NSF field inspection of equipment operations and sampling and field analysis procedures can be carried out. After the field inspection, simultaneous testing of multiple bags or cartridges is required before the first period of verification testing so performance variability of bags or cartridges within one lot or between manufacturing lots can be evaluated.

### **8.2 Objectives**

One objective of these test runs is to determine the proper approach for treatment of the feedwater during Verification Testing. Treatment requirements may be different for feedwaters from different test sites or for the feedwater from the same site at different times of testing. Therefore, conducting initial test runs for each testing period is strongly recommended. Some source waters used as feedwater may require prefiltration to remove coarse particulate matter, as a means of extending the life of the bag filters or cartridge filters that will be used for the control of microorganisms. Testing may also be needed to demonstrate the level of filtered water turbidity that the equipment can produce at the test site.

A second objective of initial test runs is to operate the equipment as it would be operated during Verification Testing, and to conduct sampling and analysis for purposes of a field inspection.

A third objective is to set up and operate filters to assess variability of filter bags or filter cartridges within one manufacturing lot and among three different manufacturing lots.

### **8.3 Work Plan**

Initial tests for bag filtration and cartridge filtration can be conducted using the filtration equipment that would be used for Verification Testing, so an assessment could be made to determine whether prefiltration might be needed during verification testing. During exploratory tests, filters can be operated until terminal headloss is reached or until sufficient data are collected to facilitate making reliable projections on the total volume of water that could be filtered through a filter bag or cartridge before it clogs and must be replaced.

Before the first period of Verification Testing, simultaneous testing of three filters from the same lot and receiving feed water from a single source, shall be carried out for 10 days. Then the Field Testing Organization shall change out the filter bags or cartridges and replace them with one bag or cartridge from the first lot tested and with two other bags or cartridges from two different lots. Following the change of cartridges or bags, another 10 days of simultaneous testing shall be done with treatment of feed water from a single source. All filters shall be operated at the same rate of flow except for reductions in flow caused by head loss.

During both of the 10 day testing periods, each filter shall be operated for 23 hours and stopped for 1 hour during each of the 10 days of operation. If a filter bag or cartridge fails due to terminal head

loss or turbidity breakthrough, it shall be replaced by another bag or cartridge from the same lot and testing shall continue until the 10 days are concluded.

The testing for water quality shall focus on turbidity and particle counting only, with no microbiological sampling done for detection of differences between bags or cartridges, to obtain data using a sensitive monitoring technique, but at the same time minimizing the monitoring costs. A single particle counter equipped with a portable grab sampler device can obtain continuous samples sequentially from three different filters. In a similar manner, a single flow-trough turbidimeter can be used to sequentially sample filtered water from three filters. Sampling filtered water from each filter for 20 minutes during each hour would provide for collecting one set of data from each filter for each hour during a work day, and this would yield about 80 data points for each filter in a 10 day period. Appropriate statistical analyses shall be carried out to assess the differences in performance among three bags or cartridges of the same lot and among three bags or cartridges from three different lots. Other data collected shall include rate of flow and head loss. Raw water particle count and turbidity data may be helpful in assessing filter performance.

#### **8.4 Analytical Schedule**

Because these runs are being conducted to define operating conditions for Verification Testing, a strictly defined schedule for sampling and analysis does not need to be followed. Adhering to the schedule for sampling and analysis to be followed during Verification Testing would be wise, however, so the operator can gain familiarity with the time requirements that will be applicable later on in the test program. Also, during the Initial Operations phase, NSF will be conducting an initial on-site inspection of field operations, sampling activities, and on-site sample analysis. The sampling and analysis schedule for Verification Testing shall be followed during the on-site inspection. In addition, the testing of three filter bags from one lot followed by the testing of three bags from three lots shall not begin until after the on-site inspection of field operations has been conducted and operating procedures, turbidity analysis, and particle counting have been deemed acceptable. During each of the days in which variability testing is done, at least 8 samples of filtered water from each filter shall be analyzed for turbidity and particle count, with sampling from each filter carried out over at least an 8 hour time span.

#### **8.5 Evaluation Criteria**

The Manufacturer should evaluate the data produced during the Initial Operations to determine if the water treatment equipment performed so as to meet or exceed expectations based on the statement of performance objectives with regard to water quality. If the performance was not as good as the statement of performance objectives, the Manufacturer may wish to conduct more Initial Operations or to cancel the testing program. In addition, the initial test run results on expected water production per individual filter bag or filter cartridge may provide guidance regarding the need for prefiltration ahead of the bag filtration or cartridge filtration equipment to be operated during Verification Testing.

After the variability testing of multiple bags or cartridges has been completed, the Field Testing Organization shall use the turbidity data and the particle count data collected during the variability testing to calculate 95% confidence intervals as described in "EPA/NSF ETV Protocol For Equipment Verification Testing For Physical Removal of Microbiological And Particulate Contaminants: Requirements For All Studies." The manufacturer is encouraged to review the variability in performance of bags or cartridges from the same lot and the variability in performance

of bags or cartridges from three different lots. If the variability is so great that both successful performance and performance failures occurred during simultaneous testing of multiple bag or cartridge filters, the manufacturer may wish to consider whether it is appropriate to continue with Verification Testing.

## **9.0 TASK 1: VERIFICATION TESTING RUNS AND ROUTINE EQUIPMENT OPERATION**

### **9.1 Introduction**

Water treatment equipment employing bag filtration or cartridge filtration shall be operated for Verification Testing purposes, with the approach to treatment based on the results of the Initial Operations testing.

### **9.2 Experimental Objectives**

The objective of this task is to operate the treatment equipment provided by the Manufacturer for periods of 30 days or longer and to evaluate equipment performance under a range of circumstances including installation of new bags or cartridges and attainment of terminal head loss.

### **9.3 Work Plan**

#### **9.3.1 Verification Testing Runs**

The Verification Testing Runs in this task consist of continued evaluation of the treatment system, using the most successful treatment parameters defined in Initial Operations. To obtain a perspective on the overall performance of the equipment, one or more Verification Testing periods, each lasting for a minimum of 30 days, are anticipated for evaluating the performance of a treatment system. Verification Testing shall be conducted under conditions likely to provide a suitable range of feed water quality for testing purposes. During each testing period, Tasks 1 through 6 shall be conducted simultaneously.

Testing over a range of feed water quality is recommended because of the differences in water quality that occur on a seasonal basis or at different locations. For bag filtration and cartridge filtration treatment equipment, factors that can influence treatment performance include:

- high turbidity, often occurring in spring, encountered in rivers carrying a high sediment load or in surface waters during periods of high runoff resulting from heavy rains or snowmelt
- algae, which may exhibit blooms on a seasonal basis in spring, summer or fall
- lake or reservoir turnover, if this results in bottom sediments being suspended and carried up closer to the surface where they enter the source water (feedwater) intake

It is highly unlikely that all of the above problems would occur in a surface water during a single testing period, and this results in the requirement for multiple testing periods or multiple sites or both to capture critical events that affect water quality.

### 9.3.2 Routine Equipment Operation

If the water treatment equipment is being used for production of potable water, in the time intervals between verification runs, routine operation for water production is anticipated. In this situation, the operating and water quality data collected and furnished to the SDWA primacy agency shall also be supplied to the NSF-qualified Testing Organization.

## 9.4 Schedule

During Verification Testing, water treatment equipment shall be operated for a minimum of 30 days. Bag filtration or cartridge filtration treatment equipment shall be operated from start-up until terminal head loss is attained or until the turbidity performance objective of the Manufacturer is not met for 8 hours. During this period of time, the filtration equipment shall be operated for 23 hours and turned off for one hour, for each day after the first day of operation. The one-hour shutdown shall be done to simulate the on-off operating mode that may be encountered in many small systems, while the 23 hours of operation provides the opportunity for the FTO to log close to the maximum number of hours of equipment operation available each day, thus helping to minimize the total number of days of operation needed to attain terminal head loss. When terminal head loss is attained, the clogged bag or cartridge shall be removed and replaced with a new one, and operation shall resume. The duration of each filter run from initial start to filter clogging and the number of gallons of water produced per square foot (or cubic meters of water produced per square meter) of filter area or the volume of water produced by a specified bag or cartridge shall be recorded in the operational results.

During routine equipment operation, the water treatment equipment should be operated in a manner appropriate for the needs of the water system.

## 9.5 Evaluation Criteria

The goal of this task is to operate the equipment for the 30-day period, including time for changing prefilters or bag or cartridge filters and other necessary operating activities, during Verification Testing. Data shall be provided to substantiate the operation for 30 days or more.

## 10.0 TASK 2: TEST RUNS FOR FEEDWATER AND FINISHED WATER QUALITY

### 10.1 Introduction

Surface waters of high quality are the only surface waters appropriate for treatment by bag filtration and cartridge filtration equipment. Characterization of the feed water is very important, as feed water quality can strongly influence the performance of this equipment. Bag filters and cartridge filters function by straining, so a mat or cake builds up on the filter surface and in the pores of the filter medium. If the materials being removed are not compressible, such as hard, mineral materials, the build-up of this cake may not hinder filtration seriously. On the other hand, removal of compressible particles such as algae or fragments of biological matter can cause the filter to become blinded. Because filtration of some types of particles can blind bag and cartridge filters, they are appropriate only for high quality waters. Turbidity of a source water may not be an adequate indicator of its suitability for treatment by these filters. The volume of water that can be filtered could vary by a factor of ten fold or greater for water of a given turbidity, depending on the nature of the particulate

matter in the raw water because turbidity cannot indicate whether particles are compressible or incompressible.

As always in Verification Testing, characterization of the filtered water is very important. Water quality data shall be collected for the feedwater and filtered water as shown in Table 2, during Verification Testing. At a minimum, the required sampling schedule shown in Table 2 shall be observed by the Testing Organization on behalf of the Manufacturer. Water quality goals and target removal goals for the water treatment equipment shall be recorded in the Product-Specific Test Plan in the statement of objectives.

## 10.2 Experimental Objectives

A list of the minimum number of water quality parameters to be monitored during equipment verification testing is provided in the Analytical Schedule section below and in Table 2. The actual water quality parameters selected for testing shall be stipulated by the Manufacturer in the Product-Specific Test Plan and shall include all those necessary to permit verification of the statement of performance objectives. If the water being filtered tends to cause rapid increases in head loss, efforts should be made to identify the nature of the particulate matter that is causing the rapid clogging. If prefiltration is used, the performance of the prefilter or prefilters with respect to water quality must also be documented. Without such documentation the range of water quality for which bag filtration or cartridge filtration equipment may be accepted could be considerably more restricted.

The characterization of feed water is intended to provide sufficient information to enable State drinking water regulators to compare the quality of the feed water used in Verification Testing with the quality of source water at a site where the use of the equipment may be proposed.

## 10.3 Work Plan

The manufacturer will be responsible for establishing the filtration equipment operating parameters, on the basis of the initial test runs. The bag filtration or cartridge filtration equipment shall be operated as described in Task 1, Section 9.4, Schedule. If terminal head loss is reached, the filter bag (or bags) or filter cartridge (or cartridges) shall be replaced with new ones, and filtration operations shall be resumed and continued until the end of the 30-day period.

Many of the water quality parameters described in this task will be measured on-site by the Field Testing Organization. Analysis of the remaining water quality parameters will be performed by a state-certified or third party- or EPA-accredited analytical laboratory. The methods to be used for measurement of water quality parameters in the field will be described in the Analytical Methods section below and in Table 3. The analytical methods utilized in this study for on-site monitoring of feedwater and filtered water qualities are described in Task 6, Quality Assurance/Quality Control (QA/QC). Where appropriate, the *Standard Methods* reference numbers for water quality parameters are provided for both the field and laboratory analytical procedures. One analytical procedure that is not required but which might prove helpful if excessive clogging of the filters is encountered is the Microscopic Particulate Analysis (MPA) for Filtration Plant Optimization (EPA 910-R-96-001).

### 10.3.1 Water Quality Sample Collection

Water quality data shall be collected at regular intervals during each period of filtration testing, as noted in this section. Additional sampling and data collection may be performed

at the discretion of the Manufacturer. Sample collection frequency and protocol shall be defined by the Manufacturer in the Product-Specific Test Plan.

In the case of water quality samples that will be shipped to the state-certified or third party- or EPA-accredited analytical laboratory for analysis, the samples shall be collected in appropriate containers (containing preservatives as applicable) prepared by the state-certified or third party- or EPA-accredited analytical laboratory. These samples shall be preserved, stored, shipped and analyzed in accordance with appropriate procedures and holding times, as specified by the analytical laboratory.

#### 10.4 Analytical Schedule

During Verification Testing for bag filtration and cartridge filtration treatment equipment, the feedwater (raw water) quality and filtered water quality shall be characterized by measurement of the following water quality parameters:

- temperature (daily)
- pH (daily)
- total alkalinity (desired weekly but optional)
- hardness (desired weekly but optional)
- total organic carbon (desired weekly but required only once per test period)
- iron (once per test period if less than 0.3 mg/L, or weekly if 0.3 mg/L or greater in feed water)
- manganese (once per test period if less than 0.05 mg/L, or weekly if 0.05 mg/L or greater in feed water)
- algae, number and species (weekly if no pre-filtration used; three times per week if pre-filtration used; three times per week if the pressure drop [head loss] across the bag filter or cartridge filter increases in one day's time by more than 5 percent of the total head loss initially available)
- UV<sub>254</sub> absorbance (desired weekly but optional)
- true color (desired weekly but optional)
- total coliform bacteria (desired twice per week but optional)
- turbidity (every four hours or continuous for feedwater; continuous for filtered water; and at shutdowns and startups as described in Section 12.5)
- particle counts (see Task 4)

Any parameter that is part of the Manufacturer's performance objective is not considered optional; the recommended frequency shall be the minimum frequency of sampling. If grab samples are used for feed water turbidity measurements, two samples for feed water turbidity shall be collected during the 30 minutes prior to the one-hour shutdown, and two samples for feed water turbidity shall be collected during the 30 minutes after start-up following the one-hour shutdown.



If prefiltration is done to condition the feed water for treatment by bag filtration or by cartridge filtration, the water discharged from the prefiltration process shall be sampled and the following water quality parameters shall be measured:

- iron (same as above)
- manganese (same as above)
- algae, number and species (three times per week)
- turbidity (continuous)
- particle counts (see Task 4)
- TOC (desired weekly but required only once per test period)
- true color and UV<sub>254</sub> absorbance (desired weekly but optional)

Turbidity of filtered water shall be measured and recorded using a continuous, flow-through turbidimeter. Turbidity of feed water (before seeding of microorganisms or microspheres) shall be measured continuously using a flow-through turbidimeter or at intervals of not more than four (4) hours if a bench model turbidimeter is used for grab samples. On a daily basis a bench model turbidimeter shall be used to check the continuous turbidimeter readings.

The above water quality parameters are listed to provide verification report readers with background data on the quality of the feed water being treated and data on the quality of the filtered water. These data are to be collected to enhance the usefulness of the Verification Testing data to a wide range of verification report readers.

### **10.5 Evaluation Criteria**

Evaluation of water quality in this task is related to any general water quality capabilities indicated by the Manufacturer.

- Turbidity removal equals or exceeds goals specified by the Manufacturer
- Water quality and removal goals specified by the Manufacturer
- Water quality improvement attained by prefiltration

## **11.0 TASK 3: DOCUMENTATION OF OPERATING CONDITIONS AND TREATMENT EQUIPMENT PERFORMANCE**

### **11.1 Introduction**

During each day of Verification Testing, operating conditions shall be documented. This shall include descriptions of treatment processes used and their operating conditions. In addition, the performance of the water treatment equipment shall be documented, including rate of filter head loss gain, water pressure at the inlet to the bag filter or cartridge filter pressure vessel, length of filter run and terminal head loss. Operating conditions are likely to be evaluated in great detail by state reviewers and are an important aspect related to approval of equipment.

### **11.2 Objectives**

The objective of this task is to accurately and fully document the operating conditions that applied during treatment, and the performance of the equipment. This task is intended to result in data that

describe the operation of the equipment and data that can be used to develop cost estimates for operation of the equipment.

### 11.3 Work Plan

A complete description of each process shall be given. Data on the filter shall be provided and shall include the following:

- flow capacity
- nominal pore rating of filter bag or filter cartridge and the method used to determine this pore rating
- number of filter bags or filter cartridges housed within the pressure vessel
- maximum operating pressure of filter vessel
- volume of filter vessel
- if any pre-filtration equipment is used, a complete description of the pre-filtration equipment shall be provided that conveys the same types of the information required for bag filtration or cartridge filtration equipment.

In addition, system reliability features including redundancy of components, shall be described. Spatial requirements for the equipment (footprint) shall be stated. Some of the above requirements might be met by providing manufacturer's engineering drawings of the equipment used in Verification Testing.

During each day of Verification Testing, treatment equipment operating parameters for bag filtration and cartridge filtration will be monitored and recorded on a routine basis. This shall include rate of flow, filtration rate, pressure at filter vessel inlet and outlet, and maximum head loss. Electrical energy consumed by the treatment equipment shall be measured, or as an alternative, the aggregate horsepower of all motors supplied with the equipment could be used to develop an estimate of the maximum power consumption during operation. Performance shall be evaluated to develop data on the number of gallons of water that are treated by each bag or cartridge and on energy needed for operation of the process train being tested.

A daily log shall be kept in which events in the watershed are noted if they could influence source water quality. This includes such things as major storm systems, rainfall, snowmelt, temperature, cloud cover, upstream construction activities that disturb soil, and intermittent operation of hydroelectric generating facilities.

If prefiltration equipment is used, the performance of that equipment shall be documented in the same manner as the bag filtration or cartridge filtration is documented.

Performance of bag filtration and cartridge filtration for removal of turbidity and microorganisms can be strongly influenced by the pore sizes of the bag filter or the cartridge filter. Therefore the manufacturer's specifications on the bag filter or cartridge filter used when turbidity or microorganism data are gathered shall be identified.

### 11.4 Schedule

Table 4 presents the schedule for observing and recording bag filtration and cartridge filtration equipment plant operating and performance data.

## 11.5 Evaluation Criteria

Where applicable, the data developed from this task will be compared to statements of performance objectives. The quantity of water that is produced and meets quality criteria for acceptance will be an important factor in this evaluation.

If no relevant statement of performance capability exists, results of operating and performance data will be tabulated for inclusion in the Verification Report.

## 12.0 TASK 4: MICROBIOLOGICAL CONTAMINANT REMOVAL

### 12.1 Introduction

Removal of microbiological contaminants is a primary purpose of filtration of surface waters. Consequently, the effectiveness of bag filtration and cartridge filtration treatment processes for microbial removal will be evaluated in this task. Assessment of treatment efficacy will be made on the basis of particle counting and removal of polymeric microspheres. Testing for removal of protozoan microorganisms is optional.

The bag filtration and cartridge filtration process removes particles, including microorganisms, in the size range of *Giardia* and *Cryptosporidium* from water by physically straining out the particles and trapping them in the bag filter or cartridge filter. Because particle removal is accomplished primarily by straining out particles from water on the basis of the sizes of the particles and of the pores in the filter, the applicability of surrogate particles depends on their size, shape and pliability, rather than on their biological nature. Thus appropriately sized microspheres could be suitable surrogates for protozoan cysts and oocysts. Bag filtration and cartridge filtration equipment now is produced for purposes of removing the smaller *Cryptosporidium* oocysts, so testing for *Giardia* cyst removal is not needed.

Cysts and oocysts are biological particles without hard shells or skeletons, so they are capable of deforming slightly and squeezing through pores that might seem to be small enough to prevent their passage. In addition, the pore sizes for filter bags and filter cartridges is not absolute, and these filters will have some pores that are both larger and some that are smaller than the nominal size. Therefore they do not provide an absolute cutoff for particles at or slightly larger than their nominal size. For these reasons, microspheres used in challenge tests should be close to or slightly smaller than the smallest size for the protozoan organism for which the microspheres are a surrogate.

Removal of turbidity by bag filtration and cartridge filtration is not synonymous with removal of protozoan organisms because turbidity-causing particles can be much smaller than protozoa. This results in bag filters and cartridge filters being able to remove protozoan-sized particles while passing particles in the size range of bacteria, or the micron-sized and sub-micron-sized particles that cause turbidity. Therefore turbidity removal is not a surrogate for protozoan removal in bag filtration and cartridge filtration.

Use of electronic particle counting to assess protozoan removal would be appropriate only for feed waters containing large numbers of particles in the size range of *Cryptosporidium*. For *Cryptosporidium* oocyst removal, assessment of particle removal in the size range of 3 to 7  $\mu\text{m}$  would be appropriate. For a general evaluation of particle removal capabilities, total particles in the

1 to 15  $\mu\text{m}$  shall also be counted. If sufficient concentrations of appropriately sized particles are not present in the feed water, use of electronic particle counting may not be capable of demonstrating adequately high log removals and therefore microsphere seeding technique described in Section 12.3.1 must be employed.

## 12.2 Experimental Objectives

The objective of this task is to evaluate removal of particles and microbiological contaminants during Verification Testing by measuring removal of microorganisms seeded into the feed water or by assessing removal of polystyrene fluorescent microspheres if *Cryptosporidium* oocysts are not seeded into the feed water.

## 12.3 Work Plan

Task 4 shall consist of particle counting and tests involving seeded *Cryptosporidium* oocysts or seeded microspheres, or of both seeded oocysts and seeded microspheres if the manufacturer chooses to test both.

### 12.3.1 Seeding Technique

The purpose of this task is evaluation of the bag filter or cartridge filter for microorganism removal, so any seeding of *Cryptosporidium* or microspheres shall be done after the feed water has passed prefiltration equipment and just prior to the entry of the water into the bag filtration or cartridge filtration equipment, unless the prefilter and the bag or cartridge filter are designed and sold as a single system having filters in series. During seeding tests, the concentrated suspension of microspheres or oocysts shall be gently stirred to maintain the particles in suspension. The concentrated microspheres shall be suspended in a solution of distilled or deionized water with 0.01% Tween 20. Before each run with seeded microspheres, the holding vessel shall be washed with hot water and laboratory glassware detergent and thoroughly rinsed with tap water or filtered water. The oocyst suspension shall be kept chilled during seeding. Microspheres or oocysts shall be added to the feed water using a variable speed chemical feed pump. Mixing of seeded particles into the feed water shall be done with an in-line mixer that attains a head loss of about 0.3 to 0.5 feet of water during operation.

In order to show a 3-log reduction of either microspheres or oocysts, it is likely that at least  $10^6$  microspheres or oocysts would need to be spiked in a challenge test.

### 12.3.2 Electronic Particle Counting

When an electronic particle counter is used for evaluation of particle removal, particle counts in feed water just before entry into the bag filtration or cartridge filtration equipment shall be measured to determine the concentration of particles before filtration, and particle counts in the filtered water shall be measured. For assessing *Cryptosporidium* oocyst removal and removal of larger organisms, particles in the size range of 3  $\mu\text{m}$  to 7  $\mu\text{m}$  shall be counted. If appropriately sized particles are not present in sufficient densities (concentrations) in the feed water to permit calculation of log removals consistent with the Manufacturer's statement of performance capability, then laboratory enumeration should be done during microsphere

challenge events. For a general evaluation of particle removal capabilities, total particles in the 1 to 15  $\mu\text{m}$  shall also be counted.

### 12.3.3 Microspheres

Evaluation of microsphere removal shall be conducted by measuring the density (or concentration) of microspheres seeded on a continuous basis in the feed water and then measuring the density (or concentration) of microspheres in the filtered water or by determining the number of microspheres added to the feed water in a slug dose and then measuring the total number of microspheres detected in the filtered water. Microspheres used as surrogates for *Cryptosporidium* oocysts shall be 3 to 6  $\mu\text{m}$  in diameter. Microspheres in this size range can be obtained by ordering batches of microspheres in two or more sizes. At least 50% (by number or count) of the microspheres used in challenge tests must be in the 3 to 4  $\mu\text{m}$  size range. *Cryptosporidium* oocysts are considerably smaller than *Giardia* cysts, and a bag filter or cartridge filter capable of attaining a certain degree of removal for *Cryptosporidium* will attain an equal or greater removal of *Giardia*, based on the filtration mechanism being straining or physical blockage of the passage of particles through the filter when all operating conditions are the same.

The number of microspheres used shall be sufficient to permit calculation of log removals that exceed the removal capability as set forth in the Manufacturer's statement of performance objectives. Recovery of microspheres in filtered water provides data for use in calculating definite removal percentages, in contrast to the practice of reporting removals that exceed a specified value based on the detection limit, which would have to be done when no microspheres are detected in filtered water. For testing involving microscopic enumeration, fluorescent microspheres and an optical microscope equipped with ultraviolet illumination shall be used.

If microspheres are seeded into the feed water on a continuous basis, enumeration of microspheres in feed water and filtered water by optical microscopy shall be required.

Two techniques for analysis of water samples containing fluorescent microspheres may be used. One is the method used by Abbaszadegan et al. (1997) for enumeration of *Giardia* cysts and *Cryptosporidium* oocysts, and the other is the method of Li et al. (1997) which they used for enumeration of microspheres.

If the techniques for microsphere sampling and enumeration are based on the research work of Li et al. (1997) which was carried out at the U.S. EPA's research laboratory in Cincinnati, the procedures below shall be followed.

Samples of feed water seeded with microspheres and samples of filtered water shall be filtered through 1  $\mu\text{m}$  pore size, 293 mm diameter polycarbonate membranes. A stainless steel filter manifold shall be used to support the polycarbonate membrane. Volume of water filtered, and the times of initiation and completion of filtration shall be noted. The filter shall be removed from the manifold and placed in a container specified by the analytical laboratory, and refrigerated until shipped to the EPA-accredited analytical laboratory. At the analytical laboratory the microspheres removed from the filter with a laboratory squeegee and by washing with about 200 mL of 0.01% Tween 20. The liquid and particulate matter removed from the membrane shall be concentrated to a volume of between 1 and 10 mL by

means of centrifugation for 10 minutes at 1200 x gravity. The volume of the concentrated suspension shall be recorded. Microspheres shall be enumerated using a hemacytometer under a UV microscope at 400 magnification. A minimum of three hemacytometer counts shall be performed for each sample. The volume of suspension examined in the hemacytometer shall be recorded and used to determine the fraction of the original water sample which was ultimately examined under the microscope.

*Standard Methods* states that hemacytometer chambers come with detailed manufacturer's instructions concerning calculations and proper usage. *Standard Methods* contains the precaution that disadvantage of hemacytometers is that the sample must have a very high density of objects being counted in order to yield statistically reliable data. Some exploratory tests may be needed to identify appropriate volumes of treated water to filter through the polycarbonate membrane or appropriate densities (concentrations) of microspheres in the seeded feed water, so that reliable statistics can be attained in filtered water analysis. The total number of microspheres counted in the hemacytometer should be between 30 and 300 to obtain good statistical results without counting overwhelming numbers of microspheres.

If the entire flow stream produced by the bag filtration or cartridge filtration equipment can not be filtered through the 293 mm membrane filter for sampling, a measured portion of the total filtered water flow can be sampled as it is produced, or the entire flow of filtered water from a seeding test can be stored in clean vessel and later filtered through the 293 mm membrane filter at a rate of flow suitable for the membrane filter. If an instantaneous slug dose of microspheres is applied and the entire volume of filtered water is saved in a storage vessel for subsequent membrane filtration as the sampling procedure, a volume of filtered water of at least 20 times the volume of the bag filter or cartridge filter pressure vessel shall be filtered through the bag or cartridge filtration equipment and saved for sampling and analysis.

#### 12.3.4 Organisms Employed for Challenge Tests

Microbiological testing, if done, shall be performed by seeding *Cryptosporidium* oocysts into the feed water and by analyzing for the organism in question in the feed water and in the filtered water.

The oocysts shall be used in densities sufficient to permit calculation of at least 3-log removal, and seeding of microorganisms shall begin at start-up of the treatment equipment. The organism feed suspension will be prepared by diluting the organisms to be seeded into dilution water that is distilled or deionized and disinfectant free. The feed reservoir for the organism suspension shall be made of biologically inert material (i.e., not toxic to the organisms in the suspension.) The reservoir will be mixed continuously throughout the experiment and kept packed in ice in a cooler. The seed suspension will be fed into the feedwater using an adjustable rate chemical feed pump. Mixing of this suspension with the feedwater will be accomplished using an in-line static mixer.

The analytical method required to be used for *Cryptosporidium* oocysts are EPA methods 1622/1623. If changes to the *Cryptosporidium* methods are tested, peer reviewed, evaluated by several laboratories, and then accepted by the U.S. EPA or are published by *Standard Methods*, the improved methods should be followed. Refer to [www.epa.gov/nerlcwww/index.html](http://www.epa.gov/nerlcwww/index.html) for updates.

## 12.4 Analytical Schedule

### 12.4.1 Particle Counting

Analysis of feed water samples by electronic particle counters may be measured on a batch or a continuous basis. If batch measurements are made, they shall be made for at least 8 hours each working day during Verification Testing, with samples collected and analyzed at least once each hour. Filtered water analysis shall be done using flow-through particle counters, equipped with recording capability so data can be collected on a 24-hour-per-day basis during Verification Testing.

In addition to the sampling and analysis for particle counts during continuous operation, particle count data shall be obtained for three feed water samples and for three filtered water samples during the last 30 minutes before the daily shutdown occurs. After the filter has been restarted one hour later, filtered water particle count data shall be obtained for six samples collected at five-minute intervals during the first 30 minutes of operation after restart, and then three samples of feed water shall be analyzed for particle counts as soon as practical. The purpose of this sampling and analysis is to evaluate the effect of stop-start operations that are common in small systems.

On days when challenge tests are not carried out, at least eight feed water samples shall be obtained for particle counting and for purposes of comparison with filtered water so calculation of log removal of particles can be done.

### 12.4.2 Microsphere Samples

Planning a sampling schedule for bag filtration or cartridge filtration equipment may be challenging, as the length of a filter run could exceed the 30 days allotted for intense sampling and analysis called for in Verification Testing runs. If the Initial Test Runs conducted during Task B indicate that evaluating three filter runs during the 30 days of Verification Testing will not be possible because of the long duration of the runs, then three sets of microsphere samples shall be collected at each time when seeding is done during the filter run. This will provide data that can be used for statistical analysis, during each time period when Verification Testing is done.

During each microsphere challenge test run, microspheres shall be seeded for evaluating the performance of a continuously running filter three times during a run: at the start-up of the equipment after a new filter bag or filter cartridge has been installed, near the middle of the run when head loss has approached one half of the recommended terminal head loss, and near the end of the run after head loss has exceeded 90 percent of recommended terminal head loss. In addition, after the seeding challenge and sampling event in the middle of the run has been completed, the filter flow shall be stopped and preparations shall be made for another round of sampling. The filter shall be restarted and sampling shall be done again, to evaluate the effect of stopping and starting a filter that has removed a very large number of microspheres.

The timing for collection of samples shall be different based on whether continuous seeding or slug dose seeding is used. When microspheres are seeded on a continuous basis, microsphere samples shall be collected from the plant influent (feed water after seeding) and

the filter effluent. Samples shall not be collected until the treatment plant has been in operation for a total of 3 theoretical detention times as measured through the filter vessel. For microsphere sampling purposes, the time of operation when 3 filtration vessel detention times have elapsed shall be considered time zero. Four microsphere samples shall be collected, beginning at time zero and at 0.5, 1.0 and 2.0 hours. The exact time of sampling will be recorded so turbidity measurements can be determined at the time of sampling. Volumes of feed water and filtered water to be filtered should be large enough that 30 to 300 microspheres are detected in each seeded feed water sample. Ideally for statistical purposes 30 to 300 microspheres should be detected in each filtered water sample also. If the filtration process is highly efficient for removal of the microspheres, detection of such large numbers in samples of filtered water would not be possible. In such a case, detection of at least 5 microspheres is desirable. If removal is extremely high, detecting 5 or more microspheres in filtered water may not be possible but probably would be indicative of very high log removals of microspheres.

For seeding on a slug dose basis, the number of microspheres in the concentrated suspension shall be based on an analysis of the concentrated suspension before it was dosed. The entire production of filtered water shall be collected for sampling, from the instant of dosing until a volume of filtered water equal to 20 volumes of the filter vessel have been collected. For example, if the filter vessel volume is 40 liters, an 800 liter sample of filtered water shall be collected and then filtered through a membrane filter as described above in the procedure of Li *et al.*

As an alternative to collecting the entire production of filtered water, a side stream of filtered water may be collected for analysis. The entire volume of the side stream shall be filtered through a membrane filter, as described above. This reduces the volume of water that must be filtered through the membrane. In calculation of log removals, the FTO must adjust the number of microspheres seeded into the feed water in proportion to the volume of the side stream as compared to the full flow of the treatment equipment. For instance if the volume of the side stream was only 10 percent of the volume of the full flow treated, the number of microspheres used for calculation of log removals would equal only 10 percent of the total number of microspheres seeded.

Microsphere samples shall be analyzed by an EPA-accredited analytical laboratory.

After the first round of Verification Testing has been done, the results of equipment performance shall be reviewed. If terminal head loss was not approached in the bag filtration or cartridge filtration equipment, it may be desirable to operate the filtration equipment until the filters are approaching terminal head loss and then start another period of Verification Testing with nearly-clogged filters, so challenge testing can be undertaken to evaluate that aspect of filter performance. Failure to do this could cause a serious gap in filter performance data and could have an impact on acceptability of the equipment by state regulators.

#### **12.4.3 Microbiological Samples**

Microbiological samples shall be collected from feed water and filtered water on the same schedule stipulated for microsphere samples.



The Field Testing Organization shall then submit collected water samples to an EPA-accredited analytical laboratory for microbial testing.

## **12.5 Evaluation Criteria**

Performance evaluation shall be conducted in a number of ways, depending on the types of data collected during testing.

Performance of bag filtration and cartridge filtration equipment shall be evaluated in the context of the Manufacturer's statement of performance objectives. Turbidity results will be analyzed to determine the percentage of turbidity data in the range of 0.50 NTU or lower, the percentage between 0.51 NTU and 1.0 NTU, the percentage between 1.0 and 5 NTU, and the percentage that exceeded 5 NTU. The time intervals used for determining filtered water turbidity values shall be the same for all data analyzed, and because continuous turbidimeters are to be used to collect turbidity data, the intervals shall be 1/4, 1/2, or 1 hour. In addition, the highest filtered water turbidity observed each day shall be tabulated. The feed water and filtered water turbidity data collected during the 30 minute periods immediately before and following the one-hour shutdowns shall be presented in tables or graphs.

Electronic particle count data shall be evaluated by calculating the change in total particle count from feed water to filtered water, expressing the change as log reduction. The aggregate of particle counting data obtained during each verification testing period shall be analyzed to determine the median log removal and 95th percentile log removal during that verification testing period. Because of possible complications in conducting electronic particle counts on feed water, 1 to 4 hour time intervals shall be used for analysis of particle counting data for log reduction of particles. In addition, particle count data for filtered water shall be presented as time series data showing trends of particle counts with passage of time. Data shall be presented showing particle counts in filtered water at time intervals no longer than one hour for the 30 days of Verification Testing. The feed water and filtered water particle count data collected during the 30 minute periods immediately before and following the one-hour shutdowns shall be presented in tables or graphs.

Data on the density (concentration) of microspheres or protozoa in feed water and filtered water shall be analyzed by the EPA-accredited analytical laboratory to determine the median log removal and 95th percentile log removal during that verification testing period. This analysis shall be done separately for each filter operating condition: at start-up with a new bag or cartridge, mid-way through a run, and after 85 to 95 percent of terminal head loss has been attained.

## **13.0 TASK 5: DATA MANAGEMENT**

### **13.1 Introduction**

The data management system used in the verification testing program shall involve the use of computer spreadsheet software or manual recording methods, or both, for recording operational parameters for the bag filtration or cartridge filtration equipment on a daily basis.

### **13.2 Experimental Objectives**

One objective of this task is to establish a viable structure for the recording and transmission of field testing data such that the Testing Organization provides sufficient and reliable operational data for

verification purposes. A second objective is to develop a statistical analysis of the data, as described in "EPA/NSF ETV Protocol For Equipment Verification Testing For Physical Removal of Microbiological And Particulate Contaminants: Requirements For All Studies."

### 13.3 Work Plan

#### 13.3.1 Data Management

The following protocol has been developed for data handling and data verification by the Testing Organization. Where possible, a Supervisory Control and Data Acquisition (SCADA) system should be used for automatic entry of testing data into computer databases. Specific parcels of the computer databases for operational and water quality parameters should then be downloaded by manual importation into Excel (or similar spreadsheet software) as a comma delimited file. These specific database parcels will be identified based upon discrete time spans and monitoring parameters. In spreadsheet form, the data will be manipulated into a convenient framework to allow analysis of equipment operation. Backup of the computer databases to diskette should be performed on a monthly basis at a minimum.

In the case when a SCADA system is not available, field testing operators will record data and calculations by hand in laboratory notebooks. (Daily measurements will be recorded on specially-prepared data log sheets as appropriate.) The laboratory notebook will provide carbon copies of each page. The original notebooks will be stored on-site; the carbon copy sheets will be forwarded to the project engineer of the Testing Organization at least once per week. This protocol will not only ease referencing the original data, but offer protection of the original record of results. Operating logs shall include a description of the bag filtration and cartridge filtration equipment (description of test runs, names of visitors, description of any problems or issues, etc.); such descriptions shall be provided in addition to experimental calculations and other items.

The database for the project will be set up in the form of custom-designed spreadsheets. The spreadsheets will be capable of storing and manipulating each monitored water quality and operational parameter from each task, each sampling location, and each sampling time. All data from the laboratory notebooks and data log sheets will be entered into the appropriate spreadsheet. Data entry will be conducted on-site by the designated field testing operators. All recorded calculations will also be checked at this time. Following data entry, the spreadsheet will be printed out and the print-out will be checked against the handwritten data sheet. Any corrections will be noted on the hard-copies and corrected on the screen, and then a corrected version of the spreadsheet will be printed out. Each step of the verification process will be initialed by the field testing operator or engineer performing the entry or verification step.

Each experiment (e.g. each filtration test run) will be assigned a run number which will then be tied to the data from that experiment through each step of data entry and analysis. As samples are collected and sent to state-certified or third party- or EPA-accredited analytical laboratories, the data will be tracked by use of the same system of run numbers. Data from the outside laboratories will be received and reviewed by the field testing operator. These data will be entered into the data spreadsheets, corrected, and verified in the same manner as the field data.

If filter bags or cartridges having different design specifications are used during Verification Testing, each filter bag or cartridge shall be operated for a minimum of 30 days, and the water quality data collected in conjunction with the use of each type of bag or cartridge shall be analyzed and presented separately.

### 13.3.2 Statistical Analysis

Water quality data developed from grab samples collected during filter runs according to the Analytical Schedule in Task 4 of this Test Plan shall be analyzed for statistical uncertainty. The Testing Organization shall calculate 95% confidence intervals for grab sample data obtained during Verification Testing as described in "EPA/NSF ETV Protocol For Equipment Verification Testing For Physical Removal of Microbiological And Particulate Contaminants: Requirements For All Studies."

The statistics developed will be helpful in demonstrating the degree of reliability with which water treatment equipment can attain quality goals. Each of the four conditions described in Task 4 (start of run, middle of run before flow stops, middle of run after flow is stopped and restarted, and near end of run approaching terminal head loss) shall be analyzed separately for 95% confidence intervals. Information on the differences in water quality for the beginning, the middle, and the end of filter runs would be useful in evaluating the effect of installing a new bag or cartridge, and the effect of approaching terminal head loss. Data on microsphere removal in the middle of the run, before and after the filter flow was stopped, can be used to assess the effects of stopping and starting the flow in bag filtration or cartridge filtration equipment.

## 14.0 TASK 6: QA/QC

### 14.1 Introduction

Quality assurance and quality control of the operation of the bag filtration and cartridge filtration equipment and the measured water quality parameters shall be maintained during the Verification Testing program.

### 14.2 Experimental Objectives

The objective of this task is to maintain strict QA/QC methods and procedures during the Equipment Verification Testing Program. When specific items of equipment or instruments are used, the objective is to maintain the operation of the equipment or instructions within the ranges specified by the Manufacturer or by *Standard Methods*. Maintenance of strict QA/QC procedures is important, in that if a question arises when analyzing or interpreting data collected for a given experiment, it will be possible to verify exact conditions at the time of testing.

### 14.3 Work Plan

Equipment flow rates and associated signals should be documented and recorded on a routine basis. A routine daily walk-through during testing will be established to verify that each piece of equipment or instrumentation is operating properly. In-line monitoring equipment such as flow meters, etc. will be checked to confirm that the readout matches with the actual measurement (i.e. flow rate) and that

the signal being recorded is correct. The items listed are in addition to any specified checks outlined in the analytical methods.

#### 14.4 Daily QA/QC Verifications

- In-line turbidimeters flowrates (verified volumetrically over a specific time period)
- In-line turbidimeter readings checked against a properly calibrated bench model
- Batch and in-line particle counters flowrates (verified volumetrically over a specific time period).

#### 14.5 QA/QC Verifications Performed Every Two Weeks

- In-line flow meters/rotameters (clean equipment to remove any debris or biological buildup and verify flow volumetrically to avoid erroneous readings).

#### 14.6 QA/QC Verifications for Each Testing Period

- In-line turbidimeters (clean out reservoirs and recalibrate)
- Differential pressure transmitters (verify gauge readings and electrical signal using a pressure meter)
- Tubing (verify good condition of all tubing and connections, replace if necessary)
- Particle counters (perform microsphere calibration verification)

#### 14.7 On-Site Analytical Methods

The analytical methods utilized in this study for on-site monitoring of raw water and filtered water quality are described in the section below. In-line equipment is recommended for its ease of operation and because it limits the introduction of error and the variability of analytical results generated by inconsistent sampling techniques. In-line equipment is recommended for measurement of turbidity and for particle counting for feed water and is required for measurement of turbidity and for particle counting for filtered water.

##### 14.7.1 pH

Analysis for pH shall be performed according to *Standard Methods* 4500-H<sup>+</sup>. A three-point calibration of the pH meter used in this study shall be performed once per day when the instrument is in use. Certified pH buffers in the expected range shall be used. The pH probe shall be stored in the appropriate solution defined in the instrument manual. Transport of carbon dioxide across the air-water interface can confound pH measurement in poorly buffered waters. If this is a problem, measurement of pH in a confined vessel is recommended to minimize the effects of carbon dioxide loss to the atmosphere.

##### 14.7.2 Temperature

Readings for temperature shall be conducted in accordance with *Standard Methods* 2550. Raw water temperatures shall be obtained at least once daily. The thermometer shall have a scale marked for every 0.1°C, as a minimum, and should be calibrated weekly against a precision thermometer certified by the National Institute of Standards and Technology

(NIST). (A thermometer having a range of  $-1^{\circ}\text{C}$  to  $+51^{\circ}\text{C}$ , subdivided in  $0.1^{\circ}$  increments, would be appropriate for this work.)

### 14.7.3 Color (Optional Parameter)

True color shall be measured with a spectrophotometer at 455 nm, using a Hach Company adaptation of the *Standard Methods* 2120 procedure. Samples shall be collected in clean plastic or glass bottles and analyzed as soon after collection as possible. If samples can not be analyzed immediately they shall be stored at  $4^{\circ}\text{C}$  for up to 24 hours, and then warmed to room temperature before analysis. The filtration system described in *Standard Methods* 2120 C shall be used, and results should be expressed in terms of PtCo color units.

### 14.7.4 Turbidity Analysis

Turbidity analyses shall be performed according to *Standard Methods* 2130 or EPA Method 180.1 with either a bench-top or in-line turbidimeter. In-line turbidimeters shall be used for measurement of turbidity in the filtrate waters, and either an in-line or bench-top may be used for measurement of the feedwater.

During each verification testing period, the bench-top and in-line turbidimeters will be left on continuously. Once each turbidity measurement is complete, the unit will be switched back to its lowest setting. All glassware used for turbidity measurements will be cleaned and handled using lint-free tissues to prevent scratching. Sample vials will be stored inverted to prevent deposits from forming on the bottom surface of the cell.

The Field Testing Organization shall be required to document any problems experienced with the monitoring turbidity instruments, and shall also be required to document any subsequent modifications or enhancements made to monitoring equipment.

**14.7.4.1 Bench-Top Turbidimeters.** Grab samples shall be analyzed using a bench-top turbidimeter. Readings from this instrument will serve as reference measurements throughout the study. The bench-top turbidimeter shall be calibrated within the expected range of sample measurements at the beginning of equipment operation and on a weekly basis using primary turbidity standards of 0.1, 0.5, and 3.0 NTU. Secondary turbidity standards shall be obtained and checked against the primary standards. Secondary standards shall be used on a daily basis to verify calibration of the turbidimeter and to recalibrate when more than one turbidity range is used.

The method for collecting grab samples will consist of running a slow, steady stream from the sample tap, triple-rinsing a dedicated sample beaker in this stream, allowing the sample to flow down the side of the beaker to minimize bubble entrainment, double-rinsing the sample vial with the sample, carefully pouring from the beaker down the side of the sample vial, wiping the sample vial clean, inserting the sample vial into the turbidimeter, and recording the measured turbidity.

For the case of cold water samples that cause the vial to fog preventing accurate readings, allow the vial to warm up by submersing partially into a warm water bath for approximately 30 seconds.

**14.7.4.2 In-Line Turbidimeters.** In-line turbidimeters are required for filtered water monitoring during verification testing and must be calibrated and maintained as specified in the manufacturer's operation and maintenance manual. It will be necessary to verify the in-line readings using a bench-top turbidimeter at least daily; although the mechanism of analysis is not identical between the two instruments the readings should be comparable. Should these readings suggest inaccurate readings then all in-line turbidimeters should be recalibrated. In addition to calibration, periodic cleaning of the lens should be conducted, using lint-free paper, to prevent any particle or microbiological build-up that could produce inaccurate readings. Periodic verification of the sample flow rate should also be performed using a volumetric measurement. Instrument bulbs should be replaced on an as-needed basis. It should also be verified that the LED readout matches the data recorded on the data acquisition system, if the latter is employed.

### 14.7.5 Particle Counting

In-line particle counters shall be employed for measurement of particle concentrations in filtrate waters. However, either a bench-top or an in-line particle counter may be used to measure particle concentrations in the feedwater, concentrate (where applicable) and pretreated waters (where applicable). Laser light scattering or light blocking instruments are recommended for particle counting during verification testing. However, other types of counters such as Coulter counters or Elzone counters may be considered for use if they can be configured to provide continuous, in-line monitoring for the filtrate product water stream. The following discussion of operation and maintenance applies primarily for use of laser light blocking instruments.

The following particle size ranges (as recommended by the AWWARF Task Force) shall be monitored by both in-line and bench-top analytical instruments during the verification testing:

- 2-3  $\mu\text{m}$
- 3-5  $\mu\text{m}$
- 5-7  $\mu\text{m}$
- 7-10  $\mu\text{m}$
- 10-15  $\mu\text{m}$
- > 15  $\mu\text{m}$

The Field Testing Organization shall be required to document any problems experienced with the monitoring particle counting instruments, and shall also be required to document any subsequent modifications or enhancements made to monitoring instruments.

Use of particle counting to characterize feedwater and filtered water quality is required as one surrogate method for evaluation of microbiological contaminant removal.

**14.7.5.1 Bench-Top Particle Counters.** All particle counting shall be performed on-site. The particle sensor selected must be capable of measuring particles as small as 2  $\mu\text{m}$ . There should be less than a ten percent coincidence error for any one measurement.

*Calibration.* Calibration of the particle counter is generally performed by the instrument manufacturer. The calibration data will be provided by the manufacturer for entry into the software calibration program. Once the data has been entered it should be verified using

calibrated commercially-available particle standards or methods. This calibration should be verified at the beginning of each Verification Testing period.

*Maintenance.* The need for routine cleaning of the sensor cell is typically indicated by: 1) illumination of the sensor's "cell" or "laser" lamps, 2) an increase in sampling time from measurement to measurement, or 3) an increase in particle counts from measurement to measurement. During the ETV testing, the sensor's "cell" and "laser" lamps and the sampling time will be checked periodically. The number of particles in the "particle-free water" will also be monitored daily.

*Particle-Free Water System.* "Particle-free water" (PFW) will be used for final glassware rinsing, dilution water, and blank water. This water will consist of de-ionized (DI) water that has passed through a 0.22- $\mu\text{m}$  cartridge filtration system. This water is expected to contain fewer than 10 total particles per mL, as quantified by the on-site particle counter.

*Glassware Preparation.* All glassware used for particle counting samples shall consist of beakers designed specifically for the instrument being used. Glassware will be cleaned after every use by hand washing using hot water and laboratory glassware detergent solution followed by a triple PFW rinse. Sample beakers will then be stored inverted.

Dedicated beakers will be used at all times for unfiltered water, diluted unfiltered water, prefiltered water (if prefiltration is used), filtered water, and PFW. When several samples are collected from various equipment sampling points during one day, the appropriate beakers will be hand-washed as described above, and then rinsed three times with sample prior to collection.

Other materials in contact with the samples, including volumetric pipettes, volumetric flasks, and other glassware used for dilution, will also be triple-rinsed with both PFW and sample between each measurement.

*Sample Collection.* Beakers should be rinsed with the sample at least three times prior to sample collection for particle counting. Sample taps should be opened slowly prior to sampling. Sudden changes in the velocity of flow through the sampling taps should be avoided immediately prior to sample collection to avoid scouring of particles from interior surfaces. A slow, steady flow rate from the sample tap will be established and maintained for at least one minute prior to sample collection. The sample will be collected by allowing the sample water to flow down the side of the flask or beaker; thereby minimizing entrainment of air bubbles.

*Dilution.* The number of particles in the raw and pretreated waters (where applicable) is likely to exceed the coincidence limit of the sensor. If so, these samples will be diluted prior to analysis. In all cases, PFW will be used as dilution water.

When necessary, dilutions will be performed as follows:

- Dilution water will be dispensed directly into a 500-mL volumetric flask;
- A volumetric pipette (i.e. 10-mL for a 50:1 dilution) will be used to collect an aliquot of the sample to be diluted (stock);
- The appropriate volume of the stock will be slowly added to the volumetric flask containing the dilution water;
- The volumetric flask will be slowly filled to the full-volume etch with dilution water;
- The volumetric flask will be inverted gently and then its contents will be poured slowly into the appropriate 500-mL flask for analysis.

During each of the above steps, care will be taken to avoid entrainment of air bubbles; thus, samples and dilution water will flow slowly down the side of containers to which they are added. Excessive flow rates through pipette tips, which can cause particle break-up, will be avoided by use of wide-mouth pipettes. Sample water will be drawn into and out of pipettes slowly to further minimize particle break-up.

$$\text{Sample Particle Concentration} = \frac{\{MP - (1 - X) \times PF\}}{X}$$

Actual particle counts in a size range for diluted samples will be calculated based on the following formula:

where MP is the measured particle concentration (particles per mL) in the diluted sample, PF is the measured particle concentration (particles per mL) in the particle-free water, and X represents the dilution factor. For a 25:1 dilution, the dilution factor would be 1/25, or 0.04. The expression for the dilution factor is provided by the following equation:

$$\text{Dilution Factor} = X = \frac{\text{Volume Sample}}{\text{Addition of Volume Sample} + \text{Volume Dilution Water}}$$

*Particle Counting Sample Analysis.* To collect samples for particle counting, at least 200 mL of each water sample to be counted (diluted or not) should be collected in the appropriate beaker. The beaker will be placed into the pressure cell and counting will take place in the "auto" mode of the instrument. Four counts will be made of each sample. The first count will serve to rinse the instrument with the sample; data from this count are discarded. Data from the subsequent three counts will be averaged, and the average value will be reported as the count for that sample.

**14.7.5.2 In-Line Particle Counters.** Any in-line particle sensors selected for use must have capabilities for measurement of particles as small as 2  $\mu\text{m}$  and have a coincidence error of less than ten percent. The particle counter manufacturer shall provide data and methods that the in-line particle sensors meet these criteria or an independent third party shall verify the in-line particle sensor meets the above criteria. The particle counter manufacturer shall provide the methods for demonstration of coincidence error.



The sensors of the in-line units must also be provided with a recent (two months before the start of testing) manufacturer calibration. The calibration shall be verified by measurement of the individual and cocktail suspensions of the monospheres as described for the batch counter; however, in this case the samples must be fed in-line to the counters.

No dilution of the filtered water samples will be conducted. The data acquired from the counters will be electronically transferred to the data acquisition system. If it is known that a particular sensor will not be used for a period of several days or more, refer to the manufacturer recommendations for an appropriate storage protocol.

## 14.8 Chemical and Biological Samples Shipped Off-Site for Analyses

### 14.8.1 Organic Parameter: Total Organic Carbon and UV<sub>254</sub> Absorbance (UV is an Optional Parameter)

Samples for analysis of TOC and UV<sub>254</sub> absorbance shall be collected in glass bottles supplied by the state-certified or third party- or EPA-accredited laboratory and shipped at 4°C to the analytical laboratory. These samples shall be preserved, held, and shipped in accordance with Standard Method 5010B. Storage time before analysis shall be minimized, according to *Standard Methods*. TOC is a required sampling parameter. UV<sub>254</sub> absorbance is an optional sampling parameter.

### 14.8.2 Microbial Parameters: Total Coliform (Optional) and Algae

Samples for analysis of total coliform (TC) shall be collected in bottles supplied by the state-certified or third party- or EPA-accredited laboratory and shipped with an internal cooler temperature of approximately 4°C to the analytical laboratory. Samples shall be processed for analysis by a state-certified or third party- or EPA-accredited analytical laboratory within the time specified for the relevant analytical method. The laboratory shall keep the samples at approximately 4°C until initiation of analysis. TC densities shall be reported as most probable number per 100 mL (MPN/100 mL) or as total coliform densities per 100 mL. TC is an optional sampling parameter.

Algae samples shall be preserved with Lugol's solution after collection, stored and shipped in a cooler at a temperature of approximately 4°C, and held at that temperature range until counted.

### 14.8.3 Inorganic Samples

Inorganic chemical samples, including, alkalinity, hardness, iron, and manganese, shall be collected, preserved and held in accordance with *Standard Methods* 3010B, paying particular attention to the sources of contamination as outlined in Standard Method 3010C. The samples shall be refrigerated at approximately 4°C immediately upon collection, shipped in a cooler, and maintained at a temperature of approximately 4°C during shipment. Samples shall be processed for analysis by a state-certified or third party- or EPA-accredited laboratory within 24 hours of collection. The laboratory shall keep the samples at approximately 4°C until initiation of analysis.

## 14.9 Microspheres

The membrane filters used for obtaining microsphere samples shall be refrigerated at approximately 2 to 8°C immediately upon collection. Such samples shall be shipped in a cooler and maintained at a temperature of approximately 2 to 8°C during shipment and in the analytical laboratory, until they are analyzed. This is done to minimize microbiological growth on the membranes.

Recovery of microspheres from suspensions held in glassware shall be evaluated by preparing a suspension of microspheres in which the number of microspheres used to make the suspension is estimated, based on either the weight of dry microspheres or the volume of microspheres in liquid suspension as provided by the supplier. After the suspension is prepared and mixed until it is homogeneous, five aliquots shall be taken and counted in the hemacytometer. After the microsphere density (concentration) has been calculated, aliquots of the suspension shall be diluted and filtered through polycarbonate membrane filters having 1  $\mu\text{m}$  pore size. The elution and concentration steps described in Task 4 shall be followed, and the microspheres shall be counted in a hemacytometer. This shall be done five times, so that statistics can be developed on the recovery of microspheres in the sampling procedure.

As a check on possible interference from fluorescing organisms in the feed water, during each Verification Testing run in which fluorescent microspheres are used, a sample of feed water with no seeded microspheres shall be filtered through a polycarbonate membrane, and the particulate matter on the membrane shall be concentrated using the procedures for microsphere analysis, and the concentrate shall be examined in a hemacytometer by microscope, with UV illumination. If no objects of the size and shape of the microspheres are seen to fluoresce, displaying the same color as the microspheres, then fluorescent objects of the proper color seen in samples with seeded microspheres can be considered to be microspheres.

Microspheres may adhere to surfaces of tanks, vessels, and glassware. All glassware, holding tanks, and membrane filter manifolds must be cleaned between seeding events or sampling events.

## 15.0 OPERATION & MAINTENANCE

The Field Testing Organization shall obtain the Manufacturer-supplied O&M manual to evaluate the instructions and procedures for their applicability during the verification testing period. The following are recommendations for criteria for O&M Manuals for equipment employing bag filters and cartridge filters.

### 15.1 Maintenance

The manufacturer should provide readily understood information on the recommended or required maintenance schedule for each piece of operating equipment such as:

- pumps
- valves
- pressure filter vessel opening mechanisms
- instruments, such as turbidimeters
- water meters, if provided

The manufacturer should provide readily understood information on the recommended or required maintenance for non-mechanical or non-electrical equipment such as:

- tanks and basins
- filter vessels

If prefiltration equipment is used, the manufacturer should provide the same sort of information for that equipment as the information described above.

## 15.2 Operation

The manufacturer should provide readily understood recommendations for procedures related to proper operation of the equipment, both for filtration equipment and for prefiltration equipment, if that also is used. Among the operating aspects that should be discussed are:

Filtration:

- control of filtration rate
- observation and measurement of head loss during filter run

Filter medium (bag or cartridge) replacement:

- criteria for determining end of filter run
- technique for removal of used filter bag or cartridge
- cleaning of filter vessel, if needed
- procedure for installation of new bag or cartridge
- does manufacturer recommend a technique for confirming proper fit and seal of bag or cartridge after installation and before use to treat water?

Monitoring and observing operation:

- filter vessel inlet pressure
- filter vessel outlet pressure
- raw water turbidity
- filtered water turbidity
- rate of flow
- what to do if turbidity breakthrough occurs

The manufacturer should provide a troubleshooting guide for filtration equipment and for prefiltration equipment, if the latter was also provided. The guide should be a simple check-list of what to do for a variety of problems including:

- loss of raw water (feed water) flow to plant during a filter run
- can't control rate of flow of water through equipment
- no reading on turbidimeter
- newly installed bag or cartridge not seated or fit properly
- filtered water turbidity too high
- filter head loss builds up excessively rapidly
- no head loss readings
- valve stuck or won't operate
- clogged prefiltration equipment (if used)

The following are recommendations regarding operability aspects of equipment employing bag filters or cartridge filters. These aspects of plant operation should be included if possible in reviews of

historical data, and should be included to the extent practical in reports of equipment testing when the testing is done under the ETV Program.

During Verification Testing and during compilation of historical equipment operating data, attention shall be given to equipment operability aspects. If prefiltration equipment is also used, operability of that equipment shall also be discussed. Among the factors that should be considered are:

- can both influent pressure and effluent pressure be measured at filter vessel?
- is rate of flow of raw (feed) water measured?
- can raw (feed) water turbidity be measured continuously?
- can filtered water turbidity be measured continuously?
- can spent filter bags or cartridges be replaced easily and without contamination of filter vessel?
- does operator have a simple, reliable way of knowing the new filter bag or cartridge is installed and seated properly in the filter vessel?
- comment on operability of filtration equipment with and without use of prefiltration equipment, if filtration equipment was operated in both modes
- susceptibility of prefiltration equipment to clogging

Both the reviews of historical data and the reports on Verification Testing should address the above questions in the written reports. The issues of operability should be dealt with in the portion of the reports that are written in response to Task 3: Documentation of Operating Conditions and Treatment Equipment Performance, in the Test Plan for Bag Filters and Cartridge Filters.

## 16.0 REFERENCES

Abbaszadegan, M., Hansan, M.N., Gerba, C.P., Roessler, P.F., Wilson, B.R., Kuennen, R., and Van Dellen, E. 1997. "The Disinfection Efficacy of a Point-of-Use Water Treatment System Against Bacterial, Viral and Protozoan Waterborne Pathogens," *Water Research*, 31:3:574-582.

Alaska Department of Environmental Conservation, Drinking Water Program. 1994. "Approval of Alternative Filtration Systems in Alaska," October 14, 1994.

APHA, AWWA, and WEF. 1999. *Standard Methods for the Examination of Water and Wastewater*, 20th ed., Washington, D.C.

Hach Company. 1992. *Hach Water Analysis Handbook*, 2nd Ed., Loveland, Colorado.

Li, S.Y., Goodrich, J.A., Owens, J.H., Willeke, G.E., Schaefer, F.W. III, and Clark, R.M. 1997. "Reliability of Non-Hazardous Surrogates for Determining *Cryptosporidium* Removal in Bag Filters," *Journal AWWA*, 89:5:90-99.

Table 1. Generic Schedule for Verification Testing		
Testing Period	Initial Operations, Estimated Time	Verification Testing, Minimum Time
Testing Period #1 - Required	1 - 6 weeks	30 days
Testing Period #2 - Optional	1 - 3 weeks	30 days
Testing Period #3 - Optional	1 - 3 weeks	30 days
Testing Period #4 - Optional	1 - 3 weeks	30 days

Table 2. Water Quality Sampling and Measurement Schedule	
Sample or Measure For:	Minimum Frequency:
Temperature	Daily
pH	Daily
Total alkalinity	Desired weekly but optional
Hardness	Desired weekly but optional
Total organic carbon	Desired weekly but required only once per test period
Turbidity grab samples	Every four hours at bench to check continuous turbidimeters and at shutdown and restart
Continuous turbidity monitoring	Use data at 1/4, 1/2, or 1 hour for calculations of long-term performance. Also note maximum turbidity observed each day. Separate analysis for shutdowns and restarts.
Iron	Once each testing period or weekly if present in concentration of 0.3 mg/L or greater
Manganese	Once each testing period or weekly if present in concentration of 0.05 mg/L or greater
Total coliform bacteria	Desired twice per week but optional
Algae, number and species	Weekly if no prefiltration used; three times per week if prefiltration used; three times per week if pressure across bag filter or cartridge filter increases by more than five percent of total allowable pressure increase in one day's time.
UV <sub>254</sub> absorbance	Desired weekly but optional
True color	Desired weekly but optional
For schedule for microspheres, particle counting, and <i>Cryptosporidium</i> , see Task 4.	

Table 3. Analytical Methods			
Parameter	Facility	<i>Standard Methods</i> <sup>1</sup> number or Other Method Reference	EPA Method <sup>2</sup>
Temperature	On-Site	2550 B	
pH	On-Site	4500-H <sup>+</sup> B	150.1 / 150.2
Total alkalinity	Lab	2320 B	
Total Hardness	Lab	2340 C	
Total organic carbon	Lab	5310 C	
Turbidity	On-Site	2130 B / Method 2	180.1
Particle counts (electronic)	On-Site	Manufacturer	
Iron	Lab	3111 D / 3113 B / 3120 B	200.7 / 200.8 / 200.9
Manganese	Lab	3111 D / 3113 B / 3120 B	200.7 / 200.8 / 200.9
Algae, number and species	Lab	10200 and 10900	
True color	On-Site	Hach Company adaptation of <i>Standard Methods</i> 2120	
UV <sub>254</sub> absorbance	Lab	5910 B	
Total coliform	Lab	9221 / 9222 / 9223	
<i>Cryptosporidium</i>	Lab	NSF and EPA may consider alternative methods if sufficient data on precision, accuracy, and comparative studies are available for alternative methods.	EPA 1622, EPA 1623
Microsphere counts	Lab	Li <i>et al.</i> , 1995	

Notes:

1) *Standard Methods* Source: 20th Edition of *Standard Methods* for the Examination of Water and Wastewater, 1999, American Water Works Association.

2) EPA Methods Source: EPA Office of Ground Water and Drinking Water. EPA Methods are available from the National Technical Information Service (NTIS).

Table 4. Cartridge Filtration and Bag Filtration Equipment Operating Data	
Operating Data	Action
Feedwater Flow and Filter Flow	Check and record twice per day, adjust when >10% above or below goal. Record both before and after adjustment.
Filter Head Loss (filter inlet pressure and filter outlet pressure)	Record initial clean bed total head loss at start of filter run and record total head loss two times per day. Also record this separately for the prefilter if a prefilter is used.
Filtered Water Production	Record gallons or cubic meters of water produced per filter bag or filter cartridge for each filter run, and total water produced by the filtration equipment each day it is operated.
Bag or Cartridge Replacement	Record date and time for replacement, and total gallons or cubic meters of water treated before replacement, and the reason for replacement, such as terminal head loss or excessive filtered water turbidity.
Electric Power	Record meter reading once per day.
Hours operated per day	Record in log book at end of day or at beginning of first shift on the following work day. (Around-the-clock operation is recommended).